

29/08/2015

Mr. Adrian Donnelly,
 Treasurer Killone GWS,
 Imleach,
 Barntick,
 Ballynacally,
 Co. Clare.

Report No. 7765
 Ref: 26-124

Dear Adrian,

Re: Drinking Water Quality Certification – August 2015

We examined six drinking water samples taken from the indicated locations on the 19/08/2015 to determine the level of compliance with the drinking water/food regulations on coliforms and chemical parameters indicated.

Regulations: SI 278 of 2007 and the Drinking Water Directive.
 Food hygiene regulations

Sample location	Sample No.	Total coliforms No./100 mL	E. Coli No./100 mL	Residual free chlorine mg/L	Total chlorine mg/L
Pat Haren	19504	<1	<1	0.16	0.16
Andy Price	19505	<1	<1	0.12	0.16
Creche	19506	<1	<1	0.12	0.12
Michael Hogan	19507	<1	<1	0.11	0.17
School/Hall	19508	<1	<1	0.10	0.10
Sheedy's Shop	19509	<1	<1	0.12	0.12

Drinking Water Quality Rating: Please maintain free chlorine levels at a minimum of 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Sincerely,

Signed: 

Lorna Moynihan

Amberley Water Solutions Ltd.