

Drinking Water Quality Certification – January 2017

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 8248
Reference: 28-149
Date Sampled: 09 Jan 2017
Date Reported: 14 Jan 2017

Regulations: SI 122 of 2014 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	21185	<1	<1	0.07	0.07
Andy Price*	21186	<1	<1	0.14	0.24
Creche	21187	<1	<1	0.05	0.10
Michael Hogan	21188	<1	<1	0.05	0.07
School/Hall	21189	<1	<1	0.07	0.07
Sheedy's Shop	21190	<1	<1	0.01	0.06

*This sample was taken from R Murphy's House

Drinking Water Quality Rating: Please ensure to maintain free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.