

Drinking Water Quality Certification – April 2026

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 12183
Reference: 45-17
Date Sampled: 22 Apr 2026
Date Reported: 30 Apr 2026

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	37379	<1	<1	0.01	0.01
R Murphy	37380	<1	<1	0.02	0.03
Michael Hogan	37381	<1	<1	0.03	0.05
School	37382	<1	<1	0.02	0.03
Londis Shop	37383	<1	<1	0.04	0.05
Banner Steel	37384	<1	<1	0.02	0.03

Comment:

No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.