

Drinking Water Quality Certification – August 2026

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 12312
Reference: 45-106
Date Sampled: 20 Aug 2026
Date Reported: 26 Aug 2026

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	37990	<1	<1	0.41	0.52
R Murphy	37991	<1	<1	0.95	1.06
Michael Hogan	37992	<1	<1	0.75	0.80
School	-	-	-	-	-
Londis Shop	37994	<1	<1	0.56	0.66
--	-	-	-	-	-

Comment: School closed for summer holidays. Banner Steel closed.

No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.