

Drinking Water Quality Certification – February 2026

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 12118
Reference: 44-87
Date Sampled: 04 Feb 2016
Date Reported: 08 Feb 2026

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	36983	<1	<1	1.00	1.12
R Murphy	-	-	-	-	-
Michael Hogan	36985	<1	<1	1.02	1.10
School	-	-	-	-	-
Londis Shop	36987	<1	<1	1.08	1.14
Banner Steel	36988	<1	<1	1.22	1.32

Comment: No flow at Murphy's and school was closed on day of sampling

No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.