

Drinking Water Quality Certification – July 2026

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 12279
Reference: 45-77
Date Sampled: 07 Jul 2026
Date Reported: 13 Jul 2026

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	37794	<1	<1	0.02	0.04
R Murphy	37795	<1	<1	0.09	0.13
Michael Hogan	37796	<1	<1	0.12	0.18
School	-	-	-	-	-
Londis Shop	37798	<1	<1	0.09	0.11
Banner Steel	37799	<1	<1	0.01	0.05

Comment: School closed for summer holidays

No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.