

Drinking Water Quality Certification – June 2026

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 12239
Reference: 45-44
Date Sampled: 02 Jun 2026
Date Reported: 08 Jun 2026

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	37540	<1	<1	0.12	0.14
R Murphy	37541	<1	<1	0.37	0.40
Michael Hogan	37542	<1	<1	0.36	0.40
School	37543	<1	<1	0.00	0.00
Londis Shop	37544	<1	<1	0.15	0.17
Banner Steel	37545	<1	<1	0.09	0.11

Comment:

No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.