

Drinking Water Quality Certification – March 2026

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 12142
Reference: 44-114
Date Sampled: 09 Mar 2026
Date Reported: 12 Mar 2026

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	N/A	-	-	-	-
R Murphy	37163	<1	<1	0.41	0.45
Michael Hogan	37164	<1	<1	0.23	0.30
School	37165	<1	<1	0.30	0.37
Londis Shop	37166	<1	<1	0.40	0.55
Banner Steel	37167	<1	<1	0.40	0.45

Comment: No flow at Pat Harens on day of sampling.

No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.