

Drinking Water Quality Certification – May 2026

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 12212
Reference: 45-30
Date Sampled: 12 May 2026
Date Reported: 18 May 2026

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	37443	<1	<1	0.20	0.25
R Murphy	37444	<1	<1	0.30	0.34
Michael Hogan	37445	<1	<1	0.40	0.44
School	37446	<1	<1	0.30	0.33
Londis Shop	37447	<1	<1	0.20	0.22
Banner Steel	37448	<1	<1	0.10	0.12

Comment:

No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.