

Drinking Water Quality Certification – September 2026

Killone GWS,
Imleach,
Barntick,
Ballynacally,
Co. Clare.

Report No: 12348
Reference: 45-124
Date Sampled: 02 Sep 2026
Date Reported: 07 Sep 2026

Regulations: SI No. 122 of 2014, SI No. 464 of 2017 and the Drinking Water Directive

Sample Location	Sample No.	Total Coliforms No./100 mL	<i>E. coli</i> No./100 mL	Free Chlorine mg/L	Total Chlorine mg/L
Pat Haren	38087	<1	<1	0.01	0.02
R Murphy	38088	<1	<1	0.01	0.03
Michael Hogan	38089	<1	<1	0.00	0.00
School	38090	<1	<1	0.00	0.00
Londis Shop	38091	<1	<1	0.01	0.03
Banner Steel	38092	<1	<1	0.01	0.03

Comment: Chlorine levels are low across the scheme.

No Coliforms or *E. coli* were detected in the samples tested. It is recommended to continue maintaining free chlorine at approx. 0.2 mg/L.

If you have any questions in relation to this report, please don't hesitate to contact us.

Yours sincerely,



Lorna Moynihan
Amberley Water Solutions Ltd.