

P&ID PIPING AND INSTRUMENTATION DIAGRAM

DRAWING NO: PND-4012 REVISION: B

SYSTEM: COOLING WATER PUMP STATION 101

Centrifugal Pump P-101A is monitored by Pressure Transmitter PT-101.
Flow Transmitter FT-204 measures flow rate on Line 6"-CW-101-CS150.
Emergency Valve VLV-302 controls isolation on Line 6"-CW-101-CS150.
Storage Tank TK-201 feeds Pump P-101A suction line.