

NUCOR
BUILDING SYSTEMS GROUP

Terrell,

Texas

Flat Sheet Inspection Sheet
 Receiving/Quality Control TX.77.004

P.O. # _____ Vendor: _____ Inspector: _____ Date: _____

Heat#	Description	NBS#	Qty. Rec./BOL	Length	Width	Gauge	Comments

Gage	Coating	Min. Thickness	Gage	Coating	Min. Thickness	Gage	Coating	Min. Thickness
10	G60	0.1295	18	G60	0.0471			
12	G60	0.1011	22	G60	0.0286			
14	G60	0.0727	24	G60	0.0217			
16	G60	0.0585	26	G60	0.0177			