

STRAIGHT BILL OF LADING - SHORT FORM

ORIGINAL - NOT NEGOTIABLE

* RE-PRINT *

BILL OF LADING NO.

1929915

RECEIVED, subject to the classifications and tariffs in effect on the date of the issue of this Bill of Lading.

FROM: NUCOR STEEL BERKELEY

TELEPHONE: 843/336-6000

Page: 1

AT: 1455 Hagan Avenue
Huger, SC 29450

* BEAM MILL DATE:

8/22/26

Subject to Section 7 of the terms and conditions of this bill of lading, if this shipment is to be delivered to the consignee without recourse on the consignor, the consignor shall sign the following statement:
The carrier may decline to make delivery of this shipment without payment of freight and all other lawful charges.

R.A.C.

(Signature of Consignor)

If charges are to be prepaid, write or stamp here, "To Be Prepaid."

Prepaid

The property described below in apparent good order, except as noted (contents and condition of contents of packages unknown), marked, consigned, and destined as indicated below, which said carrier (the word carrier being understood throughout this contract as meaning any person or corporation in possession of the property under the contract) agrees to carry to its usual place of delivery at said destination, if on its route, otherwise to deliver to another carrier on route to said destination. It is mutually agreed that every service to be performed hereunder shall be subject to all the terms and conditions of this bill of lading. THIS BILL OF LADING IS NOT SUBJECT TO ANY CLASSIFICATION OR TARIFFS, WHETHER INDIVIDUALLY DETERMINED OR FILED WITH ANY FEDERAL OR STATE REGULATORY AGENCY, EXCEPT AS SPECIFICALLY AGREED TO IN WRITING BY THE SHIPPER AND CARRIER.

SHIP NUCOR BUILDING SYSTEMS
TO: 600 APACHE TRL
TERRELL, TX 75160

1281 - 001 SOLD

NUCOR BUILDING SYSTEMS
600 APACHE TRL
TO: TERRELL, TX 75160

1281

ROUTE

CARRIER TRUCK @ 01092 MILES

FTMG - FREIGHT TEC MANAGEMENT GROUP

CAR OR

VEHICLE NO.

DSM 64737910 Ticket 3452583
Load# 2154924 Gross Wt 78,940.00

Trailer#

399

Bundle No.	Cust. PO#	Product	Roll Grade	Length	Order/Line	Pcs	Weight
61123384	TX-0015373	W12x30	A992-22	43' 00.00"	636243 - 2	6	7,740.00
			Heat #:	1612252 /	 Pieces:	6	
		CC# 161886					
61123486	TX-0015373	W12x30	A992-22	43' 00.00"	636243 - 2	6	7,740.00
			Heat #:	2612251 /	 Pieces:	6	
		CC# 161887					
61123402	TX-0015373	W12x30	A992-22	43' 00.00"	636243 - 2	6	7,740.00
			Heat #:	2612253 /	 Pieces:	6	
		CC# 161888					
61123386	TX-0015373	W12x30	A992-22	43' 00.00"	636243 - 2	6	7,740.00
			Heat #:	1612252 /	 Pieces:	6	
		CC# 161889					
61123385	TX-0015373	W12x30	A992-22	43' 00.00"	636243 - 2	6	7,740.00
			Heat #:	1612252 /	 Pieces:	6	
		CC# 161890					
61124736	TX-0015478	W12x26	A992-22	50' 00.00"	641439 - 1	6	7,800.00
			Heat #:	1612390 /	 Pieces:	6	
		CC# 161891					
Total Weight:							46,500.00
Total Tons..:							23.25
Total Pieces:							36
Bundle Count:							6
***** SPECIAL INSTRUCTIONS/NOTATIONS *****							
Load Created by: GATHERSR							
							9.30AM
							8.24.2026
							TX YARD

If the shipment moves between two ports by a carrier by water, the law requires that the bill of lading shall state whether it is "carrier's weight" or "shipper's weight".
The agreed-on declared value of the property is hereby specifically stated by the shipper to be not exceeding _____ per _____.
Shipper hereby certifies that he is familiar with all the terms and conditions of this bill of lading, including those on the back hereof, and the said terms and conditions are hereby agreed to by the shipper and accepted for itself and its assigns.

NUCOR STEEL BERKELEY
1455 Hagan Avenue
Huger, South Carolina 29450

SHIPPER'S SIGNATURE: _____
SIGNATURE ON FILE
Raye A Coward

Permanent post office address of shipper

CARRIER'S
SIGNATURE: _____

Carrier acknowledges receipt of property described above in good order and condition.
(This Bill of Lading is to be signed by the shipper and agent of the carrier issuing same.)

NUCOR STEEL - BERKELEY
1455 Hagan Avenue
Burger, SC 29430
Phone: (843) 336-6000

CERTIFIED MILL TEST REPORT

8/22/26 15:10:45
100% EAF MELTED AND MANUFACTURED IN THE USA
Structural sections produced by Nucor-Berkeley are cast
and hot rolled to a fully killed and fine grain practice,
Mercury not intentionally added at any point during manufacturing.

Sold To: NUCOR BUILDING SYSTEMS
600 APRACHE TRL

Ship To: NUCOR BUILDING SYSTEMS
600 APRACHE TRL

Customer #: 1281 - 1
B.O.L. H....: 1929915
MOS: I

TERRELL, TX 75160

TERRELL, TX 75160

SPECIFICATIONS: Tested in accordance with ASTM specification A6/A6M-26 and A370-24a. Tested in accordance with EN10204-2004-3.1.
Quality Manual Rev #21 (12-13-24).

ARSHD : M270-50-23
ASIM : A992-22;A36-19/A529-19-50/A5725021T1/A7095021
CSA : G40.2150WM

Description	Heat	Yield/	Yield Tensile	Elong	C	Mn	P	S	Si	Cu	Ni	CE1
Part #	Test/Heat	Ratio	(PSI)	%	*****	Ti	Ca	B	V	Nb	CI	CE2
W12x26	1612390	.82	58800	71700	24.00	.07	1.12	.010	.016	.24	.09	.04
030', 00.00'	A992-22	.81	405	494	.05	.00	.0046	.0003	.002	.030		.27
W310X38.7			57600	71200	23.00	.001	.0002	.0063	.0063			.3215
015.2400m			397	491	6 Pc(s)	7,800 lbs	Customer PO: TX-0015478					.1433
SH12260												

W12x30	1612252	.80	55200	69200	25.00	.07	1.06	.010	.017	.23	.09	.04
043', 00.00'	A992-22		381	477	.03	.00	.0061	.0003	.002	.029		.26
W310X44.5		.81	56100	69600	25.00	.001	.0012	.0062				.3066
013.1064m			387	480	18 Pc(s)	23,220 lbs	Customer PO: TX-0015373					.1391
SH12300												

W12x30	2612253	.81	55900	69400	25.00	.07	1.05	.010	.018	.23	.08	.03
043', 00.00'	A992-22		385	479	.04	.00	.0039	.0002	.002	.028		.26
W310X44.5		.81	56700	69600	24.00	.001	.0010	.0072				.3044
013.1064m			391	480	6 Pc(s)	7,740 lbs	Customer PO: TX-0015373					.1371
SH12300												

Elongation based on 8" (20.32cm) gauge length. 'No Weld Repair' was performed. 'All mechanical testing is performed by the quality testing lab, which is independent of the production departments'

CE1 = C+(Mn/6)+((Cr+Mo+V)/5)+((Ni+Cu)/15)
CE2 = C+((Mn+Si)/6)+((Cr+Mo+V+Cb)/5)+((Ni+Cu)/15)

Nucor certifies that the contents of this report are accurate and correct. All test results and operations performed by the material manufacturer are in compliance with material specifications, and when designated by the purchaser, meet applicable specifications.

Damian Munkbold
Metallurgist/
Quality Control

DM

NUCOR STEEL - BERKELEY
1455 Hagan Avenue
Hager, SC 29450
Phone: (843) 336-6000

CERTIFIED MILL TEST REPORT

8/22/26 15:10:45
100% EAF MELTED AND MANUFACTURED IN THE USA
Structural sections produced by Nucor-Berkeley are cast
and hot rolled to a fully killed and fine grain practice.
Mercury not intentionally added at any point during manufacturing.

Sold To: NUCOR BUILDING SYSTEMS
600 APACHE TRI

Ship To: NUCOR BUILDING SYSTEMS
600 APACHE TRI

Customer #: 1281 - 1
B.O.I. #...: 1929915

TERRELL, TX 75160

TERRELL, TX 75160

MOS: I

SPECIFICATIONS: Tested in accordance with ASTM Specification A6/A6M-26 and A370-24a. Tested in accordance with EN10204-2004-3.1.

ASTM: M270-30-23
ASTM: A992-22; A36-19/A529-19-50/A5725021T1/A7095021
CSR: G40.2150WM

Description	Heat#	Grade(s)	Yield/ Tensile Ratio	Yield (psi)	Tensile (psi)	Elong %	C	Cr	Mn	Mo	P	Sn	S	B	Si	V	N	Cu	Nb	Ni	CE1	CE2	CEM
Part #	Test/Heat #			(Mpa)	(Mpa)		xxxxxx		il		Ca	xxxxxx	xxxxxx	xxxxxx	xxxxxx	xxxxxx	xxxxxx	xxxxxx	xxxxxx	xxxxxx	xxxxxx	xxxxxx	xxxxxx
W12x30	2612251		.80	56100	69800	24.00	.07		1.02		.010		.019		.29		.08		.03		.26		
043' 00.00"	A992-22			387	481	27.00	.04		.00		.0044		.0003		.002		.029		2.67		.3092		
W310x44.5			.81	56600	70000				.001		.0004				.0072						.1369		
013.1064m				390	483																		
SH12300																							

4 Heat(s) for this MTR.

Elongation based on 8" (20.32cm) gauge length. 'No Weld Repair' was performed.
CI = 26.01(Cu+3.88Ni+1.20Cr+1.49Si+17.28P-(7.29CuXNi)-(9.10NiXp)-33.39(CuXCu)
PCM = C+(Si/30)+(Mn/20)+(Cu/20)+(Ni/60)+(Cr/20)+(Mo/15)+(V/10)+5B
CE1 = C+(Mn/6)+((Cr+Mo+V)/5)+((Ni+Cu)/15)
CE2 = C+((Mn+Si)/6)+((Cr+Mo+V+Cb)/5)+((Ni+Cu)/15)

Nucor certifies that the contents of this report are accurate and correct. All test results and operations performed by the material manufacturer are in compliance with material specifications, and when designated by the purchaser, meet applicable specifications.

Dawdin Munkhbold
Metallurgist/
Quality Control

Dawdin Munkhbold

PURCHASE ORDER



PO Number: TX-0015373

Date: 05/15/2026

This Purchase Order Number must appear on all Packages, Invoices and Packing Slips.

Nucor Building Systems Texas
600 Apache Trail
Terrell, TX 75160
USA

PH: Sales Tax Exempt
No.:

Vendor: V000151
NUCOR BERKELEY
PO BOX 751412
CHARLOTTE, NC 28275-1412
USA

Vendor
Contact:
PH:

FAX:

Ship To: Nucor Building Systems
600 Apache Trail
Terrell, TX 75160
USA

Job ID:
Job Name:

Deliveries to NBGTx are by appointment only

Phone: (972) 210-4941

Email: nbgtx.receiving@nucor.onmicrosoft.com

Hours: Monday - Friday from 6:00am - 2:00pm CST

Hot-Rolled Material (Wide Flange sections, Channels, & Angles): Application-Structural Steel Buildings; ASTM A572-07 (or latest edition) Grade 50 (or A992-06a for "W" shapes only): Minimum Yield Strength (Fy) = 50 ksi; Minimum Tensile Strength (Fu min) = 65 ksi; Dimensional Tolerances per ASTM A6-08a (or latest edition) Loading Instructions: Bundles must be banded with 4" minimum dunnage underneath and 4" minimum dunnage between bundles. Bundles not to exceed 10,000 lbs. **MUST BE MELTED AND MANUFACTURED IN USA**

Buyer:	Payment Terms:	Delivery Terms:	Shipping Method:	Cash discount
ANGELA COOK	CIA			

L/N	Item Number	Description	Req. Date	U/M	Ordered	Unit Price	Ext. Price
1	SH12300	W12 X 30.0 BEAM ~30 PCS @ 43' For Frontier 310 (No job# yet) Account: 130013	7/13/2026	LBS	38,700.00	0.78250	30,282.75
2	SH12300	W12 X 30.0 BEAM ~30 PCS @ 43' For Frontier 306 (No job# yet) Account: 130013	7/13/2026	LBS	38,700.00	0.78250	30,282.75

PURCHASE ORDER

Shipper to ensure all products are properly packaged, loaded and blocked to prevent any movement or shifting during transit and unloading. Delivering driver is responsible for safely removing straps, tie-down, etc. and following all Division safety rules and procedures.



Authorized Signature

Order Total (USD):

60,565.50

By acceptance and acknowledgement of this order, vendor agrees to furnish materials and/or services in accordance with all terms and conditions provided.

PURCHASE ORDER



PO Number: TX-0015478

Date: 08/07/2026

This Purchase Order Number must appear on all Packages, Invoices and Packing Slips.

Nucor Building Systems Texas
600 Apache Trail
Terrell, TX 75160
USA

PH: Sales Tax Exempt
No.:

Vendor: V000151
NUCOR BERKELEY
PO BOX 751412
CHARLOTTE, NC 28275-1412
USA

Vendor
Contact:
PH:

FAX:

Ship To: Nucor Building Systems
600 Apache Trail
Terrell, TX 75160
USA

Job ID:
Job Name:

Deliveries to NBGTx are by appointment only

Phone: (972) 210-4941

Email: nbgtx.receiving@nucor.onmicrosoft.com

Hours: Monday - Friday from 6:00am - 2:00pm CST

Hot-Rolled Material (Wide Flange sections, Channels, & Angles): Application-Structural Steel Buildings; ASTM A572-07 (or latest edition) Grade 50 (or A992-06a for "W" shapes only): Minimum Yield Strength (Fy) = 50 ksi; Minimum Tensile Strength (Fu min) = 65 ksi; Dimensional Tolerances per ASTM A6-08a (or latest edition) Loading Instructions: Bundles must be banded with 4" minimum dunnage underneath and 4" minimum dunnage between bundles. Bundles not to exceed 10,000 lbs. ****MUST BE MELTED AND MANUFACTURED IN USA****

Buyer:	Payment Terms:	Delivery Terms:	Shipping Method:	Cash discount
ANGELA COOK	CIA			

L/N	Item Number	Description	Req. Date	U/M	Ordered	Unit Price	Ext. Price
1	SH12260	W12 X 26.0 BEAM ~900 PCS/150 Bundles @ 50' From July Rolling Account: 130013	7/31/2026	LBS	1,170,000.00	0.78000	912,600.00
2	SH10220	W10 X 22.0 BEAM ~42 PCS/7 Bundles @ 50' From July Rolling Account: 130013	7/27/2026	LBS	46,200.00	0.78000	36,036.00

PURCHASE ORDER

L/N	Item Number	Description	Req. Date	U/M	Ordered	Unit Price	Ext. Price
3	SH08240	W8 X 24 BEAM ~78 PCS/13 Bundles @ 50' From July Rolling Account: 130013	7/5/2026	LBS	93,600.00	0.78000	73,008.00
4	SH08100	W8 X 10 BEAM ~84 PCS/6 Bundles @ 50' From July Rolling Account: 130013	7/13/2026	LBS	42,000.00	0.78000	32,760.00
5	SH12260	W12 X 26.0 BEAM ~360 PCS @ 50' Account: 130013	7/6/2026	LBS	468,000.00	0.80500	376,740.00

Shipper to ensure all products are properly packaged, loaded and blocked to prevent any movement or shifting during transit and unloading. Delivering driver is responsible for safely removing straps, tie-down, etc. and following all Division safety rules and procedures.



Authorized Signature

Order Total (USD):	1,431,144.00
---------------------------	---------------------

By acceptance and acknowledgement of this order, vendor agrees to furnish materials and/or services in accordance with all terms and conditions provided.

BUILDING SYSTEMS GROUP

Beam, Channel and Angle Inspection Sheet

Receiving/Quality Control TX-77.004

Address: Berkeley

Director: JH

Date: 8-24-26

Heat#	Description	NBS#	Qty. Rec./BOL	Depth	Width	Visual Insp.	Thickness	Sweep/ Camber	Comments	Cert.
1612252	12 x 30	161886	6	6 5/8	12 3/8		.254		84	
2612251		161887	1						86	
2612253		161888	1						02	
1612252		161889	1						86	
		161890	1						85	

PREFACE

Beam, Channel and Angle Inspection Sheet

Receiving/Quality Control TX.77.004

Verona Berkeley

51-H

Date: 8-24-8

A
O
9
A
C
200-1
34-152

2500