

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 12:48:26	Added	/Services	EmailService		Email Service	admin
04-Jun-2025 12:48:43	Added	/Services/EmailService	OutgoingAccount		Outgoing Account	admin
04-Jun-2025 12:50:12	Added	/	REPORT		Folder	admin
04-Jun-2025 12:50:34	Added	/REPORT	ExportSource		Export Source	admin
04-Jun-2025 12:50:42	Added	/REPORT	EmailRecipient		Email Recipient	admin
04-Jun-2025 12:50:47	Added	/REPORT/EmailRecipient	Link		Indirect: h:1277.out - > slot:/REPORT/Email Recipient.route	admin
04-Jun-2025 13:12:09	Added	/Services	OrionAlarmService		Orion Alarm Service	admin
04-Jun-2025 13:13:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/RH_MIS_ROOM/Numeri cInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:13:40	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/RH_RM_CONSUMABLE S_2/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:13:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/RH_RM_CONSUMABLE S_1/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:13:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/RH_BUFFER_ROOM/N umericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:14:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/RH_PLASMA_ROOM/N umericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:14:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/RH_DRY_DOWN_WOR K_STATION/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:14:19	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/RH_QC_LAB/NumericInt erval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:14:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/RH_FORMULATION_R OOM/NumericInterval	interval	15 minutes	10 minutes	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 13:14:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:14:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PACKING_AMD_STORAGE_AREA_COLD/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:14:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_HOT_SPOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:14:52	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:14:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:15:06	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:15:13	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PLASMA_ROOM/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:15:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_MIS_ROOM/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:15:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_RM_CONSUMABLES_2/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:15:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_RM_CONSUMABLES_1/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:15:42	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_BUFFER_ROOM/NumericInterval	interval	15 minutes	10 minutes	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 13:15:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_DRY_DOWN_W ORK_STATION/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:15:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_T EMP_COLD_SPOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:16:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AMD _STORAGE_AREA/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:16:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_NCMR_ROOM/N umericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:16:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_FORMULATION _ROOM/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:16:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_QC_LAB/Numeri cInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:16:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TE MP_COLD_SPOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:16:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORA GE_ROOM_MFG_07_RH_HOT/NumericInt erval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:16:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORA GE_ROOM_MFG_07_TH_HOT/NumericInt erval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:16:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_TH_H OT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:17:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_RH_H OT/NumericInterval	interval	15 minutes	10 minutes	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 13:17:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_RH_13_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:17:34	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_TH_13_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:17:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_RH_14_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:17:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_TH_14_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:17:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_RH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:18:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_TH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:18:15	Removed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_TH_HOT	NumericInterval1	Numeric Interval History Ext		admin
04-Jun-2025 13:18:22	Removed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_RH_HOT	NumericInterval1	Numeric Interval History Ext		admin
04-Jun-2025 13:18:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_RH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:18:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_TH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:18:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_RH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 13:18:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_TH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:18:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_RH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:19:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_TH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:19:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_RH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:19:12	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_TH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:19:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_RH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:19:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_TH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:19:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_QA_RETAINS_TEMP_HOT_SPOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:19:42	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_GLASS_WARE_TEMP_HOT_SPOT	NumericInterval		Numeric Interval History Ext	admin
04-Jun-2025 13:19:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_GLASS_WARE_TEMP_HOT_SPOT/NumericInterval	enabled	false	true	admin
04-Jun-2025 13:20:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_STABILITY_ROOM_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 13:20:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPL E_OPP_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:20:15	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CHEMISTRY_LA B_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:20:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INNOVATION_R OOM_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:20:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CONJUGATION_ ROOM_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:20:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INVENTORY_RO OM_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:20:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ ROOM_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:20:40	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ OPP_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:20:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INNOVATION_ ROOM_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:20:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CONJUGATIO N_ROOM_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:20:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CELL_CULTU RE_ROOM_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:20:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INVENTORY_ ROOM_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 13:21:05	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPL_E_ROOM_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:21:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CELL_CULTURE_ROOM_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:21:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CHEMISTRY_LAB_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:21:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_STABILITY_ROOM_R_AND_D/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:21:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_RH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:21:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_TH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:21:40	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_TH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:21:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_RH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:21:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_AND_D_03_RH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:21:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_AND_D_03_TH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:22:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_TH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 13:22:06	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_RH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:22:11	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:22:19	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_TH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:22:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_RH_HOT/NumericInterval	interval	15 minutes	1 hour, 10 minutes	admin
04-Jun-2025 13:22:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_TH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:22:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_RH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:22:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_TH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:22:44	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_RH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:22:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_TH_HOT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:23:06	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRIERATOR_2/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:23:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRIERATOR_1/NumericInterval	interval	15 minutes	10 minutes	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 13:23:40	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_FORMULATION_REFRIGERATOR_1/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:23:44	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_RM_CONSUMABLE_2\$20FREEZER/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:23:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2015/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:23:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB_REFRIGERATOR_16/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:23:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$206/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:24:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2013/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:24:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2014/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:24:12	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:24:17	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:24:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_2/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:24:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1/NumericInterval	interval	15 minutes	10 minutes	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 13:24:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/TEMP_MIS_ROOM/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:24:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_2/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:24:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_1/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:24:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:24:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_3/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:25:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY_CHAMBER_2_EQUIPMENT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:25:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY\$20CHAMBER\$203_EQUIPMENT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:25:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGERATOR_4/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:25:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGERATOR_5/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:25:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_LOW_DIFFERENTIAL/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:25:52	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_HIGH_DIFFERENTIAL/NumericInterval	interval	15 minutes	10 minutes	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 13:25:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_HIGH_TEMP_ALARM/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:26:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_LOW_TEMP_ALARM/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:26:06	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_SWAP_TIME/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:26:12	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:26:19	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_2/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:26:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_LOW_SETPOINT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:27:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_HIGH_SETPOINT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:28:34	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:28:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_2/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:28:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_LOW_SETPOINT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:28:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_LOW_DIFFERENTIAL/NumericInterval	interval	15 minutes	10 minutes	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 13:28:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/R\$26D_BDC051_HIGH_S ETPOINT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:28:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/R\$26D_BDC051_HIGH_D IFFERENTIAL/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:29:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/R\$26D_BDC051_HIGH_T EMP_ALARM/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:29:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/R\$26D_BDC051_LOW_T EMP_ALARM/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:29:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/R\$26D_BDC051_SWAP_ TIME/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:29:21	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/R\$26D_BDC053_ROOM_ TEMP_1/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:29:34	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/R\$26D_BDC053_ROOM_ TEMP_2/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:29:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/R\$26D_BDC053_LOW_S ETPOINT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:29:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/R\$26D_BDC053_LOW_DI FFERENTIAL/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:29:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/R\$26D_BDC053_HIGH_S ETPOINT/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:29:52	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/R\$26D_BDC053_HIGH_D IFFERENTIAL/NumericInterval	interval	15 minutes	10 minutes	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 13:29:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_HIGH_T EMP_ALARM/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:30:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_LOW_T EMP_ALARM/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:30:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_SWAP_ TIME/NumericInterval	interval	15 minutes	10 minutes	admin
04-Jun-2025 13:31:07	PLV	PointListServlet	station: h:ccf	Fetch Points, Views, Graphics and Schedules	Request	admin
04-Jun-2025 13:31:07	PLV	PointListServlet	station: h:ccf	Fetch Points, Views, Graphics and Schedules	Response with:(0,0,0,0)	admin
04-Jun-2025 14:08:31	Added	/Services/OrionAlarmService	DefaultTrendAlarmCl ass		Default Trend Alarm Class	admin
04-Jun-2025 14:08:31	Added	/Services/OrionAlarmService	Trend\$20Network\$20 and\$20Device\$20Ala rms		Trend Network and Device Alarms	admin
04-Jun-2025 14:08:31	Added	/Services/OrionAlarmService	Alarms\$20From\$20T rend\$20Systems		Alarms\$20From\$20T rend\$20Systems	admin
04-Jun-2025 14:08:31	Added	/Services/OrionAlarmService	Trend\$20Example\$2 0Alarm\$20Class\$20f or\$20\$22filter\$20by\$ 20device\$22		Trend Example Alarm Class for "filter by device"	admin
04-Jun-2025 14:08:31	Added	/Services/OrionAlarmService	Trend\$20Example\$2 0Alarm\$20Class\$20f or\$20\$22filter\$20by\$ 20label\$20matching\$ 22		Trend Example Alarm Class for "filter by label matching"	admin
04-Jun-2025 14:08:31	Added	/Services/OrionAlarmService	TrendExampleAlarm Classes		TrendExampleAlarm Classes	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 14:08:31	Added	/Services/OrionAlarmService	Trend\$20Buffer\$20Ready\$20\$28BBUF\$29\$20Alarm\$20Class		Trend Buffer Ready (BBUF) Alarm Class	admin
04-Jun-2025 14:08:52	Removed	/Services/AlarmService	DefaultTrendAlarmClass			admin
04-Jun-2025 14:08:52	Removed	/Services/AlarmService	Trend\$20Network\$20and\$20Device\$20Alarms			admin
04-Jun-2025 14:08:52	Removed	/Services/AlarmService	Alarms\$20From\$20Trend\$20Systems	AlarmRecipient		admin
04-Jun-2025 14:08:52	Removed	/Services/AlarmService	Trend\$20Example\$20Alarm\$20Class\$20for\$20\$22filter\$20by\$20device\$22			admin
04-Jun-2025 14:08:52	Removed	/Services/AlarmService	Trend\$20Example\$20Alarm\$20Class\$20for\$20\$22filter\$20by\$20label\$20matching\$22			admin
04-Jun-2025 14:08:52	Removed	/Services/AlarmService	TrendExampleAlarmClasses	AlarmRecipient		admin
04-Jun-2025 14:08:52	Removed	/Services/AlarmService	Trend\$20Buffer\$20Ready\$20\$28BBUF\$29\$20Alarm\$20Class			admin
04-Jun-2025 14:09:58	Added	/Services	OrionService		Orion Service	admin
04-Jun-2025 14:14:54	Removed	/Services	AlarmService	Alarm Service		admin
04-Jun-2025 14:17:32	Changed	/Services/OrionAlarmService	database	null	station: slot:/Drivers/RdbmsNetwork/SqlServerDatabase	admin
04-Jun-2025 14:17:42	Invoked	/Services/JobService	submitAction		Station Save	admin
04-Jun-2025 14:17:42	Invoked	/	save			admin
04-Jun-2025 14:24:22	Changed	/Drivers/RdbmsNetwork/SqlServerDatabase/worker	maxThreads	1	max	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 14:24:22	Changed	/Drivers/RdbmsNetwork/SqlServerDatabase/worker	maxQueueSize	1000	max	admin
04-Jun-2025 14:24:43	Flags Changed	/Drivers/RdbmsNetwork/SqlServerDatabase	connectionPool	h	o	admin
04-Jun-2025 14:25:12	Changed	/Drivers/RdbmsNetwork/SqlServerDatabase/connectionPool	maxActive	30	max	admin
04-Jun-2025 14:25:12	Changed	/Drivers/RdbmsNetwork/SqlServerDatabase/connectionPool	maxIdle	10	max	admin
04-Jun-2025 15:54:19	PLV	PointListServlet	station: h:880	Fetch Points, Views, Graphics and Schedules	Request	admin
04-Jun-2025 15:54:20	PLV	PointListServlet	station: h:880	Fetch Points, Views, Graphics and Schedules	Response with:(26,0,0,0)	admin
04-Jun-2025 15:56:18	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_MIS_ROOM	OutOfRangeAlarmExt		Alarm Source Ext	admin
04-Jun-2025 15:59:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_MIS_ROOM/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
04-Jun-2025 15:59:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	24.0 °C	admin
04-Jun-2025 15:59:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
04-Jun-2025 15:59:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_COLDSPOT RH MIS ROOM TEMP IS ABOVE 24 °C	admin
04-Jun-2025 15:59:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_COLDSPOT RH MIS ROOM TEMP IS BELOW 18 °C	admin
04-Jun-2025 15:59:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 15:59:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
04-Jun-2025 15:59:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_MIS_ROOM/OutOfRangeAlarmExt	alarmClass	defaultAlarmClass	DefaultTrendAlarmClass	admin
04-Jun-2025 16:00:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_MIS_ROOM/OutOfRangeAlarmExt	toOffnormalText		MFG_COLDSPOT RH MIS ROOM TEMP IS NOT NORMAL	admin
04-Jun-2025 16:00:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_MIS_ROOM/OutOfRangeAlarmExt	toNormalText		MFG_COLDSPOT RH MIS ROOM TEMP IS NORMAL	admin
04-Jun-2025 16:00:51	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLES_2	OutOfRangeAlarmExt		Alarm Source Ext	admin
04-Jun-2025 16:01:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLES_2/OutOfRangeAlarmExt	toOffnormalText	MFG_COLDSPOT RH MIS ROOM TEMP IS NOT NORMAL	MFG_COLDSPOT RH_RM_CONSUMABLES_2 TEMP IS NOT NORMAL	admin
04-Jun-2025 16:01:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLES_2/OutOfRangeAlarmExt	toNormalText	MFG_COLDSPOT RH MIS ROOM TEMP IS NORMAL	MFG_COLDSPOT RH_RM_CONSUMABLES_2 TEMP IS NORMAL	admin
04-Jun-2025 16:01:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLES_2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_COLDSPOT RH MIS ROOM TEMP IS ABOVE 24 °C	MFG_COLDSPOT RH_RM_CONSUMABLES_2 TEMP IS ABOVE 24 °C	admin
04-Jun-2025 16:01:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLES_2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_COLDSPOT RH MIS ROOM TEMP IS BELOW 18 °C	MFG_COLDSPOT RH_RM_CONSUMABLES_2 TEMP IS BELOW 18 °C	admin
04-Jun-2025 16:01:55	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLES_1	OutOfRangeAlarmExt		Alarm Source Ext	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 16:02:15	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLE S_1/OutOfRangeAlarmExt	toOffnormalText	MFG_COLDSPOT RH_RM_CONSUMABLES_2 TEMP IS NOT NORMAL	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS NOT NORMAL	admin
04-Jun-2025 16:02:15	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLE S_1/OutOfRangeAlarmExt	toNormalText	MFG_COLDSPOT RH_RM_CONSUMABLES_2 TEMP IS NORMAL	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS NORMAL	admin
04-Jun-2025 16:02:15	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLE S_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_COLDSPOT RH_RM_CONSUMABLES_2 TEMP IS ABOVE 24 °C	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS ABOVE 24 °C	admin
04-Jun-2025 16:02:15	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLE S_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_COLDSPOT RH_RM_CONSUMABLES_2 TEMP IS BELOW 18 °C	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS BELOW 18 °C	admin
04-Jun-2025 16:02:24	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_BUFFER_ROOM	OutOfRangeAlarmExt		Alarm Source Ext	admin
04-Jun-2025 16:03:48	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
04-Jun-2025 16:04:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/OutOfRangeAlarmExt	toOffnormalText	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS NOT NORMAL	MFG_QA_RETAINS_TEMP_COLD_SPOT IS NOT NORMAL	admin
04-Jun-2025 16:04:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/OutOfRangeAlarmExt	toNormalText	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS NORMAL	MFG_QA_RETAINS_TEMP_COLD_SPOT IS NORMAL	admin
04-Jun-2025 16:04:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS ABOVE 24 °C	MFG_QA_RETAINS_TEMP_COLD_SPOT TEMP IS ABOVE 24 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 16:04:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS BELOW 18 °C	MFG_QA_RETAINS_TEMP_COLD_SPOT TEMP IS BELOW 18 °C	admin
04-Jun-2025 16:04:38	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_QC_LAB	OutOfRangeAlarmExt		Alarm Source Ext	admin
04-Jun-2025 16:06:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_QC_LAB/OutOfRangeAlarmExt	toOffnormalText	MFG_QA_RETAINS_TEMP_COLD_SPOT IS NOT NORMAL	QC_LAB COLD SPOT TEMP IS NOT NORMAL	admin
04-Jun-2025 16:06:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_QC_LAB/OutOfRangeAlarmExt	toNormalText	MFG_QA_RETAINS_TEMP_COLD_SPOT IS NORMAL	QC_LAB COLD SPOT TEMP IS NORMAL	admin
04-Jun-2025 16:06:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_QC_LAB/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_QA_RETAINS_TEMP_COLD_SPOT TEMP IS ABOVE 24 °C	QC_LAB COLD SPOT TEMP TEMP IS ABOVE 24 °C	admin
04-Jun-2025 16:06:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_QC_LAB/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_QA_RETAINS_TEMP_COLD_SPOT TEMP IS BELOW 18 °C	QC_LAB COLD SPOT TEMP TEMP IS BELOW 18 °C	admin
04-Jun-2025 16:06:23	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_FORMULATION_ROOM	OutOfRangeAlarmExt		Alarm Source Ext	admin
04-Jun-2025 16:36:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/OutOfRangeAlarmExt	toOffnormalText	MFG_QA_RETAINS_TEMP_COLD_SPOT IS NOT NORMAL	%alarmData.sourceName%_Alarm	admin
04-Jun-2025 16:36:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/OutOfRangeAlarmExt	toNormalText	MFG_QA_RETAINS_TEMP_COLD_SPOT IS NORMAL	%alarmData.sourceName%_within range	admin
04-Jun-2025 16:36:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_QA_RETAINS_TEMP_COLD_SPOT TEMP IS ABOVE 24 °C	%alarmData.sourceName% above 25	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
04-Jun-2025 16:36:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/OutOfRangeAlarmExt/off normalAlgorithm	lowLimitText	MFG_QA_RETAINS_TEMP_COLD_SPO T TEMP IS BELOW 18 °C	%alarmData.sourceName% below 18	admin
04-Jun-2025 16:37:02	PLV	PointListServlet	station: h:880	Fetch Points, Views, Graphics and Schedules	Request	admin
04-Jun-2025 16:37:02	PLV	PointListServlet	station: h:880	Fetch Points, Views, Graphics and Schedules	Response with:(26,0,0,0)	admin
04-Jun-2025 16:37:04	PLV	PointListServlet	station: h:880	Fetch Points, Views, Graphics and Schedules	Request	admin
04-Jun-2025 16:37:04	PLV	PointListServlet	station: h:880	Fetch Points, Views, Graphics and Schedules	Response with:(26,0,0,0)	admin
04-Jun-2025 16:37:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/proxyExt	conversion	Default	Linear +20.00	admin
04-Jun-2025 16:38:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/proxyExt	conversion	Linear +20.00	Default	admin
04-Jun-2025 16:43:58	Changed	/Services/OrionAlarmService/Alarms\$20From\$20Trend\$20Systems	wsAnnotation	33,27,20	38,27,20	admin
04-Jun-2025 16:43:58	Added	/Services/OrionAlarmService/defaultAlarmClass	wsAnnotation		6,6,8	admin
04-Jun-2025 16:43:58	Added	/Services/OrionAlarmService/alarmDbConfig	wsAnnotation		2,2,8	admin
10-Jun-2025 11:06:54	Changed	/Services/EmailService/OutgoingAccount	hostname		na-relay.danahermail.com	admin
10-Jun-2025 11:06:54	Changed	/Services/EmailService/OutgoingAccount	account		authsmtp	admin
10-Jun-2025 11:06:54	Changed	/Services/EmailService/OutgoingAccount	replyTo		emsalerts@beckman.com EMS Alarms Bengaluru	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
10-Jun-2025 11:06:54	Changed	/Services/EmailService/OutgoingAccount	maxQueueSize	100	1000	admin
10-Jun-2025 11:11:18	Added	/Services/OrionAlarmService	EmailRecipient		EmailRecipient	admin
10-Jun-2025 11:11:26	Added	/Services/OrionAlarmService/EmailRecipient	Link		Indirect: h:1289.alarm -> slot:/Services/OrionAlarmService/EmailRecipient.routeAlarm	admin
10-Jun-2025 11:11:30	Added	/Services/OrionAlarmService/EmailRecipient	Link1		Indirect: h:128a.alarm -> slot:/Services/OrionAlarmService/EmailRecipient.routeAlarm	admin
10-Jun-2025 11:11:33	Added	/Services/OrionAlarmService/EmailRecipient	Link2		Indirect: h:128f.alarm -> slot:/Services/OrionAlarmService/EmailRecipient.routeAlarm	admin
10-Jun-2025 11:12:02	Changed	/Services/OrionAlarmService/EmailRecipient	emailAccount		OutgoingAccount	admin
10-Jun-2025 11:12:15	Changed	/Services/OrionAlarmService/EmailRecipient	wsAnnotation	45,18,8	45,18,15	admin
10-Jun-2025 11:12:17	Changed	/Services/OrionAlarmService/EmailRecipient	wsAnnotation	45,18,15	38,18,15	admin
10-Jun-2025 11:32:05	Changed	/Services/EmailService/OutgoingAccount	password	--password--	--password--	admin
10-Jun-2025 11:58:48	Invoked	/Services/EmailService/OutgoingAccount	send		Email	admin
10-Jun-2025 12:21:23	Changed	/Services/OrionAlarmService/EmailRecipient	to		bdcfacility@beckman.com BDC Facility	admin
12-Jun-2025 14:05:22	Changed	/Services/EmailService/OutgoingAccount	hostname	na-relay.danahermail.com	relay.danahermail.com	admin
12-Jun-2025 14:05:36	Changed	/Services/EmailService/OutgoingAccount	password	--password--	--password--	admin
12-Jun-2025 14:06:01	Invoked	/Services/EmailService/OutgoingAccount	send		Email	admin
12-Jun-2025 14:06:44	Changed	/Services/EmailService/OutgoingAccount	password	--password--	--password--	admin
12-Jun-2025 14:07:00	Invoked	/Services/EmailService/OutgoingAccount	send		Email	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
12-Jun-2025 14:07:55	Changed	/Services/EmailService/OutgoingAccount	useAuthentication	false	true	admin
12-Jun-2025 14:07:55	Changed	/Services/EmailService/OutgoingAccount	persistent	false	true	admin
12-Jun-2025 14:08:15	Invoked	/Services/EmailService/OutgoingAccount	send		Email	admin
12-Jun-2025 14:08:56	Invoked	/Services/JobService	submitAction		Station Save	admin
12-Jun-2025 14:08:56	Invoked	/	save			admin
12-Jun-2025 14:12:15	Invoked	/Services/EmailService/OutgoingAccount	send		Email	admin
12-Jun-2025 14:24:21	Invoked	/Services/EmailService/OutgoingAccount	send		Email	admin
14-Jun-2025 12:05:00	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 12:37:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 12:37:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT	admin
14-Jun-2025 12:37:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT SPOT IS NOT NORMALHI	admin
14-Jun-2025 12:37:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT/OutOfRangeAlarmExt	toNormalText		PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT SPOT IS NORMAL	admin
14-Jun-2025 12:37:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 12:37:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 12:37:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT SPOT IS ABOVE 25 DEGREE	admin
14-Jun-2025 12:37:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT SPOT IS BELOW 18 DEGREE	admin
14-Jun-2025 12:37:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 12:37:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 12:40:28	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 12:48:05	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 12:48:05	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT SPOT IS NOT NORMAL	admin
14-Jun-2025 12:48:05	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT/OutOfRangeAlarmExt	toNormalText		PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT SPOT IS NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 12:48:05	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 12:48:05	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin
14-Jun-2025 12:48:05	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT SPOT IS ABOVE 80 PERCENTAGE	admin
14-Jun-2025 12:48:05	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT SPOT IS BELOW 30 PERCENTAGE	admin
14-Jun-2025 12:48:05	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 12:48:05	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 12:51:13	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AND_STORAGE_AREA	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 12:55:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AND_STORAGE_AREA/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 12:55:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AMD_STORAGE_AREA/OutOfRangeAlarmExt	sourceName	%parent.displayName%	PACKING_AND_STORAGE_AREA_07_COLD SPOT	admin
14-Jun-2025 12:55:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AMD_STORAGE_AREA/OutOfRangeAlarmExt	toOffnormalText		PACKING_AND_STORAGE_AREA_07_COLD SPOT IS NOT NORMAL	admin
14-Jun-2025 12:55:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AMD_STORAGE_AREA/OutOfRangeAlarmExt	toNormalText		PACKING_AND_STORAGE_AREA_07_COLD SPOT IS NORMAL	admin
14-Jun-2025 12:55:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AMD_STORAGE_AREA/OutOfRangeAlarmExt/offsetNormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 12:55:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AMD_STORAGE_AREA/OutOfRangeAlarmExt/offsetNormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 12:55:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AMD_STORAGE_AREA/OutOfRangeAlarmExt/offsetNormalAlgorithm	highLimitText		PACKING_AND_STORAGE_AREA_07_COLD SPOT IS ABOVE 25 DEGREE	admin
14-Jun-2025 12:55:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AMD_STORAGE_AREA/OutOfRangeAlarmExt/offsetNormalAlgorithm	lowLimitText		PACKING_AND_STORAGE_AREA_07_COLD SPOT BELOW 18 DEGREE	admin
14-Jun-2025 12:55:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AMD_STORAGE_AREA/OutOfRangeAlarmExt/offsetNormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 12:55:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AMD_STORAGE_AREA/OutOfRangeAlarmExt/offsetNormalAlgorithm	limitEnable/highLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 12:56:34	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PACKING_AMD_STORAGE_AREA_COLD	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 12:59:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PACKING_AMD_STORAGE_AREA_COLD/OutOfRangeAlarmExt	sourceName	%parent.displayName%	PACKING_AND_STORAGE_AREA_COLD_SPOT_RH	admin
14-Jun-2025 12:59:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PACKING_AMD_STORAGE_AREA_COLD/OutOfRangeAlarmExt	toOffnormalText		PACKING_AND_STORAGE_AREA_COLD_SPOT_RH IS NOT NORMAL	admin
14-Jun-2025 12:59:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PACKING_AMD_STORAGE_AREA_COLD/OutOfRangeAlarmExt	toNormalText		PACKING_AND_STORAGE_AREA_COLD_SPOT_RH IS NORMAL	admin
14-Jun-2025 12:59:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PACKING_AMD_STORAGE_AREA_COLD/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 12:59:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PACKING_AMD_STORAGE_AREA_COLD/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 12:59:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PACKING_AMD_STORAGE_AREA_COLD/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		PACKING_AND_STORAGE_AREA_COLD_SPOT_RH IS ABOVE 80 PERCENTAGE	admin
14-Jun-2025 12:59:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PACKING_AMD_STORAGE_AREA_COLD/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		PACKING_AND_STORAGE_AREA_COLD_SPOT_RH IS BELOW 30 PERCENTAGE	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 12:59:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PACKING_AMD_STORAGE_AREA_COLD/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 12:59:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PACKING_AMD_STORAGE_AREA_COLD/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 13:00:12	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PACKING_AMD_STORAGE_AREA_COLD/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 13:04:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT	admin
14-Jun-2025 13:04:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT SPOT IS ABOVE 80 PERCENTAGE	PACKING_AND_STORAGE_ROOM_MFG_07_RH_HOT SPOT IS ABOVE 80 PERCENTAGE	admin
14-Jun-2025 13:06:34	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AMD_STORAGE_AREA/OutOfRangeAlarmExt	sourceName	PACKING_AND_STORAGE_AREA_07_COLD SPOT	PACKING_AND_STORAGE_AREA_07_COLD TH	admin
14-Jun-2025 13:06:34	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AMD_STORAGE_AREA/OutOfRangeAlarmExt	toOffnormalText	PACKING_AND_STORAGE_AREA_07_COLD SPOT IS NOT NORMAL	PACKING_AND_STORAGE_AREA_07_COLD SPOT TEMP IS NOT NORMAL	admin
14-Jun-2025 13:06:34	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AMD_STORAGE_AREA/OutOfRangeAlarmExt	toNormalText	PACKING_AND_STORAGE_AREA_07_COLD SPOT IS NORMAL	PACKING_AND_STORAGE_AREA_07_COLD SPOT TEMP IS NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 13:06:34	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AMD_STORAGE_AREA/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	PACKING_AND_STORAGE_AREA_07_COLD SPOT IS ABOVE 25 DEGREE	PACKING_AND_STORAGE_AREA_07_COLD SPOT TEMP IS ABOVE 25 DEGREE	admin
14-Jun-2025 13:06:34	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PACKING_AMD_STORAGE_AREA/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	PACKING_AND_STORAGE_AREA_07_COLD SPOT BELOW 18 DEGREE	PACKING_AND_STORAGE_AREA_07_COLD SPOT TEMP BELOW 18 DEGREE	admin
14-Jun-2025 13:08:51	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_TH_HOT/OutOfRangeAlarmExt	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 13:13:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 13:13:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_TH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	QC_LAB_MFG_09_TH_HOT	admin
14-Jun-2025 13:13:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		QC_LAB_MFG_09_TH_HOT IS NOT NORMAL	admin
14-Jun-2025 13:13:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_TH_HOT/OutOfRangeAlarmExt	toNormalText		QC_LAB_MFG_09_TH_HOT IS NOT NORMAL	admin
14-Jun-2025 13:13:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 13:13:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin
14-Jun-2025 13:13:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		QC_LAB_MFG_09_TH_HOT IS ABOVE 25 DEGREE	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 13:13:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		QC_LAB_MFG_09_TH_HOT IS BELOW 18 DEGREE	admin
14-Jun-2025 13:13:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 13:13:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 13:15:06	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 13:18:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 13:18:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_RH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	QC_LAB_MFG_09_RH_HOT	admin
14-Jun-2025 13:18:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		QC_LAB_MFG_09_RH_HOT IS NOT NORMAL	admin
14-Jun-2025 13:18:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_RH_HOT/OutOfRangeAlarmExt	toNormalText		QC_LAB_MFG_09_RH_HOT IS NORMAL	admin
14-Jun-2025 13:18:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 13:18:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 13:18:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		QC_LAB_MFG_09_RH_HOT IS ABOVE 80 PERCENTAGE	admin
14-Jun-2025 13:18:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		QC_LAB_MFG_09_RH_HOT IS BELOW 30 PERCENTAGE	admin
14-Jun-2025 13:18:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 13:18:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 13:22:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_QC_LAB/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	24.0 °C	25.0 °C	admin
14-Jun-2025 13:22:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_QC_LAB/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	QC_LAB COLD SPOT TEMP IS ABOVE 24 °C	QC_LAB COLD SPOT TEMP IS ABOVE 25°C	admin
14-Jun-2025 13:22:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_QC_LAB/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	QC_LAB COLD SPOT TEMP IS BELOW 18 °C	QC_LAB COLD SPOT TEMP IS BELOW 18°C	admin
14-Jun-2025 13:24:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_QC_LAB/OutOfRangeAlarmExt	sourceName	%parent.displayName%	QC_LAB_COLD_SPOT_TEMP	admin
14-Jun-2025 13:24:52	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 13:28:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 13:28:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB/OutOfRangeAlarmExt	sourceName	%parent.displayName%	QC_LAB_COLD_SPOT_RH	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 13:28:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB/OutOfRangeAlarmExt	toOffnormalText		QC_LAB_COLD_SPOT_RH IS NOT NORMAL	admin
14-Jun-2025 13:28:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB/OutOfRangeAlarmExt	toNormalText		QC_LAB_COLD_SPOT_RH IS NORMAL	admin
14-Jun-2025 13:28:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 13:28:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 13:28:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		QC_LAB_COLD_SPOT_RH IS ABOVE 80%	admin
14-Jun-2025 13:28:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		QC_LAB_COLD_SPOT_RH IS BELOW 30%	admin
14-Jun-2025 13:28:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 13:28:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 13:29:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	QC_LAB_MFG_09_TH_HOT IS ABOVE 25 DEGREE	QC_LAB_MFG_09_TH_HOT IS ABOVE 25°C	admin
14-Jun-2025 13:29:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	QC_LAB_MFG_09_TH_HOT IS BELOW 18 DEGREE	QC_LAB_MFG_09_TH_HOT IS BELOW 18°C	admin
14-Jun-2025 13:31:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	QC_LAB_MFG_09_RH_HOT IS ABOVE 80 PERCENTAGE	QC_LAB_MFG_09_RH_HOT IS ABOVE 80%	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 13:31:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/QC_LAB_MFG_09_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	QC_LAB_MFG_09_RH_HOT IS BELOW 30 PERCENTAGE	QC_LAB_MFG_09_RH_HOT IS BELOW 30%	admin
14-Jun-2025 13:33:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT SPOT IS ABOVE 25 DEGREE	PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT SPOT IS ABOVE 25°C	admin
14-Jun-2025 13:33:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT SPOT IS BELOW 18 DEGREE	PACKING_AND_STORAGE_ROOM_MFG_07_TH_HOT SPOT IS BELOW 18°C	admin
14-Jun-2025 13:35:43	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_TH_13_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 13:41:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_TH_13_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 13:41:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_TH_13_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	BUFFER_ROOM_MFG_13_TH_HOT	admin
14-Jun-2025 13:41:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_TH_13_HOT/OutOfRangeAlarmExt	toOffnormalText		BUFFER_ROOM_MFG_13_TH_HOT IS NOT NORMAL	admin
14-Jun-2025 13:41:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_TH_13_HOT/OutOfRangeAlarmExt	toNormalText		BUFFER_ROOM_MFG_13_TH_HOT IS NORMAL	admin
14-Jun-2025 13:41:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_TH_13_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	25.00 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 13:41:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_TH_13_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin
14-Jun-2025 13:41:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_TH_13_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		BUFFER_ROOM_MFG_13_TH_HOT IS ABOVE 25°C	admin
14-Jun-2025 13:41:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_TH_13_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		BUFFER_ROOM_MFG_13_TH_HOT IS ABOVE 18°C	admin
14-Jun-2025 13:41:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_TH_13_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 13:41:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_TH_13_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 13:43:52	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_RH_13_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 13:46:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_RH_13_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 13:46:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_RH_13_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayname%	BUFFER_ROOM_MFG_13_HOT	admin
14-Jun-2025 13:46:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_RH_13_HOT/OutOfRangeAlarmExt	toOffnormalText		BUFFER_ROOM_MFG_13_HOT IS NOT NORMAL	admin
14-Jun-2025 13:46:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_RH_13_HOT/OutOfRangeAlarmExt	toNormalText		BUFFER_ROOM_MFG_13_HOT IS NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 13:46:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_RH_13_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 13:46:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_RH_13_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin
14-Jun-2025 13:46:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_RH_13_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		BUFFER_ROOM_MFG_13_HOT IS ABOVE 80%	admin
14-Jun-2025 13:46:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_RH_13_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		BUFFER_ROOM_MFG_13_HOT IS BELOW 30%	admin
14-Jun-2025 13:46:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_RH_13_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 13:46:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/BUFFER_ROOM_MFG_RH_13_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 14:19:43	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_RH_14_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 14:23:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_RH_14_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 14:23:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_RH_14_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	FORMULATION_ROOM_MFG_RH_14_HOT	admin
14-Jun-2025 14:23:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_RH_14_HOT/OutOfRangeAlarmExt	toOffnormalText		FORMULATION_ROOM_MFG_RH_14_HOT IS NOT NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 14:23:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_RH_14_HOT/OutOfRangeAlarmExt	toNormalText		FORMULATION_ROOM_MFG_RH_14_HOT IS NORMAL	admin
14-Jun-2025 14:23:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_RH_14_HOT/OutOfRangeAlarmExt/of fnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 14:23:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_RH_14_HOT/OutOfRangeAlarmExt/of fnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin
14-Jun-2025 14:23:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_RH_14_HOT/OutOfRangeAlarmExt/of fnormalAlgorithm	highLimitText		FORMULATION_ROOM_MFG_RH_14_HOT IS ABOVE 80%	admin
14-Jun-2025 14:23:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_RH_14_HOT/OutOfRangeAlarmExt/of fnormalAlgorithm	lowLimitText		FORMULATION_ROOM_MFG_RH_14_HOT IS BELOW 30	admin
14-Jun-2025 14:23:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_RH_14_HOT/OutOfRangeAlarmExt/of fnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 14:23:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_RH_14_HOT/OutOfRangeAlarmExt/of fnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 14:23:52	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_TH_14_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 14:26:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_TH_14_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	FORMULATION_ROOM_MFG_TH_14_HOT	admin
14-Jun-2025 14:26:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_TH_14_HOT/OutOfRangeAlarmExt	toOffnormalText		FORMULATION_ROOM_MFG_TH_14_HOT IS NOT NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 14:26:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_TH_14_HOT/OutOfRangeAlarmExt	toNormalText		FORMULATION_ROOM_MFG_TH_14_HOT IS NORMAL	admin
14-Jun-2025 14:26:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_TH_14_HOT/OutOfRangeAlarmExt/of fnormalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 14:26:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_TH_14_HOT/OutOfRangeAlarmExt/of fnormalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin
14-Jun-2025 14:26:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_TH_14_HOT/OutOfRangeAlarmExt/of fnormalAlgorithm	highLimitText		FORMULATION_ROOM_MFG_TH_14_HOT IS ABOVE 25°C	admin
14-Jun-2025 14:26:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_TH_14_HOT/OutOfRangeAlarmExt/of fnormalAlgorithm	lowLimitText		FORMULATION_ROOM_MFG_TH_14_HOT IS BELOW 18°C	admin
14-Jun-2025 14:26:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_TH_14_HOT/OutOfRangeAlarmExt/of fnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 14:26:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_TH_14_HOT/OutOfRangeAlarmExt/of fnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 14:28:49	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 14:30:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 14:30:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_RH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	NCMR_ROOM_MFG_16_RH_HOT	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 14:30:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		NCMR_ROOM_MFG_16_RH_HOT IS NOT NORMAL	admin
14-Jun-2025 14:30:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_RH_HOT/OutOfRangeAlarmExt	toNormalText		NCMR_ROOM_MFG_16_RH_HOT IS NORMAL	admin
14-Jun-2025 14:30:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 14:30:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin
14-Jun-2025 14:30:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		NCMR_ROOM_MFG_16_RH_HOT IS ABOVE 80%	admin
14-Jun-2025 14:30:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		NCMR_ROOM_MFG_16_RH_HOT IS BELOW 30%	admin
14-Jun-2025 14:30:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 14:30:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 14:32:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/FORMULATION_ROOM_MFG_TH_14_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 14:32:34	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_TH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 14:34:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 14:34:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_TH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	NCMR_ROOM_MFG_16_TH_HOT	admin
14-Jun-2025 14:34:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		NCMR_ROOM_MFG_16_TH_HOT IS NOT NORMAL	admin
14-Jun-2025 14:34:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_TH_HOT/OutOfRangeAlarmExt	toNormalText		NCMR_ROOM_MFG_16_TH_HOT IS NORMAL	admin
14-Jun-2025 14:34:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 14:34:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin
14-Jun-2025 14:34:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		NCMR_ROOM_MFG_16_TH_HOT IS ABOVE 25°C	admin
14-Jun-2025 14:34:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		NCMR_ROOM_MFG_16_TH_HOT IS BELOW 18°C	admin
14-Jun-2025 14:34:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 14:34:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/NCMR_ROOM_MFG_16_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 14:35:16	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 14:37:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 14:37:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_RH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	PLASMA_ROOM_MFG_17_RH_HOT	admin
14-Jun-2025 14:37:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		PLASMA_ROOM_MFG_17_RH_HOT IS NOT NORMAL	admin
14-Jun-2025 14:37:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_RH_HOT/OutOfRangeAlarmExt	toNormalText		PLASMA_ROOM_MFG_17_RH_HOT IS NORMAL	admin
14-Jun-2025 14:37:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 14:37:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin
14-Jun-2025 14:37:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		PLASMA_ROOM_MFG_17_RH_HOT IS ABOVE 80%	admin
14-Jun-2025 14:37:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		PLASMA_ROOM_MFG_17_RH_HOT IS BELOW 30%	admin
14-Jun-2025 14:37:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 14:37:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 14:38:09	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_TH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 14:41:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 14:41:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_TH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	PLASMA_ROOM_MFG_17_TH_HOT	admin
14-Jun-2025 14:41:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		PLASMA_ROOM_MFG_17_HOT TEMP IS NOT NORMAL	admin
14-Jun-2025 14:41:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_TH_HOT/OutOfRangeAlarmExt	toNormalText		PLASMA_ROOM_MFG_17_HOT TEMP IS NORMAL	admin
14-Jun-2025 14:41:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 14:41:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin
14-Jun-2025 14:41:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		PLASMA_ROOM_MFG_17_HOT TEMP IS ABOVE 25°C	admin
14-Jun-2025 14:41:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		PLASMA_ROOM_MFG_17_HOT TEMP IS BELOW 18°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 14:41:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 14:41:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/PLASMA_ROOM_MFG_17_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 14:41:38	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 14:44:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_RH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	RM_CONSUMABLES_2_MFG_18_RH_HOT	admin
14-Jun-2025 14:44:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		RM_CONSUMABLES_2_MFG_18_HOT RH IS NOT NORMAL	admin
14-Jun-2025 14:44:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_RH_HOT/OutOfRangeAlarmExt	toNormalText		RM_CONSUMABLES_2_MFG_18_HOT RH IS NORMAL	admin
14-Jun-2025 14:44:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 14:44:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin
14-Jun-2025 14:44:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		RM_CONSUMABLES_2_MFG_18_HOT RH IS ABOVE 80%	admin
14-Jun-2025 14:44:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		RM_CONSUMABLES_2_MFG_18_HOT RH IS BELOW 30%	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 14:44:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_RH_HOT/OutOfRangeAlarmExt/normalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 14:44:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_RH_HOT/OutOfRangeAlarmExt/normalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 14:44:47	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_TH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 14:47:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 14:47:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_TH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	RM_CONSUMABLES_2_MFG_18_TH_HOT	admin
14-Jun-2025 14:47:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		RM_CONSUMABLES_2_MFG_18_TH_HOT IS NOT NORMAL	admin
14-Jun-2025 14:47:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_TH_HOT/OutOfRangeAlarmExt	toNormalText		RM_CONSUMABLES_2_MFG_18_HOT TEMP IS NORMAL	admin
14-Jun-2025 14:47:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_TH_HOT/OutOfRangeAlarmExt/normalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 14:47:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_TH_HOT/OutOfRangeAlarmExt/normalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin
14-Jun-2025 14:47:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_TH_HOT/OutOfRangeAlarmExt/normalAlgorithm	highLimitText		RM_CONSUMABLES_2_MFG_18_HOT TEMP IS ABOVE 25°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 14:47:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_TH_HOT/OutOfRangeAlarmExt/normalAlgorithm	lowLimitText		RM_CONSUMABLES_2_MFG_18_HOT TEMP IS BELOW 18°C	admin
14-Jun-2025 14:47:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_TH_HOT/OutOfRangeAlarmExt/normalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 14:47:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_TH_HOT/OutOfRangeAlarmExt/normalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 14:47:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_2_MFG_18_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 14:48:36	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 14:51:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 14:51:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_RH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	DRY_DOWN_WORK_MFG_19_RH_HOT	admin
14-Jun-2025 14:51:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		DRY_DOWN_WORK_STATION_MFG_19_RH_HOT IS NOT NORMAL	admin
14-Jun-2025 14:51:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_RH_HOT/OutOfRangeAlarmExt	toNormalText		DRY_DOWN_WORK_STATION_MFG_19_RH_HOT IS NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 14:51:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 14:51:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin
14-Jun-2025 14:51:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		DRY_DOWN_WORK_STATION_MFG_19_HOT_RH IS ABOVE 80%	admin
14-Jun-2025 14:51:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		DRY_DOWN_WORK_STATION_MFG_19_HOT_RH IS BELOW 30%	admin
14-Jun-2025 14:51:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 14:51:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 14:52:18	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_TH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 14:55:41	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_TH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	DRY_DOWN_WORK_MFG_19_TH_HOT	admin
14-Jun-2025 14:55:41	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		DRY_DOWN_WORK_MFG_19_HOT TEMP IS NOT NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 14:55:41	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_TH_HOT/OutOfRangeAlarmExt	toNormalText		DRY_DOWN_WORK_MFG_19_HOT TEMP IS NORMAL	admin
14-Jun-2025 14:55:41	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 14:55:41	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin
14-Jun-2025 14:55:41	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		DRY_DOWN_WORK_MFG_19_HOT TEMP IS ABOVE 25°C	admin
14-Jun-2025 14:55:41	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		DRY_DOWN_WORK_MFG_19_HOT TEMP IS BELOW 18°C	admin
14-Jun-2025 14:55:41	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 14:55:41	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 14:56:38	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 14:58:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 14:58:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		MIS_ROOM_MFG_20_HOT_RH IS NOT NORMAL	admin
14-Jun-2025 14:58:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_RH_HOT/OutOfRangeAlarmExt	toNormalText		MIS_ROOM_MFG_20_HOT_RH IS NORMAL	admin
14-Jun-2025 14:58:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 14:58:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin
14-Jun-2025 14:58:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MIS_ROOM_MFG_20_HOT_RH IS ABOVE 80%	admin
14-Jun-2025 14:58:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MIS_ROOM_MFG_20_HOT_RH IS BELOW 30%	admin
14-Jun-2025 14:58:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 14:58:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 14:59:06	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/DRY_DOWN_WORK_STATION_MFG_19_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 14:59:29	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_TH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 15:01:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 15:01:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		MIS_ROOM_MFG_20_HOT TEMP IS NOT NORMAL	admin
14-Jun-2025 15:01:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_TH_HOT/OutOfRangeAlarmExt	toNormalText		MIS_ROOM_MFG_20_HOT TEMP IS NORMAL	admin
14-Jun-2025 15:01:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 15:01:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin
14-Jun-2025 15:01:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MIS_ROOM_MFG_20_HOT TEMP IS ABOVE 25	admin
14-Jun-2025 15:01:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MIS_ROOM_MFG_20_HOT TEMP IS BELOW 25	admin
14-Jun-2025 15:01:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 15:01:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:02:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MIS_ROOM_MFG_20_HOT TEMP IS ABOVE 25	MIS_ROOM_MFG_20_HOT TEMP IS ABOVE 25°C	admin
14-Jun-2025 15:02:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MIS_ROOM_MFG_20_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MIS_ROOM_MFG_20_HOT TEMP IS BELOW 25	MIS_ROOM_MFG_20_HOT TEMP IS BELOW 18°C	admin
14-Jun-2025 15:02:29	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 15:04:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 15:04:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_RH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	RM_CONSUMABLES_1_MFG_21_RH_HOT	admin
14-Jun-2025 15:04:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		RM_CONSUMABLES_1_MFG_21_HOT RH IS NOT NORMAL	admin
14-Jun-2025 15:04:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_RH_HOT/OutOfRangeAlarmExt	toNormalText		RM_CONSUMABLES_1_MFG_21_RH_HOT RH IS NORMAL	admin
14-Jun-2025 15:04:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 15:04:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin
14-Jun-2025 15:04:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		RM_CONSUMABLES_1_MFG_21_RH_HOT RH IS ABOVE 80%	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:04:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_RH_HOT/OutOfRangeAlarmExt/normalAlgorithm	lowLimitText		RM_CONSUMABLES_1_MFG_21_RH_HOT RH IS BELOW 30%	admin
14-Jun-2025 15:04:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_RH_HOT/OutOfRangeAlarmExt/normalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 15:04:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_RH_HOT/OutOfRangeAlarmExt/normalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 15:05:07	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_TH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 15:07:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 15:07:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_TH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	RM_CONSUMABLES_1_MFG_21_TH_HOT	admin
14-Jun-2025 15:07:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		RM_CONSUMABLES_1_MFG_21_HOT TEMP IS NOT NORMAL	admin
14-Jun-2025 15:07:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_TH_HOT/OutOfRangeAlarmExt	toNormalText		RM_CONSUMABLES_1_MFG_21_HOT TEMP IS NORMAL	admin
14-Jun-2025 15:07:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_TH_HOT/OutOfRangeAlarmExt/normalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 15:07:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_TH_HOT/OutOfRangeAlarmExt/normalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:07:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_TH_HOT/OutOfRangeAlarmExt/normalAlgorithm	highLimitText		RM_CONSUMABLES_1_MFG_21_HOT TEMP IS ABOVE 25°C	admin
14-Jun-2025 15:07:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_TH_HOT/OutOfRangeAlarmExt/normalAlgorithm	lowLimitText		RM_CONSUMABLES_1_MFG_21_HOT TEMP IS BELOW 18°C	admin
14-Jun-2025 15:07:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_TH_HOT/OutOfRangeAlarmExt/normalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 15:07:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/RM_CONSUMABLES_1_MFG_21_TH_HOT/OutOfRangeAlarmExt/normalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 15:08:34	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_QA_RETAINS_TEMP_HOT_SPOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 15:13:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_QA_RETAINS_TEMP_HOT_SPOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 15:13:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_QA_RETAINS_TEMP_HOT_SPOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_QA_RETAINS_TEMP_HOT	admin
14-Jun-2025 15:13:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_QA_RETAINS_TEMP_HOT_SPOT/OutOfRangeAlarmExt	toOffnormalText		MFG_QA_RETAINS_TEMP_HOT TEMP IS NOT NORMAL	admin
14-Jun-2025 15:13:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_QA_RETAINS_TEMP_HOT_SPOT/OutOfRangeAlarmExt	toNormalText		MFG_QA_RETAINS_TEMP_HOT TEMP IS NORMAL	admin
14-Jun-2025 15:13:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_QA_RETAINS_TEMP_HOT_SPOT/OutOfRangeAlarmExt/normalAlgorithm	highLimit	0.0 °C	25.0 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:13:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_QA_RETAINS_TEMP_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 15:13:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_QA_RETAINS_TEMP_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_QA_RETAINS_HOT TEMP IS ABOVE 25°C	admin
14-Jun-2025 15:13:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_QA_RETAINS_TEMP_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_QA_RETAINS_HOT TEMP IS BELOW 18°C	admin
14-Jun-2025 15:13:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_QA_RETAINS_TEMP_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 15:13:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_QA_RETAINS_TEMP_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 15:13:38	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_GLASS_WARE_TEMP_HOT_SPOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 15:17:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_GLASS_WARE_TEMP_HOT_SPOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 15:17:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_GLASS_WARE_TEMP_HOT_SPOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_GLASS_WARE_HOT_TEMP	admin
14-Jun-2025 15:17:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_GLASS_WARE_TEMP_HOT_SPOT/OutOfRangeAlarmExt	toOffnormalText		MFG_GLASS_WARE_HOT_TEMP IS NOT NORMAL	admin
14-Jun-2025 15:17:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_GLASS_WARE_TEMP_HOT_SPOT/OutOfRangeAlarmExt	toNormalText		MFG_GLASS_WARE_HOT_TEMP IS NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:17:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_GLASS_WARE_TEMP_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 15:17:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_GLASS_WARE_TEMP_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 15:17:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_GLASS_WARE_TEMP_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_GLASS_WARE_HOT_TEMP IS ABOVE 25°C	admin
14-Jun-2025 15:17:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_GLASS_WARE_TEMP_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_GLASS_WARE_HOT_TEMP IS BELOW 18°C	admin
14-Jun-2025 15:17:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_GLASS_WARE_TEMP_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 15:17:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_HOTSPOT/MFG_GLASS_WARE_TEMP_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 15:21:17	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLES_2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	24.0 %RH	80.0 %RH	admin
14-Jun-2025 15:21:17	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLES_2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	18.0 %RH	30.0 %RH	admin
14-Jun-2025 15:21:17	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLES_2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_COLDSPOT RH_RM_CONSUMABLES_2 TEMP IS ABOVE 24 °C	MFG_COLDSPOT RH_RM_CONSUMABLES_2 TEMP IS ABOVE 80%	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:21:17	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLES_2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_COLDSPOT RH_RM_CONSUMABLES_2 TEMP IS BELOW 18 °C	MFG_COLDSPOT RH_RM_CONSUMABLES_2 TEMP IS BELOW 30%	admin
14-Jun-2025 15:22:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLES_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	24.0 %RH	80.0 %RH	admin
14-Jun-2025 15:22:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLES_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	18.0 %RH	30.0 %RH	admin
14-Jun-2025 15:22:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLES_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS ABOVE 24 °C	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS ABOVE 80%	admin
14-Jun-2025 15:22:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_RM_CONSUMABLES_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS BELOW 18 °C	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS BELOW 30%	admin
14-Jun-2025 15:23:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_BUFFER_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	24.0 %RH	80.0 %RH	admin
14-Jun-2025 15:23:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_BUFFER_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	18.0 %RH	30.0 %RH	admin
14-Jun-2025 15:23:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_BUFFER_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS ABOVE 24 °C	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS ABOVE 80%	admin
14-Jun-2025 15:23:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_BUFFER_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS BELOW 18 °C	MFG_COLDSPOT RH_RM_CONSUMABLES_1 TEMP IS BELOW 30%	admin
14-Jun-2025 15:23:41	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM	OutOfRangeAlarmExt		Alarm Source Ext	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:25:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 15:25:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/OutOfRangeAlarmExt	sourceName	%parent.displayName%	PLASMA_ROOM_RH	admin
14-Jun-2025 15:25:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/OutOfRangeAlarmExt	toOffnormalText		PLASMA_ROOM_MFG_COLD_RH IS NOT NORMAL	admin
14-Jun-2025 15:25:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/OutOfRangeAlarmExt	toNormalText		PLASMA_ROOM_MFG_COLD_RH IS NOT NORMAL	admin
14-Jun-2025 15:25:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 15:25:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 15:25:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		PLASMA_ROOM_MFG_COLD_RH IS ABOVE 80%	admin
14-Jun-2025 15:25:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		PLASMA_ROOM_MFG_COLD_RH IS BELOW 30%	admin
14-Jun-2025 15:25:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 15:25:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 15:26:15	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WORK_STATION	OutOfRangeAlarmExt		Alarm Source Ext	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:30:12	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WOR K_STATION/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 15:30:12	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WOR K_STATION/OutOfRangeAlarmExt	sourceName	%parent.displayName e%	DRY_DOWN_COLD _RH	admin
14-Jun-2025 15:30:12	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WOR K_STATION/OutOfRangeAlarmExt	toOffnormalText		DRY_DOWN_COLD _RH IS NOT NORMAL	admin
14-Jun-2025 15:30:12	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WOR K_STATION/OutOfRangeAlarmExt	toNormalText		DRY_DOWN_COLD _RH IS NORMAL	admin
14-Jun-2025 15:30:12	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WOR K_STATION/OutOfRangeAlarmExt/offnorm alAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 15:30:12	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WOR K_STATION/OutOfRangeAlarmExt/offnorm alAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 15:30:12	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WOR K_STATION/OutOfRangeAlarmExt/offnorm alAlgorithm	highLimitText		DRY_DOWN_COLD _RH IS ABOVE 80%	admin
14-Jun-2025 15:30:12	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WOR K_STATION/OutOfRangeAlarmExt/offnorm alAlgorithm	lowLimitText		DRY_DOWN_COLD _RH IS BELOW 30%	admin
14-Jun-2025 15:30:12	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WOR K_STATION/OutOfRangeAlarmExt/offnorm alAlgorithm	limitEnable/lowLimitE nable	false	true	admin
14-Jun-2025 15:30:12	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WOR K_STATION/OutOfRangeAlarmExt/offnorm alAlgorithm	limitEnable/highLimit Enable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:35:25	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_R OOM	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 15:37:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_R OOM/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 15:37:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_R OOM/OutOfRangeAlarmExt	sourceName	%parent.displayName%	FORMULATION_RO OM_COLD_RH	admin
14-Jun-2025 15:37:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_R OOM/OutOfRangeAlarmExt	toOffnormalText		FORMULATION_RO OM_COLD_RH IS NOT NORMAL	admin
14-Jun-2025 15:37:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_R OOM/OutOfRangeAlarmExt	toNormalText		FORMULATION_RO OM_COLD_RH IS NORMAL	admin
14-Jun-2025 15:37:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_R OOM/OutOfRangeAlarmExt/offnormalAlgorit hm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 15:37:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_R OOM/OutOfRangeAlarmExt/offnormalAlgorit hm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 15:37:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_R OOM/OutOfRangeAlarmExt/offnormalAlgorit hm	highLimitText		FORMULATION_RO OM_COLD_RH IS ABOVE 80%	admin
14-Jun-2025 15:37:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_R OOM/OutOfRangeAlarmExt/offnormalAlgorit hm	lowLimitText		FORMULATION_RO OM_COLD_RH IS BELOW 30%	admin
14-Jun-2025 15:37:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_R OOM/OutOfRangeAlarmExt/offnormalAlgorit hm	limitEnable/lowLimitE nable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:37:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 15:38:09	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 15:39:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 15:39:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/OutOfRangeAlarmExt	sourceName	%parent.displayName%	NCMR_ROOM_MFG_COLD_RH	admin
14-Jun-2025 15:39:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/OutOfRangeAlarmExt	toOffnormalText		NCMR_ROOM_MFG_COLD_RH IS NOT NORMAL	admin
14-Jun-2025 15:39:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/OutOfRangeAlarmExt	toNormalText		NCMR_ROOM_MFG_COLD_RH IS NORMAL	admin
14-Jun-2025 15:39:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 15:39:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 15:39:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		NCMR_ROOM_MFG_COLD_RH IS ABOVE 80%	admin
14-Jun-2025 15:39:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		NCMR_ROOM_MFG_COLD_RH IS BELOW 30%	admin
14-Jun-2025 15:39:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:39:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 15:40:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_ROOM/OutOfRangeAlarmExt	toOffnormalText	FORMULATION_ROOM_COLD_RH IS NOT NORMAL	FORMULATION_ROOM_MFG_COLD_RH IS NOT NORMAL	admin
14-Jun-2025 15:40:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_ROOM/OutOfRangeAlarmExt	toNormalText	FORMULATION_ROOM_COLD_RH IS NORMAL	FORMULATION_ROOM_MFG_COLD_RH IS NORMAL	admin
14-Jun-2025 15:40:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	FORMULATION_ROOM_COLD_RH IS ABOVE 80%	FORMULATION_ROOM_MFG_COLD_RH IS ABOVE 80%	admin
14-Jun-2025 15:40:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	FORMULATION_ROOM_COLD_RH IS BELOW 30%	FORMULATION_ROOM_MFG_COLD_RH IS BELOW 30%	admin
14-Jun-2025 15:41:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB/OutOfRangeAlarmExt	sourceName	QC_LAB_COLD_SPOT_RH	QC_LAB_MFG_COLD_SPOT_RH	admin
14-Jun-2025 15:41:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB/OutOfRangeAlarmExt	toOffnormalText	QC_LAB_COLD_SPOT_RH IS NOT NORMAL	QC_LAB_MFG_COLD_SPOT_RH IS NOT NORMAL	admin
14-Jun-2025 15:41:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB/OutOfRangeAlarmExt	toNormalText	QC_LAB_COLD_SPOT_RH IS NORMAL	QC_LAB_MFG_COLD_SPOT_RH IS NORMAL	admin
14-Jun-2025 15:41:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	QC_LAB_COLD_SPOT_RH IS ABOVE 80%	QC_LAB_MFG_COLD_SPOT_RH IS ABOVE 80%	admin
14-Jun-2025 15:41:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_QC_LAB/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	QC_LAB_COLD_SPOT_RH IS BELOW 30%	QC_LAB_MFG_COLD_SPOT_RH IS BELOW 30%	admin
14-Jun-2025 15:42:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WORK_STATION/OutOfRangeAlarmExt	sourceName	DRY_DOWN_COLD_RH	DRY_DOWN_MFG_COLD_RH	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:42:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WOR K_STATION/OutOfRangeAlarmExt	toOffnormalText	DRY_DOWN_COLD _RH IS NOT NORMAL	DRY_DOWN_MFG_ COLD_RH IS NOT NORMAL	admin
14-Jun-2025 15:42:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WOR K_STATION/OutOfRangeAlarmExt	toNormalText	DRY_DOWN_COLD _RH IS NORMAL	DRY_DOWN_MFG_ COLD_RH IS NORMAL	admin
14-Jun-2025 15:42:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WOR K_STATION/OutOfRangeAlarmExt/offnorm alAlgorithm	highLimitText	DRY_DOWN_COLD _RH IS ABOVE 80%	DRY_DOWN_MFG_ COLD_RH IS ABOVE 80%	admin
14-Jun-2025 15:42:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WOR K_STATION/OutOfRangeAlarmExt/offnorm alAlgorithm	lowLimitText	DRY_DOWN_COLD _RH IS BELOW 30%	DRY_DOWN_MFG_ COLD_RH IS BELOW 30%	admin
14-Jun-2025 15:43:12	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_R H_HOT_SPOT	OutOfRangeAlarmEx t		Alarm Source Ext	admin
14-Jun-2025 15:45:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_R H_HOT_SPOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 15:45:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_R H_HOT_SPOT/OutOfRangeAlarmExt	sourceName	%parent.displayNam e%	MFG_GLASS_WAR E_HOT_RH	admin
14-Jun-2025 15:45:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_R H_HOT_SPOT/OutOfRangeAlarmExt	toOffnormalText		MFG_GLASS_WAR E_HOT_RH IS NOT NORMAL	admin
14-Jun-2025 15:45:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_R H_HOT_SPOT/OutOfRangeAlarmExt	toNormalText		MFG_GLASS_WAR E_HOT_RH IS NORMAL	admin
14-Jun-2025 15:45:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_R H_HOT_SPOT/OutOfRangeAlarmExt/offnor malAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:45:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 15:45:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_GLASS_WARE_HOT_RH IS ABOVE 80%	admin
14-Jun-2025 15:45:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_GLASS_WARE_HOT_RH IS BELOW 30%	admin
14-Jun-2025 15:45:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 15:45:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 15:45:27	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 15:47:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 15:47:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_GLASS_WARE_COLD_RH	admin
14-Jun-2025 15:47:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/OutOfRangeAlarmExt	toOffnormalText		MFG_GLASS_WARE_COLD_RH IS NOT NORMAL	admin
14-Jun-2025 15:47:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/OutOfRangeAlarmExt	toNormalText		MFG_GLASS_WARE_COLD_RH IS NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:47:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 15:47:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 15:47:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_GLASS_WARE_COLD_RH IS ABOVE 80%	admin
14-Jun-2025 15:47:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_GLASS_WARE_COLD_RH IS BELOW 30%	admin
14-Jun-2025 15:47:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 15:47:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 15:47:35	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 15:49:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 15:49:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_QA_RETAINS_COLD_RH	admin
14-Jun-2025 15:49:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/OutOfRangeAlarmExt	toOffnormalText		MFG_QA_RETAINS_COLD_RH IS NOT NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:49:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/OutOfRangeAlarmExt	toNormalText		MFG_QA_RETAINS_COLD_RH IS NORMAL	admin
14-Jun-2025 15:49:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 15:49:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 15:49:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_QA_RETAINS_COLD_RH IS ABOVE 80%	admin
14-Jun-2025 15:49:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_QA_RETAINS_COLD_RH IS BELOW 30%	admin
14-Jun-2025 15:49:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 15:49:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 15:49:50	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 15:52:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 15:52:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_QA_RETAINS_HOT_RH	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:52:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/OutOfRangeAlarmExt	toOffnormalText		MFG_QA_RETAINS_HOT_RH IS NOT NORMAL	admin
14-Jun-2025 15:52:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/OutOfRangeAlarmExt	toNormalText		MFG_QA_RETAINS_HOT_RH IS NORMAL	admin
14-Jun-2025 15:52:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 15:52:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 15:52:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_QA_RETAINS_HOT_RH IS ABOVE 80%	admin
14-Jun-2025 15:52:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_QA_RETAINS_HOT_RH IS BELOW 30%	admin
14-Jun-2025 15:52:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 15:52:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 15:52:20	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PLASMA_ROOM	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 15:55:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PLASMA_ROOM/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:55:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PLASMA_ROOM/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_PLASMA_ROOM_COLD_SPOT_TEMP	admin
14-Jun-2025 15:55:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PLASMA_ROOM/OutOfRangeAlarmExt	toOffnormalText		MFG_PLASMA_ROOM_COLD_SPOT_TEMP IS NOT NORMAL	admin
14-Jun-2025 15:55:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PLASMA_ROOM/OutOfRangeAlarmExt	toNormalText		MFG_PLASMA_ROOM_COLD_SPOT_TEMP IS NOT NORMAL	admin
14-Jun-2025 15:55:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PLASMA_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 15:55:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PLASMA_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 15:55:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PLASMA_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_PLASMA_ROOM_COLD_SPOT_TEMP IS ABOVE 25°C	admin
14-Jun-2025 15:55:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PLASMA_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_PLASMA_ROOM_COLD_SPOT_TEMP IS BELOW 18°C	admin
14-Jun-2025 15:55:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PLASMA_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 15:55:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_PLASMA_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 15:56:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/OutOfRangeAlarmExt	sourceName	MFG_QA_RETAINS_HOT_RH	MFG_QA_RETAINS_HOT_SPOT_RH	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:56:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/OutOfRangeAlarmExt	toOffnormalText	MFG_QA_RETAINS_HOT_RH IS NOT NORMAL	MFG_QA_RETAINS_HOT_SPOT_RH IS NOT NORMAL	admin
14-Jun-2025 15:56:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/OutOfRangeAlarmExt	toNormalText	MFG_QA_RETAINS_HOT_RH IS NORMAL	MFG_QA_RETAINS_HOT_SPOT_RH IS NORMAL	admin
14-Jun-2025 15:56:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_QA_RETAINS_HOT_RH IS ABOVE 80%	MFG_QA_RETAINS_HOT_SPOT_RH IS ABOVE 80%	admin
14-Jun-2025 15:56:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_QA_RETAINS_HOT_RH IS BELOW 30%	MFG_QA_RETAINS_HOT_SPOT_RH IS BELOW 30%	admin
14-Jun-2025 15:57:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/OutOfRangeAlarmExt	sourceName	MFG_QA_RETAINS_COLD_RH	MFG_QA_RETAINS_COLD_SPOT_RH	admin
14-Jun-2025 15:57:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/OutOfRangeAlarmExt	toOffnormalText	MFG_QA_RETAINS_COLD_RH IS NOT NORMAL	MFG_QA_RETAINS_COLD_SPOT_RH IS NOT NORMAL	admin
14-Jun-2025 15:57:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/OutOfRangeAlarmExt	toNormalText	MFG_QA_RETAINS_COLD_RH IS NORMAL	MFG_QA_RETAINS_COLD_SPOT_RH IS NORMAL	admin
14-Jun-2025 15:57:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_QA_RETAINS_COLD_RH IS ABOVE 80%	MFG_QA_RETAINS_COLD_SPOT_RH IS ABOVE 80%	admin
14-Jun-2025 15:57:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_QA_RETAINS_COLD_RH IS BELOW 30%	MFG_QA_RETAINS_COLD_SPOT_RH IS BELOW 30%	admin
14-Jun-2025 15:58:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/OutOfRangeAlarmExt	sourceName	MFG_GLASS_WARE_COLD_RH	MFG_GLASS_WARE_COLD_SPOT_RH	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:58:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/OutOfRangeAlarmExt	toOffnormalText	MFG_GLASS_WARE_COLD_RH IS NOT NORMAL	MFG_GLASS_WARE_COLD_SPOT_RH IS NOT NORMAL	admin
14-Jun-2025 15:58:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/OutOfRangeAlarmExt	toNormalText	MFG_GLASS_WARE_COLD_RH IS NORMAL	MFG_GLASS_WARE_COLD_SPOT_RH IS NORMAL	admin
14-Jun-2025 15:58:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_GLASS_WARE_COLD_RH IS ABOVE 80%	MFG_GLASS_WARE_COLD_SPOT_RH IS ABOVE 80%	admin
14-Jun-2025 15:58:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_GLASS_WARE_COLD_RH IS BELOW 30%	MFG_GLASS_WARE_COLD_SPOT_RH IS BELOW 30%	admin
14-Jun-2025 15:58:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_HOT_SPOT/OutOfRangeAlarmExt	toOffnormalText	MFG_GLASS_WARE_HOT_RH IS NOT NORMAL	MFG_GLASS_WARE_HOT_SPOT_RH IS NOT NORMAL	admin
14-Jun-2025 15:58:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_HOT_SPOT/OutOfRangeAlarmExt	toNormalText	MFG_GLASS_WARE_HOT_RH IS NORMAL	MFG_GLASS_WARE_HOT_SPOT_RH IS NORMAL	admin
14-Jun-2025 15:58:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_GLASS_WARE_HOT_RH IS ABOVE 80%	MFG_GLASS_WARE_HOT_SPOT_RH IS ABOVE 80%	admin
14-Jun-2025 15:58:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_HOT_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_GLASS_WARE_HOT_RH IS BELOW 30%	MFG_GLASS_WARE_HOT_SPOT_RH IS BELOW 30%	admin
14-Jun-2025 15:58:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/OutOfRangeAlarmExt	sourceName	NCMR_ROOM_MFG_COLD_RH	NCMR_ROOM_MFG_COLD_SPOT_RH	admin
14-Jun-2025 15:58:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/OutOfRangeAlarmExt	toOffnormalText	NCMR_ROOM_MFG_COLD_RH IS NOT NORMAL	NCMR_ROOM_MFG_COLD_SPOT_RH IS NOT NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:58:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/OutOfRangeAlarmExt	toNormalText	NCMR_ROOM_MFG_COLD_RH IS NORMAL	NCMR_ROOM_MFG_COLD_SPOT_RH IS NORMAL	admin
14-Jun-2025 15:58:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	NCMR_ROOM_MFG_COLD_RH IS ABOVE 80%	NCMR_ROOM_MFG_COLD_SPOT_RH IS ABOVE 80%	admin
14-Jun-2025 15:58:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	NCMR_ROOM_MFG_COLD_RH IS BELOW 30%	NCMR_ROOM_MFG_COLD_SPOT_RH IS BELOW 30%	admin
14-Jun-2025 15:59:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_ROOM/OutOfRangeAlarmExt	sourceName	FORMULATION_ROOM_COLD_RH	FORMULATION_ROOM_COLD_SPOT_RH	admin
14-Jun-2025 15:59:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_ROOM/OutOfRangeAlarmExt	toOffnormalText	FORMULATION_ROOM_MFG_COLD_RH IS NOT NORMAL	FORMULATION_ROOM_MFG_COLD_SPOT_RH IS NOT NORMAL	admin
14-Jun-2025 15:59:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_ROOM/OutOfRangeAlarmExt	toNormalText	FORMULATION_ROOM_MFG_COLD_RH IS NORMAL	FORMULATION_ROOM_MFG_COLD_SPOT_RH IS NORMAL	admin
14-Jun-2025 15:59:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	FORMULATION_ROOM_MFG_COLD_RH IS ABOVE 80%	FORMULATION_ROOM_MFG_COLD_SPOT_RH IS ABOVE 80%	admin
14-Jun-2025 15:59:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_FORMULATION_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	FORMULATION_ROOM_MFG_COLD_RH IS BELOW 30%	FORMULATION_ROOM_MFG_COLD_SPOT_RH IS BELOW 30%	admin
14-Jun-2025 15:59:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WORK_STATION/OutOfRangeAlarmExt	sourceName	DRY_DOWN_MFG_COLD_RH	DRY_DOWN_MFG_COLD_SPOT_RH	admin
14-Jun-2025 15:59:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WORK_STATION/OutOfRangeAlarmExt	toOffnormalText	DRY_DOWN_MFG_COLD_RH IS NOT NORMAL	DRY_DOWN_MFG_COLD_SPOT_RH IS NOT NORMAL	admin
14-Jun-2025 15:59:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WORK_STATION/OutOfRangeAlarmExt	toNormalText	DRY_DOWN_MFG_COLD_RH IS NORMAL	DRY_DOWN_MFG_COLD_SPOT_RH IS NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 15:59:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WORK_STATION/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	DRY_DOWN_MFG_COLD_RH IS ABOVE 80%	DRY_DOWN_MFG_COLD_SPOT_RH IS ABOVE 80%	admin
14-Jun-2025 15:59:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WORK_STATION/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	DRY_DOWN_MFG_COLD_RH IS BELOW 30%	DRY_DOWN_MFG_COLD_SPOT_RH IS BELOW 30%	admin
14-Jun-2025 16:00:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/OutOfRangeAlarmExt	sourceName	PLASMA_ROOM_RH	PLASMA_ROOM_COLD_SPOT_RH	admin
14-Jun-2025 16:00:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/OutOfRangeAlarmExt	toOffnormalText	PLASMA_ROOM_MFG_COLD_RH IS NOT NORMAL	PLASMA_ROOM_MFG_COLD_SPOT_RH IS NOT NORMAL	admin
14-Jun-2025 16:00:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/OutOfRangeAlarmExt	toNormalText	PLASMA_ROOM_MFG_COLD_RH IS NOT NORMAL	PLASMA_ROOM_MFG_COLD_SPOT_RH IS NOT NORMAL	admin
14-Jun-2025 16:00:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	PLASMA_ROOM_MFG_COLD_RH IS ABOVE 80%	PLASMA_ROOM_MFG_COLD_SPOT_RH IS ABOVE 80%	admin
14-Jun-2025 16:00:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	PLASMA_ROOM_MFG_COLD_RH IS BELOW 30%	PLASMA_ROOM_MFG_COLD_SPOT_RH IS BELOW 30%	admin
14-Jun-2025 16:01:00	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_MIS_ROOM	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 16:04:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_MIS_ROOM/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 16:04:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_MIS_ROOM/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_COLD_SPOT_MIS_ROOM_TEMP	admin
14-Jun-2025 16:04:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_MIS_ROOM/OutOfRangeAlarmExt	toOffnormalText		MFG_COLD_SPOT_MIS_ROOM_TEMP IS NOT NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 16:04:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_MIS_ROOM/OutOfRangeAlarmExt	toNormalText		MFG_COLD_SPOT_MIS_ROOM_TEMP IS NORMAL	admin
14-Jun-2025 16:04:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 16:04:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 16:04:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_COLD_SPOT_MIS_ROOM_TEMP IS ABOVE 25°C	admin
14-Jun-2025 16:04:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_COLD_SPOT_MIS_ROOM_TEMP IS BELOW 18°C	admin
14-Jun-2025 16:04:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 16:04:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 16:04:13	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_RM_CONSUMABLES_2	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 16:06:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_RM_CONSUMABLES_2/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 16:06:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_RM_CONSUMABLES_2/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_COLD_SPOT_RM_CONSUMABLES_2_TEMP	admin
14-Jun-2025 16:06:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_RM_CONSUMABLES_2/OutOfRangeAlarmExt	toOffnormalText		MFG_COLD_SPOT_RM_CONSUMABLES_2_TEMP IS NOT NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 16:06:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_2/OutOfRangeAlarmExt	toNormalText		MFG_COLD_SPOT_ RM_CONSUMBLES _2_TEMP IS NORMAL	admin
14-Jun-2025 16:06:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_2/OutOfRangeAlarmExt/offnormalAlg orithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 16:06:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_2/OutOfRangeAlarmExt/offnormalAlg orithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 16:06:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_2/OutOfRangeAlarmExt/offnormalAlg orithm	highLimitText		MFG_COLD_SPOT_ RM_CONSUMBLES _2_TEMP IS ABOVE 25°C	admin
14-Jun-2025 16:06:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_2/OutOfRangeAlarmExt/offnormalAlg orithm	lowLimitText		MFG_COLD_SPOT_ RM_CONSUMBLES _2_TEMP IS BELOW 18°C	admin
14-Jun-2025 16:06:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_2/OutOfRangeAlarmExt/offnormalAlg orithm	limitEnable/lowLimitE nable	false	true	admin
14-Jun-2025 16:06:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_2/OutOfRangeAlarmExt/offnormalAlg orithm	limitEnable/highLimit Enable	false	true	admin
14-Jun-2025 16:06:55	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_1	OutOfRangeAlarmEx t		Alarm Source Ext	admin
14-Jun-2025 16:09:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_1/OutOfRangeAlarmExt	sourceName	%parent.displayNam e%	MFG_COLD_SPOT_ RM_CONSUMBLES _1_TEMP	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 16:09:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_1/OutOfRangeAlarmExt	toOffnormalText		MFG_COLD_SPOT_ RM_CONSUMBLES _1_TEMP IS NOT NORMAL	admin
14-Jun-2025 16:09:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_1/OutOfRangeAlarmExt	toNormalText		MFG_COLD_SPOT_ RM_CONSUMBLES _1_TEMP IS NORMAL	admin
14-Jun-2025 16:09:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_1/OutOfRangeAlarmExt/offnormalAlg orithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 16:09:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_1/OutOfRangeAlarmExt/offnormalAlg orithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 16:09:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_1/OutOfRangeAlarmExt/offnormalAlg orithm	highLimitText		MFG_COLD_SPOT_ RM_CONSUMBLES _1_TEMP IS ABOVE 25°C	admin
14-Jun-2025 16:09:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_1/OutOfRangeAlarmExt/offnormalAlg orithm	lowLimitText		MFG_COLD_SPOT_ RM_CONSUMBLES _1_TEMP IS BELOW 18°C	admin
14-Jun-2025 16:09:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_1/OutOfRangeAlarmExt/offnormalAlg orithm	limitEnable/lowLimitE nable	false	true	admin
14-Jun-2025 16:09:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_1/OutOfRangeAlarmExt/offnormalAlg orithm	limitEnable/highLimit Enable	false	true	admin
14-Jun-2025 16:09:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/TEMP_RM_CONSUMA BLES_1/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 16:09:36	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_BUFFER_ROOM	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 16:11:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_BUFFER_ROOM/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 16:11:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_BUFFER_ROOM/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_COLD_SPOT_BUFFER_ROOM_TEMP	admin
14-Jun-2025 16:11:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_BUFFER_ROOM/OutOfRangeAlarmExt	toOffnormalText		MFG_COLD_SPOT_BUFFER_ROOM_TEMP IS NOT NORMAL	admin
14-Jun-2025 16:11:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_BUFFER_ROOM/OutOfRangeAlarmExt	toNormalText		MFG_COLD_SPOT_BUFFER_ROOM_TEMP IS NORMAL	admin
14-Jun-2025 16:11:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_BUFFER_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 16:11:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_BUFFER_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 16:11:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_BUFFER_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_COLD_SPOT_BUFFER_ROOM_TEMP IS ABOVE 25°C	admin
14-Jun-2025 16:11:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_BUFFER_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_COLD_SPOT_BUFFER_ROOM_TEMP IS BELOW 18°C	admin
14-Jun-2025 16:11:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_BUFFER_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 16:11:48	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_BUFFER_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 16:12:02	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_DRY_DOWN_W ORK_STATION	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 16:14:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_DRY_DOWN_W ORK_STATION/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 16:14:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_DRY_DOWN_W ORK_STATION/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_COLD_SPOT_DRY_DOWN_WORK_TEMP	admin
14-Jun-2025 16:14:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_DRY_DOWN_W ORK_STATION/OutOfRangeAlarmExt	toOffnormalText		MFG_COLD_SPOT_DRY_DOWN_WORK_TEMP IS NOT NORMAL	admin
14-Jun-2025 16:14:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_DRY_DOWN_W ORK_STATION/OutOfRangeAlarmExt	toNormalText		MFG_COLD_SPOT_DRY_DOWN_WORK_TEMP IS NORMAL	admin
14-Jun-2025 16:14:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_DRY_DOWN_W ORK_STATION/OutOfRangeAlarmExt/offno rmalAlgorithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 16:14:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_DRY_DOWN_W ORK_STATION/OutOfRangeAlarmExt/offno rmalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 16:14:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_DRY_DOWN_W ORK_STATION/OutOfRangeAlarmExt/offno rmalAlgorithm	highLimitText		MFG_COLD_SPOT_DRY_DOWN_WORK_TEMP IS ABOVE 25°C	admin
14-Jun-2025 16:14:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_DRY_DOWN_W ORK_STATION/OutOfRangeAlarmExt/offno rmalAlgorithm	lowLimitText		MFG_COLD_SPOT_DRY_DOWN_WORK_TEMP IS BELOW 18°C	admin
14-Jun-2025 16:14:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_DRY_DOWN_W ORK_STATION/OutOfRangeAlarmExt/offno rmalAlgorithm	limitEnable/lowLimitE nable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 16:14:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_DRY_DOWN_WORK_STATION/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 16:15:00	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_TEMP_COLD_SPOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 16:17:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_TEMP_COLD_SPOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 16:17:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_TEMP_COLD_SPOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_COLD_SPOT_GLASS_WARE_TEMP	admin
14-Jun-2025 16:17:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_TEMP_COLD_SPOT/OutOfRangeAlarmExt	toOffnormalText		MFG_COLD_SPOT_GLASS_WARE_TEMP IS NOT NORMAL	admin
14-Jun-2025 16:17:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_TEMP_COLD_SPOT/OutOfRangeAlarmExt	toNormalText		MFG_COLD_SPOT_GLASS_WARE_TEMP IS NORMAL	admin
14-Jun-2025 16:17:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_TEMP_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 16:17:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_TEMP_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 16:17:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_TEMP_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_COLD_SPOT_GLASS_WARE_TEMP IS ABOVE 25°C	admin
14-Jun-2025 16:17:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_TEMP_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_COLD_SPOT_GLASS_WARE_TEMP IS BELOW 18°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 16:17:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_TEMP_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 16:17:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_TEMP_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 16:17:46	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_NCMR_ROOM	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 16:19:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_NCMR_ROOM/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 16:19:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_NCMR_ROOM/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_COLD_SPOT_NCMR_ROOM_TEMP	admin
14-Jun-2025 16:19:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_NCMR_ROOM/OutOfRangeAlarmExt	toOffnormalText		MFG_COLD_SPOT_NCMR_ROOM_TEMP IS NOT NORMAL	admin
14-Jun-2025 16:19:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_NCMR_ROOM/OutOfRangeAlarmExt	toNormalText		MFG_COLD_SPOT_NCMR_ROOM_TEMP IS NORMAL	admin
14-Jun-2025 16:19:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_NCMR_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 16:19:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_NCMR_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 16:19:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_NCMR_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_COLD_SPOT_NCMR_ROOM_TEMP IS ABOVE 25°C	admin
14-Jun-2025 16:19:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_NCMR_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_COLD_SPOT_NCMR_ROOM_TEMP IS BELOW 18°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 16:19:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_NCMR_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 16:19:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_NCMR_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 16:20:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_FORMULATION_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	24.0 °C	25.0 °C	admin
14-Jun-2025 16:20:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_FORMULATION_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	QC_LAB COLD SPOT TEMP TEMP IS ABOVE 24 °C	QC_LAB COLD SPOT TEMP IS ABOVE 25 °C	admin
14-Jun-2025 16:20:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_FORMULATION_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	QC_LAB COLD SPOT TEMP TEMP IS BELOW 18 °C	QC_LAB COLD SPOT TEMP IS BELOW 18 °C	admin
14-Jun-2025 16:22:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_FORMULATION_ROOM/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_COLD_SPOT_FORMULATION_ROOM_TEMP	admin
14-Jun-2025 16:22:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_FORMULATION_ROOM/OutOfRangeAlarmExt	toOffnormalText	QC_LAB COLD SPOT TEMP IS NOT NORMAL	MFG_COLD_SPOT_FORMULATION_ROOM_TEMP IS NOT NORMAL	admin
14-Jun-2025 16:22:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_FORMULATION_ROOM/OutOfRangeAlarmExt	toNormalText	QC_LAB COLD SPOT TEMP IS NORMAL	MFG_COLD_SPOT_FORMULATION_ROOM_TEMP IS NORMAL	admin
14-Jun-2025 16:22:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_FORMULATION_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	QC_LAB COLD SPOT TEMP IS ABOVE 25 °C	MFG_COLD_SPOT_FORMULATION_ROOM_TEMP IS ABOVE 25 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 16:22:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_FORMULATION_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	QC_LAB COLD SPOT TEMP IS BELOW 18 °C	MFG_COLD_SPOT_FORMULATION_ROOM_TEMP IS BELOW 18 °C	admin
14-Jun-2025 16:23:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_QC_LAB/OutOfRangeAlarmExt	sourceName	QC_LAB_COLD_SPOT_TEMP	MFG_QC_LAB_COLD_SPOT_TEMP	admin
14-Jun-2025 16:23:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_QC_LAB/OutOfRangeAlarmExt	toOffnormalText	QC_LAB COLD SPOT TEMP IS NOT NORMAL	MFG_QC_LAB COLD SPOT TEMP IS NOT NORMAL	admin
14-Jun-2025 16:23:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_QC_LAB/OutOfRangeAlarmExt	toNormalText	QC_LAB COLD SPOT TEMP IS NORMAL	MFG_QC_LAB COLD SPOT TEMP IS NORMAL	admin
14-Jun-2025 16:23:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_QC_LAB/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	QC_LAB COLD SPOT TEMP IS ABOVE 25°C	MFG_QC_LAB COLD SPOT TEMP IS ABOVE 25°C	admin
14-Jun-2025 16:23:39	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/TEMP_QC_LAB/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	QC_LAB COLD SPOT TEMP IS BELOW 18°C	MFG_QC_LAB COLD SPOT TEMP IS BELOW 18°C	admin
14-Jun-2025 16:28:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_COLD_SPOT_QA_RETAINS_TEMP	admin
14-Jun-2025 16:28:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/OutOfRangeAlarmExt	toOffnormalText	%alarmData.sourceName%_Alarm	MFG_COLD_SPOT_QA_RETAINS_TEMP IS NOT NORMAL	admin
14-Jun-2025 16:28:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/OutOfRangeAlarmExt	toNormalText	%alarmData.sourceName%_within range	MFG_COLD_SPOT_QA_RETAINS_TEMP IS NORMAL	admin
14-Jun-2025 16:28:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	24.0 °C	25.0 °C	admin
14-Jun-2025 16:28:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	%alarmData.sourceName% above 25	MFG_COLD_SPOT_QA_RETAINS_TEMP IS ABOVE 25°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 16:28:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_TEMP_COLD_SPOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	%alarmData.sourceName% below 18	MFG_COLD_SPOT_QA_RETAINS_TEMP IS BELOW 18°C	admin
14-Jun-2025 16:32:17	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_STABILITY_ROOM_R_AND_D	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 16:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 16:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_COLD_SPOT_STABILITY_ROOM_RH	admin
14-Jun-2025 16:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D_COLD_SPOT_STABILITY_ROOM_RH IS NOT NORMAL	admin
14-Jun-2025 16:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D_COLD_SPOT_STABILITY_ROOM_RH IS NORMAL	admin
14-Jun-2025 16:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 16:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 16:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_COLD_SPOT_STABILITY_ROOM_RH IS ABOVE 80%	admin
14-Jun-2025 16:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_COLD_SPOT_STABILITY_ROOM_RH IS ABOVE 30%	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 16:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 16:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 16:36:58	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPLE_OPP_R_AND_D	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 16:40:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPLE_OPP_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 16:40:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPLE_OPP_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_COLD_SPOT_FLOW_SAMPLE_OPP_TEMP	admin
14-Jun-2025 16:40:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPLE_OPP_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D_COLD_SPOT_FLOW_SAMPLE_OPP_TEMP IS NOT NORMAL	admin
14-Jun-2025 16:40:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPLE_OPP_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D_COLD_SPOT_FLOW_SAMPLE_OPP_TEMP IS NORMAL	admin
14-Jun-2025 16:40:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPLE_OPP_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 16:40:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPLE_OPP_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 16:40:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPL E_OPP_R_AND_D/OutOfRangeAlarmExt/of fnormalAlgorithm	highLimitText		R&D_COLD_SPOT_FLOW_SAMPLE_OP P_TEMP IS ABOVE 25 °C	admin
14-Jun-2025 16:40:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPL E_OPP_R_AND_D/OutOfRangeAlarmExt/of fnormalAlgorithm	lowLimitText		R&D_COLD_SPOT_FLOW_SAMPLE_OP P_TEMP IS BELOW 18 °C	admin
14-Jun-2025 16:40:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPL E_OPP_R_AND_D/OutOfRangeAlarmExt/of fnormalAlgorithm	limitEnable/lowLimitE nable	false	true	admin
14-Jun-2025 16:40:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPL E_OPP_R_AND_D/OutOfRangeAlarmExt/of fnormalAlgorithm	limitEnable/highLimit Enable	false	true	admin
14-Jun-2025 16:54:08	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CHEMISTRY_LA B_R_AND_D	OutOfRangeAlarmEx t		Alarm Source Ext	admin
14-Jun-2025 16:56:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CHEMISTRY_LA B_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 16:56:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CHEMISTRY_LA B_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName e%	R&D COLD_SPOT_CHEM ISTRY_LAB_RH	admin
14-Jun-2025 16:56:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CHEMISTRY_LA B_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D COLD_SPOT_CHEM ISTRY_LAB_RH IS NOT NORMAL	admin
14-Jun-2025 16:56:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CHEMISTRY_LA B_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D COLD_SPOT_CHEM ISTRY_LAB_RH IS NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 16:56:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 16:56:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 16:56:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D COLD_SPOT_CHEMISTRY_LAB_RH IS ABOVE 80%	admin
14-Jun-2025 16:56:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D COLD_SPOT_CHEMISTRY_LAB_RH IS BELOW 30%	admin
14-Jun-2025 16:56:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 16:56:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 16:56:39	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INNOVATION_ROOM_R_AND_D	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 16:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 16:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_COLD_SPOT_INNOVATION_ROOM_RH	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 16:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D_COLD_SPOT_INNOVATION_ROOM_RH IS NOT NORMAL	admin
14-Jun-2025 16:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D_COLD_SPOT_INNOVATION_ROOM_RH IS NORMAL	admin
14-Jun-2025 16:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 16:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 16:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_COLD_SPOT_INNOVATION_ROOM_RH IS ABOVE 80%	admin
14-Jun-2025 16:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_COLD_SPOT_INNOVATION_ROOM_RH IS BELOW 30%	admin
14-Jun-2025 16:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 16:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 16:58:45	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CONJUGATION_ROOM_R_AND_D	OutOfRangeAlarmExt		Alarm Source Ext	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:00:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 17:00:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_COLD_SPOT_CONJUGATION_ROOM_RH	admin
14-Jun-2025 17:00:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D_COLD_SPOT_CONJUGATION_ROOM_RH IS NOT NORMAL	admin
14-Jun-2025 17:00:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D_COLD_SPOT_CONJUGATION_ROOM_RH IS NORMAL	admin
14-Jun-2025 17:00:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 17:00:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 17:00:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_COLD_SPOT_CONJUGATION_ROOM_RH IS ABOVE 80%	admin
14-Jun-2025 17:00:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_COLD_SPOT_CONJUGATION_ROOM_RH IS BELOW 30%	admin
14-Jun-2025 17:00:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:00:47	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 17:00:58	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INVENTORY_ROOM_R_AND_D	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 17:02:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 17:02:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_COLD_SPOT_INVENTORY_ROOM_RH	admin
14-Jun-2025 17:02:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D_COLD_SPOT_INVENTORY_ROOM_RH IS NOT NORMAL	admin
14-Jun-2025 17:02:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D_COLD_SPOT_INVENTORY_ROOM_RH IS NORMAL	admin
14-Jun-2025 17:02:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 17:02:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 17:02:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_COLD_SPOT_INVENTORY_ROOM_RH IS ABOVE 80%	admin
14-Jun-2025 17:02:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_COLD_SPOT_INVENTORY_ROOM_RH IS BELOW 30%	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:02:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 17:02:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 17:03:13	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 17:05:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 17:05:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_COLD_SPOT_FLOW_SAMPLE_ROOM_RH	admin
14-Jun-2025 17:05:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D_COLD_SPOT_FLOW_SAMPLE_ROOM_RH IS NOT NORMAL	admin
14-Jun-2025 17:05:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D_COLD_SPOT_FLOW_SAMPLE_ROOM_RH IS NORMAL	admin
14-Jun-2025 17:05:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 17:05:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 17:05:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_COLD_SPOT_FLOW_SAMPLE_ROOM_RH IS ABOVE 80%	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:05:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_COLD_SPOT_FLOW_SAMPLE_ROOM_RH IS BELOW 30%	admin
14-Jun-2025 17:05:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 17:05:20	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 17:05:29	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 17:07:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 17:07:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_COLD_SPOT_FLOW_SAMPLE_ROOM_RH	admin
14-Jun-2025 17:07:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D_COLD_SPOT_FLOW_SAMPLE_ROOM_RH IS NOT NORMAL	admin
14-Jun-2025 17:07:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D_COLD_SPOT_FLOW_SAMPLE_ROOM_RH IS NORMAL	admin
14-Jun-2025 17:07:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 17:07:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:07:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_OPP_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_COLD_SPOT_FLOW_SAMPLE_OP_P_RH IS ABOVE 80%	admin
14-Jun-2025 17:07:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_OPP_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_COLD_SPOT_FLOW_SAMPLE_OP_P_RH IS BELOW 30%	admin
14-Jun-2025 17:07:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_OPP_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 17:07:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_FLOW_SAMPLE_OPP_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 17:07:43	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INNOVATION_ROOM_R_AND_D	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 17:09:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 17:09:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_COLD_SPOT_INNOVATION_ROOM_TEMP	admin
14-Jun-2025 17:09:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D_COLD_SPOT_INNOVATION_ROOM_TEMP IS NOT NORMAL	admin
14-Jun-2025 17:09:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D_COLD_SPOT_INNOVATION_ROOM_TEMP IS NORMAL	admin
14-Jun-2025 17:09:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:09:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 17:09:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_COLD_SPOT_INNOVATION_ROOM_TEMP IS ABOVE 25°C	admin
14-Jun-2025 17:09:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_COLD_SPOT_INNOVATION_ROOM_TEMP IS BELOW 18°C	admin
14-Jun-2025 17:09:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 17:09:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INNOVATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 17:10:00	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CONJUGATION_ROOM_R_AND_D	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 17:12:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 17:12:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_COLD_SPOT_CONJUGATION_ROOM_TEMP	admin
14-Jun-2025 17:12:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D_COLD_SPOT_CONJUGATION_ROOM_TEMP IS NOT NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:12:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D_COLD_SPOT_CONJUGATION_ROOM_TEMP IS NORMAL	admin
14-Jun-2025 17:12:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 17:12:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 17:12:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_COLD_SPOT_CONJUGATION_ROOM_TEMP IS ABOVE 25°C	admin
14-Jun-2025 17:12:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_COLD_SPOT_CONJUGATION_ROOM_TEMP IS BELOW 18°C	admin
14-Jun-2025 17:12:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 17:12:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CONJUGATION_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 17:12:39	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CELL_CULTURE_ROOM_R_AND_D	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 17:14:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:14:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_COLD_SPOT_CELL_CULTURE_ROOM_TEMP	admin
14-Jun-2025 17:14:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D_COLD_SPOT_CELL_CULTURE_ROOM_TEMP IS NOT NORMAL	admin
14-Jun-2025 17:14:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D_COLD_SPOT_CELL_CULTURE_ROOM_TEMP IS NORMAL	admin
14-Jun-2025 17:14:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 17:14:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 17:14:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_COLD_SPOT_CELL_CULTURE_ROOM_TEMP IS ABOVE 25°C	admin
14-Jun-2025 17:14:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_COLD_SPOT_CELL_CULTURE_ROOM_TEMP IS BELOW 18°C	admin
14-Jun-2025 17:14:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 17:14:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:15:23	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INVENTORY_ROOM_R_AND_D	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 17:17:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 17:17:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_COLD_SPOT_INVENTORY_ROOM_TEMP	admin
14-Jun-2025 17:17:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D_COLD_SPOT_INVENTORY_ROOM_TEMP IS NOT NORMAL	admin
14-Jun-2025 17:17:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D_COLD_SPOT_INVENTORY_ROOM_TEMP IS NORMAL	admin
14-Jun-2025 17:17:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 17:17:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	30.0 °C	admin
14-Jun-2025 17:17:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_COLD_SPOT_INVENTORY_ROOM_TEMP IS ABOVE 25°C	admin
14-Jun-2025 17:17:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_COLD_SPOT_INVENTORY_ROOM_TEMP IS BELOW 18°C	admin
14-Jun-2025 17:17:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:17:49	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INVENTORY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 17:17:59	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPLE_ROOM_R_AND_D	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 17:20:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 17:20:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_COLD_SPOT_FLOW_SAMPLE_ROOM_TEMP	admin
14-Jun-2025 17:20:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D_COLD_SPOT_FLOW_SAMPLE_ROOM_TEMP IS NOT NORMAL	admin
14-Jun-2025 17:20:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D_COLD_SPOT_FLOW_SAMPLE_ROOM_TEMP IS NORMAL	admin
14-Jun-2025 17:20:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 17:20:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 17:20:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPLE_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_COLD_SPOT_FLOW_SAMPLE_ROOM_TEMP IS ABOVE 25 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:20:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPL E_ROOM_R_AND_D/OutOfRangeAlarmExt /offnormalAlgorithm	lowLimitText		R&D_COLD_SPOT_ FLOW_SAMPLE_RO OM_TEMP IS BELOW 18 °C	admin
14-Jun-2025 17:20:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPL E_ROOM_R_AND_D/OutOfRangeAlarmExt /offnormalAlgorithm	limitEnable/lowLimitE nable	false	true	admin
14-Jun-2025 17:20:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_FLOW_SAMPL E_ROOM_R_AND_D/OutOfRangeAlarmExt /offnormalAlgorithm	limitEnable/highLimit Enable	false	true	admin
14-Jun-2025 17:20:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_INVENTORY_ ROOM_R_AND_D/OutOfRangeAlarmExt/off normalAlgorithm	lowLimit	30.0 °C	18.0 °C	admin
14-Jun-2025 17:21:33	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CELL_CULTURE _ROOM_R_AND_D	OutOfRangeAlarmEx t		Alarm Source Ext	admin
14-Jun-2025 17:39:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CELL_CULTURE _ROOM_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 17:39:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CELL_CULTURE _ROOM_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName e%	R&D_COLD_SPOT_ CELL_CULTURE_R OOM_RH	admin
14-Jun-2025 17:39:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CELL_CULTURE _ROOM_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D_COLD_SPOT_ CELL_CULTURE_R OOM_RH IS NOT NORMAL	admin
14-Jun-2025 17:39:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CELL_CULTURE _ROOM_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D_COLD_SPOT_ CELL_CULTURE_R OOM_RH IS NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:39:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt/offsetnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 17:39:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt/offsetnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 17:39:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt/offsetnormalAlgorithm	highLimitText		R&D_COLD_SPOT_CELL_CULTURE_ROOM_RH IS ABOVE 80%	admin
14-Jun-2025 17:39:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt/offsetnormalAlgorithm	lowLimitText		R&D_COLD_SPOT_CELL_CULTURE_ROOM_RH IS BELOW 30%	admin
14-Jun-2025 17:39:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt/offsetnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 17:39:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/RH_CELL_CULTURE_ROOM_R_AND_D/OutOfRangeAlarmExt/offsetnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 17:40:30	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CHEMISTRY_LAB_R_AND_D	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 17:42:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 17:42:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_COLD_SPOT_CHEMISTRY_LAB_TEMP	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:42:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D_COLD_SPOT_CHEMISTRY_LAB_TEMP IS NOT NORMAL	admin
14-Jun-2025 17:42:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D_COLD_SPOT_CHEMISTRY_LAB_TEMP IS NORMAL	admin
14-Jun-2025 17:42:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 17:42:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 17:42:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_COLD_SPOT_CHEMISTRY_LAB_TEMP IS ABOVE 25°C	admin
14-Jun-2025 17:42:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_COLD_SPOT_CHEMISTRY_LAB_TEMP IS BELOW 18°C	admin
14-Jun-2025 17:42:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 17:42:43	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_CHEMISTRY_LAB_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 17:42:56	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_STABILITY_ROOM_R_AND_D	OutOfRangeAlarmExt		Alarm Source Ext	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:45:11	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 17:45:11	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_COLD_SPOT_STABILITY_ROOM_TEMP	admin
14-Jun-2025 17:45:11	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt	toOffnormalText		R&D_COLD_SPOT_STABILITY_ROOM_TEMP IS NOT NORMAL	admin
14-Jun-2025 17:45:11	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt	toNormalText		R&D_COLD_SPOT_STABILITY_ROOM_TEMP IS NORMAL	admin
14-Jun-2025 17:45:11	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin
14-Jun-2025 17:45:11	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 17:45:11	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_COLD_SPOT_STABILITY_ROOM_TEMP IS ABOVE 25°C	admin
14-Jun-2025 17:45:11	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_COLD_SPOT_STABILITY_ROOM_TEMP IS BELOW 18°C	admin
14-Jun-2025 17:45:11	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnabled	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:45:11	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_COLDSPOT/TEMP_STABILITY_ROOM_R_AND_D/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 17:45:55	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 17:48:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 17:48:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_RH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_HOT_SPOT_INVENTORY_ROOM_RH	admin
14-Jun-2025 17:48:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_INVENTORY_ROOM_RH IS NOT NORMAL	admin
14-Jun-2025 17:48:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_RH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_INVENTORY_ROOM_RH IS NORMAL	admin
14-Jun-2025 17:48:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 %RH	80.0 %RH	admin
14-Jun-2025 17:48:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 %RH	30.0 %RH	admin
14-Jun-2025 17:48:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_INVENTORY_ROOM_RH IS ABOVE 80%	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:48:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_INVENTORY_ROOM_RH IS BELOW 30%	admin
14-Jun-2025 17:48:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 17:48:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 17:48:09	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_TH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 17:50:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 17:50:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_TH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_HOT_SPOT_INVENTORY_ROOM_TEMP	admin
14-Jun-2025 17:50:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_INVENTORY_ROOM_TEMP IS NOT NORMAL	admin
14-Jun-2025 17:50:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_TH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_INVENTORY_ROOM_TEMP IS NORMAL	admin
14-Jun-2025 17:50:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	25.0 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:50:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	18.0 °C	admin
14-Jun-2025 17:50:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_INVENTORY_ROOM_TEMP IS ABOVE 25°C	admin
14-Jun-2025 17:50:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_INVENTORY_ROOM_TEMP IS BELOW 18°C	admin
14-Jun-2025 17:50:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 17:50:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INVENTORY_ROOM_R_AND_D_01_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 17:50:44	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_TH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 17:52:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 17:52:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_TH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_HOT_SPOT_CELL_CULTURE_ROOM_TEMP	admin
14-Jun-2025 17:52:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_CELL_CULTURE_ROOM_TEMP IS NOT NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:52:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_TH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_CELL_CULTURE_ROOM_TEMP IS NORMAL	admin
14-Jun-2025 17:52:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 17:52:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin
14-Jun-2025 17:52:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_CELL_CULTURE_ROOM_TEMP IS ABOVE 25°C	admin
14-Jun-2025 17:52:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_CELL_CULTURE_ROOM_TEMP IS BELOW 18°C	admin
14-Jun-2025 17:52:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 17:52:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 17:53:32	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 17:55:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:55:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_RH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_HOT_SPOT_CELL_CULTURE_ROOM_RH	admin
14-Jun-2025 17:55:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_CELL_CULTURE_ROOM_RH IS NOT NORMAL	admin
14-Jun-2025 17:55:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_RH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_CELL_CULTURE_ROOM_RH IS NORMAL	admin
14-Jun-2025 17:55:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 17:55:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin
14-Jun-2025 17:55:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_CELL_CULTURE_ROOM_RH IS ABOVE 80%	admin
14-Jun-2025 17:55:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_CELL_CULTURE_ROOM_RH IS BELOW 30%	admin
14-Jun-2025 17:55:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 17:55:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CELL_CULTURE_ROOM_R_AND_D_02_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:55:43	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 17:57:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 17:57:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_RH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_HOT_SPOT_C HEMISTRY_LAB_RH	admin
14-Jun-2025 17:57:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_C HEMISTRY_LAB_RH IS NOT NORMAL	admin
14-Jun-2025 17:57:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_RH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_C HEMISTRY_LAB_RH IS NORMAL	admin
14-Jun-2025 17:57:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_RH_HOT/OutOfRangeAlarmExt/ offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 17:57:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_RH_HOT/OutOfRangeAlarmExt/ offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin
14-Jun-2025 17:57:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_RH_HOT/OutOfRangeAlarmExt/ offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_C HEMISTRY_LAB_RH IS ABOVE 80%	admin
14-Jun-2025 17:57:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_RH_HOT/OutOfRangeAlarmExt/ offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_C HEMISTRY_LAB_RH IS BELOW 30%	admin
14-Jun-2025 17:57:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_RH_HOT/OutOfRangeAlarmExt/ offnormalAlgorithm	limitEnable/lowLimitE nable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 17:57:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_RH_HOT/OutOfRangeAlarmExt/ offnormalAlgorithm	limitEnable/highLimit Enable	false	true	admin
14-Jun-2025 17:57:54	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_TH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 18:01:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 18:01:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_TH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName e%	R&D_HOT_SPOT_C HEMISTRY_LAB_TE MP	admin
14-Jun-2025 18:01:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_C HEMISTRY_LAB_TE MP IS NOT NORMAL	admin
14-Jun-2025 18:01:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_TH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_C HEMISTRY_LAB_TE MP IS NORMAL	admin
14-Jun-2025 18:01:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_TH_HOT/OutOfRangeAlarmExt/ offnormalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 18:01:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_TH_HOT/OutOfRangeAlarmExt/ offnormalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin
14-Jun-2025 18:01:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_TH_HOT/OutOfRangeAlarmExt/ offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_C HEMISTRY_LAB_TE MP IS ABOVE 25°C	admin
14-Jun-2025 18:01:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_A ND_D_03_TH_HOT/OutOfRangeAlarmExt/ offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_C HEMISTRY_LAB_TE MP IS BELOW 18°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:01:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_AND_D_03_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 18:01:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CHEMISTRY_LAB_R_AND_D_03_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 18:02:08	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_TH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 18:04:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 18:04:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_TH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_HOT_SPOT_STABILITY_ROOM_TEMP	admin
14-Jun-2025 18:04:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_STABILITY_ROOM_TEMP IS NOT NORMAL	admin
14-Jun-2025 18:04:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_TH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_STABILITY_ROOM_TEMP IS NORMAL	admin
14-Jun-2025 18:04:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 18:04:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin
14-Jun-2025 18:04:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_STABILITY_ROOM_TEMP IS ABOVE 25°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:04:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_STABILITY_ROOM_TEMP IS BELOW 18°C	admin
14-Jun-2025 18:04:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 18:04:23	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 18:04:42	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 18:06:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 18:06:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_RH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_HOT_SPOT_STABILITY_ROOM_RH	admin
14-Jun-2025 18:06:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_STABILITY_ROOM_RH IS NOT NORMAL	admin
14-Jun-2025 18:06:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_RH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_STABILITY_ROOM_RH IS NORMAL	admin
14-Jun-2025 18:06:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 18:06:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:06:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_STABILITY_ROOM_RH IS ABOVE 80%	admin
14-Jun-2025 18:06:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_STABILITY_ROOM_RH IS BELOW 30%	admin
14-Jun-2025 18:06:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 18:06:50	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/STABILITY_ROOM_R_AND_D_04_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 18:07:02	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 18:09:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 18:09:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_HOT_SPOT_CONJUNCTION_ROOM_RH	admin
14-Jun-2025 18:09:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_CONJUNCTION_ROOM_RH IS NOT NORMAL	admin
14-Jun-2025 18:09:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_CONJUNCTION_ROOM_RH IS NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:09:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 18:09:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin
14-Jun-2025 18:09:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_CONJUNCTION_ROOM_RH IS ABOVE 80%	admin
14-Jun-2025 18:09:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_CONJUNCTION_ROOM_RH IS BELOW 30%	admin
14-Jun-2025 18:09:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 18:09:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 18:09:14	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_TH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 18:11:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 18:11:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_TH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_HOT_SPOT_CONJUNCTION_ROOM_TEMP	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:11:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_CONJUGATION_ROOM_TEMP IS NOT NORMAL	admin
14-Jun-2025 18:11:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_TH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_CONJUGATION_ROOM_TEMP IS NORMAL	admin
14-Jun-2025 18:11:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 18:11:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin
14-Jun-2025 18:11:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_CONJUGATION_ROOM_TEMP IS ABOVE 25°C	admin
14-Jun-2025 18:11:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_CONJUGATION_ROOM_TEMP IS BELOW 18°C	admin
14-Jun-2025 18:11:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 18:11:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 18:12:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/OutOfRangeAlarmExt	sourceName	R&D_HOT_SPOT_CONJUNCTION_ROOM_RH	R&D_HOT_SPOT_CONJUGATION_ROOM_RH	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:12:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/OutOfRangeAlarmExt	toOffnormalText	R&D_HOT_SPOT_CONJUNCTION_ROOM_RH IS NOT NORMAL	R&D_HOT_SPOT_CONJUGATION_ROOM_RH IS NOT NORMAL	admin
14-Jun-2025 18:12:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/OutOfRangeAlarmExt	toNormalText	R&D_HOT_SPOT_CONJUNCTION_ROOM_RH IS NORMAL	R&D_HOT_SPOT_CONJUGATION_ROOM_RH IS NORMAL	admin
14-Jun-2025 18:12:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	R&D_HOT_SPOT_CONJUNCTION_ROOM_RH IS ABOVE 80%	R&D_HOT_SPOT_CONJUGATION_ROOM_RH IS ABOVE 80%	admin
14-Jun-2025 18:12:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/CONJUGATION_ROOM_R_AND_D_05_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	R&D_HOT_SPOT_CONJUNCTION_ROOM_RH IS BELOW 30%	R&D_HOT_SPOT_CONJUGATION_ROOM_RH IS BELOW 30%	admin
14-Jun-2025 18:12:57	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 18:15:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 18:15:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_RH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_HOT_SPOT_INNOVATION_LAB_RH	admin
14-Jun-2025 18:15:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_INNOVATION_LAB_RH IS NOT NORMAL	admin
14-Jun-2025 18:15:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_RH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_INNOVATION_LAB_RH IS NORMAL	admin
14-Jun-2025 18:15:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:15:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin
14-Jun-2025 18:15:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_INNOVATION_LAB_RH IS ABOVE 80%	admin
14-Jun-2025 18:15:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_INNOVATION_LAB_RH IS BELOW 30%	admin
14-Jun-2025 18:15:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 18:15:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 18:15:13	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_TH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 18:17:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 18:17:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_TH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_HOT_SPOT_INNOVATION_LAB_TEMP	admin
14-Jun-2025 18:17:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_INNOVATION_LAB_TEMP IS NOT NORMAL	admin
14-Jun-2025 18:17:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_TH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_INNOVATION_LAB_TEMP IS NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:17:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 18:17:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin
14-Jun-2025 18:17:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_INNOVATION_LAB_TEMP IS ABOVE 25°C	admin
14-Jun-2025 18:17:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_INNOVATION_LAB_TEMP IS BELOW 18°C	admin
14-Jun-2025 18:17:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 18:17:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/INNOVATION_LAB_R_AND_D_06_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 18:18:10	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 18:20:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 18:20:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_RH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_HOT_SPOT_FLOW_AND_SAMPLE_RH	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:20:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_FLOW_AND_SAMPLE_RH IS NOT NORMAL	admin
14-Jun-2025 18:20:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_RH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_FLOW_AND_SAMPLE_RH IS NORMAL	admin
14-Jun-2025 18:20:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 18:20:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin
14-Jun-2025 18:20:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_FLOW_AND_SAMPLE_RH IS ABOVE 80%	admin
14-Jun-2025 18:20:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_FLOW_AND_SAMPLE_RH IS BELOW 30%	admin
14-Jun-2025 18:20:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 18:20:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 18:20:51	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_TH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:23:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 18:23:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_TH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_HOT_SPOT_F LOW_AND_SAMPLE _TEMP	admin
14-Jun-2025 18:23:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_F LOW_AND_SAMPLE _TEMP IS NOT NORMAL	admin
14-Jun-2025 18:23:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_TH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_F LOW_AND_SAMPLE _TEMP IS NORMAL	admin
14-Jun-2025 18:23:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 18:23:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin
14-Jun-2025 18:23:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_F LOW_AND_SAMPLE _TEMP IS ABOVE 25°C	admin
14-Jun-2025 18:23:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_F LOW_AND_SAMPLE _TEMP IS BELOW 18°C	admin
14-Jun-2025 18:23:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:23:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_27_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 18:24:10	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_RH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 18:26:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_RH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 18:26:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_RH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_HOT_SPOT_FLOW_AND_SAMPLE_OPP_RH	admin
14-Jun-2025 18:26:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_RH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_FLOW_AND_SAMPLE_OPP_RH IS NOT NORMAL	admin
14-Jun-2025 18:26:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_RH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_FLOW_AND_SAMPLE_OPP_RH IS NORMAL	admin
14-Jun-2025 18:26:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 %RH	80.00 %RH	admin
14-Jun-2025 18:26:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 %RH	30.00 %RH	admin
14-Jun-2025 18:26:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_FLOW_AND_SAMPLE_OPP_RH IS ABOVE 80%	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:26:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_FLOW_AND_SAMPLE_OPP_RH IS BELOW 30%	admin
14-Jun-2025 18:26:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 18:26:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_RH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 18:26:31	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_TH_HOT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 18:28:42	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_TH_HOT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 18:28:42	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_TH_HOT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_HOT_SPOT_FLOWE_AND_SAMPLE_OPP	admin
14-Jun-2025 18:28:42	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_TH_HOT/OutOfRangeAlarmExt	toOffnormalText		R&D_HOT_SPOT_FLOWE_AND_SAMPLE_OPP IS NOT NORMAL	admin
14-Jun-2025 18:28:42	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_TH_HOT/OutOfRangeAlarmExt	toNormalText		R&D_HOT_SPOT_FLOWE_AND_SAMPLE_OPP IS NORMAL	admin
14-Jun-2025 18:28:42	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	25.00 °C	admin
14-Jun-2025 18:28:42	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	18.00 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:28:42	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_HOT_SPOT_F LOE_AND_SAMPLE _OPP IS ABOVE 25°C	admin
14-Jun-2025 18:28:42	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_HOT_SPOT_F LOE_AND_SAMPLE _OPP IS BELOW 18°C	admin
14-Jun-2025 18:28:42	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 18:28:42	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_HOTSPOT/FLOW_\$26_SAMP_OP_P_29_TH_HOT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 18:33:09	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_1	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 18:34:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_1/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 18:34:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_1/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_EQP_STABILITY_1_INCUBATOR_3_TEMP	admin
14-Jun-2025 18:38:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_1/OutOfRangeAlarmExt	toOffnormalText		R&D_EQP_STABILITY_1_INCUBATOR_3_TEMP IS NOT NORMAL	admin
14-Jun-2025 18:38:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_1/OutOfRangeAlarmExt	toNormalText		R&D_EQP_STABILITY_1_INCUBATOR_3_TEMP IS NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:38:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	17.0 °C	admin
14-Jun-2025 18:38:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	13.0 °C	admin
14-Jun-2025 18:38:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_EQP_STABILITY_1_INCUBATOR_3_TEMP IS ABOVE 17°C	admin
14-Jun-2025 18:38:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_EQP_STABILITY_1_INCUBATOR_3_TEMP IS BELOW 13°C	admin
14-Jun-2025 18:38:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_1/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 18:38:22	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_1/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 18:38:56	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_2	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 18:41:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_2/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 18:41:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_2/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_EQP_STABILITY_2_INCUBATOR_4_TEMP	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:41:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_2/OutOfRangeAlarmExt	toOffnormalText		R&D_EQP_STABILITY_2_INCUBATOR_4_TEMP IS NOT NORMAL	admin
14-Jun-2025 18:41:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_2/OutOfRangeAlarmExt	toNormalText		R&D_EQP_STABILITY_2_INCUBATOR_4_TEMP IS NORMAL	admin
14-Jun-2025 18:41:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	32.0 °C	admin
14-Jun-2025 18:41:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	28.0 °C	admin
14-Jun-2025 18:41:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_EQP_STABILITY_2_INCUBATOR_4_TEMP IS ABOVE 32°C	admin
14-Jun-2025 18:41:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_EQP_STABILITY_2_INCUBATOR_4_TEMP IS BELOW 28°C	admin
14-Jun-2025 18:41:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_2/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 18:41:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_STABILITY_2/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 18:42:50	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2	OutOfRangeAlarmExt		Alarm Source Ext	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:45:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 18:45:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_EQP_CHEMISTRY_L2_REFRIGERATOR_3_TEMP	admin
14-Jun-2025 18:45:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/OutOfRangeAlarmExt	toOffnormalText		R&D_EQP_CHEMISTRY_L2_REFRIGERATOR_3_TEMP IS NOT NORMAL	admin
14-Jun-2025 18:45:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/OutOfRangeAlarmExt	toNormalText		R&D_EQP_CHEMISTRY_L2_REFRIGERATOR_3_TEMP IS NORMAL	admin
14-Jun-2025 18:45:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	8.0 °C	admin
14-Jun-2025 18:45:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	2.0 °C	admin
14-Jun-2025 18:45:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_EQP_CHEMISTRY_L2_REFRIGERATOR_3_TEMP IS ABOVE 8°C	admin
14-Jun-2025 18:45:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_EQP_CHEMISTRY_L2_REFRIGERATOR_3_TEMP IS BELOW 2°C	admin
14-Jun-2025 18:45:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:45:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 18:50:16	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY_CHAMBER_2_EQUIPMENT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 18:54:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY_CHAMBER_2_EQUIPMENT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 18:54:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY_CHAMBER_2_EQUIPMENT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_EQP_STAB_C HAM_2_INCUBATO R_1_TEMP	admin
14-Jun-2025 18:54:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY_CHAMBER_2_EQUIPMENT/OutOfRangeAlarmExt	toOffnormalText		R&D_EQP_STAB_C HAM_2_INCUBATO R_1_TEMP IS NOT NORMAL	admin
14-Jun-2025 18:54:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY_CHAMBER_2_EQUIPMENT/OutOfRangeAlarmExt	toNormalText		R&D_EQP_STAB_C HAM_2_INCUBATO R_1_TEMP IS NORMAL	admin
14-Jun-2025 18:54:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY_CHAMBER_2_EQUIPMENT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	39.0 °C	admin
14-Jun-2025 18:54:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY_CHAMBER_2_EQUIPMENT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	35.0 °C	admin
14-Jun-2025 18:54:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY_CHAMBER_2_EQUIPMENT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_EQP_STAB_C HAM_2_INCUBATO R_1_TEMP IS ABOVE 39°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 18:54:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY_CHAMBER_2_EQUIPMENT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_EQP_STAB_C HAM_2_INCUBATO R_1_TEMP IS BELOW 35°C	admin
14-Jun-2025 18:54:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY_CHAMBER_2_EQUIPMENT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 18:54:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY_CHAMBER_2_EQUIPMENT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 18:54:54	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY\$20CHAMBER\$203_EQUIPMENT	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 19:02:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY\$20CHAMBER\$203_EQUIPMENT/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 19:02:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY\$20CHAMBER\$203_EQUIPMENT/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_EQP_STAB_C HAM_3_TEMP	admin
14-Jun-2025 19:02:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY\$20CHAMBER\$203_EQUIPMENT/OutOfRangeAlarmExt	toOffnormalText		R&D_EQP_STABI TY_CHAMBER_3_T EMP IS NOT NORMAL	admin
14-Jun-2025 19:02:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY\$20CHAMBER\$203_EQUIPMENT/OutOfRangeAlarmExt	toNormalText		R&D_EQP_STABI TY_CHAMBER_3_T EMP IS NORMAL	admin
14-Jun-2025 19:02:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY\$20CHAMBER\$203_EQUIPMENT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	50.0 °C	admin
14-Jun-2025 19:02:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILITY\$20CHAMBER\$203_EQUIPMENT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	45.0 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 19:02:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILTY\$20CHAMBER\$203_EQUIPMENT/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_EQP_STABILITY_CHAMBER_3_TEMP IS ABOVE 50°C	admin
14-Jun-2025 19:02:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILTY\$20CHAMBER\$203_EQUIPMENT/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_EQP_STABILITY_CHAMBER_3_TEMP IS BELOW 45°C	admin
14-Jun-2025 19:02:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILTY\$20CHAMBER\$203_EQUIPMENT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 19:02:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/STABILTY\$20CHAMBER\$203_EQUIPMENT/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 19:03:23	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGERATOR_4	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 19:06:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGERATOR_4/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 19:06:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGERATOR_4/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_EQP_LAB_REFRIGERATOR_4_TEMP	admin
14-Jun-2025 19:06:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGERATOR_4/OutOfRangeAlarmExt	toOffnormalText		R&D_EQP_LAB_REFRIGERATOR_4_TEMP IS NOT NORMAL	admin
14-Jun-2025 19:06:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGERATOR_4/OutOfRangeAlarmExt	toNormalText		R&D_EQP_LAB_REFRIGERATOR_4_TEMP IS NORMAL	admin
14-Jun-2025 19:06:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGERATOR_4/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	8.0 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 19:06:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGERATOR_4/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	2.0 °C	admin
14-Jun-2025 19:06:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGERATOR_4/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_EQP_LAB_REFRIGERATOR_4_TEMP IS ABOVE 8°C	admin
14-Jun-2025 19:06:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGERATOR_4/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_EQP_LAB_REFRIGERATOR_4_TEMP IS BELOW 2°C	admin
14-Jun-2025 19:06:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGERATOR_4/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
14-Jun-2025 19:06:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGERATOR_4/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
14-Jun-2025 19:07:03	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5	OutOfRangeAlarmExt		Alarm Source Ext	admin
14-Jun-2025 19:13:44	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	-20.0 °C	admin
14-Jun-2025 19:13:44	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	-10.0 °C	admin
14-Jun-2025 19:13:44	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_EQP_LAB_FREEZER_LR_5_TEMP IS ABOVE -30°C	admin
14-Jun-2025 19:13:44	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_EQP_LAB_FREEZER_LR_5_TEMP IS BELOW -10°C	admin
14-Jun-2025 19:18:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	-20.0 °C	0.0 °C	admin
14-Jun-2025 19:18:14	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	-10.0 °C	0.0 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
14-Jun-2025 19:24:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
14-Jun-2025 19:24:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	R&D_EQP_LAB_FR EEZER_LR_5_TEMP IS ABOVE -30°C		admin
14-Jun-2025 19:24:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	R&D_EQP_LAB_FR EEZER_LR_5_TEMP IS BELOW -10°C		admin
15-Jun-2025 09:59:19	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 10:01:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 10:01:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_EQP_QC_LAB REFRIGERATOR_1 _TEMP	admin
15-Jun-2025 10:01:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1/OutOfRangeAlarmExt	toOffnormalText		MFG_EQP_QC_LAB REFRIGERATOR_1 _TEMP IS NOT NORMAL	admin
15-Jun-2025 10:01:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1/OutOfRangeAlarmExt	toNormalText		MFG_EQP_QC_LAB REFRIGERATOR_1 _TEMP IS NORMAL	admin
15-Jun-2025 10:01:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_EQP_QC_LAB REFRIGERATOR_1 _TEMP	admin
15-Jun-2025 10:01:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_EQP_QC_LAB REFRIGERATOR_1 _TEMP	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 10:02:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	8.0 °C	admin
15-Jun-2025 10:02:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	2.0 °C	admin
15-Jun-2025 10:02:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_EQP_QC_LAB_REFRIGERATOR_1_TEMP	MFG_EQP_QC_LAB_REFRIGERATOR_1_TEMP IS ABOVE 8°C	admin
15-Jun-2025 10:02:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_EQP_QC_LAB_REFRIGERATOR_1_TEMP	MFG_EQP_QC_LAB_REFRIGERATOR_1_TEMP IS BELOW 2°C	admin
15-Jun-2025 10:02:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
15-Jun-2025 10:02:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 10:04:41	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_2	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 10:06:40	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_2/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 10:06:40	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_2/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_EQP_QC_LAB_REFRIGERATOR_2_INCUBATOR	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 10:06:40	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_2/OutOfRangeAlarmExt	toOffnormalText		MFG_EQP_QC_LAB_REFRIGERATOR_2_INCUBATOR IS NOT NORMAL	admin
15-Jun-2025 10:06:40	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_2/OutOfRangeAlarmExt	toNormalText		MFG_EQP_QC_LAB_REFRIGERATOR_2_INCUBATOR IS NORMAL	admin
15-Jun-2025 10:06:40	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_EQP_QC_LAB_REFRIGERATOR_2_INCUBATOR IS	admin
15-Jun-2025 10:06:40	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_EQP_QC_LAB_REFRIGERATOR_2_INCUBATOR IS	admin
15-Jun-2025 10:07:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	39.0 °C	admin
15-Jun-2025 10:07:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	35.0 °C	admin
15-Jun-2025 10:07:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_EQP_QC_LAB_REFRIGERATOR_2_INCUBATOR IS	MFG_EQP_QC_LAB_REFRIGERATOR_2_INCUBATOR IS ABOVE 39°C	admin
15-Jun-2025 10:07:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_EQP_QC_LAB_REFRIGERATOR_2_INCUBATOR IS	MFG_EQP_QC_LAB_REFRIGERATOR_2_INCUBATOR IS BELOW 35°C	admin
15-Jun-2025 10:07:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_2/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 10:07:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_2/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 10:09:28	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB_REFRIGERATOR_16	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 10:12:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB_REFRIGERATOR_16/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_EQP_LAB_REFRIGERATOR_16_TEMP	admin
15-Jun-2025 10:12:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB_REFRIGERATOR_16/OutOfRangeAlarmExt	toOffnormalText		MFG_EQP_LAB_REFRIGERATOR_16_TEMP IS NOT NORMAL	admin
15-Jun-2025 10:12:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB_REFRIGERATOR_16/OutOfRangeAlarmExt	toNormalText		MFG_EQP_LAB_REFRIGERATOR_16_TEMP IS NORMAL	admin
15-Jun-2025 10:12:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB_REFRIGERATOR_16/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_EQP_LAB_REFRIGERATOR_16_TEMP IS	admin
15-Jun-2025 10:12:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB_REFRIGERATOR_16/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_EQP_LAB_REFRIGERATOR_16_TEMP IS	admin
15-Jun-2025 10:14:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB_REFRIGERATOR_16/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	8.0 °C	admin
15-Jun-2025 10:14:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB_REFRIGERATOR_16/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	2.0 °C	admin
15-Jun-2025 10:14:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB_REFRIGERATOR_16/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_EQP_LAB_REFRIGERATOR_16_TEMP IS	MFG_EQP_LAB_REFRIGERATOR_16_TEMP IS ABOVE 8°C	admin
15-Jun-2025 10:14:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB_REFRIGERATOR_16/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_EQP_LAB_REFRIGERATOR_16_TEMP IS	MFG_EQP_LAB_REFRIGERATOR_16_TEMP IS BELOW 2°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 10:14:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB_REFRIGERATOR_16/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
15-Jun-2025 10:14:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB_REFRIGERATOR_16/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 10:18:19	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2014	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 10:21:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2014/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 10:21:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2014/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_EQP_LAB_REFRIGERATOR_14_T EMP	admin
15-Jun-2025 10:21:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2014/OutOfRangeAlarmExt	toOffnormalText		MFG_EQP_LAB_REFRIGERATOR_14_T EMP IS NOT NORMAL	admin
15-Jun-2025 10:21:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2014/OutOfRangeAlarmExt	toNormalText		MFG_EQP_LAB_REFRIGERATOR_14_T EMP IS NORMAL	admin
15-Jun-2025 10:21:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2014/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	8.0 °C	admin
15-Jun-2025 10:21:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2014/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	2.0 °C	admin
15-Jun-2025 10:21:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2014/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_EQP_LAB_REFRIGERATOR_14_T EMP IS ABOVE 8°C	admin
15-Jun-2025 10:21:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2014/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_EQP_LAB_REFRIGERATOR_14_T EMP IS BELOW 2°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 10:21:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2014/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
15-Jun-2025 10:21:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2014/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 10:22:10	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_FORMULATION_REFRIGERATOR_1	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 10:24:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_FORMULATION_REFRIGERATOR_1/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 10:24:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_FORMULATION_REFRIGERATOR_1/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_FORMULATION_REFRIGERATOR_1_TEMP	admin
15-Jun-2025 10:24:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_FORMULATION_REFRIGERATOR_1/OutOfRangeAlarmExt	toOffnormalText		MFG_FORMULATION_REFRIGERATOR_1_TEMP IS NOT NORMAL	admin
15-Jun-2025 10:24:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_FORMULATION_REFRIGERATOR_1/OutOfRangeAlarmExt	toNormalText		MFG_FORMULATION_REFRIGERATOR_1_TEMP IS NORMAL	admin
15-Jun-2025 10:24:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_FORMULATION_REFRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	8.0 °C	admin
15-Jun-2025 10:24:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_FORMULATION_REFRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	2.0 °C	admin
15-Jun-2025 10:24:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_FORMULATION_REFRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_FORMULATION_REFRIGERATOR_1_TEMP IS ABOVE 8°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 10:24:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_FORMULATION_REFRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_FORMULATION_REFRIGERATOR_1_TEMP IS BELOW 2°C	admin
15-Jun-2025 10:24:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_FORMULATION_REFRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
15-Jun-2025 10:24:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_FORMULATION_REFRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 10:26:57	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_RM_CONSUMABLE_2\$20FREEZER	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 10:28:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_RM_CONSUMABLE_2\$20FREEZER/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 10:28:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_RM_CONSUMABLE_2\$20FREEZER/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_EQP_RM_CONSUMABLE_2_FREEZER_LR12_TEMP	admin
15-Jun-2025 10:28:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_RM_CONSUMABLE_2\$20FREEZER/OutOfRangeAlarmExt	toOffnormalText		MFG_EQP_RM_CONSUMABLE_2_FREEZER_LR12_TEMP IS NOT NORMAL	admin
15-Jun-2025 10:28:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_RM_CONSUMABLE_2\$20FREEZER/OutOfRangeAlarmExt	toNormalText		MFG_EQP_RM_CONSUMABLE_2_FREEZER_LR12_TEMP IS NORMAL	admin
15-Jun-2025 10:28:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_RM_CONSUMABLE_2\$20FREEZER/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_EQP_RM_CONSUMABLE_2_FREEZER_LR12_TEMP IS	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 10:28:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_RM_CONSUMABLE_2\$20FREEZER/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_EQP_RM_CONSUMABLE_2_FREEZER_LR12_TEMP IS	admin
15-Jun-2025 10:30:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_RM_CONSUMABLE_2\$20FREEZER/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	-22.0 °C	admin
15-Jun-2025 10:30:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_RM_CONSUMABLE_2\$20FREEZER/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	-18.0 °C	admin
15-Jun-2025 10:30:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_RM_CONSUMABLE_2\$20FREEZER/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_EQP_RM_CONSUMABLE_2_FREEZER_LR12_TEMP IS	MFG_EQP_RM_CONSUMABLE_2_FREEZER_LR12_TEMP IS ABOVE -22°C	admin
15-Jun-2025 10:30:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_RM_CONSUMABLE_2\$20FREEZER/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_EQP_RM_CONSUMABLE_2_FREEZER_LR12_TEMP IS	MFG_EQP_RM_CONSUMABLE_2_FREEZER_LR12_TEMP IS BELOW -18°C	admin
15-Jun-2025 10:30:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_RM_CONSUMABLE_2\$20FREEZER/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
15-Jun-2025 10:30:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_RM_CONSUMABLE_2\$20FREEZER/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 10:32:03	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2015	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 10:33:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2015/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 10:33:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2015/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_EQP_LAB_REFRIGERATOR_15-TEMP	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 10:33:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2015/OutOfRangeAlarmExt	toOffnormalText		MFG_EQP_LAB_REFRIGERATOR_15-TEMP IS NOT NORMAL	admin
15-Jun-2025 10:33:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2015/OutOfRangeAlarmExt	toNormalText		MFG_EQP_LAB_REFRIGERATOR_15-TEMP IS NORMAL	admin
15-Jun-2025 10:33:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2015/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	8.0 °C	admin
15-Jun-2025 10:33:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2015/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	2.0 °C	admin
15-Jun-2025 10:33:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2015/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_EQP_LAB_REFRIGERATOR_15-TEMP IS ABOVE 8°C	admin
15-Jun-2025 10:33:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2015/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_EQP_LAB_REFRIGERATOR_15-TEMP IS BELOW 2°C	admin
15-Jun-2025 10:33:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2015/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
15-Jun-2025 10:33:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2015/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 10:41:59	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$206	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 10:44:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$206/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 10:44:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$206/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_EQP_LAB_REFRIGERATOR_16_TEMP	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 10:44:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt	toOffnormalText		MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS NOT NORMAL	admin
15-Jun-2025 10:44:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt	toNormalText		MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS NORMAL	admin
15-Jun-2025 10:44:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS	admin
15-Jun-2025 10:44:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS	admin
15-Jun-2025 10:46:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	-22.0 °C	admin
15-Jun-2025 10:46:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	-18.0 °C	admin
15-Jun-2025 10:46:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS	MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS ABOVE - 22°C	admin
15-Jun-2025 10:46:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS	MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS BELOW - 18°C	admin
15-Jun-2025 10:46:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitE nable	false	true	admin
15-Jun-2025 10:46:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimit Enable	false	true	admin
15-Jun-2025 10:47:15	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/TEMP_MIS_ROOM	OutOfRangeAlarmEx t		Alarm Source Ext	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 10:48:13	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/TEMP_MIS_ROOM/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 10:48:13	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/TEMP_MIS_ROOM/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_EQP_MIS_ROOM_TEMP	admin
15-Jun-2025 10:48:13	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/TEMP_MIS_ROOM/OutOfRangeAlarmExt	toOffnormalText		MFG_EQP_MIS_ROOM_TEMP IS NOT NORMAL	admin
15-Jun-2025 10:48:13	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/TEMP_MIS_ROOM/OutOfRangeAlarmExt	toNormalText		MFG_EQP_MIS_ROOM_TEMP IS NORMAL	admin
15-Jun-2025 10:48:13	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/TEMP_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_EQP_MIS_ROOM_TEMP IS	admin
15-Jun-2025 10:48:13	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/TEMP_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_EQP_MIS_ROOM_TEMP IS	admin
15-Jun-2025 10:49:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/TEMP_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	8.0 °C	admin
15-Jun-2025 10:49:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/TEMP_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	2.0 °C	admin
15-Jun-2025 10:49:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/TEMP_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_EQP_MIS_ROOM_TEMP IS	MFG_EQP_MIS_ROOM_TEMP IS ABOVE 8°C	admin
15-Jun-2025 10:49:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/TEMP_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_EQP_MIS_ROOM_TEMP IS	MFG_EQP_MIS_ROOM_TEMP IS BELOW 2°C	admin
15-Jun-2025 10:49:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/TEMP_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 10:49:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/TEMP_MIS_ROOM/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 10:49:46	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2013	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 10:51:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2013/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 10:51:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2013/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_EQP_LAB_REFRIGERATOR_13_T EMP	admin
15-Jun-2025 10:51:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2013/OutOfRangeAlarmExt	toOffnormalText		MFG_EQP_LAB_REFRIGERATOR_13_T EMP IS NOT NORMAL	admin
15-Jun-2025 10:51:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2013/OutOfRangeAlarmExt	toNormalText		MFG_EQP_LAB_REFRIGERATOR_13_T EMP IS NORMAL	admin
15-Jun-2025 10:51:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2013/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	8.0 °C	admin
15-Jun-2025 10:51:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2013/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	2.0 °C	admin
15-Jun-2025 10:51:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2013/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_EQP_LAB_REFRIGERATOR_13_T EMP IS ABOVE 8°C	admin
15-Jun-2025 10:51:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2013/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_EQP_LAB_REFRIGERATOR_13_T EMP IS BELOW 2°C	admin
15-Jun-2025 10:51:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2013/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 10:51:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$2013/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 10:53:13	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRIGERATOR_1	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 10:55:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRIGERATOR_1/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 10:55:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRIGERATOR_1/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_POLYMER_LAB_REFRIGERATOR_1_TEMP	admin
15-Jun-2025 10:55:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRIGERATOR_1/OutOfRangeAlarmExt	toOffnormalText		MFG_POLYMER_LAB_REFRIGERATOR_1_TEMP IS NOT NORMAL	admin
15-Jun-2025 10:55:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRIGERATOR_1/OutOfRangeAlarmExt	toNormalText		MFG_POLYMER_LAB_REFRIGERATOR_1_TEMP IS NORMAL	admin
15-Jun-2025 10:55:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	8.0 °C	admin
15-Jun-2025 10:55:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	2.0 °C	admin
15-Jun-2025 10:55:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_POLYMER_LAB_REFRIGERATOR_1_TEMP IS ABOVE 8°C	admin
15-Jun-2025 10:55:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRIGERATOR_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_POLYMER_LAB_REFRIGERATOR_1_TEMP IS BELOW 2°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 10:55:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRI GENERATOR_1/OutOfRangeAlarmExt/offnorm alAlgorithm	limitEnable/lowLimitE nable	false	true	admin
15-Jun-2025 10:55:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRI GENERATOR_1/OutOfRangeAlarmExt/offnorm alAlgorithm	limitEnable/highLimit Enable	false	true	admin
15-Jun-2025 10:56:30	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206	OutOfRangeAlarmEx t		Alarm Source Ext	admin
15-Jun-2025 10:57:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206/OutOfRangeAl armExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 10:57:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206/OutOfRangeAl armExt	sourceName	%parent.displayName e%	MFG_EQP_LAB_RE F_6_TEMP	admin
15-Jun-2025 10:57:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206/OutOfRangeAl armExt	toOffnormalText		MFG_EQP_LAB_RE F_6_TEMP IS NOT NORMAL	admin
15-Jun-2025 10:57:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206/OutOfRangeAl armExt	toNormalText		MFG_EQP_LAB_RE F_6_TEMP IS NORMAL	admin
15-Jun-2025 10:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206/OutOfRangeAl armExt/offnormalAlgorithm	highLimit	0.0 °C	-22.0 °C	admin
15-Jun-2025 10:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206/OutOfRangeAl armExt/offnormalAlgorithm	lowLimit	0.0 °C	-18.0 °C	admin
15-Jun-2025 10:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206/OutOfRangeAl armExt/offnormalAlgorithm	highLimitText		MFG_EQP_LAB_RE F_6_TEMP IS ABOVE -22°C	admin
15-Jun-2025 10:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206/OutOfRangeAl armExt/offnormalAlgorithm	lowLimitText		MFG_EQP_LAB_RE F_6_TEMP IS BELOW -18°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 10:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
15-Jun-2025 10:58:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 11:03:04	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 11:04:13	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 11:04:13	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_EQP_LAB_RE F_7_TEMP	admin
15-Jun-2025 11:04:13	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt	toOffnormalText		MFG_EQP_LAB_RE F_7_TEMP IS NOT NORMAL	admin
15-Jun-2025 11:04:13	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt	toNormalText		MFG_EQP_LAB_RE F_7_TEMP IS NOT NORMAL	admin
15-Jun-2025 11:04:13	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_EQP_LAB_RE F_7_TEMP IS	admin
15-Jun-2025 11:04:13	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_EQP_LAB_RE F_7_TEMP IS	admin
15-Jun-2025 11:05:17	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	-22.0 °C	admin
15-Jun-2025 11:05:17	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	-18.0 °C	admin
15-Jun-2025 11:05:17	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_EQP_LAB_RE F_7_TEMP IS	MFG_EQP_LAB_RE F_7_TEMP IS ABOVE -22°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 11:05:17	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_EQP_LAB_REF_7_TEMP IS	MFG_EQP_LAB_REF_7_TEMP IS BELOW -18°C	admin
15-Jun-2025 11:05:17	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
15-Jun-2025 11:05:17	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 11:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt	alarmEnable	{toOffnormal}	{toOffnormal toFault}	admin
15-Jun-2025 11:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_EQP_LAB_REFREGIRATOR_5_TEMP	admin
15-Jun-2025 11:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt	toOffnormalText		R&D_EQP_LAB_REFREGIRATOR_5_TEMP IS NOT NORMAL	admin
15-Jun-2025 11:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt	toNormalText		R&D_EQP_LAB_REFREGIRATOR_5_TEMP IS NORMAL	admin
15-Jun-2025 11:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.0 °C	-20.0 °C	admin
15-Jun-2025 11:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.0 °C	-10.0 °C	admin
15-Jun-2025 11:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_EQP_LAB_REFREGIRATOR_5_TEMP IS ABOVE -20°C	admin
15-Jun-2025 11:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_EQP_LAB_REFREGIRATOR_5_TEMP IS BELOW -10°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 11:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
15-Jun-2025 11:36:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 11:43:40	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 11:46:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 11:46:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_COLD_ROOM_TEMP_1	admin
15-Jun-2025 11:46:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1/OutOfRangeAlarmExt	toOffnormalText		MFG_COLD_ROOM_1_TEMP IS NOT NORMAL	admin
15-Jun-2025 11:46:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1/OutOfRangeAlarmExt	toNormalText		MFG_COLD_ROOM_1_TEMP IS NORMAL	admin
15-Jun-2025 11:46:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	8.00 °C	admin
15-Jun-2025 11:46:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	2.00 °C	admin
15-Jun-2025 11:46:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_COLD_ROOM_1_TEMP IS ABOVE 8°C	admin
15-Jun-2025 11:46:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_COLD_ROOM_1_TEMP IS BELOW 2°C	admin
15-Jun-2025 11:46:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 11:46:58	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 11:48:14	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_2	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 11:50:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_2/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 11:50:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_2/OutOfRangeAlarmExt	sourceName	%parent.displayName%	MFG_COLD_ROOM_TEMP_2	admin
15-Jun-2025 11:50:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_2/OutOfRangeAlarmExt	toOffnormalText		MFG_COLD_ROOM_TEMP_2 IS NOT NORMAL	admin
15-Jun-2025 11:50:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_2/OutOfRangeAlarmExt	toNormalText		MFG_COLD_ROOM_TEMP_2 IS NORMAL	admin
15-Jun-2025 11:50:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	8.00 °C	admin
15-Jun-2025 11:50:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	2.00 °C	admin
15-Jun-2025 11:50:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		MFG_COLD_ROOM_TEMP_2 IS ABOVE 8°C	admin
15-Jun-2025 11:50:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		MFG_COLD_ROOM_TEMP_2 IS BELOW 2°C	admin
15-Jun-2025 11:50:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
15-Jun-2025 11:50:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 11:51:28	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 11:54:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 11:54:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_BDC051_COL D_ROOM_TEMP_1	admin
15-Jun-2025 11:54:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/OutOfRangeAlarmExt	toOffnormalText		R&D_BDC051_COL D_ROOM_TEMP_1 IS NOT NORMAL	admin
15-Jun-2025 11:54:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/OutOfRangeAlarmExt	toNormalText		R&D_BDC051_COL D_ROOM_TEMP_1 IS NORMAL	admin
15-Jun-2025 11:54:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	8.00 °C	admin
15-Jun-2025 11:54:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	2.00 °C	admin
15-Jun-2025 11:54:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_BDC051_COL D_ROOM_TEMP_1 IS ABOVE 8°C	admin
15-Jun-2025 11:54:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_BDC051_COL D_ROOM_TEMP_1 IS BELOW 2°C	admin
15-Jun-2025 11:54:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 11:54:02	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 11:54:45	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 11:56:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 11:56:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D_BDC053_COL D_ROOM_TEMP_1	admin
15-Jun-2025 11:56:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1/OutOfRangeAlarmExt	toOffnormalText		R&D_BDC053_COL D_ROOM_TEMP_1 IS NOT NORMAL	admin
15-Jun-2025 11:56:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1/OutOfRangeAlarmExt	toNormalText		R&D_BDC053_COL D_ROOM_TEMP_1 IS NOT NORMAL	admin
15-Jun-2025 11:56:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	8.00 °C	admin
15-Jun-2025 11:56:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	2.00 °C	admin
15-Jun-2025 11:56:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D_BDC053_COL D_ROOM_TEMP_1 IS ABOVE 8°C	admin
15-Jun-2025 11:56:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D_BDC053_COL D_ROOM_TEMP_1 IS BELOW 2°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 11:56:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
15-Jun-2025 11:56:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 11:57:47	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_2	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:00:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_2/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 12:00:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_2/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D1_BDC051_COLD_ROOM_TEMP_2	admin
15-Jun-2025 12:00:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_2/OutOfRangeAlarmExt	toOffnormalText		R&D1_BDC051_COLD_ROOM_TEMP_2 IS NOT NORMAL	admin
15-Jun-2025 12:00:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_2/OutOfRangeAlarmExt	toNormalText		R&D1_BDC051_COLD_ROOM_TEMP_2 IS NORMAL	admin
15-Jun-2025 12:00:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	8.00 °C	admin
15-Jun-2025 12:00:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	2.00 °C	admin
15-Jun-2025 12:00:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D1_BDC051_COLD_ROOM_TEMP_2 IS ABOVE 8°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:00:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D1_BDC051_COL D_ROOM_TEMP_2 IS BELOW 2°C	admin
15-Jun-2025 12:00:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
15-Jun-2025 12:00:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 12:01:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/OutOfRangeAlarmExt	sourceName	R&D_BDC051_COL D_ROOM_TEMP_1	R&D1_BDC051_CO LD_ROOM_TEMP_1	admin
15-Jun-2025 12:01:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/OutOfRangeAlarmExt	toOffnormalText	R&D_BDC051_COL D_ROOM_TEMP_1 IS NOT NORMAL	R&D1_BDC051_CO LD_ROOM_TEMP_1 IS NOT NORMAL	admin
15-Jun-2025 12:01:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/OutOfRangeAlarmExt	toNormalText	R&D_BDC051_COL D_ROOM_TEMP_1 IS NORMAL	R&D1_BDC051_CO LD_ROOM_TEMP_1 IS NORMAL	admin
15-Jun-2025 12:01:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	R&D_BDC051_COL D_ROOM_TEMP_1 IS ABOVE 8°C	R&D1_BDC051_CO LD_ROOM_TEMP_1 IS ABOVE 8°C	admin
15-Jun-2025 12:01:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	R&D_BDC051_COL D_ROOM_TEMP_1 IS BELOW 2°C	R&D1_BDC051_CO LD_ROOM_TEMP_1 IS BELOW 2°C	admin
15-Jun-2025 12:01:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1/OutOfRangeAlarmExt	sourceName	R&D_BDC053_COL D_ROOM_TEMP_1	R&D2_BDC053_COL D_ROOM_TEMP_1	admin
15-Jun-2025 12:01:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1/OutOfRangeAlarmExt	toOffnormalText	R&D_BDC053_COL D_ROOM_TEMP_1 IS NOT NORMAL	R&D2_BDC053_COL D_ROOM_TEMP_1 IS NOT NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:01:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1/OutOfRangeAlarmExt	toNormalText	R&D_BDC053_COL D_ROOM_TEMP_1 IS NOT NORMAL	R&D2_BDC053_COL D_ROOM_TEMP_1 IS NOT NORMAL	admin
15-Jun-2025 12:01:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	R&D_BDC053_COL D_ROOM_TEMP_1 IS ABOVE 8°C	R&D2_BDC053_COL D_ROOM_TEMP_1 IS ABOVE 8°C	admin
15-Jun-2025 12:01:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	R&D_BDC053_COL D_ROOM_TEMP_1 IS BELOW 2°C	R&D2_BDC053_COL D_ROOM_TEMP_1 IS BELOW 2°C	admin
15-Jun-2025 12:02:36	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_2	OutOfRangeAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:04:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_2/OutOfRangeAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 12:04:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_2/OutOfRangeAlarmExt	sourceName	%parent.displayName%	R&D2_BDC053_CO LD_ROOM_TEMP_2	admin
15-Jun-2025 12:04:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_2/OutOfRangeAlarmExt	toOffnormalText		R&D2_BDC053_CO LD_ROOM_TEMP_2 IS NOT NORMAL	admin
15-Jun-2025 12:04:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_2/OutOfRangeAlarmExt	toNormalText		R&D2_BDC053_CO LD_ROOM_TEMP_2 IS NORMAL	admin
15-Jun-2025 12:04:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	0.00 °C	8.00 °C	admin
15-Jun-2025 12:04:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	0.00 °C	2.00 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:04:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText		R&D2_BDC053_CO LD_ROOM_TEMP_2 IS ABOVE 8	admin
15-Jun-2025 12:04:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText		R&D2_BDC053_CO LD_ROOM_TEMP_2 IS BELOW 2	admin
15-Jun-2025 12:04:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/lowLimitEnable	false	true	admin
15-Jun-2025 12:04:32	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_ROOM_TEMP_2/OutOfRangeAlarmExt/offnormalAlgorithm	limitEnable/highLimitEnable	false	true	admin
15-Jun-2025 12:06:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1/OutOfRangeAlarmExt	toOffnormalText	MFG_COLD_ROOM _1_TEMP IS NOT NORMAL	MFG_COLD_ROOM _TEMP_1 IS NOT NORMAL	admin
15-Jun-2025 12:06:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1/OutOfRangeAlarmExt	toNormalText	MFG_COLD_ROOM _1_TEMP IS NORMAL	MFG_COLD_ROOM _TEMP_1 IS NORMAL	admin
15-Jun-2025 12:06:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_COLD_ROOM _1_TEMP IS ABOVE 8°C	MFG_COLD_ROOM _TEMP_1 IS ABOVE 8°C	admin
15-Jun-2025 12:06:16	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_ROOM_TEMP_1/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_COLD_ROOM _1_TEMP IS BELOW 2°C	MFG_COLD_ROOM _TEMP_1 IS BELOW 2°C	admin
15-Jun-2025 12:07:16	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_HP	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:15:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName e%	MFG_COLD_ROOM _COMPRESSOR_01 _HP	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:15:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt	toFaultText		MFG_COLD_ROOM_COMPRESSOR_01_HP IS FAULT	admin
15-Jun-2025 12:15:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt	toNormalText		MFG_COLD_ROOM_COMPRESSOR_01_HP IS NORMAL	admin
15-Jun-2025 12:15:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:16:13	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_HP	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:17:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toFault}	admin
15-Jun-2025 12:17:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	MFG_COLD_ROOM_COMPRESSOR_02_HP	admin
15-Jun-2025 12:17:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	toFaultText		MFG_COLD_ROOM_COMPRESSOR_02_HP IS FAULT	admin
15-Jun-2025 12:17:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	toNormalText		MFG_COLD_ROOM_COMPRESSOR_02_HP IS NORMAL	admin
15-Jun-2025 12:17:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:17:55	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toFault}	admin
15-Jun-2025 12:18:19	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_LP	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:19:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toFault}	admin
15-Jun-2025 12:19:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	MFG_COLD_ROOM_COMPRESSOR_01_LP	admin
15-Jun-2025 12:19:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt	toFaultText		MFG_COLD_ROOM_COMPRESSOR_01_LP IS FAULT	admin
15-Jun-2025 12:19:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt	toNormalText		MFG_COLD_ROOM_COMPRESSOR_01_LP IS NORMAL	admin
15-Jun-2025 12:19:36	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:19:53	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_LP	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:21:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toFault}	admin
15-Jun-2025 12:21:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	MFG_COLD_ROOM_COMPRESSOR_02_LP	admin
15-Jun-2025 12:21:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt	toFaultText		MFG_COLD_ROOM_COMPRESSOR_02_LP IS FAULT	admin
15-Jun-2025 12:21:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt	toNormalText		MFG_COLD_ROOM_COMPRESSOR_02_LP IS NORMAL	admin
15-Jun-2025 12:21:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:21:49	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_OVER_LOAD	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:22:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toFault}	admin
15-Jun-2025 12:22:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	MFG_COLD_ROOM_COMPRESSOR_01_OVER_LOAD	admin
15-Jun-2025 12:22:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	toFaultText		MFG_COLD_ROOM_COMPRESSOR_01_OVER_LOAD IS FAULT	admin
15-Jun-2025 12:22:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	toNormalText		MFG_COLD_ROOM_COMPRESSOR_01_OVER_LOAD IS NORMAL	admin
15-Jun-2025 12:22:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:23:16	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_OVER_LOAD	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:24:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toFault}	admin
15-Jun-2025 12:24:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	MFG_COLD_ROOM_COMPRESSOR_02_OVER_LOAD	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:24:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	toFaultText		MFG_COLD_ROOM_COMPRESSOR_02_OVER_LOAD IS FAULT	admin
15-Jun-2025 12:24:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	toNormalText		MFG_COLD_ROOM_COMPRESSOR_02_OVER_LOAD IS NORMAL	admin
15-Jun-2025 12:24:03	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_OVER_LOAD/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:24:21	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_SINGAL_PHASE_P REVENTER	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:25:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_SINGAL_PHASE_P REVENTER/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toFault}	admin
15-Jun-2025 12:25:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_SINGAL_PHASE_P REVENTER/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	MFG_COLD_ROOM_SINGAL_PHASE_P REVENTER	admin
15-Jun-2025 12:25:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_SINGAL_PHASE_P REVENTER/BooleanChangeOfStateAlarmExt	toFaultText		MFG_COLD_ROOM_SINGAL_PHASE_P REVENTER IS FAULT	admin
15-Jun-2025 12:25:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_SINGAL_PHASE_P REVENTER/BooleanChangeOfStateAlarmExt	toNormalText		MFG_COLD_ROOM_SINGAL_PHASE_P REVENTER IS NORMAL	admin
15-Jun-2025 12:25:30	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_SINGAL_PHASE_P REVENTER/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:26:08	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_CONDENSER_01_OVER_LOAD	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:28:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_CONDENSER_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	MFG_COLD_ROOM_CONDENSER_01_OVER_LOAD	admin
15-Jun-2025 12:28:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_CONDENSER_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	toOffnormalText		MFG_COLD_ROOM_CONDENSER_01_OVER_LOAD IS FAULT	admin
15-Jun-2025 12:28:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_CONDENSER_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	toNormalText		MFG_COLD_ROOM_CONDENSER_01_OVER_LOAD IS NORMAL	admin
15-Jun-2025 12:28:33	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_CONDENSER_01_OVER_LOAD/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:28:58	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_CONDENSER_02_OVER_LOAD	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:31:06	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_CONDENSER_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 12:31:06	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_CONDENSER_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	MFG_COLD_ROOM_CONDENSER_02_OVER_LOAD	admin
15-Jun-2025 12:31:06	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_CONDENSER_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	toOffnormalText		MFG_COLD_ROOM_CONDENSER_02_OVER_LOAD IS FAULT	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:31:06	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/MFG_CONDENSER_02_ OVER_LOAD/BooleanChangeOfStateAlarm Ext	toNormalText		MFG_COLD_ROOM _CONDENSER_02_ OVER_LOAD IS NORMAL	admin
15-Jun-2025 12:31:06	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/MFG_CONDENSER_02_ OVER_LOAD/BooleanChangeOfStateAlarm Ext/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:31:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/MFG_CONDENSER_01_ OVER_LOAD/BooleanChangeOfStateAlarm Ext	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 12:32:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/MFG_COMPRESSOR_02_ OVER_LOAD/BooleanChangeOfStateAlar mExt	alarmEnable	{toFault}	{toOffnormal}	admin
15-Jun-2025 12:32:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/MFG_COMPRESSOR_02_ OVER_LOAD/BooleanChangeOfStateAlar mExt	toFaultText	MFG_COLD_ROOM _COMPRESSOR_02_ OVER_LOAD IS FAULT		admin
15-Jun-2025 12:32:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/MFG_COMPRESSOR_02_ OVER_LOAD/BooleanChangeOfStateAlar mExt	toOffnormalText		MFG_COLD_ROOM _COMPRESSOR_02_ OVER_LOAD IS FAULT	admin
15-Jun-2025 12:32:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/MFG_COMPRESSOR_01_ OVER_LOAD/BooleanChangeOfStateAlar mExt	alarmEnable	{toFault}	{toOffnormal}	admin
15-Jun-2025 12:32:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/MFG_COMPRESSOR_01_ OVER_LOAD/BooleanChangeOfStateAlar mExt	toFaultText	MFG_COLD_ROOM _COMPRESSOR_01_ OVER_LOAD IS FAULT		admin
15-Jun-2025 12:32:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ COLD\$20ROOM/MFG_COMPRESSOR_01_ OVER_LOAD/BooleanChangeOfStateAlar mExt	toOffnormalText		MFG_COLD_ROOM _COMPRESSOR_01_ OVER_LOAD IS FAULT	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:32:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt	alarmEnable	{toFault}	{toOffnormal}	admin
15-Jun-2025 12:32:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt	toFaultText	MFG_COLD_ROOM_COMPRESSOR_02_LP IS FAULT		admin
15-Jun-2025 12:32:54	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt	toOffnormalText		MFG_COLD_ROOM_COMPRESSOR_02_LP IS FAULT	admin
15-Jun-2025 12:33:17	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt	alarmEnable	{toFault}	{toOffnormal}	admin
15-Jun-2025 12:33:17	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt	toFaultText	MFG_COLD_ROOM_COMPRESSOR_01_LP IS FAULT		admin
15-Jun-2025 12:33:17	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt	toOffnormalText		MFG_COLD_ROOM_COMPRESSOR_01_LP IS FAULT	admin
15-Jun-2025 12:33:44	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	alarmEnable	{toFault}	{toOffnormal}	admin
15-Jun-2025 12:33:44	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	toFaultText	MFG_COLD_ROOM_COMPRESSOR_02_HP IS FAULT		admin
15-Jun-2025 12:33:44	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	toOffnormalText		MFG_COLD_ROOM_COMPRESSOR_02_HP IS FAULT	admin
15-Jun-2025 12:34:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt	alarmEnable	{toFault}	{toOffnormal}	admin
15-Jun-2025 12:34:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt	toFaultText	MFG_COLD_ROOM_COMPRESSOR_01_HP IS FAULT		admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:34:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/MFG_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt	toOffnormalText		MFG_COLD_ROOM_COMPRESSOR_01_HP IS FAULT	admin
15-Jun-2025 12:35:30	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_CONDENSER_01_OVER_LOAD	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:38:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_CONDENSER_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 12:38:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_CONDENSER_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	R&D1_BDC051_COLD_ROOM_CONDENSER_01_OVER_LOAD	admin
15-Jun-2025 12:38:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_CONDENSER_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	toOffnormalText		R&D1_BDC051_COLD_ROOM_CONDENSER_01_OVER_LOAD IS FAULT	admin
15-Jun-2025 12:38:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_CONDENSER_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	toNormalText		R&D1_BDC051_COLD_ROOM_CONDENSER_01_OVER_LOAD IS NORMAL	admin
15-Jun-2025 12:38:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_CONDENSER_01_OVER_LOAD/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:38:18	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_CONDENSER_02_OVER_LOAD	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:39:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_CONDENSER_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:39:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_CONDE NSER_02_OVER_LOAD/BooleanChangeOf StateAlarmExt	sourceName	%parent.displayName e%	R&D1_BDC051_COL D_ROOM_CONDEN SER_02_OVER_LO AD	admin
15-Jun-2025 12:39:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_CONDE NSER_02_OVER_LOAD/BooleanChangeOf StateAlarmExt	toOffnormalText		R&D1_BDC051_COL D_ROOM_CONDEN SER_02_OVER_LO AD IS FAULT	admin
15-Jun-2025 12:39:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_CONDE NSER_02_OVER_LOAD/BooleanChangeOf StateAlarmExt	toNormalText		R&D1_BDC051_COL D_ROOM_CONDEN SER_02_OVER_LO AD IS NORMAL	admin
15-Jun-2025 12:39:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_CONDE NSER_02_OVER_LOAD/BooleanChangeOf StateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:41:34	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPR ESSOR_01_HP	BooleanChangeOfSt ateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:43:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPR ESSOR_01_HP/BooleanChangeOfStateAla rmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 12:43:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPR ESSOR_01_HP/BooleanChangeOfStateAla rmExt	sourceName	%parent.displayName e%	R&D2_BDC053_CO MPRESSOR_01_HP	admin
15-Jun-2025 12:43:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPR ESSOR_01_HP/BooleanChangeOfStateAla rmExt	toOffnormalText		R&D2_BDC053_CO MPRESSOR_01_HP IS FAULT	admin
15-Jun-2025 12:43:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPR ESSOR_01_HP/BooleanChangeOfStateAla rmExt	toNormalText		R&D2_BDC053_CO MPRESSOR_01_HP IS NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:43:28	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:43:44	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_HP	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:44:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 12:44:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	R&D2_BDC053_COMPRESSOR_02_HP	admin
15-Jun-2025 12:44:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	toOffnormalText		R&D2_BDC053_COMPRESSOR_02_HP IS FAULT	admin
15-Jun-2025 12:44:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	toNormalText		R&D2_BDC053_COMPRESSOR_02_HP IS NORMAL	admin
15-Jun-2025 12:44:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:46:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	sourceName	R&D2_BDC053_COMPRESSOR_02_HP	R&D2_COLD_ROOM_BDC053_COMPRESSOR_02_HP	admin
15-Jun-2025 12:46:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	toOffnormalText	R&D2_BDC053_COMPRESSOR_02_HP IS FAULT	R&D2_COLD_ROOM_BDC053_COMPRESSOR_02_HP IS FAULT	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:46:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	toNormalText	R&D2_BDC053_COMPRESSOR_02_HP IS NORMAL	R&D2_COLD_ROOM_BDC053_COMPRESSOR_02_HP IS NORMAL	admin
15-Jun-2025 12:46:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt	sourceName	R&D2_BDC053_COMPRESSOR_01_HP	R&D2_COLD_ROOM_BDC053_COMPRESSOR_01_HP	admin
15-Jun-2025 12:46:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt	toOffnormalText	R&D2_BDC053_COMPRESSOR_01_HP IS FAULT	R&D2_COLD_ROOM_BDC053_COMPRESSOR_01_HP IS FAULT	admin
15-Jun-2025 12:46:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt	toNormalText	R&D2_BDC053_COMPRESSOR_01_HP IS NORMAL	R&D2_COLD_ROOM_BDC053_COMPRESSOR_01_HP IS NORMAL	admin
15-Jun-2025 12:47:11	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_LP	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:48:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 12:48:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	R&D2_COLD_ROOM_BDC053_COMPRESSOR_01_LP	admin
15-Jun-2025 12:48:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt	toOffnormalText		R&D2_COLD_ROOM_BDC053_COMPRESSOR_01_LP IS FAULT	admin
15-Jun-2025 12:48:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt	toNormalText		R&D2_COLD_ROOM_BDC053_COMPRESSOR_01_LP IS NORMAL	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:48:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:48:19	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_LP	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:49:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 12:49:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	R&D2_COLD_ROOM_BDC053_COMPRESSOR_02_LP	admin
15-Jun-2025 12:49:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt	toOffnormalText		R&D2_COLD_ROOM_BDC053_COMPRESSOR_02_LP IS FAULT	admin
15-Jun-2025 12:49:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt	toNormalText		R&D2_COLD_ROOM_BDC053_COMPRESSOR_02_LP IS NORMAL	admin
15-Jun-2025 12:49:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:49:38	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_OVER_LOAD	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:51:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:51:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	R&D2_COLD_ROOM_BDC053_COMPRESSOR_02_OVER_LOAD	admin
15-Jun-2025 12:51:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	toOffnormalText		R&D2_COLD_ROOM_BDC053_COMPRESSOR_02_OVER_LOAD IS FAULT	admin
15-Jun-2025 12:51:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	toNormalText		R&D2_COLD_ROOM_BDC053_COMPRESSOR_02_OVER_LOAD IS NORMAL	admin
15-Jun-2025 12:51:04	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:51:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	sourceName	R&D2_COLD_ROOM_BDC053_COMPRESSOR_02_OVER_LOAD	R&D2_COLD_ROOM_BDC053_COMPRESSOR_01_OVER_LOAD	admin
15-Jun-2025 12:51:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	toOffnormalText	R&D2_COLD_ROOM_BDC053_COMPRESSOR_02_OVER_LOAD IS FAULT	R&D2_COLD_ROOM_BDC053_COMPRESSOR_01_OVER_LOAD IS FAULT	admin
15-Jun-2025 12:51:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	toNormalText	R&D2_COLD_ROOM_BDC053_COMPRESSOR_02_OVER_LOAD IS NORMAL	R&D2_COLD_ROOM_BDC053_COMPRESSOR_01_OVER_LOAD IS NORMAL	admin
15-Jun-2025 12:52:19	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_OVER_LOAD	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:53:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:53:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	R&D2_COLD_ROOM_BDC053_COMPRESSOR_02_OVER_LOAD	admin
15-Jun-2025 12:53:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	toOffnormalText		R&D2_COLD_ROOM_BDC053_COMPRESSOR_02_OVER_LOAD IS FAULT	admin
15-Jun-2025 12:53:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_COMPRESSOR_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	toNormalText		R&D2_COLD_ROOM_BDC053_COMPRESSOR_02_OVER_LOAD IS NORMAL	admin
15-Jun-2025 12:53:43	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_SINGAL_PHASE_PREVENTER	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:55:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_SINGAL_PHASE_PREVENTER/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 12:55:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_SINGAL_PHASE_PREVENTER/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	R&D2_COLD_ROOM_BDC053_SINGLE_PHASE_PREVENTER	admin
15-Jun-2025 12:55:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_SINGAL_PHASE_PREVENTER/BooleanChangeOfStateAlarmExt	toOffnormalText		R&D2_COLD_ROOM_BDC053_SINGLE_PHASE_PREVENTER IS FAULT	admin
15-Jun-2025 12:55:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_SINGAL_PHASE_PREVENTER/BooleanChangeOfStateAlarmExt	toNormalText		R&D2_COLD_ROOM_BDC053_SINGLE_PHASE_PREVENTER IS NORMAL	admin
15-Jun-2025 12:55:01	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_SINGAL_PHASE_PREVENTER/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:56:37	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_HP	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:58:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 12:58:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	R&D1_BDC051_COLD_ROOM_COMPRESSOR_01_HP	admin
15-Jun-2025 12:58:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt	toOffnormalText		R&D1_BDC051_COLD_ROOM_COMPRESSOR_01_HP IS FAULT	admin
15-Jun-2025 12:58:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt	toNormalText		R&D1_BDC051_COLD_ROOM_COMPRESSOR_01_HP IS NORML	admin
15-Jun-2025 12:58:27	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_HP/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:58:42	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_HP	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 12:59:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 12:59:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	R&D1_BDC051_COLD_ROOM_COMPRESSOR_02_HP	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 12:59:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	toOffnormalText		R&D1_BDC051_COLD_ROOM_COMPRESSOR_02_HP IS FAULT	admin
15-Jun-2025 12:59:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt	toNormalText		R&D1_BDC051_COLD_ROOM_COMPRESSOR_02_HP IS NORMAL	admin
15-Jun-2025 12:59:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_HP/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 12:59:49	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_LP	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 13:01:40	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 13:01:40	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	R&D1_BDC051_COLD_ROOM_COMPRESSOR_01_LP	admin
15-Jun-2025 13:01:40	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt	toOffnormalText		R&D1_BDC051_COLD_ROOM_COMPRESSOR_01_LP IS FAULT	admin
15-Jun-2025 13:01:40	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt	toNormalText		R&D1_BDC051_COLD_ROOM_COMPRESSOR_01_LP IS NORMAL	admin
15-Jun-2025 13:01:40	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_LP/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 13:01:54	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_LP	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 13:02:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 13:02:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	R&D1_BDC051_COLD_ROOM_COMPRESSOR_02_LP	admin
15-Jun-2025 13:02:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt	toOffnormalText		R&D1_BDC051_COLD_ROOM_COMPRESSOR_02_LP IS FAULT	admin
15-Jun-2025 13:02:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt	toNormalText		R&D1_BDC051_COLD_ROOM_COMPRESSOR_02_LP IS FAULT	admin
15-Jun-2025 13:02:46	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_LP/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 13:03:07	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_OVER_LOAD	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 13:04:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 13:04:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	R&D1_BDC051_COLD_ROOM_COMPRESSOR_01_OVER_LOAD	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 13:04:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	toOffnormalText		R&D1_BDC051_COL D_ROOM_COMPRE SSOR_01_OVER_L OAD IS FAULT	admin
15-Jun-2025 13:04:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	toNormalText		R&D1_BDC051_COL D_ROOM_COMPRE SSOR_01_OVER_L OAD IS NORMAL	admin
15-Jun-2025 13:04:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_01_OVER_LOAD/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 13:04:33	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_OVER_LOAD	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 13:09:15	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 13:09:15	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	R&D1_BDC051_COL D_ROOM_COMPRE SSOR_02_OVER_L OAD	admin
15-Jun-2025 13:09:15	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	toOffnormalText		R&D1_BDC051_COL D_ROOM_COMPRE SSOR_02_OVER_L OAD IS FAULT	admin
15-Jun-2025 13:09:15	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_OVER_LOAD/BooleanChangeOfStateAlarmExt	toNormalText		R&D1_BDC051_COL D_ROOM_COMPRE SSOR_01_OVER_L OAD IS NORMAL	admin
15-Jun-2025 13:09:15	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_COMPRESSOR_02_OVER_LOAD/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 13:09:45	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_SINGAL_PHASE_PREVENTER	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 13:14:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_SINGAL_PHASE_PREVENTER/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 13:14:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_SINGAL_PHASE_PREVENTER/BooleanChangeOfStateAlarmExt	sourceName	%parent.displayName%	R&D1_BDC051_COLD_ROOM_SINGLE_PHASE_PREVENTER	admin
15-Jun-2025 13:14:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_SINGAL_PHASE_PREVENTER/BooleanChangeOfStateAlarmExt	toOffnormalText		R&D1_BDC051_COLD_ROOM_SINGLE_PHASE_PREVENTER IS FAULT	admin
15-Jun-2025 13:14:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_SINGAL_PHASE_PREVENTER/BooleanChangeOfStateAlarmExt	toNormalText		R&D1_BDC051_COLD_ROOM_SINGLE_PHASE_PREVENTER IS NORMAL	admin
15-Jun-2025 13:14:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC051_SINGAL_PHASE_PREVENTER/BooleanChangeOfStateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 13:15:56	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_CONDENSER_01_OVER_LOAD	BooleanChangeOfStateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 13:17:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_CONDENSER_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 13:17:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_CONDENSER_01_OVER_LOAD/BooleanChangeOfStateAlarmExt	toOffnormalText		R&D2_COLD_ROOM_BDC053_CONDENSER_01_OVER_LOAD IS FAULT	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 13:17:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_CONDE NSER_01_OVER_LOAD/BooleanChangeOf StateAlarmExt	toNormalText		R&D2_COLD_ROO M_BDC053_CONDE NSER_01_OVER_L OAD IS NORMAL	admin
15-Jun-2025 13:17:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_CONDE NSER_01_OVER_LOAD/BooleanChangeOf StateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 13:18:29	Added	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_CONDE NSER_02_OVER_LOAD	BooleanChangeOfSt ateAlarmExt		Alarm Source Ext	admin
15-Jun-2025 13:20:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_CONDE NSER_02_OVER_LOAD/BooleanChangeOf StateAlarmExt	alarmEnable	{toOffnormal toFault}	{toOffnormal}	admin
15-Jun-2025 13:20:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_CONDE NSER_02_OVER_LOAD/BooleanChangeOf StateAlarmExt	toOffnormalText		R&D2_COL_ROOM_ BDC053_CONDE NSER_02_OVER LOAD IS FAULT	admin
15-Jun-2025 13:20:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_CONDE NSER_02_OVER_LOAD/BooleanChangeOf StateAlarmExt	toNormalText		R&D2_COL_ROOM_ BDC053_CONDE NSER_02_OVER LOAD IS NORMAL	admin
15-Jun-2025 13:20:09	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/COLD\$20ROOM/R\$26D_BDC053_CONDE NSER_02_OVER_LOAD/BooleanChangeOf StateAlarmExt/offnormalAlgorithm	alarmValue	HEALTHY	FAULT	admin
15-Jun-2025 13:37:41	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_RM_CONSUMABLE_2\$2 0FREEZER/NumericInterval	activePeriod/timeRan ge	12:00 AM - 12:00 AM	12:00 AM - 12:00 AM	admin
15-Jun-2025 14:12:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	-22.0 °C	-18.0 °C	admin
15-Jun-2025 14:12:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	-18.0 °C	-22.0 °C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 14:12:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS ABOVE - 22°C	MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS BELOW - 18°C	admin
15-Jun-2025 14:12:35	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS BELOW - 18°C	MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS ABOVE - 22°C	admin
15-Jun-2025 14:18:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt	sourceName	MFG_EQP_LAB_RE FRIGERATOR_16_T EMP	MFG_EQP_LAB_RE FRIGERATOR_6_TE MP	admin
15-Jun-2025 14:18:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt	toOffnormalText	MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS NOT NORMAL	MFG_EQP_LAB_RE FRIGERATOR_6_TE MP IS NOT NORMAL	admin
15-Jun-2025 14:18:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt	toNormalText	MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS NORMAL	MFG_EQP_LAB_RE FRIGERATOR_6_TE MP IS NORMAL	admin
15-Jun-2025 14:18:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS BELOW - 18°C	MFG_EQP_LAB_RE FRIGERATOR_6_TE MP IS BELOW -18°C	admin
15-Jun-2025 14:18:29	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$206/ OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_EQP_LAB_RE FRIGERATOR_16_T EMP IS ABOVE - 22°C	MFG_EQP_LAB_RE FRIGERATOR_6_TE MP IS ABOVE -22°C	admin
15-Jun-2025 14:52:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB_REFRIGERATOR_16/Num ericInterval	historyName	MFG_POLYMER_LA B_REFRIGERATOR _1	LAB_REFRIGERAT OR_16	admin
15-Jun-2025 15:01:13	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/MFG_POLYMER_LAB_REGRI GERATOR_1/NumericInterval	historyName	MFG_NCMR_ROOM _REFRIGERATOR	MFG_POLYMER_LA B_REFRIGERATOR _1	admin
15-Jun-2025 15:06:25	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/LAB\$20REFRIGERATOR\$2014 /NumericInterval	historyName	MFG_POLYMER_LA B_FREEZER_8	MFG_LAB_REFRIG ERATOR_14	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 15:15:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	-22.0 °C	-18.0 °C	admin
15-Jun-2025 15:15:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	-18.0 °C	-22.0 °C	admin
15-Jun-2025 15:15:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_EQP_LAB_RE F_6_TEMP IS ABOVE -22°C	MFG_EQP_LAB_RE F_6_TEMP IS BELOW -18°C	admin
15-Jun-2025 15:15:08	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$206/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_EQP_LAB_RE F_6_TEMP IS BELOW -18°C	MFG_EQP_LAB_RE F_6_TEMP IS ABOVE -22°C	admin
15-Jun-2025 15:16:41	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	-22.0 °C	-18.0 °C	admin
15-Jun-2025 15:16:41	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	-18.0 °C	-22.0 °C	admin
15-Jun-2025 15:16:41	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	MFG_EQP_LAB_RE F_7_TEMP IS ABOVE -22°C	MFG_EQP_LAB_RE F_7_TEMP IS BELOW -18°C	admin
15-Jun-2025 15:16:41	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/Lab\$20REF\$207/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	MFG_EQP_LAB_RE F_7_TEMP IS BELOW -18°C	MFG_EQP_LAB_RE F_7_TEMP IS ABOVE -22°C	admin
15-Jun-2025 15:21:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimit	-10.0 °C	-20.0 °C	admin
15-Jun-2025 15:21:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	highLimitText	R&D_EQP_LAB_RE FRIGERATOR_5_TE MP IS ABOVE -20°C	R&D_EQP_LAB_RE FRIGERATOR_5_TE MP IS BELOW -10°C	admin
15-Jun-2025 15:21:00	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	lowLimitText	R&D_EQP_LAB_RE FRIGERATOR_5_TE MP IS BELOW -10°C	R&D_EQP_LAB_RE FRIGERATOR_5_TE MP IS ABOVE -20°C	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
15-Jun-2025 15:21:10	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/LAB_REFREGIRATOR_5/OutOfRangeAlarmExt/offnormalAlgorithm	highLimit	-20.0 °C	-10.0 °C	admin
16-Jun-2025 12:06:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_PLASMA_ROOM/proxyExt	deviceFacets	units=°C,min=0.00,max=100.00,precision=1	units=%RH,min=0.00,max=100.00,precision=1	admin
16-Jun-2025 12:09:15	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_DRY_DOWN_WORK_STATION/proxyExt	deviceFacets	units=°C,min=0.00,max=100.00,precision=1	units=%RH,min=0.00,max=100.00,precision=1	admin
16-Jun-2025 12:10:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/RH_NCMR_ROOM/proxyExt	deviceFacets	units=°C,min=0.00,max=100.00,precision=1	units=%RH,min=0.00,max=100.00,precision=1	admin
16-Jun-2025 12:12:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_HOT_SPOT/proxyExt	deviceFacets	units=°C,min=0.00,max=100.00,precision=1	units=%RH,min=0.00,max=100.00,precision=1	admin
16-Jun-2025 12:13:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/proxyExt	deviceFacets	units=°C,min=0.00,max=100.00,precision=1	units=%RH,min=0.00,max=100.00,precision=1	admin
16-Jun-2025 12:15:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/proxyExt	deviceFacets	units=°C,min=0.00,max=100.00,precision=1	units=%RH,min=0.00,max=100.00,precision=1	admin
16-Jun-2025 12:33:06	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/proxyExt	conversion	Default	Linear *0.10	admin
16-Jun-2025 12:33:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/proxyExt	conversion	Linear *0.10	Linear	admin
16-Jun-2025 12:33:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/proxyExt	conversion	Linear	Linear *2.00	admin
16-Jun-2025 12:33:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/proxyExt	conversion	Linear *2.00	Linear *0.00	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
16-Jun-2025 12:34:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMI STRY\$20L2/proxyExt	conversion	Linear *0.00	Linear *0.50	admin
16-Jun-2025 12:34:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMI STRY\$20L2/proxyExt	conversion	Linear *0.50	Linear *0.60	admin
16-Jun-2025 12:34:26	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMI STRY\$20L2/proxyExt	conversion	Linear *0.60	Linear *0.40	admin
16-Jun-2025 12:39:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATO R_1/proxyExt	conversion	Default	Linear *0.50	admin
16-Jun-2025 12:39:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATO R_1/proxyExt	conversion	Linear *0.50	Linear *0.40	admin
16-Jun-2025 12:41:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRI GERATOR_1/proxyExt	conversion	Default	Linear	admin
16-Jun-2025 12:42:06	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRI GERATOR_1/proxyExt	conversion	Linear	Linear *1.10	admin
16-Jun-2025 12:42:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_POLYMER_LAB_REGRI GERATOR_1/proxyExt	conversion	Linear *1.10	Default	admin
16-Jun-2025 17:18:08	Changed	/Services/UserService/EMS	web_WebProfileConfi g	HTML5 Hx Profile	HTML5 Hx Profile	admin
16-Jun-2025 17:18:08	Changed	/Services/UserService/EMS	web_MobileWebProfi leConfig	Default Hx Profile	Default Hx Profile	admin
16-Jun-2025 17:21:47	Changed	/Services/UserService/EMS	web_WebProfileConfi g	HTML5 Hx Profile	HTML5 Hx Profile	admin
16-Jun-2025 17:21:47	Changed	/Services/UserService/EMS	web_MobileWebProfi leConfig	Default Hx Profile	Default Hx Profile	admin
16-Jun-2025 17:24:54	Invoked	/Services/EmailService/OutgoingAccount	send		Email	admin
16-Jun-2025 17:26:36	Invoked	/Services/EmailService/OutgoingAccount	send		Email	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
16-Jun-2025 17:28:02	Invoked	/Services/JobService	submitAction		Station Save	admin
16-Jun-2025 17:28:02	Invoked	/	save			admin
16-Jun-2025 17:29:49	Invoked	/Services/EmailService/OutgoingAccount	send		Email	admin
16-Jun-2025 17:30:17	Invoked	/Services/EmailService/OutgoingAccount	send		Email	admin
16-Jun-2025 17:31:05	Changed	/Services/EmailService/OutgoingAccount	pollrate	1 minute	30 seconds	admin
16-Jun-2025 17:32:14	Changed	/Services/OrionAlarmService/EmailRecipient	wsAnnotation	38,18,15	41,18,15	admin
16-Jun-2025 17:32:45	Changed	/Services/OrionAlarmService/EmailRecipient	cc		arjun@ncpl.co arjun	admin
16-Jun-2025 17:33:37	Changed	/Services/OrionAlarmService/Trend\$20Network\$20and\$20Device\$20Alarms	escalationLevel1Enabled	false	true	admin
16-Jun-2025 17:33:37	Changed	/Services/OrionAlarmService/Trend\$20Network\$20and\$20Device\$20Alarms	escalationLevel2Enabled	false	true	admin
16-Jun-2025 17:33:37	Changed	/Services/OrionAlarmService/Trend\$20Network\$20and\$20Device\$20Alarms	escalationLevel3Enabled	false	true	admin
16-Jun-2025 17:33:57	Changed	/Services/OrionAlarmService/DefaultTrendAlarmClass	escalationLevel1Enabled	false	true	admin
16-Jun-2025 17:33:57	Changed	/Services/OrionAlarmService/DefaultTrendAlarmClass	escalationLevel2Enabled	false	true	admin
16-Jun-2025 17:33:57	Changed	/Services/OrionAlarmService/DefaultTrendAlarmClass	escalationLevel3Enabled	false	true	admin
16-Jun-2025 17:34:03	Changed	/Services/OrionAlarmService/Alarms\$20From\$20Trend\$20Systems	wsAnnotation	38,27,20	43,26,20	admin
16-Jun-2025 17:36:50	Changed	/Services/EmailService/OutgoingAccount	maxSendablePerDay	100	max	admin
16-Jun-2025 17:37:25	Changed	/Services/OrionAlarmService/EmailRecipient	cc	arjun@ncpl.co arjun		admin
16-Jun-2025 17:47:19	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1/proxyExt	conversion	Linear *0.40	Default	admin
16-Jun-2025 17:47:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R\$26D_EQP/R_and_D_Equipment_CHEMISTRY\$20L2/proxyExt	conversion	Linear *0.40	Default	admin

Audit Report of EMS System

Start Date: 02-Jun-2025

End Date: 20-Jun-2025

Start Time: 17:00

End Time: 17:00

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
17-Jun-2025 18:05:21	Added	/Drivers/RdbmsNetwork/SqlServerDatabase/histories	EMS_NEW_AuditHistory		Sql Server History Export	admin
17-Jun-2025 18:06:01	Invoked	/Drivers/RdbmsNetwork/SqlServerDatabase/histories/EMS_NEW_AuditHistory	execute			admin