Audit Report

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
16-Jun-2025 12:06:45	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/RH_PLASMA_ROOM/proxyExt	deviceFacets	units=°C,min=0.00,max=100.00,precision=1	units=%RH,min=0.00,max=100.00,precision=1	admin
16-Jun-2025 12:09:15	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/RH_DRY_DOWN_WORK_STATION/proxyExt	deviceFacets	units=°C,min=0.00,max=100.00,precision=1	units=%RH,min=0.00,max=100.00,precision=1	admin
16-Jun-2025 12:10:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/RH_NCMR_ROOM/proxyExt	deviceFacets	units=°C,min=0.00,max=100.00,precision=1	units=%RH,min=0.00,max=100.00,precision=1	admin
16-Jun-2025 12:12:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/MFG_GLASS_WARE_RH_HOT_SPOT/proxyExt	deviceFacets	units=°C,min=0.00,max=100.00,precision=1	units=%RH,min=0.00,max=100.00,precision=1	admin
16-Jun-2025 12:13:56	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/MFG_GLASS_WARE_RH_COLD_SPOT/proxyExt	deviceFacets	units=°C,min=0.00,max=100.00,precision=1	units=%RH,min=0.00,max=100.00,precision=1	admin
16-Jun-2025 12:15:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_COLDSPOT/MFG_QA_RETAINS_RH_COLD_SPOT/proxyExt	deviceFacets	units=°C,min=0.00,max=100.00,precision=1	units=%RH,min=0.00,max=100.00,precision=1	admin
16-Jun-2025 12:33:06	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ R$26D_EQP/R_and_D_Equipment_CHEMISTRY$20L2/proxyExt	conversion	Default	Linear *0.10	admin
16-Jun-2025 12:33:37	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ R$26D_EQP/R_and_D_Equipment_CHEMISTRY$20L2/proxyExt	conversion	Linear *0.10	Linear	admin
16-Jun-2025 12:33:51	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ R$26D_EQP/R_and_D_Equipment_CHEMISTRY$20L2/proxyExt	conversion	Linear	Linear *2.00	admin
16-Jun-2025 12:33:59	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ R$26D_EQP/R_and_D_Equipment_CHEMISTRY$20L2/proxyExt	conversion	Linear *2.00	Linear *0.00	admin
16-Jun-2025 12:34:07	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ R$26D_EQP/R_and_D_Equipment_CHEMISTRY$20L2/proxyExt	conversion	Linear *0.00	Linear *0.50	admin

Audit Report

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
16-Jun-2025 12:34:18	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ R$26D_EQP/R_and_D_Equipment_CHEMI STRY$20L2/proxyExt	conversion	Linear *0.50	Linear *0.60	admin
16-Jun-2025 12:34:26	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ R$26D_EQP/R_and_D_Equipment_CHEMI STRY$20L2/proxyExt	conversion	Linear *0.60	Linear *0.40	admin
16-Jun-2025 12:39:31	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/MFG_QC_LAB_REFRIGERATO R_1/proxyExt	conversion	Default	Linear *0.50	admin
16-Jun-2025 12:39:38	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/MFG_QC_LAB_REFRIGERATO R_1/proxyExt	conversion	Linear *0.50	Linear *0.40	admin
16-Jun-2025 12:41:57	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/MFG_POLYMER_LAB_REGRI GERATOR_1/proxyExt	conversion	Default	Linear	admin
16-Jun-2025 12:42:06	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/MFG_POLYMER_LAB_REGRI GERATOR_1/proxyExt	conversion	Linear	Linear *1.10	admin
16-Jun-2025 12:42:24	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/ MFG_EQP/MFG_POLYMER_LAB_REGRI GERATOR_1/proxyExt	conversion	Linear *1.10	Default	admin
16-Jun-2025 17:18:08	Changed	/Services/UserService/EMS	web_WebProfileConfi g	HTML5 Hx Profile	HTML5 Hx Profile	admin
16-Jun-2025 17:18:08	Changed	/Services/UserService/EMS	web_MobileWebProfi leConfig	Default Hx Profile	Default Hx Profile	admin
16-Jun-2025 17:21:47	Changed	/Services/UserService/EMS	web_WebProfileConfi g	HTML5 Hx Profile	HTML5 Hx Profile	admin
16-Jun-2025 17:21:47	Changed	/Services/UserService/EMS	web_MobileWebProfi leConfig	Default Hx Profile	Default Hx Profile	admin
16-Jun-2025 17:24:54	Invoked	/Services/EmailService/OutgoingAccount	send		Email	admin
16-Jun-2025 17:26:36	Invoked	/Services/EmailService/OutgoingAccount	send		Email	admin
16-Jun-2025 17:28:02	Invoked	/Services/JobService	submitAction		Station Save	admin
16-Jun-2025 17:28:02	Invoked	/	save			admin
16-Jun-2025 17:29:49	Invoked	/Services/EmailService/OutgoingAccount	send		Email	admin

Audit Report

Timestamp	Operation	Target	Slot Name	Old Value	Value	User Name
16-Jun-2025 17:30:17	Invoked	/Services/EmailService/OutgoingAccount	send		Email	admin
16-Jun-2025 17:31:05	Changed	/Services/EmailService/OutgoingAccount	pollrate	1 minute	30 seconds	admin
16-Jun-2025 17:32:14	Changed	/Services/OrionAlarmService/EmailRecipient	wsAnnotation	38,18,15	41,18,15	admin
16-Jun-2025 17:32:45	Changed	/Services/OrionAlarmService/EmailRecipient	cc		arjun@ncpl.co|arjun	admin
16-Jun-2025 17:33:37	Changed	/Services/OrionAlarmService/Trend$20Network$20and$20Device$20Alarms	escalationLevel1Enabled	false	true	admin
16-Jun-2025 17:33:37	Changed	/Services/OrionAlarmService/Trend$20Network$20and$20Device$20Alarms	escalationLevel2Enabled	false	true	admin
16-Jun-2025 17:33:37	Changed	/Services/OrionAlarmService/Trend$20Network$20and$20Device$20Alarms	escalationLevel3Enabled	false	true	admin
16-Jun-2025 17:33:57	Changed	/Services/OrionAlarmService/DefaultTrendAlarmClass	escalationLevel1Enabled	false	true	admin
16-Jun-2025 17:33:57	Changed	/Services/OrionAlarmService/DefaultTrendAlarmClass	escalationLevel2Enabled	false	true	admin
16-Jun-2025 17:33:57	Changed	/Services/OrionAlarmService/DefaultTrendAlarmClass	escalationLevel3Enabled	false	true	admin
16-Jun-2025 17:34:03	Changed	/Services/OrionAlarmService/Alarms$20From$20Trend$20Systems	wsAnnotation	38,27,20	43,26,20	admin
16-Jun-2025 17:36:50	Changed	/Services/EmailService/OutgoingAccount	maxSendablePerDay	100	max	admin
16-Jun-2025 17:37:25	Changed	/Services/OrionAlarmService/EmailRecipient	cc	arjun@ncpl.co|arjun		admin
16-Jun-2025 17:47:19	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/MFG_EQP/MFG_QC_LAB_REFRIGERATOR_1/proxyExt	conversion	Linear *0.40	Default	admin
16-Jun-2025 17:47:53	Changed	/Drivers/NiagaraNetwork/EMS_JACE/points/R$26D_EQP/R_and_D_Equipment_CHEMISTRY$20L2/proxyExt	conversion	Linear *0.40	Default	admin