

SOP 302: Fire and Gas Emergencies

1 Summary

This document establishes procedures for fire and gas leak emergencies at the Notre Dame Human Neuroimaging Center (ND-HNC), located in the Lower Level of:

Veldman Family Psychology Clinic
501 North Hill St.
South Bend, IN 46617

2 Scope

These policies apply to all investigators, research assistants, and staff who use the ND-HNC.

3 Definitions

TBD

4 Notes

None

5 Policies & Procedures

Procedures for building responses to fire and gas leak emergencies are detailed. For specific policies and procedures related to fire and gas emergencies in the MRI space and MRI Zones 3 and 4, please refer to SOP 101.5.1 and SOP 101.5.2.

5.1 Location of Fire Extinguishers and Fire Alarm Pulls

Fire extinguishers are located in hallways of common accessible areas in MRI Zones 1 and 2 in the following locations:

1. South staff entrance.
2. (The staff breakroom (B25)).
3. Outside B21 the Neuro Prep Room.

4. Across from the elevator bay in the reception area.
5. Laundry room near the loading dock.
6. (There is also a fire extinguisher in MRI Zone 3 (B15).)

Fire alarm pulls are located at exit points in MRI Zone 1:

1. North and south stairwells
2. South staff entrance
3. Loading dock doors

See Fig. 1

5.2 Fire or Gas Leak

1. Pull the nearest fire alarm.
2. Call 911 to notify the South Bend Fire Department (SBFD) and say: “We have [fire, smoke, gas] in the MRI Center at B05 Veldman Family Psychology Clinic, 501 North Hill Street”.
3. For small fires, fight fire only if:
 - 3.1 The Fire Department has been notified
 - 3.2 The fire is small and not spreading to other areas
 - 3.3 An escape route is available
 - 3.4 The fire extinguisher is in working condition
 - 3.5 You are trained to use the fire extinguisher
4. Gather in the designated Safe Meeting Spot: north-west corner of parking lot (Fig. 2)
5. If you are unable to evacuate, draw attention by yelling out.

6 Figures



Figure 1: VFPC fire extinguishers and alarm pulls.



Figure 2: VFPC rendezvous location.