

Modbus Number	Download Order	Parameter	Page	Menu>Pathway	Read/Write	Range (value in decimal to send via Modbus)
900	1	PID Units	Setup	System	r/w	(0) US (Reset/Rate). (1) SI (Integral/Derivative)
901	2	°F or °C	Setup	System	r/w	(0) °F, (1) °C
452	3	Maximum Transfer Heat	Setup	System	r/w	(0 to 1000)% in tenths
453	4	Maximum Transfer Cool	Setup	System	r/w	(-1000 to 0)% in tenths
454	5	Manual to Auto Transfer	Setup	System	r/w	(0) Restore Set Point, (1) Reverse Bumpless
304	6	Autotune Set Point	Setup	System	r/w	(50 to 150)%
880	7	Failure Mode	Setup	System	r/w	(0) Bumpless Transfer, (1) Fixed
						(0 to 1000)% in tenths. 0% to High Power Limit [heat only or cool only], Cool High Power Limit to Heat High Power Limit [heat/cool or cool/heat] if Failure Mode (Setup > System) is set to Fixed
903	8	Input 1 Fail	Setup	System	r/w	
904	9	Open Loop Detect	Setup	System	r/w	(0) Off, (1) On
600	10	Sensor	Setup	Analog Input 1	r/w	(0) Thermocouple, (1) RTD, (2) Process
						(0) J, (1) K, (2) T, (3) E, (4) N, (5) C, (6) D, (7) PT2, (8) R, (9) S, (10) B, (11) JIS, (12) DIN, (13) 4 to 20mA, (14) 0 to 20mA, (15) 0 to 5V, (16) 1 to 5V, (17) 0 to 10V, (18) 0 to 50mV
601	11	Type	Setup	Analog Input 1	r/w	
608	12	Units	Setup	Analog Input 1	r/w	(0) Temperature, (1) Units
3070	13	Units (char 1)	Setup	Analog Input 1	r/w	(32) space, (37) %, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]
3071	14	Units (char 2)	Setup	Analog Input 1	r/w	(32) space, (37) %, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]
3072	15	Units (char 3)	Setup	Analog Input 1	r/w	(32) space, (37) %, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]
606	16	Decimal	Setup	Analog Input 1	r/w	(0) 0, (1) 0.0, (2) 0.00 [process], (3) 0.000 [process]
680	17	Scale Low	Setup	Analog Input 1	r/w	Depends on sensor and decimal point selection.
681	18	Scale High	Setup	Analog Input 1	r/w	Depends on sensor and decimal point selection.
602	19	Set Point Low Limit	Setup	Analog Input 1	r/w	Depends on Sensor
603	20	Set Point High Limit	Setup	Analog Input 1	r/w	Depends on Sensor
5572	21	Offset Type	Setup	Analog Input 1	r/w	(0) Single Linear, (1) Multiple Point
605	22	Calibration Offset Value	Setup	Analog Input 1	r/w	(Set Point Low Limit to Set Point High Limit)
5566	23	Clear Input 1 Offsets	Setup	Analog Input 1	r/w	(0) No, (1) Yes
5506	24	Offset Point 01	Setup	Analog Input 1	r/w	(-19999 to 30000) or to Input Offset 2 Value - 1
5536	25	Offset Value 01	Setup	Analog Input 1	r/w	(-1000 to 1000) degrees or units
5507	26	Offset Point 02	Setup	Analog Input 1	r/w	(-19999 to 30000) or Input Offset 1 Value + 1 to Input Offset 3 Value - 1
5537	27	Offset Value 02	Setup	Analog Input 1	r/w	(-1000 to 1000) degrees or units
5508	28	Offset Point 03	Setup	Analog Input 1	r/w	(-19999 to 30000) or Input Offset 2 Value + 1 to Input Offset 4 Value - 1
5538	29	Offset Value 03	Setup	Analog Input 1	r/w	(-1000 to 1000) degrees or units
5509	30	Offset Point 04	Setup	Analog Input 1	r/w	(-19999 to 30000) or Input Offset 3 Value + 1 to Input Offset 5 Value - 1
5539	31	Offset Value 04	Setup	Analog Input 1	r/w	(-1000 to 1000) degrees or units
5510	32	Offset Point 05	Setup	Analog Input 1	r/w	(-19999 to 30000) or Input Offset 4 Value + 1 to Input Offset 6 Value - 1
5540	33	Offset Value 05	Setup	Analog Input 1	r/w	(-1000 to 1000) degrees or units
5511	34	Offset Point 06	Setup	Analog Input 1	r/w	(-19999 to 30000) or Input Offset 5 Value + 1 to Input Offset 7 Value - 1
5541	35	Offset Value 06	Setup	Analog Input 1	r/w	(-1000 to 1000) degrees or units
5512	36	Offset Point 07	Setup	Analog Input 1	r/w	(-19999 to 30000) or Input Offset 6 Value + 1 to Input Offset 8 Value - 1
5542	37	Offset Value 07	Setup	Analog Input 1	r/w	(-1000 to 1000) degrees or units
5513	38	Offset Point 08	Setup	Analog Input 1	r/w	(-19999 to 30000) or Input Offset 7 Value + 1 to Input Offset 9 Value - 1
5543	39	Offset Value 08	Setup	Analog Input 1	r/w	(-1000 to 1000) degrees or units
5514	40	Offset Point 09	Setup	Analog Input 1	r/w	(-19999 to 30000) or Input Offset 8 Value + 1 to Input Offset 10 Value - 1
5544	41	Offset Value 09	Setup	Analog Input 1	r/w	(-1000 to 1000) degrees or units
5515	42	Offset Point 10	Setup	Analog Input 1	r/w	(-19999 to 30000) or Input Offset 9 Value + 1 to 30000
5545	43	Offset Value 10	Setup	Analog Input 1	r/w	(-1000 to 1000) degrees or units
604	44	Filter Time	Setup	Analog Input 1	r/w	(-600 to 600) in tenths of seconds
607	45	Error Latch	Setup	Analog Input 1	r/w	(0) Self Clear, (1) Latch
5569	46	Square Root	Setup	Analog Input 1	r/w	(0) Off, (1) On
610	47	Sensor	Setup	Analog Input 2	r/w	(0) Thermocouple, (1) RTD, (2) Process, (4) Off
						(0) J, (1) K, (2) T, (3) E, (4) N, (5) C, (6) D, (7) PT2, (8) R, (9) S, (10) B, (11) JIS, (12) DIN, (13) 4 to 20mA, (14) 0 to 20mA, (15) 0 to 5V, (16) 1 to 5V, (17) 0 to 10V, (18) 0 to 50mV
611	48	Type	Setup	Analog Input 2	r/w	
618	49	Units	Setup	Analog Input 2	r/w	(0) Temperature, (1) Units
3073	50	Units (char 1)	Setup	Analog Input 2	r/w	(32) space, (37) %, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]
3074	51	Units (char 2)	Setup	Analog Input 2	r/w	(32) space, (37) %, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]
3075	52	Units (char 3)	Setup	Analog Input 2	r/w	(32) space, (37) %, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]
616	53	Decimal	Setup	Analog Input 2	r/w	(0) 0, (1) 0.0, (2) 0.00 [process], (3) 0.000 [process]
682	54	Scale Low	Setup	Analog Input 2	r/w	Depends on sensor and decimal point selection.
683	55	Scale High	Setup	Analog Input 2	r/w	Depends on sensor and decimal point selection.
612	56	Set Point Low Limit	Setup	Analog Input 2	r/w	Depends on Sensor
613	57	Set Point High Limit	Setup	Analog Input 2	r/w	Depends on Sensor
5573	58	Offset Type	Setup	Analog Input 2	r/w	(0) Single Linear, (1) Multiple Point
615	59	Calibration Offset Value	Setup	Analog Input 2	r/w	(Set Point Low Limit to Set Point High Limit)
5567	60	Clear Input 2 Offsets	Setup	Analog Input 2	r/w	(0) No, (1) Yes
5516	61	Offset Point 01	Setup	Analog Input 2	r/w	(-19999 to 30000) or to Input Offset 2 Value - 1

5546	62	Offset Value 01	Setup	Analog Input 2	r/w	(-1000 to 1000) degrees or units	
5517	63	Offset Point 02	Setup	Analog Input 2	r/w	(-19999 to 30000) or Input Offset 1 Value + 1 to Input Offset 3 Value - 1	
5547	64	Offset Value 02	Setup	Analog Input 2	r/w	(-1000 to 1000) degrees or units	
5518	65	Offset Point 03	Setup	Analog Input 2	r/w	(-19999 to 30000) or Input Offset 2 Value + 1 to Input Offset 4 Value - 1	
5548	66	Offset Value 03	Setup	Analog Input 2	r/w	(-1000 to 1000) degrees or units	
5519	67	Offset Point 04	Setup	Analog Input 2	r/w	(-19999 to 30000) or Input Offset 3 Value + 1 to Input Offset 5 Value - 1	
5549	68	Offset Value 04	Setup	Analog Input 2	r/w	(-1000 to 1000) degrees or units	
5520	69	Offset Point 05	Setup	Analog Input 2	r/w	(-19999 to 30000) or Input Offset 4 Value + 1 to Input Offset 6 Value - 1	
5550	70	Offset Value 05	Setup	Analog Input 2	r/w	(-1000 to 1000) degrees or units	
5521	71	Offset Point 06	Setup	Analog Input 2	r/w	(-19999 to 30000) or Input Offset 5 Value + 1 to Input Offset 7 Value - 1	
5551	72	Offset Value 06	Setup	Analog Input 2	r/w	(-1000 to 1000) degrees or units	
5522	73	Offset Point 07	Setup	Analog Input 2	r/w	(-19999 to 30000) or Input Offset 6 Value + 1 to Input Offset 8 Value - 1	
5552	74	Offset Value 07	Setup	Analog Input 2	r/w	(-1000 to 1000) degrees or units	
5523	75	Offset Point 08	Setup	Analog Input 2	r/w	(-19999 to 30000) or Input Offset 7 Value + 1 to Input Offset 9 Value - 1	
5553	76	Offset Value 08	Setup	Analog Input 2	r/w	(-1000 to 1000) degrees or units	
5524	77	Offset Point 09	Setup	Analog Input 2	r/w	(-19999 to 30000) or Input Offset 8 Value + 1 to Input Offset 10 Value - 1	
5554	78	Offset Value 09	Setup	Analog Input 2	r/w	(-1000 to 1000) degrees or units	
5525	79	Offset Point 10	Setup	Analog Input 2	r/w	(-19999 to 30000) or Input Offset 9 Value + 1 to 30000	
5555	80	Offset Value 10	Setup	Analog Input 2	r/w	(-1000 to 1000) degrees or units	
614	81	Filter Time	Setup	Analog Input 2	r/w	(-600 to 600) in tenths of seconds	
617	82	Error Latch	Setup	Analog Input 2	r/w	(0) Self Clear, (1) Latch	
5570	83	Square Root	Setup	Analog Input 2	r/w	(0) Off, (1) On	
1140	84	Control Type	Setup	Analog Input 2	r/w	(0) Normal, (3) Remote, (4) Alternate	
620	85	Sensor	Setup	Analog Input 3	r/w	(0) Thermocouple, (1) RTD, (2) Process, (3) Slidewire, (4) Off	
621	86	Type	Setup	Analog Input 3	r/w	(0) J, (1) K, (2) T, (3) E, (4) N, (5) C, (6) D, (7) PT2, (8) R, (9) S, (10) B, (11) JIS, (12) DIN, (13) 4 to 20mA, (14) 0 to 20mA, (15) 0 to 5V, (16) 1 to 5V, (17) 0 to 10V, (18) 0 to 50mV	
628	87	Units	Setup	Analog Input 3	r/w	(0) Temperature, (1) Units	
3076	88	Units (char 1)	Setup	Analog Input 3	r/w	(32) space, (37) %, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3077	89	Units (char 2)	Setup	Analog Input 3	r/w	(32) space, (37) %, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3078	90	Units (char 3)	Setup	Analog Input 3	r/w	(32) space, (37) %, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
626	91	Decimal	Setup	Analog Input 3	r/w	(0) 0, (1) 0.0, (2) 0.00 [process], (3) 0.000 [process]	
684	92	Scale Low	Setup	Analog Input 3	r/w	Depends on sensor and decimal point selection.	
685	93	Scale High	Setup	Analog Input 3	r/w	Depends on sensor and decimal point selection.	
622	94	Set Point Low Limit	Setup	Analog Input 3	r/w	Depends on Sensor	
623	95	Set Point High Limit	Setup	Analog Input 3	r/w	Depends on Sensor	
5574	96	Offset Type	Setup	Analog Input 3	r/w	(0) Single Linear, (1) Multiple Point	
625	97	Calibration Offset Value	Setup	Analog Input 3	r/w	(Set Point Low Limit to Set Point High Limit)	
5568	98	Clear Input 3 Offsets	Setup	Analog Input 3	r/w	(0) No, (1) Yes	
5526	99	Offset Point 01	Setup	Analog Input 3	r/w	(-19999 to 30000) or to Input Offset 2 Value - 1	
5556	100	Offset Value 01	Setup	Analog Input 3	r/w	(-1000 to 1000) degrees or units	
5527	101	Offset Point 02	Setup	Analog Input 3	r/w	(-19999 to 30000) or Input Offset 1 Value + 1 to Input Offset 3 Value - 1	
5557	102	Offset Value 02	Setup	Analog Input 3	r/w	(-1000 to 1000) degrees or units	
5528	103	Offset Point 03	Setup	Analog Input 3	r/w	(-19999 to 30000) or Input Offset 2 Value + 1 to Input Offset 4 Value - 1	
5558	104	Offset Value 03	Setup	Analog Input 3	r/w	(-1000 to 1000) degrees or units	
5529	105	Offset Point 04	Setup	Analog Input 3	r/w	(-19999 to 30000) or Input Offset 3 Value + 1 to Input Offset 5 Value - 1	
5559	106	Offset Value 04	Setup	Analog Input 3	r/w	(-1000 to 1000) degrees or units	
5530	107	Offset Point 05	Setup	Analog Input 3	r/w	(-19999 to 30000) or Input Offset 4 Value + 1 to Input Offset 6 Value - 1	
5560	108	Offset Value 05	Setup	Analog Input 3	r/w	(-1000 to 1000) degrees or units	
5531	109	Offset Point 06	Setup	Analog Input 3	r/w	(-19999 to 30000) or Input Offset 5 Value + 1 to Input Offset 7 Value - 1	
5561	110	Offset Value 06	Setup	Analog Input 3	r/w	(-1000 to 1000) degrees or units	
5532	111	Offset Point 07	Setup	Analog Input 3	r/w	(-19999 to 30000) or Input Offset 6 Value + 1 to Input Offset 8 Value - 1	
5562	112	Offset Value 07	Setup	Analog Input 3	r/w	(-1000 to 1000) degrees or units	
5533	113	Offset Point 08	Setup	Analog Input 3	r/w	(-19999 to 30000) or Input Offset 7 Value + 1 to Input Offset 9 Value - 1	
5563	114	Offset Value 08	Setup	Analog Input 3	r/w	(-1000 to 1000) degrees or units	
5534	115	Offset Point 09	Setup	Analog Input 3	r/w	(-19999 to 30000) or Input Offset 8 Value + 1 to Input Offset 10 Value - 1	
5564	116	Offset Value 09	Setup	Analog Input 3	r/w	(-1000 to 1000) degrees or units	
5535	117	Offset Point 10	Setup	Analog Input 3	r/w	(-19999 to 30000) or Input Offset 9 Value + 1 to 30000	
5565	118	Offset Value 10	Setup	Analog Input 3	r/w	(-1000 to 1000) degrees or units	
624	119	Filter Time	Setup	Analog Input 3	r/w	(-600 to 600) in tenths of seconds	
627	120	Error Latch	Setup	Analog Input 3	r/w	(0) Self Clear, (1) Latch	
5571	121	Square Root	Setup	Analog Input 3	r/w	(0) Off, (1) On	
1141	122	Control Type	Setup	Analog Input 3	r/w	(0) Normal, (1) Ratio, (2) Differential, (3) Remote, (5) Cascade	
1915	123	Auto/Manual Slidewire Calibration	Setup	Analog Input 3	r/w	(0) Skip Calibration, (1) Automatic, (2) Manual	
1916	124	Slidewire Deadband	Setup	Analog Input 3	r/w	(3 to 1000)% in tenths	
1917	125	Slidewire Hysteresis	Setup	Analog Input 3	r/w	(0 to 1000)% in tenths	
1918	126	Slidewire Learn Closed	Setup	Analog Input 3	r/w	(Close the valve manually.)	
1919	127	Slidewire Learn Open	Setup	Analog Input 3	r/w	(Open the valve manually.)	
1925	128	Cascade	Setup	Analog Input 3	r/w	(0) Process Cascade, (1) Deviation Cascade	

1926	129	Cascade Low Deviation	Setup	Analog Input 3	r/w	(-19999 to -1) degrees or units	
1926	130	Cascade Low Range	Setup	Analog Input 3	r/w	<sensor range>	
1927	131	Cascade High Deviation	Setup	Analog Input 3	r/w	(1 to 9999) degrees or units	
1927	132	Cascade High Range	Setup	Analog Input 3	r/w	<sensor range>	
1923	133	Show "F or "C	Setup	System	r/w	(0) No, Upper Display, (1) Yes, Upper Display	
3050	134	Activate Message	Setup	Digital Input 1	r/w	(0) Message 1, (1) Message 2, (2) Message 3, (3) Message 4	
3060	135	Message Display Time	Setup	Digital Input 1	r/w	(0 to 999) seconds	
3000	136	Name (Char 01)	Setup	Digital Input 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3001	137	Name (Char 02)	Setup	Digital Input 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3002	138	Name (Char 03)	Setup	Digital Input 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3003	139	Name (Char 04)	Setup	Digital Input 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3004	140	Name (Char 05)	Setup	Digital Input 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3005	141	Name (Char 06)	Setup	Digital Input 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3006	142	Name (Char 07)	Setup	Digital Input 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3007	143	Name (Char 08)	Setup	Digital Input 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3008	144	Name (Char 09)	Setup	Digital Input 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3009	145	Name (Char 10)	Setup	Digital Input 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
1061	146	Condition	Setup	Digital Input 1	r/w	(0) Low, (1) High	
1060	147	Function	Setup	Digital Input 1	r/w	Off, (6) Dig SP, (7) Diff SP, (8) Dig Ratio SP, (9) Remote 2, (10) Remote 3, (11) Alt Ctl, (10) Man Ctl, (13) Rev Outs, (14) Act Messages, (15) Lock Auto/Man	
3051	148	Activate Message	Setup	Digital Input 2	r/w	(0) Message 1, (1) Message 2, (2) Message 3, (3) Message 4	
3061	149	Message Display Time	Setup	Digital Input 2	r/w	(0 to 999) seconds	
3010	150	Name (Char 01)	Setup	Digital Input 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3011	151	Name (Char 02)	Setup	Digital Input 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3012	152	Name (Char 03)	Setup	Digital Input 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3013	153	Name (Char 04)	Setup	Digital Input 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3014	154	Name (Char 05)	Setup	Digital Input 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3015	155	Name (Char 06)	Setup	Digital Input 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3016	156	Name (Char 07)	Setup	Digital Input 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3017	157	Name (Char 08)	Setup	Digital Input 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3018	158	Name (Char 09)	Setup	Digital Input 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3019	159	Name (Char 10)	Setup	Digital Input 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
1063	160	Condition	Setup	Digital Input 2	r/w	(0) Low, (1) High	
1062	161	Function	Setup	Digital Input 2	r/w	Off, (6) Dig SP, (7) Diff SP, (8) Dig Ratio SP, (9) Remote 2, (10) Remote 3, (11) Alt Ctl, (10) Man Ctl, (13) Rev Outs, (14) Act Messages, (15) Lock Auto/Man	
3052	162	Activate Message	Setup	Digital Input 3	r/w	(0) Message 1, (1) Message 2, (2) Message 3, (3) Message 4	
3062	163	Message Display Time	Setup	Digital Input 3	r/w	(0 to 999) seconds	
3020	164	Name (Char 01)	Setup	Digital Input 3	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3021	165	Name (Char 02)	Setup	Digital Input 3	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3022	166	Name (Char 03)	Setup	Digital Input 3	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3023	167	Name (Char 04)	Setup	Digital Input 3	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3024	168	Name (Char 05)	Setup	Digital Input 3	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3025	169	Name (Char 06)	Setup	Digital Input 3	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3026	170	Name (Char 07)	Setup	Digital Input 3	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3027	171	Name (Char 08)	Setup	Digital Input 3	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3028	172	Name (Char 09)	Setup	Digital Input 3	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3029	173	Name (Char 10)	Setup	Digital Input 3	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
1065	174	Condition	Setup	Digital Input 3	r/w	(0) Low, (1) High	
1064	175	Function	Setup	Digital Input 3	r/w	Off, (6) Dig SP, (7) Diff SP, (8) Dig Ratio SP, (9) Remote 2, (10) Remote 3, (11) Alt Ctl, (10) Man Ctl, (13) Rev Outs, (14) Act Messages, (15) Lock Auto/Man	
3053	176	Activate Message	Setup	Digital Input 4	r/w	(0) Message 1, (1) Message 2, (2) Message 3, (3) Message 4	
3063	177	Message Display Time	Setup	Digital Input 4	r/w	(0 to 999) seconds	
3030	178	Name (Char 01)	Setup	Digital Input 4	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3031	179	Name (Char 02)	Setup	Digital Input 4	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3032	180	Name (Char 03)	Setup	Digital Input 4	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3033	181	Name (Char 04)	Setup	Digital Input 4	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3034	182	Name (Char 05)	Setup	Digital Input 4	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3035	183	Name (Char 06)	Setup	Digital Input 4	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3036	184	Name (Char 07)	Setup	Digital Input 4	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3037	185	Name (Char 08)	Setup	Digital Input 4	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3038	186	Name (Char 09)	Setup	Digital Input 4	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
3039	187	Name (Char 10)	Setup	Digital Input 4	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
1067	188	Condition	Setup	Digital Input 4	r/w	(0) Low, (1) High	
1066	189	Function	Setup	Digital Input 4	r/w	Off, (6) Dig SP, (7) Diff SP, (8) Dig Ratio SP, (9) Remote 2, (10) Remote 3, (11) Alt Ctl, (10) Man Ctl, (13) Rev Outs, (14) Act Messages, (15) Lock Auto/Man	
700	190	Function	Setup	Control Output 1A	r/w	(1) Off, (2) Heat [reverse], (3) Cool [direct]	
509	191	Cycle Time Type	Setup	Control Output 1A	r/w	(0) Variable Burst, (1) Fixed Time	
506	192	Cycle Time Value	Setup	Control Output 1A	r/w	(1 to 600) in tenths of seconds	

701	193	Process	Setup	Control Output 1A	r/w	(0) 4 to 20mA, (1) 0 to 20mA, (2) 0 to 5V, (3) 1 to 5V, (4) 0 to 10V, (5) 20 to 4mA [reverse value]		
844	194	Duplex	Setup	Control Output 1A	r/w	(0) Off, (1) On		
714	195	High Power Limit	Setup	Control Output 1A	r/w	Low Limit+1 to (100)%		
715	196	Low Power Limit	Setup	Control Output 1A	r/w	(0)% to High Limit-1		
717	197	Function	Setup	Control Output 1B	r/w	(0) Off, (1) Heat [reverse], (2) Cool [direct]		
559	198	Cycle Time Type	Setup	Control Output 1B	r/w	(0) Variable Burst, (1) Fixed Time		
556	199	Cycle Time Value	Setup	Control Output 1B	r/w	(1 to 600) in tenths of seconds		
885	200	Boost Type	Setup	Control Output 1B	r/w	(0) Boost on Power, (1) Boost on Set Point		
881	201	Boost Power Mode	Setup	Control Output 1B	r/w	(0) Auto Only, (1) Auto/Manual		
882	202	Boost Set Point Type	Setup	Control Output 1B	r/w	(0) Process, (1) Deviation		
718	203	Process	Setup	Control Output 1B	r/w	(0) 4 to 20mA, (1) 0 to 20mA, (2) 0 to 5V, (3) 1 to 5V, (4) 0 to 10V, (5) 20 to 4mA [reverse value]		
731	204	High Power Limit	Setup	Control Output 1B	r/w	Low Limit+1 to (100)%		
732	205	Low Power Limit	Setup	Control Output 1B	r/w	(0)% to High Limit-1		
3200	206	Name (Char 01)	Setup	Alarm Output 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3201	207	Name (Char 02)	Setup	Alarm Output 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3202	208	Name (Char 03)	Setup	Alarm Output 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3203	209	Name (Char 04)	Setup	Alarm Output 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3204	210	Name (Char 05)	Setup	Alarm Output 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3205	211	Name (Char 06)	Setup	Alarm Output 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3206	212	Name (Char 07)	Setup	Alarm Output 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3207	213	Name (Char 08)	Setup	Alarm Output 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3208	214	Name (Char 09)	Setup	Alarm Output 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3209	215	Name (Char 10)	Setup	Alarm Output 1	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
702	216	Alarm Type	Setup	Alarm Output 1	r/w	(0) Off, (1) Process, (2) Deviation, (3) Maximum Rate		
716	217	Alarm Source	Setup	Alarm Output 1	r/w	(0) Input 1, (1) Input 2, (2) Input 3		
704	218	Latching	Setup	Alarm Output 1	r/w	(0) Alarm Self-clears, (1) Alarm Latches		
705	219	Silencing	Setup	Alarm Output 1	r/w	(0) No, (1) Yes		
703	220	Alarm Hysteresis	Setup	Alarm Output 1	r/w	(1 to 9999) degrees or units		
706	221	Alarm Sides	Setup	Alarm Output 1	r/w	(0) Both, (1) Low, (2) High		
707	222	Alarm Logic	Setup	Alarm Output 1	r/w	(0) Open on Alarm, (1) Close on Alarm		
708	223	Alarm Messages	Setup	Alarm Output 1	r/w	(0) Yes on Main Page, (1) No		
3210	224	Name (Char 01)	Setup	Alarm Output 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3211	225	Name (Char 02)	Setup	Alarm Output 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3212	226	Name (Char 03)	Setup	Alarm Output 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3213	227	Name (Char 04)	Setup	Alarm Output 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3214	228	Name (Char 05)	Setup	Alarm Output 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3215	229	Name (Char 06)	Setup	Alarm Output 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3216	230	Name (Char 07)	Setup	Alarm Output 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3217	231	Name (Char 08)	Setup	Alarm Output 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3218	232	Name (Char 09)	Setup	Alarm Output 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
3219	233	Name (Char 10)	Setup	Alarm Output 2	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
719	234	Alarm Type	Setup	Alarm Output 2	r/w	(0) Off, (1) Process, (2) Deviation, (3) Maximum Rate		
733	235	Alarm Source	Setup	Alarm Output 2	r/w	(0) Input 1, (1) Input 2, (2) Input 3		
721	236	Latching	Setup	Alarm Output 2	r/w	(0) Alarm Self-clears, (1) Alarm Latches		
722	237	Silencing	Setup	Alarm Output 2	r/w	(0) No, (1) Yes		
720	238	Alarm Hysteresis	Setup	Alarm Output 2	r/w	(1 to 9999) degrees or units		
723	239	Alarm Sides	Setup	Alarm Output 2	r/w	(0) Both, (1) Low, (2) High		
724	240	Alarm Logic	Setup	Alarm Output 2	r/w	(0) Open on Alarm, (1) Close on Alarm		
725	241	Alarm Messages	Setup	Alarm Output 2	r/w	(0) Yes on Main Page, (1) No		
709	242	Retransmit Source	Setup	Retransmit Output 1	r/w	(0) Off, (1) Input 1, (4) Set Point, (5) Channel 1 Power		
836	243	Analog Range	Setup	Retransmit Output 1	r/w	(0) 4 to 20mA, (1) 0 to 20mA, (2) 0 to 5V, (3) 1 to 5V, (4) 1 to 10V		
710	244	Low Scale	Setup	Retransmit Output 1	r/w	(-9999 to 9999) minimum sensor range		
711	245	High Scale	Setup	Retransmit Output 1	r/w	(-9999 to 9999) maximum sensor range		
712	246	Scale Offset	Setup	Retransmit Output 1	r/w	(-9999 to 9999) Range Low to Range High		
726	247	Retransmit Source	Setup	Retransmit Output 2	r/w	(0) Off, (1) Input 1, (4) Set Point, (5) Channel 1 Power		
837	248	Analog Range	Setup	Retransmit Output 2	r/w	(0) 4 to 20mA, (1) 0 to 20mA, (2) 0 to 5V, (3) 1 to 5V, (4) 1 to 10V		
727	249	Low Scale	Setup	Retransmit Output 2	r/w	(-9999 to 9999) minimum sensor range		
728	250	High Scale	Setup	Retransmit Output 2	r/w	(-9999 to 9999) maximum sensor range		
729	251	Scale Offset	Setup	Retransmit Output 2	r/w	(-9999 to 9999) Range Low to Range High		
1400	252	Parameter 01	Setup	Custom Main Page	r/w	0-No;1-In1;2-In1 Grf;3-In2;4-In2 Grf;5-In3;6-In3 Grf;7-Dig SP;8-Dig Dif;9-Dif SP;10-Set Dif;11-Dig Ratio;12-Ratio SP;13-Set Ratio;14-Rem SP2;15-Rem SP3;16-Tgt SP;17-Innr SP;18-SP1;19-SP1 Grf;20-1A%;21-1B%;22-1A Grf;23-1B Grf;24-Tune;25-Dig Ins;26-PID Set		
1401	253	Parameter 02	Setup	Custom Main Page	r/w	Dig Ratio;12-Ratio SP;13-Set Ratio;14-Rem SP2;15-Rem SP3;16-Tgt SP;17-Innr SP;18-SP1;19-SP1 Grf;20-1A%;21-1B%;22-1A Grf;23-1B Grf;24-Tune;25-Dig Ins;26-PID Set		
1402	254	Parameter 03	Setup	Custom Main Page	r/w	Dig Ratio;12-Ratio SP;13-Set Ratio;14-Rem SP2;15-Rem SP3;16-Tgt SP;17-Innr SP;18-SP1;19-SP1 Grf;20-1A%;21-1B%;22-1A Grf;23-1B Grf;24-Tune;25-Dig Ins;26-PID Set		

[illegible]

[illegible]

4781	506	Message 4 (Line 03, Char 01)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4782	507	Message 4 (Line 03, Char 02)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4783	508	Message 4 (Line 03, Char 03)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4784	509	Message 4 (Line 03, Char 04)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4785	510	Message 4 (Line 03, Char 05)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4786	511	Message 4 (Line 03, Char 06)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4787	512	Message 4 (Line 03, Char 07)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4788	513	Message 4 (Line 03, Char 08)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4789	514	Message 4 (Line 03, Char 09)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4790	515	Message 4 (Line 03, Char 10)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4791	516	Message 4 (Line 03, Char 11)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4792	517	Message 4 (Line 03, Char 12)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4793	518	Message 4 (Line 03, Char 13)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4794	519	Message 4 (Line 03, Char 14)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4795	520	Message 4 (Line 03, Char 15)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4796	521	Message 4 (Line 03, Char 16)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4797	522	Message 4 (Line 03, Char 17)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4801	523	Message 4 (Line 04, Char 01)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4802	524	Message 4 (Line 04, Char 02)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4803	525	Message 4 (Line 04, Char 03)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4804	526	Message 4 (Line 04, Char 04)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4805	527	Message 4 (Line 04, Char 05)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4806	528	Message 4 (Line 04, Char 06)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4807	529	Message 4 (Line 04, Char 07)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4808	530	Message 4 (Line 04, Char 08)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4809	531	Message 4 (Line 04, Char 09)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4810	532	Message 4 (Line 04, Char 10)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4811	533	Message 4 (Line 04, Char 11)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4812	534	Message 4 (Line 04, Char 12)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4813	535	Message 4 (Line 04, Char 13)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4814	536	Message 4 (Line 04, Char 14)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4815	537	Message 4 (Line 04, Char 15)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4816	538	Message 4 (Line 04, Char 16)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
4817	539	Message 4 (Line 04, Char 17)	Setup	Static Message	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]	
1910	540	Process Display	Setup	Process Display	r/w	(0) Input 1, (1) Alternating	
1911	541	Display Time	Setup	Process Display>Input 1	r/w	(0 to 999) seconds	
1912	542	Display Time	Setup	Process Display>Input 2	r/w	(1 to 999) seconds	
1913	543	Display Time	Setup	Process Display>Input 3	r/w	(2 to 999) seconds	
1914	544	LED Intensity	Setup	Process Display	r/w	(0 to 15)	
302	545	Alarm 1 Low Deviation	Operations	Alarm Set Points	r/w	(-19999 to -1) degrees or units	
302	546	Alarm 1 Low Set Point	Operations	Alarm Set Points	r/w	<per sensor> to Alarm 1 High Set Point	
302	547	Alarm 1 Maximum Low Rate	Operations	Alarm Set Points	r/w	(-19999) to Alarm 1 Maximum Rate High -1	
303	548	Alarm 1 High Deviation	Operations	Alarm Set Points	r/w	(1 to 20000) degrees or units	
303	549	Alarm 1 High Set Point	Operations	Alarm Set Points	r/w	<per sensor> to Alarm 1 Low Set Point	
303	550	Alarm 1 Maximum High Rate	Operations	Alarm Set Points	r/w	Alarm 1 Low Maximum Rate +1 to (30000)	
321	551	Alarm 2 Low Deviation	Operations	Alarm Set Points	r/w	(-9999 to -1) degrees or units	
321	552	Alarm 2 Low Set Point	Operations	Alarm Set Points	r/w	<per sensor> to Alarm 2 High Set Point	
321	553	Alarm 2 Maximum Low Rate	Operations	Alarm Set Points	r/w	(-19999) to Alarm 2 Maximum Rate High -1	
322	554	Alarm 2 High Deviation	Operations	Alarm Set Points	r/w	(1 to 20000) degrees or units	
322	555	Alarm 2 High Set Point	Operations	Alarm Set Points	r/w	<per sensor> to Alarm 2 Low Set Point	
322	556	Alarm 2 Maximum High Rate	Operations	Alarm Set Points	r/w	Alarm 2 Low Maximum Rate +1 to (30000)	
500	557	Proportional Band 1A	Operations	Edit PID>PID Set Channel 1>P	r/w	(0 to 30000) degrees or units	
501	558	Integral 1A	Operations	Edit PID>PID Set Channel 1>P	r/w	(0 to 9999) minutes in hundreths	
502	559	Reset 1A	Operations	Edit PID>PID Set Channel 1>P	r/w	(0 to 9999) minutes in hundreths	
503	560	Derivative 1A	Operations	Edit PID>PID Set Channel 1>P	r/w	(0 to 999) minutes in hundreths	
504	561	Rate 1A	Operations	Edit PID>PID Set Channel 1>P	r/w	(0 to 999) minutes in hundreths	
505	562	Dead Band 1A	Operations	Edit PID>PID Set Channel 1>P	r/w	(0 to 30000) degrees or units	
507	563	Hysteresis 1A	Operations	Edit PID>PID Set Channel 1>P	r/w	(1 to 30000) degrees or units	
550	564	Proportional Band 1B	Operations	Edit PID>PID Set Channel 1>P	r/w	(0 to 30000) degrees or units	
551	565	Integral 1B	Operations	Edit PID>PID Set Channel 1>P	r/w	(0 to 9999) minutes in hundreths	
552	566	Reset 1B	Operations	Edit PID>PID Set Channel 1>P	r/w	(0 to 9999) minutes in hundreths	
553	567	Derivative 1B	Operations	Edit PID>PID Set Channel 1>P	r/w	(0 to 999) minutes in hundreths	
554	568	Rate 1B	Operations	Edit PID>PID Set Channel 1>P	r/w	(0 to 999) minutes in hundreths	
555	569	Dead Band 1B	Operations	Edit PID>PID Set Channel 1>P	r/w	(0 to 30000) degrees or units	
557	570	Hysteresis 1B	Operations	Edit PID>PID Set Channel 1>P	r/w	(1 to 30000) degrees or units	
510	571	Proportional Band 1A	Operations	Edit PID>PID Set Channel 1>P	r/w	(0 to 30000) degrees or units	
511	572	Integral 1A	Operations	Edit PID>PID Set Channel 1>P	r/w	(0 to 9999) minutes in hundreths	
512	573	Reset 1A	Operations	Edit PID>PID Set Channel 1>P	r/w	(0 to 9999) minutes in hundreths	

[illegible]

2621	642	Integral 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2622	643	Reset 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2623	644	Derivative 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2624	645	Rate 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2625	646	Dead Band 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 30000) degrees or units	
2627	647	Hysteresis 1A	Operations	Edit PID > Cascade PID > PID	r/w	(1 to 30000) degrees or units	
2630	648	Proportional Band 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 30000) degrees or units	
2631	649	Integral 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2632	650	Reset 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2633	651	Derivative 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2634	652	Rate 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2635	653	Dead Band 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 30000) degrees or units	
2637	654	Hysteresis 1B	Operations	Edit PID > Cascade PID > PID	r/w	(1 to 30000) degrees or units	
2640	655	Proportional Band 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 30000) degrees or units	
2641	656	Integral 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2642	657	Reset 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2643	658	Derivative 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2644	659	Rate 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2645	660	Dead Band 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 30000) degrees or units	
2647	661	Hysteresis 1A	Operations	Edit PID > Cascade PID > PID	r/w	(1 to 30000) degrees or units	
2650	662	Proportional Band 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 30000) degrees or units	
2651	663	Integral 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2652	664	Reset 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2653	665	Derivative 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2654	666	Rate 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2655	667	Dead Band 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 30000) degrees or units	
2657	668	Hysteresis 1B	Operations	Edit PID > Cascade PID > PID	r/w	(1 to 30000) degrees or units	
2660	669	Proportional Band 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 30000) degrees or units	
2661	670	Integral 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2662	671	Reset 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2663	672	Derivative 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2664	673	Rate 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2665	674	Dead Band 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 30000) degrees or units	
2667	675	Hysteresis 1A	Operations	Edit PID > Cascade PID > PID	r/w	(1 to 30000) degrees or units	
2670	676	Proportional Band 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 30000) degrees or units	
2671	677	Integral 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2672	678	Reset 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2673	679	Derivative 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2674	680	Rate 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2675	681	Dead Band 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 30000) degrees or units	
2677	682	Hysteresis 1B	Operations	Edit PID > Cascade PID > PID	r/w	(1 to 30000) degrees or units	
2680	683	Proportional Band 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 30000) degrees or units	
2681	684	Integral 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2682	685	Reset 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2683	686	Derivative 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2684	687	Rate 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2685	688	Dead Band 1A	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 30000) degrees or units	
2687	689	Hysteresis 1A	Operations	Edit PID > Cascade PID > PID	r/w	(1 to 30000) degrees or units	
2690	690	Proportional Band 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 30000) degrees or units	
2691	691	Integral 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2692	692	Reset 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 9999) minutes in hundreths	
2693	693	Derivative 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2694	694	Rate 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 999) minutes in hundreths	
2695	695	Dead Band 1B	Operations	Edit PID > Cascade PID > PID	r/w	(0 to 30000) degrees or units	
2697	696	Hysteresis 1B	Operations	Edit PID > Cascade PID > PID	r/w	(1 to 30000) degrees or units	
1951	697	PID Crossover	Operations	none	r/w	(0) Off, (1) Process, (2) Set Point	
1961	698	PID Cross 1 to 2	Operations	none	r/w	(-19000 to 30000) degrees or units	
1962	699	PID Cross 2 to 3	Operations	none	r/w	(-19000 to 30000) degrees or units	
1963	700	PID Cross 3 to 4	Operations	none	r/w	(-19000 to 30000) degrees or units	
1964	701	PID Cross 4 to 5	Operations	none	r/w	(-19000 to 30000) degrees or units	
1100	702	Ramp to Set Point Mode	Operations	Ramp to Set Point	r/w	(0) Off, (1) Startup, (2) Startup or Change	
1102	703	Ramp to Set Point Scale	Operations	Ramp to Set Point	r/w	(0) Degrees per Minute, (1) Degrees per Hour	
1101	704	Ramp to Set Point Rate	Operations	Ramp to Set Point	r/w	(1 to 999) degrees or units per minute or hour	
883	705	Boost Power (1B)	Operations	Control Set Points	r/w	(0 to 1000)% in tenths	
884	706	Boost Delay Time (1B)	Operations	Control Set Points	r/w	(0 to 999) seconds	
309	707	Boost Set Point (1B)	Operations	Control Set Points	r/w	(-19,999 to 30,000) [deviation], Set Point Low Limit to Set Point High Limit [process]	
316	708	Remote/Local Set Point	Operations	Local/Remote Set Point	r/w	(0) Local Set Point, (1) Remote 2, (2) Remote 3	
308	709	Digital Set Point 1	Operations	Control Set Points	r/w	(SP Low Limit to SP High Limit)	

327	710	Digital Set Point 2	Operations	Control Set Points	r/w	(SP Low Limit to SP High Limit)		
346	711	Digital Set Point 3	Operations	Control Set Points	r/w	(SP Low Limit to SP High Limit)		
365	712	Digital Set Point 4	Operations	Control Set Points	r/w	(SP Low Limit to SP High Limit)		
314	713	Digital Differential Set Point 1	Operations	Control Set Points	r/w	(-19000 to 30000) degrees or units		
333	714	Digital Differential Set Point 2	Operations	Control Set Points	r/w	(-19000 to 30000) degrees or units		
352	715	Digital Differential Set Point 3	Operations	Control Set Points	r/w	(-19000 to 30000) degrees or units		
371	716	Digital Differential Set Point 4	Operations	Control Set Points	r/w	(-19000 to 30000) degrees or units		
315	717	Digital Ratio Set Point 1	Operations	Control Set Points	r/w	(0 to 30000)%		
334	718	Digital Ratio Set Point 2	Operations	Control Set Points	r/w	(0 to 30000)%		
353	719	Digital Ratio Set Point 3	Operations	Control Set Points	r/w	(0 to 30000)%		
372	720	Digital Ratio Set Point 4	Operations	Control Set Points	r/w	(0 to 30000)%		
300	721	Set Point 1	Main	None	r/w	Value		
1922	722	Cascade Internal Set Point	Main	None	r	For Process (Cascade Low Range to Cascade High Range) , For Deviation (Cascade Low Dev. To Cascade High Dev.)		
298	723	Control Set Point	Main	None	r	(Set Point Low Limit to Set Point High Limit)		
299	724	Set Differential Value	Main	None	r/w	(Set Point Low Limit to Set Point High Limit)		
301	725	Set Ratio Value	Main	None	r/w	(Set Point Low Limit to Set Point High Limit)		
305	726	Autotune PID	Operations	Autotune PID	r/w	(0) Tune Off, (1) PID Set 1, (2) PID Set 2, (3) PID Set 3, (4) PID Set 4, (5) PID Set 5		
307	727	Autotune PID Type	Operations	Autotune PID	r/w	(0) Heat Only, (1) Cool Only, (3) Heat and Cool		
343	728	Cascade Autotune	Operations	Autotune PID	r/w	(0) Inner Loop, (1) Outer Loop		
1330	729	Set/Change Password (Char 1)	Factory	Set Lockout	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
1331	730	Set/Change Password (Char 2)	Factory	Set Lockout	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
1332	731	Set/Change Password (Char 3)	Factory	Set Lockout	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
1333	732	Set/Change Password (Char 4)	Factory	Set Lockout	r/w	(32) space, (48 to 57) 0 to 9, (65 to 90) A to Z [decimal value for ASCII char]		
1300	733	Set Point	Factory	Set Lockout	r/w	(0) Full Access, (1) Read Only		
1306	734	Operations, Autotune PID	Factory	Set Lockout	r/w	(0) Full Access, (1) Read Only, (2) Password, (3) Hidden		
1307	735	Operations, Edit PID	Factory	Set Lockout	r/w	(0) Full Access, (1) Read Only, (2) Password, (3) Hidden		
1308	736	Operations, Alarm Set Point	Factory	Set Lockout	r/w	(0) Full Access, (1) Read Only, (2) Password, (3) Hidden		
1302	737	Setup Page	Factory	Set Lockout	r/w	(0) Full Access, (1) Read Only, (2) Password, (3) Hidden		
1303	738	Factory Page	Factory	Set Lockout	r/w	(0) Full Access, (1) Read Only, (2) Password		
1316	739	Operations, PID Crossover	Factory	Set Lockout	r/w	(0) Full Access, (1) Read Only, (2) Password, (3) Hidden		
1317	740	Operations, Ramp Set Point	Factory	Set Lockout	r/w	(0) Full Access, (1) Read Only, (2) Password, (3) Hidden		
1318	741	Operations, Control Set Point	Factory	Set Lockout	r/w	(0) Full Access, (1) Read Only, (2) Password, (3) Hidden		
1939	742	Operations, Remote Set Point	Factory	Set Lockout	r/w	(0) Full Access, (1) Read Only, (2) Password, (3) Hidden		
25	743	Save Changes to EE	none	Save	w	(0) Save		
1601		Restore Input 1 Calibration	Factory	Calibration	w	(0) Yes		
1601		Restore Input 2 Calibration	Factory	Calibration	w	(1) Yes		
1601		Restore Input 3 Calibration	Factory	Calibration	w	(2) Yes		
1603		0.000V	Factory	Calibration > Calibrate Input 1	r/w	(8) Yes		
1603		0.00mV Thermocouple	Factory	Calibration > Calibrate Input 1	r/w	(1) Yes		
1603		10.000V	Factory	Calibration > Calibrate Input 1	r/w	(9) Yes		
1603		1000 Ohms	Factory	Calibration > Calibrate Input 1	r/w	(7) Yes		
1603		15.0 Ohms	Factory	Calibration > Calibrate Input 1	r/w	(6) Yes		
1603		20.000mA	Factory	Calibration > Calibrate Input 1	r/w	(11) Yes		
1603		32°F Type J	Factory	Calibration > Calibrate Input 1	r/w	(3) Yes		
1603		380.0 Ohms	Factory	Calibration > Calibrate Input 1	r/w	(7) Yes		
1603		4.000mA	Factory	Calibration > Calibrate Input 1	r/w	(10) Yes		
1603		50.00mV Thermocouple	Factory	Calibration > Calibrate Input 1	r/w	(2) Yes		
1603		Ground	Factory	Calibration > Calibrate Input 1	r/w	(4) Yes		
1603		Lead	Factory	Calibration > Calibrate Input 1	r/w	(5) Yes		
1608		0.000V	Factory	Calibration > Calibrate Input 2	r/w	(8) Yes		
1608		0.00mV Thermocouple	Factory	Calibration > Calibrate Input 2	r/w	(1) Yes		
1608		10.000V	Factory	Calibration > Calibrate Input 2	r/w	(9) Yes		
1608		1000 Ohms	Factory	Calibration > Calibrate Input 2	r/w	(7) Yes		
1608		15.0 Ohms	Factory	Calibration > Calibrate Input 2	r/w	(6) Yes		
1608		20.000mA	Factory	Calibration > Calibrate Input 2	r/w	(11) Yes		
1608		32°F Type J	Factory	Calibration > Calibrate Input 2	r/w	(3) Yes		
1608		380.0 Ohms	Factory	Calibration > Calibrate Input 2	r/w	(7) Yes		
1608		4.000mA	Factory	Calibration > Calibrate Input 2	r/w	(10) Yes		
1608		50.00mV Thermocouple	Factory	Calibration > Calibrate Input 2	r/w	(2) Yes		
1608		Ground	Factory	Calibration > Calibrate Input 2	r/w	(4) Yes		
1608		Lead	Factory	Calibration > Calibrate Input 2	r/w	(5) Yes		
1613		0.000V	Factory	Calibration > Calibrate Input 3	r/w	(8) Yes		
1613		0.00mV Thermocouple	Factory	Calibration > Calibrate Input 3	r/w	(1) Yes		
1613		10.000V	Factory	Calibration > Calibrate Input 3	r/w	(9) Yes		
1613		1000 Ohms	Factory	Calibration > Calibrate Input 3	r/w	(7) Yes		
1613		15.0 Ohms	Factory	Calibration > Calibrate Input 3	r/w	(6) Yes		
1613		20.000mA	Factory	Calibration > Calibrate Input 3	r/w	(11) Yes		
1613		32°F Type J	Factory	Calibration > Calibrate Input 3	r/w	(3) Yes		

1613	380.0 Ohms	Factory	Calibration > Calibrate Input 3	r/w	(7) Yes		
1613	4.000mA	Factory	Calibration > Calibrate Input 3	r/w	(10) Yes		
1613	50.00mV Thermocouple	Factory	Calibration > Calibrate Input 3	r/w	(2) Yes		
1613	Ground	Factory	Calibration > Calibrate Input 3	r/w	(4) Yes		
1613	Lead	Factory	Calibration > Calibrate Input 3	r/w	(5) Yes		
1606	1.000V	Factory	Calibration > Process Output 1	r/w	0.000 to 3.000V		
1607	10.000V	Factory	Calibration > Process Output 1	r/w	0.000 to 12.000V		
1605	20.000mA	Factory	Calibration > Process Output 1	r/w	0.000 to 24.000mA		
1604	4.000mA	Factory	Calibration > Process Output 1	r/w	0.000mA to 6.000mA		
1611	1.000V	Factory	Calibration > Process Output 1	r/w	0.000 to 3.000V		
1612	10.000V	Factory	Calibration > Process Output 1	r/w	0.000 to 12.000V		
1610	20.000mA	Factory	Calibration > Process Output 1	r/w	0.000 to 24.000mA		
1609	4.000mA	Factory	Calibration > Process Output 1	r/w	0.000mA to 6.000mA		
1626	1.000V	Factory	Calibration > Retransmit Output	r/w	0.000 to 3.000V		
1627	10.000V	Factory	Calibration > Retransmit Output	r/w	0.000 to 12.000V		
1625	20.000mA	Factory	Calibration > Retransmit Output	r/w	0.000 to 24.000mA		
1624	4.000mA	Factory	Calibration > Retransmit Output	r/w	0.000mA to 6.000mA		
1631	1.000V	Factory	Calibration > Retransmit Output	r/w	0.000 to 3.000V		
1632	10.000V	Factory	Calibration > Retransmit Output	r/w	0.000 to 12.000V		
1630	20.000mA	Factory	Calibration > Retransmit Output	r/w	0.000 to 24.000mA		
1629	4.000mA	Factory	Calibration > Retransmit Output	r/w	0.000mA to 6.000mA		
1501	CJC1 AtoD	Factory	Diagnostic	r	HHHH		
1500	CJC1 Temp	Factory	Diagnostic	r	xx.x		
1532	CJC2 AtoD	Factory	Diagnostic	r	HHHH		
1531	CJC2 Temp	Factory	Diagnostic	r	xx.x		
1532	CJC3 AtoD	Factory	Diagnostic	r	HHHH		
1531	CJC3 Temp	Factory	Diagnostic	r	xx.x		
8	Input 1	Factory	Diagnostic	r	(7) Univ		
1504	Input 1 A to D	Factory	Diagnostic	r	HHHH		
9	Input 2	Factory	Diagnostic	r	(7) Univ		
1505	Input 2 A to D	Factory	Diagnostic	r	HHHH		
10	Input 3	Factory	Diagnostic	r	(7) Univ		
1506	Input 3 A to D	Factory	Diagnostic	r	HHHH		
1515	Line Frequency	Factory	Diagnostic	r	xx		
5	Manufacturing Date	Factory	Diagnostic	r	xxxx		
0	Model	Factory	Diagnostic	r	F4Px-xxxx-xxxx		
16	Output 1A	Factory	Diagnostic	r	(0) None, (1) Mechanical Relay, (2) SSR, (3) DC, (4) Process		
17	Output 1B	Factory	Diagnostic	r	(0) None, (1) Mechanical Relay, (2) SSR, (3) DC, (4) Process		
20	Retransmit 1	Factory	Diagnostic	r	(0) None, (4) Process		
21	Retransmit 2	Factory	Diagnostic	r	(0) None, (4) Process		
4	Revision	Factory	Diagnostic	r	0.00 to 9.99		
1	Serial Number (first part)	Factory	Diagnostic	r	(0 to ?)		
2	Serial Number (second part)	Factory	Diagnostic	r	(000000 to 999999)		
3	Software Number	Factory	Diagnostic	r	(0 to 99)		
1315	Clear Locks	Factory	Set Lockout	r/w	(0) Yes		
1319	Remote/Local Set Point Operation	Factory	Set Lockout	r/w	(0) Full, (1) Read Only, (2) Pass, (3) Hidden		
1602	Full Defaults	Factory	Test	w	(800) Yes		
1514	Test Outputs	Factory	Test	w	(0) All Off, (1) Output 1A, (2) Output 1B, (5) Retransmit 1, (6) Retransmit 2, (7) Alarm 1, (8) Alarm 2, (9) Alarm 3		
1513	Display Test	Factory	Test	w	(1) Perform Display Test		
312	Clear Alarm 1	none	Key Press Simulation	w	write any value		
331	Clear Alarm 2	none	Key Press Simulation	w	write any value		
311	Clear Error 1	none	Key Press Simulation	w	write any value		
330	Clear Error 2	none	Key Press Simulation	w	write any value		
349	Clear Error 3	none	Key Press Simulation	w	write any value		
313	Silence Alarm 1	none	Key Press Simulation	w	(0 to 9999)		
332	Silence Alarm 2	none	Key Press Simulation	w	(0 to 9999)		
103	% Power Output 1A	none	Status	r	Value		
107	% Power Output 1B	none	Status	r	Value		
102	Alarm 1	none	Status	r	(0) Off, (1) Alarm High, (2) Alarm Low		
106	Alarm 2	none	Status	r	(0) Off, (1) Alarm High, (2) Alarm Low		
200	Auto/Manual Mode	none	Status	r	(1) Auto Mode, (2) Manual		
201	Digital Input 1	none	Status	r	(0) Low, (1) High		
213	Digital Input 2	none	Status	r	(0) Low, (1) High		
225	Digital Input 3	none	Status	r	(0) Low, (1) High		
237	Digital Input 4	none	Status	r	(0) Low, (1) High		
101	Input 1 Error	none	Status	r	(0) None, (1) AtoD Under Flow, (2) Sensor Under Range, (3) Sensor Over Range, (4) AtoD Over Flow, (5) AtoD Timeout, (6) Open Loop		
210	Input 1 Open Loop	none	Status	r	(0) Off, (1) On		

100	Input 1 Value	none	Status	r	xx	
209	System Error	none	Status	r	xx	
305	Cascade Inner Loop	Operations	Autotune PID	r/w	(0) Tune Off, (1) PID Set 1, (2) PID Set 2, (3) PID Set 3, (4) PID Set 4, (5) PID Set 5	