EZ-ZONE ST Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Analog Input x	AI	always	1 - 2	Instance 1= always; Instance 2 if 4th digit of model number is an "L"		Analog Input Value	AIn	always	4043
Operations	oPEr	Analog Input x	AI		1 - 2			Input Error	iEr	always	4002
Operations	oPEr	Analog Input x	AI		1 - 2			Calibration Offset	iCA	always	4012
Operations	oPEr	Digital I/O x	dIO	If 2nd digit of PN = B, E, D, or C	5 - 6	always		Output State	doS	always	6007
Operations	oPEr	Digital I/O x	dIO		5			Event Status	EnS	always	10005
Operations	oPEr	Digital I/O x	dIO		6			Event Status	EnS	always	10005
Operations	oPEr	Limit 1	LIM1	If 3rd digit of PN = L	1	always		Limit Low Set Point	LLS	always	12003
Operations	oPEr	Limit 1	LIM1		1			Limit High Set Point	LhS	always	12004
Operations	oPEr	Limit 1	LIM1		1			Limit Status	LSt	always	12013
Operations	oPEr	Monitor 1	M1on	always	1	always		Control Mode Active	CMA	always	8002
Operations	oPEr	Monitor 1	M1on		1			Heat Power	hPr	always	8011
Operations	oPEr	Monitor 1	M1on		1			Cool Power	CPr	always	8014
Operations	oPEr	Monitor 1	M1on		1			Closed-Loop Set Point	CSP	always	8029
Operations	oPEr	Monitor 1	M1on		1			Process Value Active	PuA	always	8031
Operations	oPEr	Control Loop 1	LooP	always	1	always		Control Mode	CM	always	8001
Operations	oPEr	Control Loop 1	LooP		1			Autotune Set Point	AtSP	always	8025
Operations	oPEr	Control Loop 1	LooP		1			Autotune	AUt	always	8026
Operations	oPEr	Control Loop 1	LooP		1			Closed-Loop Set Point	CSP	always	7001
Operations	oPEr	Control Loop 1	LooP		1			Idle Set Point	idS	always	7009
Operations	oPEr	Control Loop 1	LooP		1			Heat Proportional Band	hPb	always	8009
Operations	oPEr	Control Loop 1	LooP		1			Heat Hysteresis	hHy	always	8010
Operations	oPEr	Control Loop 1	LooP		1			Cool Proportional Band	CPb	always	8012
Operations	oPEr	Control Loop 1	LooP		1			Cool Hysteresis	CHy	always	8013
Operations	oPEr	Control Loop 1	LooP		1			Time Integral	ti	always	8006
Operations	oPEr	Control Loop 1	LooP		1			Time Derivative	td	always	8007
Operations	oPEr	Control Loop 1	LooP		1			Dead Band	db	always	8008
Operations	oPEr	Control Loop 1	LooP		1			Open Loop Set Point	oSP	always	7002
Operations	oPEr	Alarm x	ALM1	always	1 - 2	always		Alarm Low Set Point	ALo	always	9002
Operations	oPEr	Alarm x	ALM1		1 - 2			Alarm High Set Point	Ahi	always	9001
Operations	oPEr	Current 1	CUrr	If 2nd digit of PN = P, E, J, or C	1	always		Current High Set Point	Chi	always	15008
Operations	oPEr	Current 1	CUrr		1			Current Low Set Point	CLo	always	15009
Operations	oPEr	Current 1	CUrr		1			Current Read	CUr	always	15007
Operations	oPEr	Current 1	CUrr		1			Current Error	CEr	always	15002
Operations	oPEr	Current 1	CUrr		1			Heater Error	hEr	always	15003
Operations	oPEr	Current 1	CUrr		1			Line Voltage	LinU	if PN digit 10 = D { wattage control }	29012
Operations	oPEr	Current 1	CUrr		1			Load Voltage	LduO		29013
Operations	oPEr	Current 1	CUrr		1			Wattage	WAt		29014
Operations	oPEr	Current 1	CUrr		1			Filter	FiL		29015
Operations	oPEr	Profile Status 1	PStA		1			Profile Start	PStr	always	22001
Operations	oPEr	Profile Status 1	PStA		1			Profile Action Request	PAcr	always	22011

EZ-ZONE ST Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Profile Status 1	P.StA	If 11th digit of PN = P	1	always		Current Step	StP	always	22004
Operations	oPEr	Profile Status 1	P.StA		1			Step Type	St.yP	always	22013
Operations	oPEr	Profile Status 1	P.StA		1			Target Set Point Loop 1	t.SP 1	always	22012
Operations	oPEr	Profile Status 1	P.StA		1			Produced Set Point 1	AC.SP	always	22005
Operations	oPEr	Profile Status 1	P.StA		1			Hours	hoUr	always	22078
Operations	oPEr	Profile Status 1	P.StA		1			Minutes	mn.in	always	22077
Operations	oPEr	Profile Status 1	P.StA		1			Seconds	SEC	always	22076
Operations	oPEr	Profile Status 1	P.StA		1			Event 1	Ent 1	always	22014
Operations	oPEr	Profile Status 1	P.StA		1			Event 2	Ent2	always	22015
Operations	oPEr	Profile Status 1	P.StA		1			Jump Count Remaining	JC	always	22010
Setup	SEt	Analog Input x	A,	always	1 - 2	Instance 1= always; Instance 2 if 4th digit of model number is an "L"		Sensor Type	SEn	always	4005
Setup	SEt	Analog Input x	A,		1 - 2			TC Linearization	L in	always	4006
Setup	SEt	Analog Input x	A,		1 - 2			RTD Leads	rt.L	always	4007
Setup	SEt	Analog Input x	A,		1 - 2			Units	Un.t	always	4042
Setup	SEt	Analog Input x	A,		1 - 2			Scale Low	S.Lo	always	4015
Setup	SEt	Analog Input x	A,		1 - 2			Scale High	S.h,	always	4016
Setup	SEt	Analog Input x	A,		1 - 2			Range Low	r.Lo	always	4017
Setup	SEt	Analog Input x	A,		1 - 2			Range High	r.h,	always	4018
Setup	SEt	Analog Input x	A,		1 - 2			Process Error Enable	P.EE	always	4030
Setup	SEt	Analog Input x	A,		1 - 2			Process Error Low Value	P.EL	always	4031
Setup	SEt	Analog Input x	A,		1 - 2			Filter	F.iL	always	4014
Setup	SEt	Analog Input x	A,		1 - 2			Input Error Latching	.Er	always	4028
Setup	SEt	Analog Input x	A,		1 - 2			Display Precision	dEC	always	4020
Setup	SEt	Analog Input x	A,		1			Sensor Backup	SbA	If PN digit 4 is L	4026
Setup	SEt	Digital I/O x	d.io	If 2nd digit of PN = B, E, D, or C	5-6	always		Digital I/O Direction	d.ir	always	6001
Setup	SEt	Digital I/O x	d.io		5-6			Output Function	Fn	always	6005
Setup	SEt	Digital I/O x	d.io		5-6			Output Function Instance	F,	always	6006
Setup	SEt	Digital I/O x	d.io		5-6			Output Control	o.Ct	always	6002
Setup	SEt	Digital I/O x	d.io		5-6			Output Time Base	o.tb	always	6003
Setup	SEt	Digital I/O x	d.io		5-6			Output Low Power Scale	o.Lo	always	6009
Setup	SEt	Digital I/O x	d.io		5-6			Output High Power Scale	o.h,	always	6010
Setup	SEt	Digital I/O x	d.io		5			Active Level	LEv	always	10001
Setup	SEt	Digital I/O x	d.io		5			Action Function	Fn	always	10003
Setup	SEt	Digital I/O x	d.io		5			Function Instance	F,	always	10004
Setup	SEt	Digital I/O x	d.io		6			Active Level	LEv	always	10001
Setup	SEt	Digital I/O x	d.io		6			Action Function	Fn	always	10003
Setup	SEt	Digital I/O x	d.io		6			Function Instance	F,	always	10004
Setup	SEt	Limit 1	L.Fn	If 3rd digit of PN = L	1	always		Limit Sides	L.Sd	always	12005
Setup	SEt	Limit 1	L.Fn		1			Limit Hysteresis	L.hy	always	12002
Setup	SEt	Limit 1	L.Fn		1			Set Point High Limit	SPLh	always	12009
Setup	SEt	Limit 1	L.Fn		1			Set Point Low Limit	SPLL	always	12010
Setup	SEt	Limit 1	L.Fn		1			Integrate with System	L.it	always	12008
Setup	SEt	Control Loop 1	LooP		1			Source Function A	SFn.A	if PN digit 10 = D { wattage control }	8050

EZ-ZONE ST Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Control Loop 1	LooP	always	1	always		Heat Algorithm	h.AG	always	8003
Setup	SEt	Control Loop 1	LooP		1			Cool Algorithm	C.AG	always	8004
Setup	SEt	Control Loop 1	LooP		1			TRU-TUNE+ Enable	t.tUn	always	8022
Setup	SEt	Control Loop 1	LooP		1			TRU-TUNE+ Band	t.bnd	always	8034
Setup	SEt	Control Loop 1	LooP		1			TRU-TUNE+ Gain	t.Gn	always	8035
Setup	SEt	Control Loop 1	LooP		1			Autotune Aggressiveness	t.AGr	always	8024
Setup	SEt	Control Loop 1	LooP		1			User Failure Action	UFA	always	7012
Setup	SEt	Control Loop 1	LooP		1			Input Error Failure	FA iL	always	7013
Setup	SEt	Control Loop 1	LooP		1			Fixed Power	mAn	always	7011
Setup	SEt	Control Loop 1	LooP		1			Open Loop Detect Enable	L.dE	always	8039
Setup	SEt	Control Loop 1	LooP		1			Open Loop Detect Time	L.dt	always	8040
Setup	SEt	Control Loop 1	LooP		1			Open Loop Detect Deviation	L.dd	always	8041
Setup	SEt	Control Loop 1	LooP		1			Ramp Action	rP	always	7014
Setup	SEt	Control Loop 1	LooP		1			Ramp Scale	r.SC	always	7015
Setup	SEt	Control Loop 1	LooP		1			Ramp Rate	r.rt	always	7017
Setup	SEt	Control Loop 1	LooP		1			Low Set Point	L.SP	always	7003
Setup	SEt	Control Loop 1	LooP		1			High Set Point	h.SP	always	7004
Setup	SEt	Control Loop 1	LooP		1			Set Point Open Limit Low	SP.Lo	always	7005
Setup	SEt	Control Loop 1	LooP		1			Set Point Open Limit High	SP.h i	always	7006
Setup	SEt	Output x	OtPt		1 - 4			Output Function	Fn	Instance 1 if PN 8th digit = B,C,D,E,K,F,G,H,L,J Instance 2 always Instance 3 if PN 3rd digit = L Instance 4 if PN 3rd digit = L	6005
Setup	SEt	Output x	OtPt		1 - 4			Output Function Instance	F i		6006
Setup	SEt	Output x	OtPt	always	1 - 4	Instance 1 & 2 always; Instance 3 & 4 if 4th digit of model number = L		Output Control	o.Ct	Instance 1 if PN 8th digit = B,C,D,E,K,F,G,H,L,J Instance 2 always Instance 3 if PN 3rd digit = L Instance 4 never { Output is discrete and can be something other than a limit function}	6002
Setup	SEt	Output x	OtPt		1 - 4			Output Time Base	o.tb		6003
Setup	SEt	Output x	OtPt		1 - 4			Output Low Power Scale	o.Lo		6009
Setup	SEt	Output x	OtPt		1 - 4			Output High Power Scale	o.h i		6010
Setup	SEt	Output x	OtPt		1			Output Type	o.ty	if PN 8th digit = M,N,P,R,S,T {Output is Analog}	18002
Setup	SEt	Output x	OtPt		1			Soft Start Time	SSt i		18021
Setup	SEt	Alarm x	ALrM	always	1 - 2	always		Alarm Type	A.ty	always	9015
Setup	SEt	Alarm x	ALrM		1 - 2			Alarm Source	Sr.A	always	9017
Setup	SEt	Alarm x	ALrM		1 - 2			Alarm Source Instance	i.SA	always	9018
Setup	SEt	Alarm x	ALrM		1 - 2			Alarm Hysteresis	A.hy	always	9003
Setup	SEt	Alarm x	ALrM		1 - 2			Alarm Logic	A.Lg	always	9005
Setup	SEt	Alarm x	ALrM		1 - 2			Alarm Sides	A.Sd	always	9004
Setup	SEt	Alarm x	ALrM		1 - 2			Alarm Latching	A.LA	always	9007
Setup	SEt	Alarm x	ALrM		1 - 2			Alarm Blocking	A.bL	always	9008
Setup	SEt	Alarm x	ALrM		1 - 2			Alarm Silencing	A.S i	always	9006
Setup	SEt	Alarm x	ALrM		1 - 2			Alarm Display	A.dSP	always	9016
Setup	SEt	Alarm x	ALrM		1 - 2			Alarm Delay Time	A.dL	always	9021
Setup	SEt	Current 1	CUrr		1			Current Sides	C.Sd	always	15005
Setup	SEt	Current 1	CUrr		1			Current Read Enable	C.Ur	always	15004
Setup	SEt	Current 1	CUrr		1			Current Limit Enable	C.LE	If 4th digit of PN = L { has a limit }	15006

EZ-ZONE ST Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Current 1	CUrr	If 2nd digit of PN = P, E, J, or C	1	always		Heater Current Offset	CoFS	always	15011
Setup	SEt	Current 1	CUrr		1			Current Gain	C,9n	always	15010
Setup	SEt	Current 1	CUrr		1			Tungsten Mode	tun9	always	15029
Setup	SEt	Current 1	CUrr		1			Delay	dEL	always	15032
Setup	SEt	Current 1	CUrr		1			eCURRENT MEMBER LOWEST FAULT LEVEL		always	15033
Setup	SEt	Current 1	CUrr		1			eCURRENT MEMBER COMPENSATED HIGH TRIP		always	15030
Setup	SEt	Current 1	CUrr		1			eCURRENT MEMBER COMPENSATED LOW TRIP		always	15031
Setup	SEt	Function Key 1	Fun	always	1	always		Action Function	Fn	always	10003
Setup	SEt	Function Key 1	Fun		1			Function Instance	F,	always	10004
Setup	SEt	Function Key 2	Fun		2			Action Function	Fn	always	10003
Setup	SEt	Function Key 2	Fun		2			Function Instance	F,	always	10004
Setup	SEt	Global 1	9LbL	always	1	always		Display Units	C_F	always	3005
Setup	SEt	Global 1	9LbL		1			AC Line Frequency	ACLF	always	1034
Setup	SEt	Global 1	9LbL		1			Ramping Type	rtYP	If 10th digit of PN = P	22038
Setup	SEt	Global 1	9LbL		1			Profile Type	PtYP	If 10th digit of PN = P	22008
Setup	SEt	Global 1	9LbL		1			Guaranteed Soak Enable	9SE	If 10th digit of PN = P	22006
Setup	SEt	Global 1	9LbL		1			Guaranteed Soak Deviation 1	9Sd1	If 10th digit of PN = P	22007
Setup	SEt	Global 1	9LbL		1			Display Pairs	dPrS	always	3028
Setup	SEt	Global 1	9LbL		1			User Settings Save	USr.S	always	1014
Setup	SEt	Global 1	9LbL		1			User Settings Restore	USr.r	always	1013
Setup	SEt	Communications 1	CoM	always	1	always		Modbus Address	Ad.M	if 7th digit of PN = M	17007
Setup	SEt	Communications 1	CoM		1			Baud Rate	bAUd	if 7th digit of PN = M	17002
Setup	SEt	Communications 1	CoM		1			Parity	PAr	if 7th digit of PN = M	17003
Setup	SEt	Communications 1	CoM		1			Modbus Word Order	MWhL	if 7th digit of PN = M	17043
Setup	SEt	Communications 1	CoM		1			Display Units	C_F	if 7th digit of PN = M	17050
Setup	SEt	Communications 1	CoM		1			Data Map	MMAP	always	17059
Setup	SEt	Communications 1	CoM		1			Non-Volatile Save	nU.S	always	17051
Factory	FCtY	Custom Setup x	CuSt	always	1 - 20	always		Parameter	PAr	always	14005
Factory	FCtY	Custom Setup x	CuSt		1 - 20			Instance ID	,id	always	14003
Factory	FCtY	Lock 1	LoC	If DspLockedState = PASS ADMIN	1	always		Operations Page	LoC.o	always	3002
Factory	FCtY	Lock 1	LoC		1			Profilng Page	LoC.P	If 10th digit of PN = P	3008
Factory	FCtY	Lock 1	LoC		1			Password Enable	PAS.E	always	3015
Factory	FCtY	Lock 1	LoC		1			Read Lock	rLoC	always	3010
Factory	FCtY	Lock 1	LoC		1			Write Security	SLoC	always	3011
Factory	FCtY	Lock 1	LoC		1			Locked Access Level	LoC.L	always	3016
Factory	FCtY	Lock 1	LoC		1			Rolling Password	roLL	always	3019
Factory	FCtY	Lock 1	LoC		1			User Password	PAS.u	always	3017
Factory	FCtY	Lock 1	LoC		1			Administrator Password	PAS.A	always	3018
Factory	FCtY	Unlock 1	ULoC	If DspSecurityEnable == ON	1	always		Public Key	CodE	always	3020
Factory	FCtY	Unlock 1	ULoC		1			Password	PASS	always	3022

EZ-ZONE ST Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Factory	FctY	Diagnostics 1	d iAG	always	1	always		Part Number	Pn	always	1009
Factory	FctY	Diagnostics 1	d iAG		1			Software Revision	rEv	always	1017
Factory	FctY	Diagnostics 1	d iAG		1			Software Build Number	S.bLd	always	1005
Factory	FctY	Diagnostics 1	d iAG		1			Serial Number	Sn	always	1032
Factory	FctY	Diagnostics 1	d iAG		1			Date of Manufacture	dAtE	always	1008
Factory	FctY	Calibration x	CAL	always	1 - 2	Instance 1= always; Instance 2 if 4th digit of PN = L		Electrical Measurement	mAu	always	4021
Factory	FctY	Calibration x	CAL		1 - 2			Electrical Input Offset	EL iO	always	4010
Factory	FctY	Calibration x	CAL		1 - 2			Electrical Input Slope	EL iS	always	4011
Factory	FctY	Calibration 1	CAL		1			Electrical Output Offset	ELoO	if PN 8th digit = M,N,P,R,S,T	18005
Factory	FctY	Calibration 1	CAL		1			Electrical Output Slope	ELoS	if PN 8th digit = M,N,P,R,S,T	18006
Profile	ProF	Profile 1 Step x	P1	always	1 - 10	always		Step Type	StYP	always	21001
Profile	ProF	Profile 1 Step x	P1		1 - 10			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 1 Step x	P1		1 - 10			Hours	hoUr	always	21003
Profile	ProF	Profile 1 Step x	P1		1 - 10			Minutes	mn in	always	21004
Profile	ProF	Profile 1 Step x	P1		1 - 10			Seconds	SEC	always	21005
Profile	ProF	Profile 1 Step x	P1		1 - 10			Rate	rAtE	always	21006
Profile	ProF	Profile 1 Step x	P1		1 - 10			Wait For Process 1	wtP1	always	21011
Profile	ProF	Profile 1 Step x	P1		1 - 10			Wait Event 1	wtE1	always	21009
Profile	ProF	Profile 1 Step x	P1		1 - 10			Wait Event 2	wtE2	always	21010
Profile	ProF	Profile 1 Step x	P1		1 - 10			Jump Step	JS	always	21012
Profile	ProF	Profile 1 Step x	P1		1 - 10			Jump Count	JC	always	21013
Profile	ProF	Profile 1 Step x	P1		1 - 10			End Type	End	always	21014
Profile	ProF	Profile 1 Step x	P1		1 - 10			Event 1	Ent1	always	21007
Profile	ProF	Profile 1 Step x	P1		1 - 10			Event 2	Ent2	always	21008
Profile	ProF	Profile 2 Step x	P2	always	11 - 20	always		Step Type	StYP	always	21001
Profile	ProF	Profile 2 Step x	P2		11 - 20			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 2 Step x	P2		11 - 20			Hours	hoUr	always	21003
Profile	ProF	Profile 2 Step x	P2		11 - 20			Minutes	mn in	always	21004
Profile	ProF	Profile 2 Step x	P2		11 - 20			Seconds	SEC	always	21005
Profile	ProF	Profile 2 Step x	P2		11 - 20			Rate	rAtE	always	21006
Profile	ProF	Profile 2 Step x	P2		11 - 20			Wait For Process 1	wtP1	always	21011
Profile	ProF	Profile 2 Step x	P2		11 - 20			Wait Event 1	wtE1	always	21009
Profile	ProF	Profile 2 Step x	P2		11 - 20			Wait Event 2	wtE2	always	21010
Profile	ProF	Profile 2 Step x	P2		11 - 20			Jump Step	JS	always	21012
Profile	ProF	Profile 2 Step x	P2		11 - 20			Jump Count	JC	always	21013
Profile	ProF	Profile 2 Step x	P2		11 - 20			End Type	End	always	21014
Profile	ProF	Profile 2 Step x	P2		11 - 20			Event 1	Ent1	always	21007
Profile	ProF	Profile 2 Step x	P2		11 - 20			Event 2	Ent2	always	21008
Profile	ProF	Profile 3 Step x	P3		21 - 30			Step Type	StYP	always	21001
Profile	ProF	Profile 3 Step x	P3		21 - 30			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 3 Step x	P3		21 - 30			Hours	hoUr	always	21003
Profile	ProF	Profile 3 Step x	P3		21 - 30			Minutes	mn in	always	21004
Profile	ProF	Profile 3 Step x	P3		21 - 30			Seconds	SEC	always	21005

EZ-ZONE ST Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 3 Step x	P3	always	21 - 30	always		Rate	rAtE	always	21006
Profile	ProF	Profile 3 Step x	P3		21 - 30			Wait For Process 1	wP1	always	21011
Profile	ProF	Profile 3 Step x	P3		21 - 30			Wait Event 1	wE1	always	21009
Profile	ProF	Profile 3 Step x	P3		21 - 30			Wait Event 2	wE2	always	21010
Profile	ProF	Profile 3 Step x	P3		21 - 30			Jump Step	JS	always	21012
Profile	ProF	Profile 3 Step x	P3		21 - 30			Jump Count	JC	always	21013
Profile	ProF	Profile 3 Step x	P3		21 - 30			End Type	End	always	21014
Profile	ProF	Profile 3 Step x	P3		21 - 30			Event 1	Ent1	always	21007
Profile	ProF	Profile 3 Step x	P3		21 - 30			Event 2	Ent2	always	21008
Profile	ProF	Profile 4 Step x	P4	always	31 - 40	always		Step Type	StyP	always	21001
Profile	ProF	Profile 4 Step x	P4		31 - 40			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 4 Step x	P4		31 - 40			Hours	hour	always	21003
Profile	ProF	Profile 4 Step x	P4		31 - 40			Minutes	Min	always	21004
Profile	ProF	Profile 4 Step x	P4		31 - 40			Seconds	SEC	always	21005
Profile	ProF	Profile 4 Step x	P4		31 - 40			Rate	rAtE	always	21006
Profile	ProF	Profile 4 Step x	P4		31 - 40			Wait For Process 1	wP1	always	21011
Profile	ProF	Profile 4 Step x	P4		31 - 40			Wait Event 1	wE1	always	21009
Profile	ProF	Profile 4 Step x	P4		31 - 40			Wait Event 2	wE2	always	21010
Profile	ProF	Profile 4 Step x	P4		31 - 40			Jump Step	JS	always	21012
Profile	ProF	Profile 4 Step x	P4		31 - 40			Jump Count	JC	always	21013
Profile	ProF	Profile 4 Step x	P4		31 - 40			End Type	End	always	21014
Profile	ProF	Profile 4 Step x	P4		31 - 40			Event 1	Ent1	always	21007
Profile	ProF	Profile 4 Step x	P4		31 - 40			Event 2	Ent2	always	21008

EZ-ZONE RUI/Gateway Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
RUI	rU1	Communications 1			1			Standard Bus Address	Ad.S	always	17001
RUI	rU1	Communications 1			1	Always		Starting Slave Address	St.2n	always	17004
RUI	rU1	Communications 1			1			Number Of Slaves	nU.2n	always	17005
RUI	rU1	Communications 2			2			Modbus Address	Ad.M7		17007
RUI	rU1	Communications 2			2			Baud Rate	bAUd	if 6th digit of PN = 2 { has Modbus RTU }	17002
RUI	rU1	Communications 2			2			Parity	PAr		17003
RUI	rU1	Communications 2			2			Modbus Word Order	M7.hL	if 6th digit of PN = 2 or 3 { supports Modbus RTU or TCP }	17043
RUI	rU1	Communications 2			2			IP Address Mode	IP M7		17012
RUI	rU1	Communications 2			2			IP Fixed Address Part 1	IP.F1		17014
RUI	rU1	Communications 2			2			IP Fixed Address Part 2	IP.F2		17015
RUI	rU1	Communications 2			2			IP Fixed Address Part 3	IP.F3		17016
RUI	rU1	Communications 2			2			IP Fixed Address Part 4	IP.F4		17017
RUI	rU1	Communications 2			2			IP Fixed Address Part 5	IP.F5		17018
RUI	rU1	Communications 2			2			IP Fixed Address Part 6	IP.F6		17019
RUI	rU1	Communications 2			2			IP Fixed Subnet Part 1	IP.S1		17020
RUI	rU1	Communications 2			2			IP Fixed Subnet Part 2	IP.S2		17021
RUI	rU1	Communications 2			2			IP Fixed Subnet Part 3	IP.S3		17022
RUI	rU1	Communications 2		Always	2			IP Fixed Subnet Part 4	IP.S4	if 6th digit of PN = 3 {it has Ethernet}	17023
RUI	rU1	Communications 2			2	If field comms is installed.		IP Fixed Subnet Part 5	IP.S5		17024
RUI	rU1	Communications 2			2			IP Fixed Subnet Part 6	IP.S6		17025
RUI	rU1	Communications 2			2			Fixed IP Gateway Part 1	IP.91		17026
RUI	rU1	Communications 2			2			Fixed IP Gateway Part 2	IP.92		17027
RUI	rU1	Communications 2			2			Fixed IP Gateway Part 3	IP.93		17028
RUI	rU1	Communications 2			2			Fixed IP Gateway Part 4	IP.94		17029
RUI	rU1	Communications 2			2			Fixed IP Gateway Part 5	IP.95		17030
RUI	rU1	Communications 2			2			Fixed IP Gateway Part 6	IP.96		17031
RUI	rU1	Communications 2			2			Modbus TCP Enable	M7.bE		17041
RUI	rU1	Communications 2			2			EtherNet/IP Enable	E.IPE		17042
RUI	rU1	Communications 2			2			DeviceNet Node Address	Ad.d		17052
RUI	rU1	Communications 2			2			Baud Rate DeviceNet	bAUd	if 6th digit of PN = 5 { has DeviceNet }	17053
RUI	rU1	Communications 2			2			DeviceNet Quick Connect Enable	FC.E		17054
RUI	rU1	Communications 2			2			Profibus Node Address	P.Add		17060
RUI	rU1	Communications 2			2			Profibus Address Lock	A.Loc	if 6th digit of PN = 6 {it has Profibus}	17061
RUI	rU1	Communications 2			2			Profibus Status	StAt		17063
RUI	rU1	Communications 2			2			Display Units	C_F	if 6th digit of PN = 2, 3, or 5 { does not have Profibus }	17050
RUI	rU1	Global 1			1			Communications Led Action	C.LEd	always	3014
RUI	rU1	Global 1		Always	1	Always		Display Time	dt1	always	3029
RUI	rU1	Global 1			1			User Settings Save	USr.S	always	1014
RUI	rU1	Global 1			1			User Settings Restore	USr.r	always	1013
RUI	rU1	GATEWAY			1-16			Device Enabled	du.En	always	24002
RUI	rU1	GATEWAY			1-16			Device Status	du.St	always	24006
RUI	rU1	GATEWAY			16			Who	uJho	always	24012
RUI	rU1	GATEWAY		if 6th digit of PN is not A	1-16	Always		Modbus Address Offset	M7oF	if 6th digit of PN = 2 or 3 { supports Modbus RTU or TCP }	24003
RUI	rU1	GATEWAY			1-16			CIP Instance Offset	oSt		24004

EZ-ZONE RUI/Gateway Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
RUI	rUi	GATEWAY			1-16			CIP Implicit Assembly Output Member Quantity	Aonb	if 6th digit of PN = 3 or 5 { supports CIP }	24009
RUI	rUi	GATEWAY			1-16			CIP Implicit Assembly Input Member Quantity	Ainb		24010
RUI	rUi	GATEWAY			1-16			Slot Offset	SoF	if 6th digit of PN = 6 {it has Profibus}	24011
RUI	rUi	Lock 1			1			Password Enable	PASE	always	3015
RUI	rUi	Lock 1			1			Read Lock	rLoC	always	3010
RUI	rUi	Lock 1			1			Write Security	SLoC	always	3011
RUI	rUi	Lock 1		kedState = PAS	1	always		Locked Access Level	LoCL	always	3016
RUI	rUi	Lock 1			1			Rolling Password	roLL	always	3019
RUI	rUi	Lock 1			1			User Password	PASu	always	3017
RUI	rUi	Lock 1			1			Administrator Password	PASA	always	3018
RUI	rUi	Unlock 1		ll DspSecurityEn able == ON	1	always		Public Key	CodE	always	3020
RUI	rUi	Unlock 1			1			Password	PASS	always	3022
RUI	rUi	Diagnostics 1						Part Number	Pn	always	1009
RUI	rUi	Diagnostics 1						Software Revision	rEv	always	1017
RUI	rUi	Diagnostics 1						Software Build Number	SbLd	always	1005
RUI	rUi	Diagnostics 1						Serial Number	Sn	always	1032
RUI	rUi	Diagnostics 1						Date of Manufacture	dAtE	always	1008
RUI	rUi	Diagnostics 1		Always	1	Always		Actual IP Addressing Mode	iPAC	if 6th digit of PN = 3 {it has Ethernet}	17013
RUI	rUi	Diagnostics 1						IP Actual Address Part 1	iPA1		17044
RUI	rUi	Diagnostics 1						IP Actual Address Part 2	iPA2		17045
RUI	rUi	Diagnostics 1						IP Actual Address Part 3	iPA3		17046
RUI	rUi	Diagnostics 1						IP Actual Address Part 4	iPA4		17047
RUI	rUi	Diagnostics 1						IP Actual Address Part 5	iPA5		17048
RUI	rUi	Diagnostics 1						IP Actual Address Part 6	iPA6		17049

EZ-ZONE PM Standard Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Analog Input x	A i	always	1 - 2	Instance 1 = Always Instance 2 = If 9th digit of model number is an C, J, R, P, M or L		Analog Input Value	A in	always	4001
Operations	oPEr	Analog Input x	A i		1 - 2			Input Error	i.Er	always	4002
Operations	oPEr	Analog Input x	A i		1 - 2			Calibration Offset	i.CA	always	4012
Operations	oPEr	Linearization x	L in	If PN digit 4 is C, R, J, B, Eor N	1 - 2	Instance 1 = Always Instance 2 = If PN digit 9 is C, J, R or P		Source Value A	SU.A	always	34004
Operations	oPEr	Linearization x	L in		1 - 2			Offset	oFSt	always	34006
Operations	oPEr	Linearization x	L in		1 - 2			Output Value	o.u	always	34007
Operations	oPEr	Process Value x	Pu	If PN digit 4 is C, R, J, B, Eor N	1 - 2	Instance 1 = Always Instance 2 = If PN digit 9 is C, J, R or P		Source Value A	SU.A	always	26016
Operations	oPEr	Process Value x	Pu		1 - 2			Source Value B	SU.b	always	26017
Operations	oPEr	Process Value x	Pu		1 - 2			Offset	oFSt	always	26023
Operations	oPEr	Process Value x	Pu		1 - 2			Output Value	o.u	always	26022
Operations	oPEr	Digital I/O x	d io	If 5th digit of PN is a 2 or 4 OR if 8th digit of PN = C or D	5 - 12	instance 5 & 6 - If 5th digit of PN = 2 or 4 instance 7-12 - if 8th digit of PN = C or D		Output State	do.S	always	6007
Operations	oPEr	Digital I/O x	d io		5 - 12			Input State	d i.S	always	6011
Operations	oPEr	Digital I/O 5	d io		5			Event Status	E i.S	always	10005
Operations	oPEr	Digital I/O 6	d io		6			Event Status	E i.S	always	10005
Operations	oPEr	Digital I/O 7	d io		7			Event Status	E i.S	always	10005
Operations	oPEr	Digital I/O 8	d io		8			Event Status	E i.S	always	10005
Operations	oPEr	Digital I/O 9	d io		9			Event Status	E i.S	always	10005
Operations	oPEr	Digital I/O 10	d io		10			Event Status	E i.S	always	10005
Operations	oPEr	Digital I/O 11	d io		11			Event Status	E i.S	always	10005
Operations	oPEr	Digital I/O 12	d io		12			Event Status	E i.S	always	10005
Operations	oPEr	Limit 1	L iM1	If 4th digit of model number is an L, M or D or 9th digit is an L or M	1	Always		Limit Low Set Point	LLS	always	12003
Operations	oPEr	Limit 1	L iM1		1			Limit High Set Point	LhS	always	12004
Operations	oPEr	Limit 1	L iM1		1			Limit Clear Request	LCr	always	12014
Operations	oPEr	Limit 1	L iM1		1			Limit Status	LSt	always	12013
Operations	oPEr	Monitor x	M1on	If 4th digit of model number is a C, R, J, B, E, N or S	1-2	instance 1 Always instance 2 IF PN digit 9 is C or J		Control Mode Active	CM1A	always	8002
Operations	oPEr	Monitor x	M1on		1-2			Heat Power	h.Pr	always	8011
Operations	oPEr	Monitor x	M1on		1-2			Cool Power	C.Pr	always	8014
Operations	oPEr	Monitor x	M1on		1-2			Closed-Loop Set Point	CSP	always	8029
Operations	oPEr	Monitor x	M1on		1-2			Process Value Active	PuA	always	8031
Operations	oPEr	Control Loop x	LooP	If 4th digit of model number is a C, R, J, B, E, N or S	1-2	instance 1 Always instance 2 If PN digit 9 is C or J		Remote Enable	r.En	if 9th digit of PN is an R or P	7021
Operations	oPEr	Control Loop x	LooP		1-2			Control Mode	CM1	always	8001
Operations	oPEr	Control Loop x	LooP		1-2			Autotune Set Point	A.tSP	always	8025
Operations	oPEr	Control Loop x	LooP		1-2			Autotune	AUt	always	8026
Operations	oPEr	Control Loop x	LooP		1-2			Closed-Loop Set Point	CSP	always	7001
Operations	oPEr	Control Loop x	LooP		1-2			Idle Set Point	id.S	always	7009
Operations	oPEr	Control Loop x	LooP		1-2			Heat Proportional Band	h.Pb	always	8009
Operations	oPEr	Control Loop x	LooP		1-2			Heat Hysteresis	h.hy	always	8010
Operations	oPEr	Control Loop x	LooP		1-2			Cool Proportional Band	C.Pb	always	8012
Operations	oPEr	Control Loop x	LooP		1-2			Cool Hysteresis	C.hy	always	8013
Operations	oPEr	Control Loop x	LooP		1-2			Time Integral	t i	always	8006
Operations	oPEr	Control Loop x	LooP		1-2			Time Derivative	td	always	8007

EZ-ZONE PM Standard Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Control Loop x	LooP		1-2			Dead Band	db	always	8008
Operations	oPEr	Control Loop x	LooP		1-2			Open Loop Set Point	o.SP	always	7002
Operations	oPEr	Alarm x	ALM	always	1 - 4	Always		Alarm Low Set Point	A.Lo	always	9002
Operations	oPEr	Alarm x	ALM		1 - 4			Alarm High Set Point	A.h i	always	9001
Operations	oPEr	Alarm x	ALM		1 - 4			Alarm Clear Request	A.CLr	always	9026
Operations	oPEr	Alarm x	ALM		1 - 4			Alarm Silence Request	A.S ir	always	9027
Operations	oPEr	Alarm x	ALM		1 - 4			Alarm State	A.St	always	9009
Operations	oPEr	Current 1	CUrr	If 9th digit of model number is a T	1	Always		Current High Set Point	C.h i	always	15008
Operations	oPEr	Current 1	CUrr		1			Current Low Set Point	C.Lo	always	15009
Operations	oPEr	Current 1	CUrr		1			Current Read	CUr	always	15007
Operations	oPEr	Current 1	CUrr		1			Current Error	C.Er	always	15002
Operations	oPEr	Current 1	CUrr		1			Heater Error	h.Er	always	15003
Operations	oPEr	Math 1	MAth	if 9th digit of PN is a C or J AND 12th digit of PN is a C	1	Always		Source Value A	SuA	always	25016
Operations	oPEr	Math 1	MAth		1			Source Value B	Sub	always	25017
Operations	oPEr	Math 1	MAth		1			Source Value E	SuE	always	25020
Operations	oPEr	Math 1	MAth		1			Offset	oFSt	always	25023
Operations	oPEr	Math 1	MAth		1			Output Value	ou	always	25022
Operations	oPEr	Special Output Function 1	SoF	If 12th digit of PN is a C	1	Always		Source Value A	SuA	always	35007
Operations	oPEr	Special Output Function 1	SoF		1			Source Value B	Sub	always	35008
Operations	oPEr	Special Output Function 1	SoF		1			Output Value 1	ou 1	always	35010
Operations	oPEr	Special Output Function 1	SoF		1			Output Value 2	ou2	always	35012
Operations	oPEr	Profile Status 1	PSTA	If 4th digit of model number is an R, B, E or N	1	Always		Profile Start	PStr	always	22001
Operations	oPEr	Profile Status 1	PSTA		1			Profile Action Request	PAcr	always	22011
Operations	oPEr	Profile Status 1	PSTA		1			Current Step	StP	always	22004
Operations	oPEr	Profile Status 1	PSTA		1			Step Type	StyP	always	22013
Operations	oPEr	Profile Status 1	PSTA		1			Target Set Point Loop 1	tSP1	always	22012
Operations	oPEr	Profile Status 1	PSTA		1			Target Set Point Loop 2	tSP2	If PN digit 9 is C or J	22048
Operations	oPEr	Profile Status 1	PSTA		1			Produced Set Point 1	AC.SP	always	22005
Operations	oPEr	Profile Status 1	PSTA		1			Produced Set Point 2	PSP2	If PN digit 9 is C or J	22051
Operations	oPEr	Profile Status 1	PSTA		1			Hours	hour	always	22078
Operations	oPEr	Profile Status 1	PSTA		1			Minutes	MIn	always	22077
Operations	oPEr	Profile Status 1	PSTA		1			Seconds	SEC	always	22076
Operations	oPEr	Profile Status 1	PSTA		1			Event 1	Ent 1	always	22014
Operations	oPEr	Profile Status 1	PSTA		1			Event 2	Ent2	always	22015
Operations	oPEr	Profile Status 1	PSTA		1			Jump Count Remaining	JC	always	22010
Setup	SEt	Analog Input x	A i		1 - 2			Sensor Type	SEn	always	4005
Setup	SEt	Analog Input x	A i		1 - 2			TC Linearization	t in	If input is universal	4006
Setup	SEt	Analog Input x	A i		1 - 2			RTD Leads	rtL	If input is universal	4007
Setup	SEt	Analog Input x	A i		1 - 2			Units	Unit	If input is universal	4042
Setup	SEt	Analog Input x	A i		1 - 2			Scale Low	SLo	If input is universal	4015
Setup	SEt	Analog Input x	A i		1 - 2			Scale High	Sh i	If input is universal	4016

EZ-ZONE PM Standard Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Analog Input x	A i	always	1 - 2	Instance 1 = Always Instance 2 = If 9th digit of model number is an C, J, R, P, M or L		Range Low	r.Lo	If input is universal	4017
Setup	SEt	Analog Input x	A i		1 - 2			Range High	r.hi	If input is universal	4018
Setup	SEt	Analog Input x	A i		1 - 2			Process Error Enable	P.EE	If input is universal	4030
Setup	SEt	Analog Input x	A i		1 - 2			Process Error Low Value	P.EL	If input is universal	4031
Setup	SEt	Analog Input x	A i		1 - 2			Thermistor Curve	t.C	if input is thermistor	4038
Setup	SEt	Analog Input x	A i		1 - 2			Resistance Range	r.r	if input is thermistor	4037
Setup	SEt	Analog Input x	A i		1 - 2			Filter	F iL	always	4014
Setup	SEt	Analog Input x	A i		1 - 2			Input Error Latching	iEr	always	4028
Setup	SEt	Analog Input x	A i		1 - 2			Display Precision	dEC	always	4020
Setup	SEt	Analog Input x	A i		1 - 2			Sensor Backup	SbA	if instance = 1 AND 3rd digit of PN is 3 or 6 AND 9th digit of PN is R, P, L, or M	4026
Setup	SEt	Analog Input x	A i		1 - 2			Calibration Offset	iCA	always	4012
Setup	SEt	Analog Input x	A i		1 - 2			Analog Input Value	A in	always	4001
Setup	SEt	Analog Input x	A i		1 - 2			Input Error	iEr	always	4002
Setup	SEt	Linearization x	L in	If PN digit 4 is C, R, J, B, Eor N	1 - 2	Instance 1 = Always Instance 2 = If PN digit 9 is C, J, R or P		Function	Fn	always	34005
Setup	SEt	Linearization x	L in		1 - 2			Units	Unit	always	34029
Setup	SEt	Linearization x	L in		1 - 2			Input Point 1	iP.1	always	34008
Setup	SEt	Linearization x	L in		1 - 2			Output Point 1	oP.1	always	34018
Setup	SEt	Linearization x	L in		1 - 2			Input Point 2	iP.2	always	34009
Setup	SEt	Linearization x	L in		1 - 2			Output Point 2	oP.2	always	34019
Setup	SEt	Linearization x	L in		1 - 2			Input Point 3	iP.3	always	34010
Setup	SEt	Linearization x	L in		1 - 2			Output Point 3	oP.3	always	34020
Setup	SEt	Linearization x	L in		1 - 2			Input Point 4	iP.4	always	34011
Setup	SEt	Linearization x	L in		1 - 2			Output Point 4	oP.4	always	34021
Setup	SEt	Linearization x	L in		1 - 2			Input Point 5	iP.5	always	34012
Setup	SEt	Linearization x	L in		1 - 2			Output Point 5	oP.5	always	34022
Setup	SEt	Linearization x	L in		1 - 2			Input Point 6	iP.6	always	34013
Setup	SEt	Linearization x	L in		1 - 2			Output Point 6	oP.6	always	34023
Setup	SEt	Linearization x	L in		1 - 2			Input Point 7	iP.7	always	34014
Setup	SEt	Linearization x	L in		1 - 2			Output Point 7	oP.7	always	34024
Setup	SEt	Linearization x	L in		1 - 2			Input Point 8	iP.8	always	34015
Setup	SEt	Linearization x	L in		1 - 2			Output Point 8	oP.8	always	34025
Setup	SEt	Linearization x	L in		1 - 2			Input Point 9	iP.9	always	34016
Setup	SEt	Linearization x	L in		1 - 2			Output Point 9	oP.9	always	34026
Setup	SEt	Linearization x	L in		1 - 2			Input Point 10	iP.10	always	34017
Setup	SEt	Linearization x	L in		1 - 2			Output Point 10	oP.10	always	34027
Setup	SEt	Process Value x	Pu	If PN digit 4 is C, R, J, B, Eor N	1 - 2	Instance 1 = Always Instance 2 = If PN digit 9 is C, J, R or P		Function	Fn	always	26021
Setup	SEt	Process Value x	Pu		1 - 2			Pressure Units	P.unt	always	26028
Setup	SEt	Process Value x	Pu		1 - 2			Altitude Units	A.unt	always	26029
Setup	SEt	Process Value x	Pu		1 - 2			Barometric Pressure	b.Pr	always	26030
Setup	SEt	Process Value x	Pu		1 - 2			Filter	F iL	always	26026
Setup	SEt	Digital I/O x	d io		5-12			Digital I/O Direction	dir	always	6001
Setup	SEt	Digital I/O x	d io		5-12			Output Function	Fn	always	6005
Setup	SEt	Digital I/O x	d io		5-12			Output Function Instance	F i	always	6006

EZ-ZONE PM Standard Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Digital I/O x	dIO	If 5th digit of PN is a 2 or 4 OR if 8th digit of PN = C or D	5-12	instance 5 & 6 - If 5th digit of PN = 2 or 4 instance 7-12 - if 8th digit of PN = C or D		Output Control	oCt	always	6002
Setup	SEt	Digital I/O x	dIO		5-12			Output Time Base	otb	always	6003
Setup	SEt	Digital I/O x	dIO		5-12			Output Low Power Scale	oLo	always	6009
Setup	SEt	Digital I/O x	dIO		5-12			Output High Power Scale	oHi	always	6010
Setup	SEt	Digital I/O 5	dIO		5			Active Level	LEv	always	10001
Setup	SEt	Digital I/O 5	dIO		5			Action Function	Fn	always	10003
Setup	SEt	Digital I/O 5	dIO		5			Function Instance	Fi	always	10004
Setup	SEt	Digital I/O 6	dIO		6			Active Level	LEv	always	10001
Setup	SEt	Digital I/O 6	dIO		6			Action Function	Fn	always	10003
Setup	SEt	Digital I/O 6	dIO		6			Function Instance	Fi	always	10004
Setup	SEt	Digital I/O 7	dIO		7			Active Level	LEv	always	10001
Setup	SEt	Digital I/O 7	dIO		7			Action Function	Fn	always	10003
Setup	SEt	Digital I/O 7	dIO		7			Function Instance	Fi	always	10004
Setup	SEt	Digital I/O 8	dIO		8			Active Level	LEv	always	10001
Setup	SEt	Digital I/O 8	dIO		8			Action Function	Fn	always	10003
Setup	SEt	Digital I/O 8	dIO		8			Function Instance	Fi	always	10004
Setup	SEt	Digital I/O 9	dIO		9			Active Level	LEv	always	10001
Setup	SEt	Digital I/O 9	dIO		9			Action Function	Fn	always	10003
Setup	SEt	Digital I/O 9	dIO		9			Function Instance	Fi	always	10004
Setup	SEt	Digital I/O 10	dIO		10			Active Level	LEv	always	10001
Setup	SEt	Digital I/O 10	dIO		10			Action Function	Fn	always	10003
Setup	SEt	Digital I/O 10	dIO		10			Function Instance	Fi	always	10004
Setup	SEt	Digital I/O 10	dIO		10			Action Function	Fn	always	10003
Setup	SEt	Digital I/O 10	dIO		10			Function Instance	Fi	always	10004
Setup	SEt	Digital I/O 11	dIO		11			Active Level	LEv	always	10001
Setup	SEt	Digital I/O 11	dIO		11			Action Function	Fn	always	10003
Setup	SEt	Digital I/O 11	dIO		11			Function Instance	Fi	always	10004
Setup	SEt	Digital I/O 12	dIO		12			Active Level	LEv	always	10001
Setup	SEt	Digital I/O 12	dIO		12			Action Function	Fn	always	10003
Setup	SEt	Digital I/O 12	dIO		12			Function Instance	Fi	always	10004
Setup	SEt	Limit 1	LIM1	If 4th digit of model number is an L, M or D or 9th digit is an L or M	1	Always		Limit Sides	LSd	always	12005
Setup	SEt	Limit 1	LIM1		1			Limit Hysteresis	LHy	always	12002
Setup	SEt	Limit 1	LIM1		1			Set Point High Limit	SPLh	always	12009
Setup	SEt	Limit 1	LIM1		1			Set Point Low Limit	SPLL	always	12010
Setup	SEt	Limit 1	LIM1		1			Limit High Set Point	LhS	always	12004
Setup	SEt	Limit 1	LIM1		1			Limit Low Set Point	LLS	always	12003
Setup	SEt	Limit 1	LIM1		1			Source Function A	SFnA	always	12015
Setup	SEt	Limit 1	LIM1		1			Source Instance A	SiA	always	12016
Setup	SEt	Limit 1	LIM1		1			Limit Clear Request	LCr	always	12014
Setup	SEt	Limit 1	LIM1		1			Limit Status	LSt	always	12013
Setup	SEt	Limit 1	LIM1		1			Integrate with System	Lit	If 4th digit of model number is a C, R, J, B, E, N or S { primary function is control, secondary function is limit }	12008
	SEt										
Setup	SEt	Control Loop x	LooP		1-2			Heat Algorithm	hAG	always	8003
Setup	SEt	Control Loop x	LooP		1-2			Cool Algorithm	CAG	always	8004
Setup	SEt	Control Loop x	LooP		1-2			Cool Output Curve	CCr	always	8038
Setup	SEt	Control Loop x	LooP		1-2			Heat Proportional Band	hPb	always	8009

EZ-ZONE PM Standard Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Control Loop x	LooP	If 4th digit of model number is a C, R, J, B, E, N or S	1-2	instance 1 Always instance 2 IF PN digit 9 is C or J		Heat Hysteresis	h.hy	always	8010
Setup	SEt	Control Loop x	LooP		1-2			Cool Proportional Band	C.Pb	always	8012
Setup	SEt	Control Loop x	LooP		1-2			Cool Hysteresis	C.hy	always	8013
Setup	SEt	Control Loop x	LooP		1-2			Time Integral	t.i	always	8006
Setup	SEt	Control Loop x	LooP		1-2			Time Derivative	t.d	always	8007
Setup	SEt	Control Loop x	LooP		1-2			Dead Band	db	always	8008
Setup	SEt	Control Loop x	LooP		1-2			TRU-TUNE+ Enable	t.tUn	always	8022
Setup	SEt	Control Loop x	LooP		1-2			TRU-TUNE+ Band	t.bnd	always	8034
Setup	SEt	Control Loop x	LooP		1-2			TRU-TUNE+ Gain	t.gn	always	8035
Setup	SEt	Control Loop x	LooP		1-2			Autotune Set Point	AtSP	always	8025
Setup	SEt	Control Loop x	LooP		1-2			Autotune Aggressiveness	tAgr	always	8024
Setup	SEt	Control Loop x	LooP		1-2			Peltier Delay	P.dL	always	8051
Setup	SEt	Control Loop x	LooP		1-2			Remote Set Point	r.En	if 9th digit of PN is an R or P	7021
Setup	SEt	Control Loop x	LooP		1-2			Remote Set Point Type	r.ty	if 9th digit of PN is an R or P	7022
Setup	SEt	Control Loop x	LooP		1-2			User Failure Action	UFA	always	7012
Setup	SEt	Control Loop x	LooP		1-2			Input Error Failure	FAiL	always	7013
Setup	SEt	Control Loop x	LooP		1-2			Fixed Power	mAn	always	7011
Setup	SEt	Control Loop x	LooP		1-2			Open Loop Detect Enable	L.dE	always	8039
Setup	SEt	Control Loop x	LooP		1-2			Open Loop Detect Time	L.dt	always	8040
Setup	SEt	Control Loop x	LooP		1-2			Open Loop Detect Deviation	L.dd	always	8041
Setup	SEt	Control Loop x	LooP		1-2			Ramp Action	rP	always	7014
Setup	SEt	Control Loop x	LooP		1-2			Ramp Scale	r.SC	always	7015
Setup	SEt	Control Loop x	LooP		1-2			Ramp Rate	r.rt	always	7017
Setup	SEt	Control Loop x	LooP		1-2			Low Set Point	L.SP	always	7003
Setup	SEt	Control Loop x	LooP		1-2			High Set Point	h.SP	always	7004
Setup	SEt	Control Loop x	LooP		1-2			Closed-Loop Set Point	C.SP	always	7001
Setup	SEt	Control Loop x	LooP		1-2			Idle Set Point	idS	always	7009
Setup	SEt	Control Loop x	LooP		1-2			Set Point Open Limit Low	SP.Lo	always	7005
Setup	SEt	Control Loop x	LooP		1-2			Set Point Open Limit High	SP.h	always	7006
Setup	SEt	Control Loop x	LooP		1-2			Open Loop Set Point	o.SP	always	7002
Setup	SEt	Control Loop x	LooP		1-2			Control Mode	Cnt	always	8001
Setup	SEt	Output x	OtPt	If digits 6, 7, 10, or 11 not an A	1 - 4	Instance 1 if 6th digit is not an A Instance 2 if 7th digit is not an A Instance 3 if 10th digit is not an A Instance 4 if 11th digit is not an A		Output Function	Fn	if output is descrete	6005
Setup	SEt	Output x	OtPt		1 - 4			Output Function Instance	F.i	if output is descrete	6006
Setup	SEt	Output x	OtPt		1 - 4			Output Control	o.Ct	if output is descrete	6002
Setup	SEt	Output x	OtPt		1 - 4			Output Time Base	o.tb	if output is descrete	6003
Setup	SEt	Output x	OtPt		1 - 4			Output Low Power Scale	o.Lo	if output is descrete	6009
Setup	SEt	Output x	OtPt		1 - 4			Output High Power Scale	o.h	if output is descrete	6010
Setup	SEt	Output x	OtPt		1 or 3			Output Type	o.ty	if output is analog	18001
Setup	SEt	Output x	OtPt		1 or 3			Output Function	Fn	if output is analog	18002
Setup	SEt	Output x	OtPt		1 or 3			Retransmit Source	r.Sr	if output is analog	18003
Setup	SEt	Output x	OtPt		1 or 3			Output Function Instance	F.i	if output is analog	18004
Setup	SEt	Output x	OtPt		1 or 3			Scale Low	S.Lo	if output is analog	18009
Setup	SEt	Output x	OtPt		1 or 3			Scale High	S.h	if output is analog	18010
Setup	SEt	Output x	OtPt		1 or 3			Range Low	r.Lo	if output is analog	18011
Setup	SEt	Output x	OtPt		1 or 3			Range High	r.h	if output is analog	18012
Setup	SEt	Output x	OtPt		1 or 3			Calibration Offset	o.CA	if output is analog	18007

EZ-ZONE PM Standard Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Alarm x	ALM1		1 - 4			Alarm Type	A.tY	always	9015
Setup	SEt	Alarm x	ALM1		1 - 4			Alarm Source	Sr.A	always	9017
Setup	SEt	Alarm x	ALM1		1 - 4			Alarm Source Instance	,S.A	If PN digit 9 is not an A or T	9018
Setup	SEt	Alarm x	ALM1		1 - 4			Control Loop	LooP	If PN digit 9 is a C or J	9023
Setup	SEt	Alarm x	ALM1		1 - 4			Alarm Hysteresis	A.hY	always	9003
Setup	SEt	Alarm x	ALM1		1 - 4			Alarm Logic	A.L9	always	9005
Setup	SEt	Alarm x	ALM1		1 - 4			Alarm Sides	A.Sd	always	9004
Setup	SEt	Alarm x	ALM1		1 - 4			Alarm Low Set Point	A.Lo	always	9002
Setup	SEt	Alarm x	ALM1	always	1 - 4	Always		Alarm High Set Point	A.h,	always	9001
Setup	SEt	Alarm x	ALM1		1 - 4			Alarm Latching	A.LA	always	9007
Setup	SEt	Alarm x	ALM1		1 - 4			Alarm Blocking	A.bL	always	9008
Setup	SEt	Alarm x	ALM1		1 - 4			Alarm Silencing	A.S,	always	9006
Setup	SEt	Alarm x	ALM1		1 - 4			Alarm Display	A.dSP	always	9016
Setup	SEt	Alarm x	ALM1		1 - 4			Alarm Delay Time	A.dL	always	9021
Setup	SEt	Alarm x	ALM1		1 - 4			Alarm Clear Request	A.CLr	always	9026
Setup	SEt	Alarm x	ALM1		1 - 4			Alarm Silence	A.S,r	always	9027
Setup	SEt	Alarm x	ALM1		1 - 4			Alarm State	A.St	always	9009
Setup	SEt	Current 1	CUrr		1			Current Sides	C.Sd	always	15005
Setup	SEt	Current 1	CUrr		1			Current Read Enable	C.Ur	always	15004
Setup	SEt	Current 1	CUrr	If 9th digit of model number is a T	1	Always		Input Current Detection Threshold	C.dt	always	15012
Setup	SEt	Current 1	CUrr		1			Current Scaling	C.SC	always	15022
Setup	SEt	Current 1	CUrr		1			Heater Current Offset	C.oFS	always	15011
Setup	SEt	Current 1	CUrr		1			Current Output Source Instance	C.S,	always	15019
Setup	SEt	Math 1	MAth		1			Function	Fn	always	25021
Setup	SEt	Math 1	MAth		1			Source Function E	SFn.E	always	25005
Setup	SEt	Math 1	MAth		1			Source Instance E	S,E	always	25010
Setup	SEt	Math 1	MAth	if 9th digit of PN is a C or J AND	1	Always		Scale Low	S.Lo	always	25024
Setup	SEt	Math 1	MAth	12th digit of PN is a C	1			Scale High	S.h,	always	25025
Setup	SEt	Math 1	MAth		1			Range Low	r.Lo	always	25026
Setup	SEt	Math 1	MAth		1			Range High	r.h,	always	25027
Setup	SEt	Math 1	MAth		1			Filter	F,L	always	25028
Setup	SEt	Special Output Function 1	SoF		1			Function	Fn	always	35009
Setup	SEt	Special Output Function 1	SoF		1			Souce Function A	SFn.A	always	35001
Setup	SEt	Special Output Function 1	SoF		1			Source Instance A	S,A	always	35003
Setup	SEt	Special Output Function 1	SoF		1			Source Function B	SFn.b	always	35002
Setup	SEt	Special Output Function 1	SoF		1			Source Instance B	S,b	always	35004
Setup	SEt	Special Output Function 1	SoF	If 12th digit of PN is a C	1			Power On Level 1	Pon.A	always	35018
Setup	SEt	Special Output Function 1	SoF		1			Power Off Level 1	PoF.A	always	35019
Setup	SEt	Special Output Function 1	SoF		1	Always		Power On Level 2	Pon.b	always	35020
Setup	SEt	Special Output Function 1	SoF		1			Power Off Level 2	PoF.b	always	35021
Setup	SEt	Special Output Function 1	SoF		1			On Time	on.t	always	35022
Setup	SEt	Special Output Function 1	SoF		1			Off Time	oF.t	always	35023
Setup	SEt	Special Output Function 1	SoF		1			Valve Travel Time	t.t	always	35024

EZ-ZONE PM Standard Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Special Output Function 1	SoF		1			Dead Band	db	always	35025
Setup	SEt	Special Output Function 1	SoF		1			Time Delay	t.dL	always	35026
Setup	SEt	Function Key 1	Fun	If 3rd digit of PN is not a 3	1	instance 1 Always instance 2 if 3rd digit of PN is not 6		Active Level	LEu	always	10001
Setup	SEt	Function Key 1	Fun		1			Action Function	Fn	always	10003
Setup	SEt	Function Key 1	Fun		1			Function Instance	F i	always	10004
Setup	SEt	Function Key 2	Fun		2			Active Level	LEu	always	10001
Setup	SEt	Function Key 2	Fun		2			Action Function	Fn	always	10003
Setup	SEt	Function Key 2	Fun		2			Function Instance	F i	always	10004
Setup	SEt	Global 1	GLbL	always	1	Always		Display Units	C_F	always	3005
Setup	SEt	Global 1	GLbL		1			AC Line Frequency	AC.LF	always	1034
Setup	SEt	Global 1	GLbL		1			Ramping Type	r.tyP	If 4th digit of PN = B, E, R or N	22038
Setup	SEt	Global 1	GLbL		1			Profile Type	P.tyP	If 4th digit of PN = B, E, R or N	22008
Setup	SEt	Global 1	GLbL		1			Guaranteed Soak Enable	gSE	If 4th digit of PN = B, E, R or N	22006
Setup	SEt	Global 1	GLbL		1			Guaranteed Soak Deviation 1	gSd1	If 4th digit of PN = B, E, R or N	22007
Setup	SEt	Global 1	GLbL		1			Guaranteed Soak Deviation 2	gSd2	If 4th digit of PN = B, E, R or N AND PN digit 9 is C or J	22041
Setup	SEt	Global 1	GLbL		1			Source Instance A	S i.A	if 3rd digit of PN is not a 3 or 6 AND 4th digit of PN = B, E, R or N	22026
Setup	SEt	Global 1	GLbL		1			Source Instance B	S i.b	if 2nd digit of PN is not a 3 or 6 AND 3rd digit of PN = B, E, R or N	22027
Setup	SEt	Global 1	GLbL		1			Power Off Time	Pot i	If 4th digit of PN = B, E	22073
Setup	SEt	Global 1	GLbL		1			Synchronized Variable Time Base	Sutb	If 4th digit of PN = R, B, E or N	1048
Setup	SEt	Global 1	GLbL		1			Communications Led Action	CLEd	always	3014
Setup	SEt	Global 1	GLbL		1			Zone	ZonE	always	3026
Setup	SEt	Global 1	GLbL		1			Channel	ChAn	always	3027
Setup	SEt	Global 1	GLbL		1			Display Pairs	dPrS	always	3028
Setup	SEt	Global 1	GLbL		1			Display Time	dt i	always	3029
Setup	SEt	Global 1	GLbL		1			User Settings Save	USr.S	always	1014
Setup	SEt	Global 1	GLbL		1			User Settings Restore	USr.r	always	1013
Setup	SEt	Communications 1	Com		1			Protocol	PCoL	if 8th digit of PN = 1 or D	17009
Setup	SEt	Communications 1	Com		1			Standard Bus Address	Ad.S	always	17001
Setup	SEt	Communications x	Com		1-2			Modbus Address	Ad.M	if 8th digit of PN = 1, 2, or D	17007
Setup	SEt	Communications x	Com		1-2			Baud Rate	bAUd	if 8th digit of PN = 1, 2, or D	17002
Setup	SEt	Communications x	Com		1-2			Parity	PAr	if 8th digit of PN = 1, 2, or D	17003
Setup	SEt	Communications x	Com		1-2			Modbus Word Order	M.hL	if 8th digit of PN = 1, 2, 3, 4, or D	17043
Setup	SEt	Communications 2	Com		2			IP Address Mode	i.PM	if 8th digit of PN = 3 or 4	17012
Setup	SEt	Communications 2	Com		2			IP Fixed Address Part 1	i.F1	if 8th digit of PN = 3 or 4	17014
Setup	SEt	Communications 2	Com		2			IP Fixed Address Part 2	i.F2	if 8th digit of PN = 3 or 4	17015
Setup	SEt	Communications 2	Com		2			IP Fixed Address Part 3	i.F3	if 8th digit of PN = 3 or 4	17016
Setup	SEt	Communications 2	Com		2			IP Fixed Address Part 4	i.F4	if 8th digit of PN = 3 or 4	17017
Setup	SEt	Communications 2	Com		2			IP Fixed Address Part 5	i.F5	if 8th digit of PN = 3 or 4	17018
Setup	SEt	Communications 2	Com		2			IP Fixed Address Part 6	i.F6	if 8th digit of PN = 3 or 4	17019
Setup	SEt	Communications 2	Com		2			IP Fixed Subnet Part 1	i.S1	if 8th digit of PN = 3 or 4	17020
Setup	SEt	Communications 2	Com		2			IP Fixed Subnet Part 2	i.S2	if 8th digit of PN = 3 or 4	17021
Setup	SEt	Communications 2	Com		2			IP Fixed Subnet Part 3	i.S3	if 8th digit of PN = 3 or 4	17022
Setup	SEt	Communications 2	Com		2			IP Fixed Subnet Part 4	i.S4	if 8th digit of PN = 3 or 4	17023

EZ-ZONE PM Standard Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Communications 2	Comm	always	2	Instance 1 Always; Instance 2 if 8th digit of model number is 2, 3, 4, 5, or 6		IP Fixed Subnet Part 5	IP.S5	if 8th digit of PN = 3 or 4	17024
Setup	SEt	Communications 2	Comm		2			IP Fixed Subnet Part 6	IP.S6	if 8th digit of PN = 3 or 4	17025
Setup	SEt	Communications 2	Comm		2			Fixed IP Gateway Part 1	IP.g1	if 8th digit of PN = 3 or 4	17026
Setup	SEt	Communications 2	Comm		2			Fixed IP Gateway Part 2	IP.g2	if 8th digit of PN = 3 or 4	17027
Setup	SEt	Communications 2	Comm		2			Fixed IP Gateway Part 3	IP.g3	if 8th digit of PN = 3 or 4	17028
Setup	SEt	Communications 2	Comm		2			Fixed IP Gateway Part 4	IP.g4	if 8th digit of PN = 3 or 4	17029
Setup	SEt	Communications 2	Comm		2			Fixed IP Gateway Part 5	IP.g5	if 8th digit of PN = 3 or 4	17030
Setup	SEt	Communications 2	Comm		2			Fixed IP Gateway Part 6	IP.g6	if 8th digit of PN = 3 or 4	17031
Setup	SEt	Communications 2	Comm		2			Modbus TCP Enable	Mb.E	if 8th digit of PN = 3 or 4	17041
Setup	SEt	Communications 2	Comm		2			EtherNet/IP Enable	E.IPE	if 8th digit of PN = 3 or 4	17042
Setup	SEt	Communications 2	Comm		2			DeviceNet Node Address	Add	if 8th digit of PN = 5	17052
Setup	SEt	Communications 2	Comm		2			Baud Rate DeviceNet	bAUd	if 8th digit of PN = 5	17053
Setup	SEt	Communications 2	Comm		2			DeviceNet Quick Connect Enable	FC.E	if 8th digit of PN = 5	17054
Setup	SEt	Communications 2	Comm		2			CIP Implicit Assembly Output Member Quantity	Ao.nb	if 8th digit of PN = 3, 4 or 5	24009
Setup	SEt	Communications 2	Comm		2			CIP Implicit Assembly Input Member Quantity	A .nb	if 8th digit of PN = 3, 4 or 5	24010
Setup	SEt	Communications 2	Comm		2			CANopen Node ID	Ad.C	if 8th digit of PN = 7	17055
Setup	SEt	Communications 2	Comm		2			CANopen Bit Rate	bAUd	if 8th digit of PN = 7	17056
Setup	SEt	Communications 2	Comm		2			CANopen PDO Assembly Member Quantity	An.b	if 8th digit of PN = 7	17057
Setup	SEt	Communications 2	Comm		2			Profibus Node Address	P.Add	if 8th digit of PN = 6	17060
Setup	SEt	Communications 2	Comm		2			Profibus Address Lock	A.Loc	if 8th digit of PN = 6	17061
Setup	SEt	Communications 2	Comm		2			Profibus Status	StAt	if 8th digit of PN = 6	17063
Setup	SEt	Communications x	Comm		1-2			Display Units	C_F	instance 1: if 8th digit of PN = 1 or D instance 2:ALways	17050
Setup	SEt	Communications x	Comm		1-2			Data Map	MAP	always	17059
Setup	SEt	Communications x	Comm		1-2			Non-Volatile Save	nU.S	always	17051
Setup	SEt	Real Time Clock 1	rtC	If 4th digit of model number is an B or E	1	Always		Hours	hoUr	always	36003
Setup	SEt	Real Time Clock 1	rtC		1			Minutes	Min	always	36004
Setup	SEt	Real Time Clock 1	rtC		1			Day of Week	doW	always	36002
Factory	FCtY	Custom Setup x	CuSt	always	1 - 20	Always		Parameter	PAr	always	14005
Factory	FCtY	Custom Setup x	CuSt		1 - 20			Instance ID	.id	always	14003
Factory	FCtY	Lock 1	LoC	If DspLockedState = PASS ADMIN	1	Always		Operations Page	LoC.o	always	3002
Factory	FCtY	Lock 1	LoC		1			Profilng Page	LoC.P	If 4th digit of PN = R, B, E or N	3008
Factory	FCtY	Lock 1	LoC		1			Password Enable	PASE	always	3015
Factory	FCtY	Lock 1	LoC		1			Read Lock	rLoC	always	3010
Factory	FCtY	Lock 1	LoC		1			Write Security	SLoC	always	3011
Factory	FCtY	Lock 1	LoC		1			Locked Access Level	LoC.L	always	3016
Factory	FCtY	Lock 1	LoC		1			Rolling Password	roLL	always	3019
Factory	FCtY	Lock 1	LoC		1			User Password	PAS.u	always	3017
Factory	FCtY	Lock 1	LoC		1			Administrator Password	PAS.A	always	3018
Factory	FCtY	Unlock 1	ULoC	If DspSecurityEnable == ON	1	Always		Public Key	CodE	always	3020
Factory	FCtY	Unlock 1	ULoC		1			Password	PASS	always	3022
Factory	FCtY	Diagnostics 1	diAG		1			Part Number	Pn	always	1009
Factory	FCtY	Diagnostics 1	diAG		1			Software Revision	rEv	always	1017

EZ-ZONE PM Standard Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Factory	FctY	Diagnostics 1	d iAG	always	1	Always		Software Build Number	S.bLd	always	1005
Factory	FctY	Diagnostics 1	d iAG		1			Serial Number	Sn	always	1032
Factory	FctY	Diagnostics 1	d iAG		1			Date of Manufacture	dAtE	always	1008
Factory	FctY	Diagnostics 1	d iAG		1			Actual IP Addressing Mode	iP.AC	if 8th digit of PN = 3 or 4	17013
Factory	FctY	Diagnostics 1	d iAG		1			IP Actual Address Part 1	iP.A1	if 8th digit of PN = 3 or 4	17044
Factory	FctY	Diagnostics 1	d iAG		1			IP Actual Address Part 2	iP.A2	if 8th digit of PN = 3 or 4	17045
Factory	FctY	Diagnostics 1	d iAG		1			IP Actual Address Part 3	iP.A3	if 8th digit of PN = 3 or 4	17046
Factory	FctY	Diagnostics 1	d iAG		1			IP Actual Address Part 4	iP.A4	if 8th digit of PN = 3 or 4	17047
Factory	FctY	Diagnostics 1	d iAG		1			IP Actual Address Part 5	iP.A5	if 8th digit of PN = 3 or 4	17048
Factory	FctY	Diagnostics 1	d iAG		1			IP Actual Address Part 6	iP.A6	if 8th digit of PN = 3 or 4	17049
Factory	FctY	Calibration x	CAL	always	1 - 2	Instance 1= Always; Instance 2 if 9th digit of model number is an C, J, R, P, M or L		Electrical Measurement	mnu	always	4021
Factory	FctY	Calibration x	CAL		1 - 2			Electrical Input Offset	EL io	always	4010
Factory	FctY	Calibration x	CAL		1 - 2			Electrical Input Slope	EL iS	always	4011
Factory	FctY	Calibration 1	CAL		1	Instance 1 Only		Part Number	Pn	always	1046
Factory	FctY	Calibration 1	CAL		1	Instance 1 Only		Public Key	CodE	always	1047
Factory	FctY	Calibration x	CAL		1 or 3	Instance 1 if 6th digit is F; Instance 3 if 10th digit is F		Electrical Output Offset	ELo.o	always	18005
Factory	FctY	Calibration x	CAL		1 or 3			Electrical Output Slope	ELo.S	always	18006
Profile	ProF	Profile 1 Step x	P 1		1 - 10			Step Type	S.tyP	always	21001
Profile	ProF	Profile 1 Step x	P 1		1 - 10			Target Set Point Loop 1	t.SP 1	always	21002
Profile	ProF	Profile 1 Step x	P 1		1 - 10			Target Set Point Loop 2	t.SP2	If PN digit 9 is C or J	21028
Profile	ProF	Profile 1 Step x	P 1		1 - 10			Hours	hoUr	always	21003
Profile	ProF	Profile 1 Step x	P 1		1 - 10			Minutes	mn in	always	21004
Profile	ProF	Profile 1 Step x	P 1		1 - 10			Seconds	SEC	always	21005
Profile	ProF	Profile 1 Step x	P 1		1 - 10			Rate	rAtE	always	21006
Profile	ProF	Profile 1 Step x	P 1		1 - 10			Wait for Process Instance	WP i	always	21015
Profile	ProF	Profile 1 Step x	P 1	always	1 - 10			Wait For Process 1	WP 1	always	21011
Profile	ProF	Profile 1 Step x	P 1		1 - 10			Wait Event 1	WE.1	always	21009
Profile	ProF	Profile 1 Step x	P 1		1 - 10			Wait Event 2	WE.2	always	21010
Profile	ProF	Profile 1 Step x	P 1		1 - 10			Day of Week	doW	If PN digit 4 is a B or E	21041
Profile	ProF	Profile 1 Step x	P 1		1 - 10			Jump Step	JS	always	21012
Profile	ProF	Profile 1 Step x	P 1		1 - 10			Jump Count	JC	always	21013
Profile	ProF	Profile 1 Step x	P 1		1 - 10			End Type	End	always	21014
Profile	ProF	Profile 1 Step x	P 1		1 - 10			Event 1	Ent 1	always	21007
Profile	ProF	Profile 1 Step x	P 1		1 - 10			Event 2	Ent2	always	21008
Profile	ProF	Profile 2 Step x	P2		11 - 20			Step Type	S.tyP	always	21001
Profile	ProF	Profile 2 Step x	P2		11 - 20			Target Set Point Loop 1	t.SP 1	always	21002
Profile	ProF	Profile 2 Step x	P2		11 - 20			Target Set Point Loop 2	t.SP2	If PN digit 9 is C or J	21028
Profile	ProF	Profile 2 Step x	P2		11 - 20			Hours	hoUr	always	21003
Profile	ProF	Profile 2 Step x	P2		11 - 20			Minutes	mn in	always	21004
Profile	ProF	Profile 2 Step x	P2		11 - 20			Seconds	SEC	always	21005
Profile	ProF	Profile 2 Step x	P2		11 - 20			Rate	rAtE	always	21006
Profile	ProF	Profile 2 Step x	P2		11 - 20			Wait for Process Instance	WP i	always	21015
Profile	ProF	Profile 2 Step x	P2	always	11 - 20			Wait For Process 1	WP 1	always	21011
Profile	ProF	Profile 2 Step x	P2		11 - 20			Wait Event 1	WE.1	always	21009

EZ-ZONE PM Standard Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 2 Step x	P2		11 - 20			Wait Event 2	WJE.2	always	21010
Profile	ProF	Profile 2 Step x	P2		11 - 20			Day of Week	doWJ	If PN digit 4 is a B or E	21041
Profile	ProF	Profile 2 Step x	P2		11 - 20			Jump Step	JS	always	21012
Profile	ProF	Profile 2 Step x	P2		11 - 20			Jump Count	JC	always	21013
Profile	ProF	Profile 2 Step x	P2		11 - 20			End Type	End	always	21014
Profile	ProF	Profile 2 Step x	P2		11 - 20			Event 1	Ent 1	always	21007
Profile	ProF	Profile 2 Step x	P2		11 - 20			Event 2	Ent2	always	21008
Profile	ProF	Profile 3 Step x	P3		21 - 30			Step Type	StYP	always	21001
Profile	ProF	Profile 3 Step x	P3		21 - 30			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 3 Step x	P3		21 - 30			Target Set Point Loop 2	tSP2	If PN digit 9 is C or J	21028
Profile	ProF	Profile 3 Step x	P3		21 - 30			Hours	hoUr	always	21003
Profile	ProF	Profile 3 Step x	P3		21 - 30			Minutes	MIn	always	21004
Profile	ProF	Profile 3 Step x	P3		21 - 30			Seconds	SEC	always	21005
Profile	ProF	Profile 3 Step x	P3		21 - 30			Rate	rAtE	always	21006
Profile	ProF	Profile 3 Step x	P3		21 - 30			Wait for Process Instance	WJP1	always	21015
Profile	ProF	Profile 3 Step x	P3	always	21 - 30			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 3 Step x	P3		21 - 30			Wait Event 1	WJE.1	always	21009
Profile	ProF	Profile 3 Step x	P3		21 - 30			Wait Event 2	WJE.2	always	21010
Profile	ProF	Profile 3 Step x	P3		21 - 30			Day of Week	doWJ	If PN digit 4 is a B or E	21041
Profile	ProF	Profile 3 Step x	P3		21 - 30			Jump Step	JS	always	21012
Profile	ProF	Profile 3 Step x	P3		21 - 30			Jump Count	JC	always	21013
Profile	ProF	Profile 3 Step x	P3		21 - 30			End Type	End	always	21014
Profile	ProF	Profile 3 Step x	P3		21 - 30			Event 1	Ent 1	always	21007
Profile	ProF	Profile 3 Step x	P3		21 - 30			Event 2	Ent2	always	21008
Profile	ProF	Profile 4 Step x	P4		31 - 40			Step Type	StYP	always	21001
Profile	ProF	Profile 4 Step x	P4		31 - 40			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 4 Step x	P4		31 - 40			Target Set Point Loop 2	tSP2	If PN digit 9 is C or J	21028
Profile	ProF	Profile 4 Step x	P4		31 - 40			Hours	hoUr	always	21003
Profile	ProF	Profile 4 Step x	P4		31 - 40			Minutes	MIn	always	21004
Profile	ProF	Profile 4 Step x	P4		31 - 40			Seconds	SEC	always	21005
Profile	ProF	Profile 4 Step x	P4		31 - 40			Rate	rAtE	always	21006
Profile	ProF	Profile 4 Step x	P4		31 - 40			Wait for Process Instance	WJP1	always	21015
Profile	ProF	Profile 4 Step x	P4	always	31 - 40			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 4 Step x	P4		31 - 40			Wait Event 1	WJE.1	always	21009
Profile	ProF	Profile 4 Step x	P4		31 - 40			Wait Event 2	WJE.2	always	21010
Profile	ProF	Profile 4 Step x	P4		31 - 40			Day of Week	doWJ	If PN digit 4 is a B or E	21041
Profile	ProF	Profile 4 Step x	P4		31 - 40			Jump Step	JS	always	21012
Profile	ProF	Profile 4 Step x	P4		31 - 40			Jump Count	JC	always	21013
Profile	ProF	Profile 4 Step x	P4		31 - 40			End Type	End	always	21014
Profile	ProF	Profile 4 Step x	P4		31 - 40			Event 1	Ent 1	always	21007
Profile	ProF	Profile 4 Step x	P4		31 - 40			Event 2	Ent2	always	21008

EZ-ZONE PM Express

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Factory	FctY	Custom Setup x	CuSt	always	1 - 2	always		Parameter	PAr	always	14005
Factory	FctY	Lock 1	LoC	always	1	always		Write Security	LoC	always	3011
Factory	FctY	Diagnostics 1	diAG	always	1	always		Part Number	Pn	always	1009
Factory	FctY	Diagnostics 1	diAG		1			Software Revision	rEv	always	1017
Factory	FctY	Diagnostics 1	diAG		1			Software Build Number	S.bLd	always	1005
Factory	FctY	Diagnostics 1	diAG		1			Serial Number	Sn	always	1032
Factory	FctY	Diagnostics 1	diAG		1			Date of Manufacture	dAtE	always	1008
Factory	FctY	Diagnostics 1	diAG		1			User Settings Restore	USr.r	always	1013
Factory	FctY	Diagnostics 1	diAG		1			Zone	ZonE	always	3026
Factory	FctY	Calibration 1	CAL	always	1	always		Electrical Measurement	mAv	always	4021
Factory	FctY	Calibration 1	CAL		1			Electrical Input Offset	EL.io	always	4010
Factory	FctY	Calibration 1	CAL		1			Electrical Input Slope	EL.iS	always	4011
Factory	FctY	Calibration 1	CAL		1	If 6th digit is F		Electrical Output Offset	ELo.o	always	18005
Factory	FctY	Calibration 1	CAL		1			Electrical Output Slope	ELo.S	always	18006
Factory	FctY	Calibration 1	CAL	always	1	always		Part Number	Pn	always	1046
Factory	FctY	Calibration 1	CAL	always	1	always		Public Key	CodE	always	1047

EZ-ZONE PM Express

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Simple Setup								Lock	LoC	always	3011
Simple Setup								Sensor Type	SEn	always	4005
Simple Setup								TC Linearization	L in	always	4006
Simple Setup								Display Precision	dEC	always	4020
Simple Setup								Display Units	C-F	always	3005
Simple Setup								Range Low	rL	always	4017
Simple Setup								Range High	rh	always	4018
Simple Setup								Output Function	Fn1	if 6th digit is C, E, or K	6005
Simple Setup								Output Function	Fn1	if 6th digit is F	18002
Simple Setup								Output Type	oty	if 6th digit is F	18001
Simple Setup								Function of Output 2	Fn2	if 7th digit is C, H, J, or K	6005
Simple Setup								Heat Algorithm	hAG	if 4th digit is C {product is a control}	8003
Simple Setup								Cool Algorithm	CAG		8004
Simple Setup								Heat Hysteresis (Heat & Cool)	hSC		8010
Simple Setup								Limit Sides	LSd	if 4th digit is L {product is limit}	12005
Simple Setup								Limit Hysteresis	LYS		12002
Simple Setup				always				Alarm Type	AtY	always	9015
Simple Setup								Alarm Hysteresis	AhY	always	9003
Simple Setup								Alarm Logic	hSC	always	9005
Simple Setup								Alarm Latching	ALA	always	9007
Simple Setup								Alarm Blocking	AbL	always	9008
Simple Setup								Alarm Silencing	SiL	always	9006
Simple Setup								Alarm Display	AdSP	always	9016
Simple Setup								Ramp Action	rP	if 4th digit is C {product is a control}	7014
Simple Setup								Ramp Rate	rrt		7017
Simple Setup								Output High Power Scale (1)	oh i1	if 6th digit is C, E, or K and 4th digit is C	6010
Simple Setup								Scale Low Output 1	SLo	if 6th digit is F	18009
Simple Setup								Scale High Output 1	Sh i	if 6th digit is F	18010
Simple Setup								Output High Power Scale (2)	oh i2	if 7th digit is C, H, J, or K AND 4th digit is C	6010
Simple Setup								Parameter (red display)	PAr 1	always	14005
Simple Setup								Parameter (green display)	PAr2	always	14005
Simple Setup								Standard Bus Address	Ad5	always	17001

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Analog Input x	A i	If model number character 4, 6, 8, or 10 is a 1,2,3,4,5, 6, R, or P	1 - 4	Instance 1 = 4th character Instance 2 = 6th character Instance 3 = 8th character Instance 4 = 10th character If character = 1-6,R,P then visible		Analog Input Value	A in	always	4001
Operations	oPEr	Analog Input x	A i		1 - 4			Input Error	i.Er	always	4002
Operations	oPEr	Analog Input x	A i		1 - 4			Calibration Offset	i.CA	always	4012
Operations	oPEr	Process Value x	Pu	If model number character 4, 6, 8, or 10 is a 1,2,3,4,5, 6, R, or P	1 - 4	Instance 1 = 4th character Instance 2 = 6th character Instance 3 = 8th character Instance 4 = 10th character If character = 1-4 then visible		Source Value A	Su.A	always	26016
Operations	oPEr	Process Value x	Pu		1 - 4			Source Value B	Su.b	always	26017
Operations	oPEr	Process Value x	Pu		1 - 4			Source Value C	Su.C	always	26018
Operations	oPEr	Process Value x	Pu		1 - 4			Source Value D	Su.d	always	26019
Operations	oPEr	Process Value x	Pu		1 - 4			Source Value E	Su.E	always	26020
Operations	oPEr	Process Value x	Pu		1 - 4			Offset	oFSt	always	26023
Operations	oPEr	Process Value x	Pu		1 - 4			Output Value	o.u	always	26022
Operations	oPEr	Digital I/O x	d io	If model number character 11 is a C	7-12	always		Output State	do.S	always	6007
Operations	oPEr	Digital I/O x	d io		7-12			Input State	d i.S	always	6011
Operations	oPEr	Action x	ACt	always	1 - 8	always		Event Status	E i.S	always	10005
Operations	oPEr	Limit x	L iM1	If model number character 4, 6, 8, or 10 is a 5 or 6	1 - 4	Instance 1 = 4th character Instance 2 = 6th character Instance 3 = 8th character Instance 4 = 10th character If character = 5-6 then visible		Limit Low Set Point	LLS	always	12003
Operations	oPEr	Limit x	L iM1		1 - 4			Limit High Set Point	Lh.S	always	12004
Operations	oPEr	Limit x	L iM1		1 - 4			Limit Clear Request	LCr	always	12014
Operations	oPEr	Limit x	L iM1		1 - 4			Limit Status	L.St	always	12013
Operations	oPEr	Monitor x	M on	If model number character 4, 6, 8, or 10 is a 1,2,3, or 4	1 - 4	Instance 1 = 4th character Instance 2 = 6th character Instance 3 = 8th character Instance 4 = 10th character If character = 1-4 then visible		Control Mode Active	C.M1A	always	8002
Operations	oPEr	Monitor x	M on		1 - 4			Heat Power	h.Pr	always	8011
Operations	oPEr	Monitor x	M on		1 - 4			Cool Power	C.Pr	always	8014
Operations	oPEr	Monitor x	M on		1 - 4			Closed-Loop Set Point	C.SP	always	8029
Operations	oPEr	Monitor x	M on		1 - 4			Process Value Active	Pu.A	always	8031
Operations	oPEr	Control Loop x	LooP	If model number character 4, 6, 8, or 10 is a 1,2,3, or 4	1 - 4	Instance 1 = 4th character Instance 2 = 6th character Instance 3 = 8th character Instance 4 = 10th character If character = 1-4 then visible		Remote Enable	r.En	always	7021
Operations	oPEr	Control Loop x	LooP		1 - 4			Control Mode	C.M1	always	8001
Operations	oPEr	Control Loop x	LooP		1 - 4			Autotune Set Point	At.SP	always	8025
Operations	oPEr	Control Loop x	LooP		1 - 4			Autotune	AUt	always	8026
Operations	oPEr	Control Loop x	LooP		1 - 4			Closed-Loop Set Point	C.SP	always	7001
Operations	oPEr	Control Loop x	LooP		1 - 4			Idle Set Point	id.S	always	7009
Operations	oPEr	Control Loop x	LooP		1 - 4			Heat Proportional Band	h.Pb	always	8009
Operations	oPEr	Control Loop x	LooP		1 - 4			Heat Hysteresis	h.hy	always	8010
Operations	oPEr	Control Loop x	LooP		1 - 4			Cool Proportional Band	C.Pb	always	8012
Operations	oPEr	Control Loop x	LooP		1 - 4			Cool Hysteresis	C.hy	always	8013
Operations	oPEr	Control Loop x	LooP		1 - 4			Time Integral	t i	always	8006
Operations	oPEr	Control Loop x	LooP		1 - 4			Time Derivative	td	always	8007
Operations	oPEr	Control Loop x	LooP		1 - 4			Dead Band	db	always	8008
Operations	oPEr	Control Loop x	LooP		1 - 4			Open Loop Set Point	o.SP	always	7002
Operations	oPEr	Alarm x	ALM1		1 - 8			Alarm Low Set Point	A.Lo	always	9002
Operations	oPEr	Alarm x	ALM1		1 - 8			Alarm High Set Point	A.h i	always	9001

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Alarm x	ALM1	always	1 - 8	always		Alarm Clear Request	A.CLr	always	9026
Operations	oPEr	Alarm x	ALM1		1 - 8			Alarm Silence Request	A.SIr	always	9027
Operations	oPEr	Alarm x	ALM1		1 - 8			Alarm State	A.St	always	9009
Operations	oPEr	Current x	Curr	If model number character 4, 6, 8, or 10 is a 7	1 - 4	Instance 1 = 4th character Instance 2 = 6th character Instance 3 = 8th character Instance 4 = 10th character If character = 7 then visible		Current High Set Point	C.hi	always	15008
Operations	oPEr	Current x	Curr		1 - 4			Current Low Set Point	C.Lo	always	15009
Operations	oPEr	Current x	Curr		1 - 4			Current Read	CU.r	always	15007
Operations	oPEr	Current x	Curr		1 - 4			Current Error	C.Er	always	15002
Operations	oPEr	Current x	Curr		1 - 4			Heater Error	h.Er	always	15003
Operations	oPEr	Linearization x	Lin	always	1 - 4	always		Source Value A	Su.A	always	34004
Operations	oPEr	Linearization x	Lin		1 - 4			Offset	oFSt	always	34006
Operations	oPEr	Linearization x	Lin		1 - 4			Output Value	o.u	always	34007
Operations	oPEr	Compare x	CPE	always	1 - 4	always		Source Value A	Su.A	always	28007
Operations	oPEr	Compare x	CPE		1 - 4			Source Value B	Su.b	always	28008
Operations	oPEr	Compare x	CPE		1 - 4			Output Value	o.u	always	28010
Operations	oPEr	Timer x	tMr	always	1 - 4	always		Source Value A	Su.A	always	31007
Operations	oPEr	Timer x	tMr		1 - 4			Source Value B	Su.b	always	31008
Operations	oPEr	Timer x	tMr		1 - 4			Elapsed Time	Et	always	31016
Operations	oPEr	Timer x	tMr		1 - 4			Output Value	o.u	always	31010
Operations	oPEr	Timer x	tMr								
Operations	oPEr	Counter x	Ctr	always	1 - 4	always		Count	Cnt	always	30015
Operations	oPEr	Counter x	Ctr		1 - 4			Source Value A	Su.A	always	30007
Operations	oPEr	Counter x	Ctr		1 - 4			Source Value B	Su.b	always	30008
Operations	oPEr	Counter x	Ctr		1 - 4			Output Value	o.u	always	30010
Operations	oPEr	Logic x	LGC	always	1 - 4	always		Source Value A	Su.A	always	27025
Operations	oPEr	Logic x	LGC		1 - 4			Source Value B	Su.b	always	27026
Operations	oPEr	Logic x	LGC		1 - 4			Source Value C	Su.C	always	27027
Operations	oPEr	Logic x	LGC		1 - 4			Source Value D	Su.d	always	27028
Operations	oPEr	Logic x	LGC		1 - 4			Source Value E	Su.E	always	27029
Operations	oPEr	Logic x	LGC		1 - 4			Source Value F	Su.F	always	27030
Operations	oPEr	Logic x	LGC		1 - 4			Source Value G	Su.g	always	27031
Operations	oPEr	Logic x	LGC		1 - 4			Source Value H	Su.h	always	27032
Operations	oPEr	Logic x	LGC		1 - 4			Output Value	o.u	always	27034
Operations	oPEr	Math x	MAt	always	1-8	always		Source Value A	Su.A	always	25016
Operations	oPEr	Math x	MAt		1-8			Source Value B	Su.b	always	25017
Operations	oPEr	Math x	MAt		1-8			Source Value C	Su.C	always	25018
Operations	oPEr	Math x	MAt		1-8			Source Value D	Su.d	always	25019
Operations	oPEr	Math x	MAt		1-8			Source Value E	Su.E	always	25020
Operations	oPEr	Math x	MAt		1-8			Offset	oFSt	always	25023
Operations	oPEr	Math x	MAt		1-8			Output Value	o.u	always	25022
Operations	oPEr	Special Output Function x	SoF		1-4			Source Value A	Su.A	always	35007

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Special Output Function x	SoF	always	1-4	always		Source Value B	Sub	always	35008
Operations	oPEr	Special Output Function x	SoF		1-4			Output Value 1	ou1	always	35010
Operations	oPEr	Special Output Function x	SoF		1-4			Output Value 2	ou2	always	35012
Operations	oPEr	Special Output Function x	SoF		1-4			Output Value 3	ou3	always	35014
Operations	oPEr	Special Output Function x	SoF		1-4			Output Value 4	ou4	always	35016
Operations	oPEr	Profile Status 1	PStA	If model number character 4 is a 3 or 4	1	always		Profile Start	PStr	always	22001
Operations	oPEr	Profile Status 1	PStA		1			Profile Action Request	PAcr	always	22011
Operations	oPEr	Profile Status 1	PStA		1			Current Step	StP	always	22004
Operations	oPEr	Profile Status 1	PStA		1			Current Sub Step	SUbS	always	22055
Operations	oPEr	Profile Status 1	PStA		1			Step Type	StyP	always	22013
Operations	oPEr	Profile Status 1	PStA		1			Target Set Point Loop 1	tSP1	always	22012
Operations	oPEr	Profile Status 1	PStA		1			Target Set Point Loop 2	tSP2	always	22048
Operations	oPEr	Profile Status 1	PStA		1			Target Set Point Loop 3	tSP3	always	22049
Operations	oPEr	Profile Status 1	PStA		1			Target Set Point Loop 4	tSP4	always	22050
Operations	oPEr	Profile Status 1	PStA		1			Produced Set Point 1	PSP1	always	22005
Operations	oPEr	Profile Status 1	PStA		1			Produced Set Point 2	PSP2	always	22051
Operations	oPEr	Profile Status 1	PStA		1			Produced Set Point 3	PSP3	always	22052
Operations	oPEr	Profile Status 1	PStA		1			Produced Set Point 4	PSP4	always	22053
Operations	oPEr	Profile Status 1	PStA		1			Hours	hour	always	22078
Operations	oPEr	Profile Status 1	PStA		1			Minutes	Min	always	22077
Operations	oPEr	Profile Status 1	PStA		1			Seconds	SEC	always	22076
Operations	oPEr	Profile Status 1	PStA		1			Event Output 1	Ent1	always	22014
Operations	oPEr	Profile Status 1	PStA		1			Event Output 2	Ent2	always	22015
Operations	oPEr	Profile Status 1	PStA		1			Event Output 3	Ent3	always	22016
Operations	oPEr	Profile Status 1	PStA		1			Event Output 4	Ent4	always	22017
Operations	oPEr	Profile Status 1	PStA		1			Event Output 5	Ent5	always	22018
Operations	oPEr	Profile Status 1	PStA		1			Event Output 6	Ent6	always	22019
Operations	oPEr	Profile Status 1	PStA		1			Event Output 7	Ent7	always	22020
Operations	oPEr	Profile Status 1	PStA		1			Event Output 8	Ent8	always	22021
Operations	oPEr	Profile Status 1	PStA		1			Jump Count Remaining	JC	always	22010
Setup	SEt	Analog Input x	A1	If model number character 4, 6, 8, or 10 is a 1,2,3,4,5, 6, R, or P	1 - 4	Instance 1 = 4th character Instance 2 = 6th character Instance 3 = 8th character Instance 4 = 10th character If character = 1-6,R,P then visible		Sensor Type	SEn	always	4005
Setup	SEt	Analog Input x	A1		1 - 4			TC Linearization	Lin	instance 1 if PN digit 4 = 1,3,5 instance 2 if PN digit 6 = 1,5,R instance 3 if PN digit 8 = 1,5,R instance 4 if PN digit 10 = 1,5,R { input is universal }	4006
Setup	SEt	Analog Input x	A1		1 - 4			RTD Leads	rtL		4007
Setup	SEt	Analog Input x	A1		1 - 4			Units	Unit		4042
Setup	SEt	Analog Input x	A1		1 - 4			Scale Low	SLo		4015
Setup	SEt	Analog Input x	A1		1 - 4			Scale High	Sh1		4016
Setup	SEt	Analog Input x	A1		1 - 4			Range Low	rLo		4017
Setup	SEt	Analog Input x	A1		1 - 4			Range High	rh1		4018
Setup	SEt	Analog Input x	A1		1 - 4			Process Error Enable	PEE		4030
Setup	SEt	Analog Input x	A1		1 - 4			Process Error Low Value	PEL		4031
Setup	SEt	Analog Input x	A1		1 - 4			Thermistor Curve	tC	instance 1 if PN digit 4 = 2,4,6 instance 2 if PN digit 6 = 2,6,P instance 3 if PN digit 8 = 2,6,P instance 4 if PN digit 10 = 2,6,P { input is thermistor }	4038
Setup	SEt	Analog Input x	A1		1 - 4			Resistance Range	rr		4037
Setup	SEt	Analog Input x	A1		1 - 4			Filter	FiL	always	4014

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Analog Input x	A i		1 - 4			Input Error Latching	iEr	always	4028
Setup	SEt	Analog Input x	A i		1 - 4			Display Precision	dEC	always	4020
Setup	SEt	Analog Input x	A i		1 - 4			Calibration Offset	iCA	always	4012
Setup	SEt	Analog Input x	A i		1 - 4			Analog Input Value	A in	always	4001
Setup	SEt	Analog Input x	A i		1 - 4			Input Error	iEr	always	4002
Setup	SEt	Process Value x	Pu		1 - 4			Function	Fn	always	26021
Setup	SEt	Process Value x	Pu		1 - 4			Source Function A	SFnA	always	26001
Setup	SEt	Process Value x	Pu		1 - 4			Source Instance A	S iA	always	26006
Setup	SEt	Process Value x	Pu		1 - 4			Source Function B	SFnb	always	26002
Setup	SEt	Process Value x	Pu		1 - 4			Source Instance B	S ib	always	26007
Setup	SEt	Process Value x	Pu		1 - 4			Source Zone B	S2b	always	26012
Setup	SEt	Process Value x	Pu		1 - 4			Source Function C	SFnC	always	26003
Setup	SEt	Process Value x	Pu		1 - 4			Source Instance C	S iC	always	26008
Setup	SEt	Process Value x	Pu		1 - 4			Source Zone C	S2C	always	26013
Setup	SEt	Process Value x	Pu	If model number character 4, 6, 8, or 10 is a 1,2,3,4,5, 6, R, or P	1 - 4	Instance 1 = 4th character Instance 2 = 6th character Instance 3 = 8th character Instance 4 = 10th character If character = 1-4 then visible		Source Function D	SFnd	always	26004
Setup	SEt	Process Value x	Pu		1 - 4			Source Instance D	S id	always	26009
Setup	SEt	Process Value x	Pu		1 - 4			Source Zone D	S2d	always	26014
Setup	SEt	Process Value x	Pu		1 - 4			Source Function E	SFnE	always	26005
Setup	SEt	Process Value x	Pu		1 - 4			Source Instance E	S iE	always	26010
Setup	SEt	Process Value x	Pu		1 - 4			Source Zone E	S2E	always	26015
Setup	SEt	Process Value x	Pu		1 - 4			Cross Over Point	CP	always	26024
Setup	SEt	Process Value x	Pu		1 - 4			Cross Over Band	Cb	always	26025
Setup	SEt	Process Value x	Pu		1 - 4			Pressure Units	P.unt	always	26028
Setup	SEt	Process Value x	Pu		1 - 4			Altitude Units	A.unt	always	26029
Setup	SEt	Process Value x	Pu		1 - 4			Barometric Pressure	b.Pr	always	26030
Setup	SEt	Process Value x	Pu		1 - 4			Filter	FiL	always	26026
Setup	SEt	Digital I/O x	d io		7-12			Digital I/O Direction	dir	always	6001
Setup	SEt	Digital I/O x	d io		7-12			Output Function	Fn	always	6005
Setup	SEt	Digital I/O x	d io		7-12			Output Function Instance	F i	always	6006
Setup	SEt	Digital I/O x	d io	If model number character 11 is a C	7-12	always		Output Source Zone A	o.Ct	always	6012
Setup	SEt	Digital I/O x	d io		7-12			Output Control	o.tb	always	6002
Setup	SEt	Digital I/O x	d io		7-12			Output Time Base	o.Lo	always	6003
Setup	SEt	Digital I/O x	d io		7-12			Output Low Power Scale	o.h i	always	6009
Setup	SEt	Digital I/O x	d io		7-12			Output High Power Scale	LEu	always	6010
Setup	SEt	Action x	ACt		1 - 8			Action Function	Fn	always	10003
Setup	SEt	Action x	ACt		1 - 8			Function Instance	F i	always	10004
Setup	SEt	Action x	ACt	always	1 - 8	always		Source Function A	SFnA	always	10006
Setup	SEt	Action x	ACt		1 - 8			Source Instance A	S iA	always	10002
Setup	SEt	Action x	ACt		1 - 8			Source Zone A	S2A	always	10007
Setup	SEt	Action x	ACt		1 - 8			Active Level	LEu	always	10001
Setup	SEt	Limit x	LiM		1 - 4			Limit Sides	L.Sd	always	12005
Setup	SEt	Limit x	LiM		1 - 4			Limit Hysteresis	L.hy	always	12002
Setup	SEt	Limit x	LiM		1 - 4			Set Point High Limit	SP.Lh	always	12009

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Limit x	LiM7	If model number character 4, 6, 8, or 10 is a 5 or 6	1 - 4	Instance 1 = 4th character Instance 2 = 6th character Instance 3 = 8th character Instance 4 = 10th character If character = 5-6 then visible		Set Point Low Limit	SPLL	always	12010
Setup	SEt	Limit x	LiM7		1 - 4			Limit High Set Point	LhS	always	12004
Setup	SEt	Limit x	LiM7		1 - 4			Limit Low Set Point	LLS	always	12003
Setup	SEt	Limit x	LiM7		1 - 4			Source Function A	SFnA	always	12015
Setup	SEt	Limit x	LiM7		1 - 4			Source Instance A	S iA	always	12016
Setup	SEt	Limit x	LiM7		1 - 4			Source Zone A	S2A	always	12017
Setup	SEt	Limit x	LiM7		1 - 4			Limit Clear Request	LCr	always	12014
Setup	SEt	Limit x	LiM7		1 - 4			Limit Status	LSt	always	12013
Setup	SEt	Control Loop x	LooP	If model number character 4, 6, 8, or 10 is a 1,2,3, or 4	1 - 4	Instance 1 = 4th character Instance 2 = 6th character Instance 3 = 8th character Instance 4 = 10th character If character = 1-4 then visible		Source Function A	SFnA	always	8050
Setup	SEt	Control Loop x	LooP		1 - 4			Source Instance A	S iA	always	8021
Setup	SEt	Control Loop x	LooP		1 - 4			Heat Algorithm	hAG	always	8003
Setup	SEt	Control Loop x	LooP		1 - 4			Cool Algorithm	CAG	always	8004
Setup	SEt	Control Loop x	LooP		1 - 4			Cool Output Curve	CCr	always	8038
Setup	SEt	Control Loop x	LooP		1 - 4			Heat Proportional Band	hPb	always	8009
Setup	SEt	Control Loop x	LooP		1 - 4			Heat Hysteresis	hHY	always	8010
Setup	SEt	Control Loop x	LooP		1 - 4			Cool Proportional Band	CPb	always	8012
Setup	SEt	Control Loop x	LooP		1 - 4			Cool Hysteresis	ChY	always	8013
Setup	SEt	Control Loop x	LooP		1 - 4			Time Integral	t i	always	8006
Setup	SEt	Control Loop x	LooP		1 - 4			Time Derivative	td	always	8007
Setup	SEt	Control Loop x	LooP		1 - 4			Dead Band	db	always	8008
Setup	SEt	Control Loop x	LooP		1 - 4			TRU-TUNE+ Enable	tEUn	always	8022
Setup	SEt	Control Loop x	LooP		1 - 4			TRU-TUNE+ Band	tbnd	always	8034
Setup	SEt	Control Loop x	LooP		1 - 4			TRU-TUNE+ Gain	tGn	always	8035
Setup	SEt	Control Loop x	LooP		1 - 4			Autotune Set Point	AtSP	always	8025
Setup	SEt	Control Loop x	LooP		1 - 4			Autotune Aggressiveness	tAGr	always	8024
Setup	SEt	Control Loop x	LooP		1 - 4			Peltier Delay	Pdl	always	8051
Setup	SEt	Control Loop x	LooP		1 - 4			Remote Set Point	rEn	always	7021
Setup	SEt	Control Loop x	LooP		1 - 4			Source Function B	SFnb	always	7023
Setup	SEt	Control Loop x	LooP		1 - 4			Source Instance B	S ib	always	7024
Setup	SEt	Control Loop x	LooP		1 - 4			Source Zone B	S2b	always	7026
Setup	SEt	Control Loop x	LooP		1 - 4			Remote Set Point Type	rtY	always	7022
Setup	SEt	Control Loop x	LooP		1 - 4			User Failure Action	UFA	always	7012
Setup	SEt	Control Loop x	LooP		1 - 4			Input Error Failure	FAiL	always	7013
Setup	SEt	Control Loop x	LooP		1 - 4			Fixed Power	MAn	always	7011
Setup	SEt	Control Loop x	LooP		1 - 4			Open Loop Detect Enable	LdE	always	8039
Setup	SEt	Control Loop x	LooP		1 - 4			Open Loop Detect Time	Ldt	always	8040
Setup	SEt	Control Loop x	LooP		1 - 4			Open Loop Detect Deviation	Ldd	always	8041
Setup	SEt	Control Loop x	LooP		1 - 4			Ramp Action	rP	always	7014
Setup	SEt	Control Loop x	LooP		1 - 4			Ramp Scale	rSC	always	7015
Setup	SEt	Control Loop x	LooP		1 - 4			Ramp Rate	rrt	always	7017
Setup	SEt	Control Loop x	LooP		1 - 4			Profiling Enable	ProE	IF PN - RMC(3,4)xxx-xxxxxx { has ramping }	7027
Setup	SEt	Control Loop x	LooP		1 - 4			Low Set Point	LSP	always	7003
Setup	SEt	Control Loop x	LooP		1 - 4			High Set Point	hSP	always	7004
Setup	SEt	Control Loop x	LooP		1 - 4			Closed-Loop Set Point	CSP	always	7001
Setup	SEt	Control Loop x	LooP		1 - 4			Idle Set Point	idS	always	7009
Setup	SEt	Control Loop x	LooP		1 - 4			Set Point Open Limit Low	SPLo	always	7005

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Control Loop x	LooP		1 - 4			Set Point Open Limit High	SP.h i	always	7006
Setup	SEt	Control Loop x	LooP		1 - 4			Open Loop Set Point	o.SP	always	7002
Setup	SEt	Control Loop x	LooP		1 - 4			Control Mode	C.Cn	always	8001
Setup	SEt	Output x	OtPt		1 - 8			Output Function	Fn	instance 1 if PN digit 5 = U,D,E,F,G,H,J,K,L,M,Y,Z instance 2 always instance 3 if PN digit 7 = U,D,E,F,G,H,J,K,L,M,Y,Z instance 4 always instance 5 if PN digit 9 = U,D,E,F,G,H,J,K,L,M,Y,Z instance 6 always instance 7 if PN digit 11 = U,D,E,F,G,H,J,K,L,M,Y,Z instance 8 always {if output is discrete}	6005
Setup	SEt	Output x	OtPt		1 - 8			Output Function Instance	F i		6006
Setup	SEt	Output x	OtPt		1 - 8			Output Source Zone	S2.A		6012
Setup	SEt	Output x	OtPt		1 - 8	Instance 1 & 2 = 5th digit Instance 3 & 4 = 7th digit Instance 5 & 6 = 9th digit Instance 7 & 8 = 11th digit If instance 1, 3, or 5 != A or T if instance 2, 4, or 6 != A, U, H or N if inst 7 != A, C or T if inst 8 != A, C, U, H or N then visible		Output Control	o.Ct	instance 1 if PN digit 5 = U,D,E,F,G,H,J,K,L,M,Y,Z instance 2 if PN digit 4 = 1,2,3,4,7 instance 3 if PN digit 7 = U,D,E,F,G,H,J,K,L,M,Y,Z instance 4 if PN digit 6 = 1,2,7 instance 5 if PN digit 9 = U,D,E,F,G,H,J,K,L,M,Y,Z instance 6 if PN digit 8 = 1,2,7 instance 7 if PN digit 11 = U,D,E,F,G,H,J,K,L,M,Y,Z instance 8 if PN digit 10 = 1,2,7 {if output is discrete and can be something other than a limit}	6002
Setup	SEt	Output x	OtPt		1 - 8			Output Time Base	o.tb		6003
Setup	SEt	Output x	OtPt		1 - 8			Output Low Power Scale	o.Lo		6009
Setup	SEt	Output x	OtPt	If model number character 5, 7, 9, or 11 is NOT an A	1 - 8			Output High Power Scale	o.h i		6010
Setup	SEt	Output x	OtPt		1, 3, 5 and 7			Output Type	o.ty	instance 1 if PN digit 5 = N,P,R,S instance 3 if PN digit 7 = N,P,R,S instance 5 if PN digit 9 = N,P,R,S instance 7 if PN digit 11 = N,P,R,S {if output is analog}	18001
Setup	SEt	Output x	OtPt		1, 3, 5 and 7			Output Function	Fn		18002
Setup	SEt	Output x	OtPt		1, 3, 5 and 7			Output Function Instance	F i		18004
Setup	SEt	Output x	OtPt		1, 3, 5 and 7			Output Source Zone	S2.A		18019
Setup	SEt	Output x	OtPt		1, 3, 5 and 7			Scale Low	S.Lo		18009
Setup	SEt	Output x	OtPt		1, 3, 5 and 7			Scale High	S.h i		18010
Setup	SEt	Output x	OtPt		1, 3, 5 and 7			Range Low	r.Lo		18011
Setup	SEt	Output x	OtPt		1, 3, 5 and 7			Range High	r.h i		18012
Setup	SEt	Output x	OtPt		1, 3, 5 and 7			Calibration Offset	o.CA		18007
Setup	SEt	Alarm x	ALMn		1 - 8			Alarm Type	A.ty	always	9015
Setup	SEt	Alarm x	ALMn		1 - 8			Alarm Source	Sr.A	always	9017
Setup	SEt	Alarm x	ALMn		1 - 8			Alarm Source Instance	iS.A	always	9018
Setup	SEt	Alarm x	ALMn		1 - 8			Alarm Source Zone	S2.A	always	9025
Setup	SEt	Alarm x	ALMn		1 - 8			Control Loop	LooP	if PN digit 4 = 1,2,3,4 or PN digit 6 = 1,2 or PN digit 8 = 1,2 or PN digit 10 = 1,2 { control loop exists }	9023
Setup	SEt	Alarm x	ALMn		1 - 8			Alarm Hysteresis	A.hy	always	9003
Setup	SEt	Alarm x	ALMn		1 - 8			Alarm Logic	A.Lg	always	9005
Setup	SEt	Alarm x	ALMn	always	1 - 8	always		Alarm Sides	A.Sd	always	9004
Setup	SEt	Alarm x	ALMn		1 - 8			Alarm Low Set Point	A.Lo	always	9002
Setup	SEt	Alarm x	ALMn		1 - 8			Alarm High Set Point	A.h i	always	9001
Setup	SEt	Alarm x	ALMn		1 - 8			Alarm Latching	A.LA	always	9007
Setup	SEt	Alarm x	ALMn		1 - 8			Alarm Blocking	A.bL	always	9008
Setup	SEt	Alarm x	ALMn		1 - 8			Alarm Silencing	A.S i	always	9006
Setup	SEt	Alarm x	ALMn		1 - 8			Alarm Display	A.dSP	always	9016
Setup	SEt	Alarm x	ALMn		1 - 8			Alarm Delay Time	A.dL	always	9021

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Alarm x	ALM		1 - 8			Alarm Clear Request	A.CLr	always	9026
Setup	SEt	Alarm x	ALM		1 - 8			Alarm Silence	A.Silr	always	9027
Setup	SEt	Alarm x	ALM		1 - 8			Alarm State	A.St	always	9009
Setup	SEt	Current x	CUrr		1 - 4			Current Sides	C.Sd	always	15005
Setup	SEt	Current x	CUrr		1 - 4			Current Read Enable	C.Ur	always	15004
Setup	SEt	Current x	CUrr	If model number character 4, 6, 8, or 10 is a 7	1 - 4	Instance 1 = 4th character Instance 2 = 6th character Instance 3 = 8th character Instance 4 = 10th character If character = 7 then visible		input Current Detection Threshold	C.dt	always	15012
Setup	SEt	Current x	CUrr		1 - 4			Current Scaling	C.SC	always	15022
Setup	SEt	Current x	CUrr		1 - 4			Heater Current Offset	C.oFS	always	15011
Setup	SEt	Current x	CUrr		1 - 4			Current Output Source Instance	C.S i	always	15019
Setup	SEt	Linearization x	Lin		1 - 4			Function	Fn	always	34005
Setup	SEt	Linearization x	Lin		1 - 4			Source Function A	SFn.A	always	34001
Setup	SEt	Linearization x	Lin		1 - 4			Source Instance A	S i.A	always	34002
Setup	SEt	Linearization x	Lin		1 - 4			Source Zone A	S2.A	always	34003
Setup	SEt	Linearization x	Lin		1 - 4			Units	Unit	always	34029
Setup	SEt	Linearization x	Lin		1 - 4			Input Point 1	iP.1	always	34008
Setup	SEt	Linearization x	Lin		1 - 4			Output Point 1	oP.1	always	34018
Setup	SEt	Linearization x	Lin		1 - 4			Input Point 2	iP.2	always	34009
Setup	SEt	Linearization x	Lin		1 - 4			Output Point 2	oP.2	always	34019
Setup	SEt	Linearization x	Lin		1 - 4			Input Point 3	iP.3	always	34010
Setup	SEt	Linearization x	Lin		1 - 4			Output Point 3	oP.3	always	34020
Setup	SEt	Linearization x	Lin		1 - 4			Input Point 4	iP.4	always	34011
Setup	SEt	Linearization x	Lin	always	1 - 4	always		Output Point 4	oP.4	always	34021
Setup	SEt	Linearization x	Lin		1 - 4			Input Point 5	iP.5	always	34012
Setup	SEt	Linearization x	Lin		1 - 4			Output Point 5	oP.5	always	34022
Setup	SEt	Linearization x	Lin		1 - 4			Input Point 6	iP.6	always	34013
Setup	SEt	Linearization x	Lin		1 - 4			Output Point 6	oP.6	always	34023
Setup	SEt	Linearization x	Lin		1 - 4			Input Point 7	iP.7	always	34014
Setup	SEt	Linearization x	Lin		1 - 4			Output Point 7	oP.7	always	34024
Setup	SEt	Linearization x	Lin		1 - 4			Input Point 8	iP.8	always	34015
Setup	SEt	Linearization x	Lin		1 - 4			Output Point 8	oP.8	always	34025
Setup	SEt	Linearization x	Lin		1 - 4			Input Point 9	iP.9	always	34016
Setup	SEt	Linearization x	Lin		1 - 4			Output Point 9	oP.9	always	34026
Setup	SEt	Linearization x	Lin		1 - 4			Input Point 10	iP.10	always	34017
Setup	SEt	Linearization x	Lin		1 - 4			Output Point 10	oP.10	always	34027
Setup	SEt	Compare x	CPE		1 - 4			Function	Fn	always	28009
Setup	SEt	Compare x	CPE		1 - 4			Tolerance	tol	always	28011
Setup	SEt	Compare x	CPE		1 - 4			Source Function A	SFn.A	always	28001
Setup	SEt	Compare x	CPE		1 - 4			Source Instance A	S i.A	always	28003
Setup	SEt	Compare x	CPE	always	1 - 4	always		Source Zone A	S2.A	always	28005
Setup	SEt	Compare x	CPE		1 - 4			Source Function B	SFn.b	always	28002
Setup	SEt	Compare x	CPE		1 - 4			Source Instance B	S i.b	always	28004
Setup	SEt	Compare x	CPE		1 - 4			Source Zone B	S2.b	always	28006
Setup	SEt	Compare x	CPE		1 - 4			Error Handling	Er.h	always	28012

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Timer x	tMr	always	1 - 4	always		Function	Fn	always	31009
Setup	SEt	Timer x	tMr		1 - 4			Source Function A	SFn.A	always	31001
Setup	SEt	Timer x	tMr		1 - 4			Source Instance A	S .A	always	31003
Setup	SEt	Timer x	tMr		1 - 4			Source Zone A	S2.A	always	31005
Setup	SEt	Timer x	tMr		1 - 4			Source Active State A	SAS.A	always	31011
Setup	SEt	Timer x	tMr		1 - 4			Source Function B	SFn.b	always	31002
Setup	SEt	Timer x	tMr		1 - 4			Source Instance B	S .b	always	31004
Setup	SEt	Timer x	tMr		1 - 4			Source Zone B	S2.b	always	31006
Setup	SEt	Timer x	tMr		1 - 4			Source Active State B	SAS.b	always	31012
Setup	SEt	Timer x	tMr		1 - 4			Time	t i	always	31013
Setup	SEt	Timer x	tMr		1 - 4			Active Level	LEv	always	31014
Setup	SEt	Counter x	Ctr	always	1 - 4	always		Function	Fn	always	30009
Setup	SEt	Counter x	Ctr		1 - 4			Source Function A	SFn.A	always	30001
Setup	SEt	Counter x	Ctr		1 - 4			Source Instance A	S .A	always	30003
Setup	SEt	Counter x	Ctr		1 - 4			Source Zone A	S2.A	always	30005
Setup	SEt	Counter x	Ctr		1 - 4			Source Active State A	SAS.A	always	30011
Setup	SEt	Counter x	Ctr		1 - 4			Source Function B	SFn.b	always	30002
Setup	SEt	Counter x	Ctr		1 - 4			Source Instance B	S .b	always	30004
Setup	SEt	Counter x	Ctr		1 - 4			Source Zone B	S2.b	always	30006
Setup	SEt	Counter x	Ctr		1 - 4			Source Active State B	SAS.b	always	30012
Setup	SEt	Counter x	Ctr		1 - 4			Load Value	LoAd	always	30013
Setup	SEt	Counter x	Ctr		1 - 4			Target Value	trgt	always	30014
Setup	SEt	Counter x	Ctr		1 - 4			Latching	LAt	always	30017
Setup	SEt	Logic x	LgC	always	1 - 4	always		Function	Fn	always	27033
Setup	SEt	Logic x	LgC		1 - 4			Source Function A	SFn.A	always	27001
Setup	SEt	Logic x	LgC		1 - 4			Source Instance A	S .A	always	27009
Setup	SEt	Logic x	LgC		1 - 4			Source Zone A	S2.A	always	27017
Setup	SEt	Logic x	LgC		1 - 4			Source Function B	SFn.b	always	27002
Setup	SEt	Logic x	LgC		1 - 4			Source Instance B	S .b	always	27010
Setup	SEt	Logic x	LgC		1 - 4			Source Zone B	S2.b	always	27018
Setup	SEt	Logic x	LgC		1 - 4			Source Function C	SFn.C	always	27003
Setup	SEt	Logic x	LgC		1 - 4			Source Instance C	S .C	always	27011
Setup	SEt	Logic x	LgC		1 - 4			Source Zone C	S2.C	always	27019
Setup	SEt	Logic x	LgC		1 - 4			Source Function D	SFn.d	always	27004
Setup	SEt	Logic x	LgC		1 - 4			Source Instance D	S .d	always	27012
Setup	SEt	Logic x	LgC		1 - 4			Source Zone D	S2.d	always	27020
Setup	SEt	Logic x	LgC	always	1 - 4	always		Source Function E	SFn.E	always	27005
Setup	SEt	Logic x	LgC		1 - 4			Source Instance E	S .E	always	27013
Setup	SEt	Logic x	LgC		1 - 4			Source Zone E	S2.E	always	27021
Setup	SEt	Logic x	LgC		1 - 4			Source Function F	SFn.F	always	27006
Setup	SEt	Logic x	LgC		1 - 4			Source Instance F	S .F	always	27014
Setup	SEt	Logic x	LgC		1 - 4			Source Zone F	S2.F	always	27022
Setup	SEt	Logic x	LgC		1 - 4			Source Function G	SFn.9	always	27007
Setup	SEt	Logic x	LgC		1 - 4			Source Instance G	S .9	always	27015
Setup	SEt	Logic x	LgC		1 - 4			Source Zone G	S2.9	always	27023

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Logic x	LGC		1 - 4			Source Function H	SFn.h	always	27008
Setup	SEt	Logic x	LGC		1 - 4			Source Instance H	S .h	always	27016
Setup	SEt	Logic x	LGC		1 - 4			Source Zone H	S2.h	always	27024
Setup	SEt	Logic x	LGC		1 - 4			Error Handling	Er.h	always	27035
Setup	SEt	Math x	MAt		1-8			Function	Fn	always	25021
Setup	SEt	Math x	MAt		1-8			Source Function A	SFn.A	always	25001
Setup	SEt	Math x	MAt		1-8			Source Instance A	S .A	always	25006
Setup	SEt	Math x	MAt		1-8			Source Zone A	S2.A	always	25011
Setup	SEt	Math x	MAt		1-8			Source Function B	SFn.b	always	25002
Setup	SEt	Math x	MAt		1-8			Source Instance B	S .b	always	25007
Setup	SEt	Math x	MAt		1-8			Source Zone B	S2.b	always	25012
Setup	SEt	Math x	MAt		1-8			Source Function C	SFn.C	always	25003
Setup	SEt	Math x	MAt		1-8			Source Instance C	S .C	always	25008
Setup	SEt	Math x	MAt		1-8			Source Zone C	S2.C	always	25013
Setup	SEt	Math x	MAt		1-8			Source Function D	SFn.d	always	25004
Setup	SEt	Math x	MAt	always	1-8	always		Source Instance D	S .d	always	25009
Setup	SEt	Math x	MAt		1-8			Source Zone D	S2.d	always	25014
Setup	SEt	Math x	MAt		1-8			Source Function E	SFn.E	always	25005
Setup	SEt	Math x	MAt		1-8			Source Instance E	S .E	always	25010
Setup	SEt	Math x	MAt		1-8			Source Zone E	S2.E	always	25015
Setup	SEt	Math x	MAt		1-8			Scale Low	S.Lo	always	25024
Setup	SEt	Math x	MAt		1-8			Scale High	S.hi	always	25025
Setup	SEt	Math x	MAt		1-8			Units	Unit	always	25032
Setup	SEt	Math x	MAt		1-8			Range Low	r.Lo	always	25026
Setup	SEt	Math x	MAt		1-8			Range High	r.hi	always	25027
Setup	SEt	Math x	MAt		1-8			Pressure Units	P.unt	always	25030
Setup	SEt	Math x	MAt		1-8			Altitude Units	A.unt	always	25031
Setup	SEt	Math x	MAt		1-8			Filter	F iL	always	25028
Setup	SEt	Special Output Function x	SoF		1-4			Function	Fn	always	35009
Setup	SEt	Special Output Function x	SoF		1-4			Source Function A	SFn.A	always	35001
Setup	SEt	Special Output Function x	SoF		1-4			Source Instance A	S .A	always	35003
Setup	SEt	Special Output Function x	SoF		1-4			Source Zone A	S2.A	always	35005
Setup	SEt	Special Output Function x	SoF		1-4			Source Function B	SFn.b	always	35002
Setup	SEt	Special Output Function x	SoF		1-4			Source Instance B	S .b	always	35004
Setup	SEt	Special Output Function x	SoF		1-4			Source Zone B	S2.b	always	35006
Setup	SEt	Special Output Function x	SoF		1-4			Power On Level 1	Pon.A	always	35018
Setup	SEt	Special Output Function x	SoF		1-4			Power Off Level 1	PoF.A	always	35019
Setup	SEt	Special Output Function x	SoF		1-4			Power On Level 2	Pon.b	always	35020
Setup	SEt	Special Output Function x	SoF	always	1-4	always		Power Off Level 2	PoF.b	always	35021
Setup	SEt	Special Output Function x	SoF		1-4			On Time	ont	always	35022
Setup	SEt	Special Output Function x	SoF		1-4			Off Time	oF.t	always	35023
Setup	SEt	Special Output Function x	SoF		1-4			Valve Travel Time	t.t	always	35024
Setup	SEt	Special Output Function x	SoF		1-4			Dead Band	db	always	35025
Setup	SEt	Special Output Function x	SoF		1-4			Output 1 Size	o.S1	always	35028
Setup	SEt	Special Output Function x	SoF		1-4			Output 2 Size	o.S2	always	35029

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Special Output Function x	SoF		1-4			Output 3 Size	o.S3	always	35030
Setup	SEt	Special Output Function x	SoF		1-4			Output 4 Size	o.S4	always	35031
Setup	SEt	Special Output Function x	SoF		1-4			Time Delay	t.dL	always	35026
Setup	SEt	Special Output Function x	SoF		1-4			Output Order	ot.o	always	35027
Setup	SEt	Variable x	uAr		1-8			Data Type	tyPE	always	2001
Setup	SEt	Variable x	uAr	always	1-8	always		Units	Un it	always	2007
Setup	SEt	Variable x	uAr		1-8			Digital	d i9	always	2002
Setup	SEt	Variable x	uAr		1-8			Analog	AnL9	always	2003
Setup	SEt	Global 1	9LbL		1			Display Units	C_F	always	3005
Setup	SEt	Global 1	9LbL		1			AC Line Frequency	AC.LF	always	1034
Setup	SEt	Global 1	9LbL	always	1	always		Display Pairs	d.Pr5	always	3028
Setup	SEt	Global 1	9LbL		1			User Settings Save	USr.S	always	1014
Setup	SEt	Global 1	9LbL		1			User Settings Restore	USr.r	always	1013
Setup	SEt	Profile 1	Pro		1			Ramping Type	r.tyP	always	22038
Setup	SEt	Profile 1	Pro		1			Profile Type	P.tyP	always	22008
Setup	SEt	Profile 1	Pro		1			Guaranteed Soak Enable	95E	always	22006
Setup	SEt	Profile 1	Pro		1			Guaranteed Soak Deviation 1	95d1	always	22007
Setup	SEt	Profile 1	Pro		1			Guaranteed Soak Deviation 2	95d2	always	22041
Setup	SEt	Profile 1	Pro		1			Guaranteed Soak Deviation 3	95d3	always	22042
Setup	SEt	Profile 1	Pro		1			Guaranteed Soak Deviation 4	95d4	always	22043
Setup	SEt	Profile 1	Pro		1			Control Mode Enable	CMdE	always	22039
Setup	SEt	Profile 1	Pro		1			Wait for Mode	WJM1	always	22040
Setup	SEt	Profile 1	Pro		1			Source Function A	SFn.A	always	22022
Setup	SEt	Profile 1	Pro		1			Source Instance A	S i.A	always	22026
Setup	SEt	Profile 1	Pro		1			Source Zone A	S2.A	always	22030
Setup	SEt	Profile 1	Pro		1			Source Function B	SFn.b	always	22023
Setup	SEt	Profile 1	Pro		1			Source Instance B	S i.b	always	22027
Setup	SEt	Profile 1	Pro		1			Source Zone B	S2.b	always	22031
Setup	SEt	Profile 1	Pro	If model number character 4 is a 3 or 4	1	always		Source Function C	SFn.C	always	22024
Setup	SEt	Profile 1	Pro		1			Source Instance C	S i.C	always	22028
Setup	SEt	Profile 1	Pro		1			Source Zone C	S2.C	always	22032
Setup	SEt	Profile 1	Pro		1			Source Function D	SFn.d	always	22025
Setup	SEt	Profile 1	Pro		1			Source Instance D	S i.d	always	22029
Setup	SEt	Profile 1	Pro		1			Source Zone D	S2.d	always	22033
Setup	SEt	Profile 1	Pro		1			Source Function E	SFn.E	always	22056
Setup	SEt	Profile 1	Pro		1			Source Instance E	S i.E	always	22060
Setup	SEt	Profile 1	Pro		1			Source Zone E	S2.E	always	22064
Setup	SEt	Profile 1	Pro		1			Source Function F	SFn.F	always	22057
Setup	SEt	Profile 1	Pro		1			Source Instance F	S i.F	always	22061
Setup	SEt	Profile 1	Pro		1			Source Zone F	S2.F	always	22065
Setup	SEt	Profile 1	Pro		1			Source Function G	SFn.9	always	22058
Setup	SEt	Profile 1	Pro		1			Source Instance G	S i.9	always	22062
Setup	SEt	Profile 1	Pro		1			Source Zone G	S2.9	always	22066
Setup	SEt	Profile 1	Pro		1			Source Function H	SFnh	always	22059

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Profile 1	Pro		1			Source Instance H	S.ih	always	22063
Setup	SEt	Profile 1	Pro		1			Source Zone H	S2.h	always	22067
Setup	SEt	Communications 1	CoM	If model number character 13 is a 1	1	always		Baud Rate	bAUd	always	17002
Setup	SEt	Communications 1	CoM		1			Parity	PAr	always	17003
Setup	SEt	Communications 1	CoM		1			Modbus Word Order	M.hL	always	17043
Setup	SEt	Communications 1	CoM		1			Display Units	C_F	always	17050
Setup	SEt	Communications 1	CoM		1			Non-Volatile Save	nVS	always	17051
Factory	FctY	Custom Setup x	CUSt	always	1 - 20	always		Parameter	PAr	always	14005
Factory	FctY	Custom Setup x	CUSt		1 - 20			Instance ID	.id	always	14003
Factory	FctY	Lock 1	LoC	If DspLockedState = PASS ADMIN	1	always		Operations Page	LoC.o	always	3002
Factory	FctY	Lock 1	LoC		1			Profilng Page	LoC.P	If PN digit 4 = 3 or 4	3008
Factory	FctY	Lock 1	LoC		1			Password Enable	PASE	always	3015
Factory	FctY	Lock 1	LoC		1			Read Lock	rLoC	always	3010
Factory	FctY	Lock 1	LoC		1			Write Security	SLoC	always	3011
Factory	FctY	Lock 1	LoC		1			Locked Access Level	LoC.L	always	3016
Factory	FctY	Lock 1	LoC		1			Rolling Password	roLL	always	3019
Factory	FctY	Lock 1	LoC		1			User Password	PAS.u	always	3017
Factory	FctY	Lock 1	LoC		1			Administrator Password	PAS.A	always	3018
Factory	FctY	Unlock 1	ULoC	If DspSecurityEnable == ON	1	always		Public Key	CodE	always	3020
Factory	FctY	Unlock 1	ULoC		1			Password	PASS	always	3022
Factory	FctY	Diagnostics 1	d.AG	always	1	always		Part Number	Pn	always	1009
Factory	FctY	Diagnostics 1	d.AG		1			Software Revision	rEv	always	1017
Factory	FctY	Diagnostics 1	d.AG		1			Software Build Number	S.bld	always	1005
Factory	FctY	Diagnostics 1	d.AG		1			Serial Number	Sn	always	1032
Factory	FctY	Diagnostics 1	d.AG		1			Date of Manufacture	dAtE	always	1008
Factory	FctY	Calibration x	CAL	always	1 - 4	Instance 1 = 4th character Instance 2 = 6th character Instance 3 = 8th character Instance 4 = 10th character If character = 1-6, R, P then visible		Electrical Measurement	M.u	always	4021
Factory	FctY	Calibration x	CAL		1 - 4			Electrical Input Offset	EL.o	always	4010
Factory	FctY	Calibration x	CAL		1 - 4			Electrical Input Slope	EL.S	always	4011
Factory	FctY	Calibration x	CAL		1, 3, 5 and 7	Instance 1 = 5th digit Instance 3 = 7th digit Instance 5 = 9th digit Instance 7 = 11th digit If instance 1, 3, 5 or 7 = N, P, R or		Electrical Output Offset	ELo.o	always	18005
Factory	FctY	Calibration x	CAL		1, 3, 5 and 7			Electrical Output Slope	ELo.S	always	18006
Profile	ProF	Profile 1 Step x	P1		1 - 10			Step Type	S.tyP	always	21001
Profile	ProF	Profile 1 Step x	P1		1 - 10			Control Mode Loop 1	C.M1	always	21024
Profile	ProF	Profile 1 Step x	P1		1 - 10			Control Mode Loop 2	C.M2	always	21025
Profile	ProF	Profile 1 Step x	P1		1 - 10			Control Mode Loop 3	C.M3	always	21026
Profile	ProF	Profile 1 Step x	P1		1 - 10			Control Mode Loop 4	C.M4	always	21027
Profile	ProF	Profile 1 Step x	P1		1 - 10			Target Set Point Loop 1	t.SP1	always	21002
Profile	ProF	Profile 1 Step x	P1		1 - 10			Target Set Point Loop 2	t.SP2	always	21028

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 1 Step x	P1		1 - 10			Target Set Point Loop 3	t.SP3	always	21029
Profile	ProF	Profile 1 Step x	P1		1 - 10			Target Set Point Loop 4	t.SP4	always	21030
Profile	ProF	Profile 1 Step x	P1		1 - 10			Hours	hoUr	always	21003
Profile	ProF	Profile 1 Step x	P1		1 - 10			Minutes	MIn	always	21004
Profile	ProF	Profile 1 Step x	P1		1 - 10			Seconds	SEC	always	21005
Profile	ProF	Profile 1 Step x	P1		1 - 10			Rate	rAtE	always	21006
Profile	ProF	Profile 1 Step x	P1		1 - 10			Step Wait For Process Enable 1	P.E1	always	21036
Profile	ProF	Profile 1 Step x	P1		1 - 10			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 1 Step x	P1		1 - 10			Step Wait For Process Enable 2	P.E2	always	21037
Profile	ProF	Profile 1 Step x	P1		1 - 10			Wait For Process 2	WJP2	always	21031
Profile	ProF	Profile 1 Step x	P1		1 - 10			Step Wait For Process Enable 3	P.E3	always	21038
Profile	ProF	Profile 1 Step x	P1		1 - 10			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 1 Step x	P1		1 - 10			Step Wait For Process Enable 4	P.E4	always	21039
Profile	ProF	Profile 1 Step x	P1		1 - 10			Wait For Process 4	WJP4	always	21033
Profile	ProF	Profile 1 Step x	P1	always	1 - 10	always		Wait Event 1	WJE1	always	21009
Profile	ProF	Profile 1 Step x	P1		1 - 10			Wait Event 2	WJE2	always	21010
Profile	ProF	Profile 1 Step x	P1		1 - 10			Wait Event 3	WJE3	always	21022
Profile	ProF	Profile 1 Step x	P1		1 - 10			Wait Event 4	WJE4	always	21023
Profile	ProF	Profile 1 Step x	P1		1 - 10			Day of Week	doWJ	always	21041
Profile	ProF	Profile 1 Step x	P1		1 - 10			Guaranteed Soak Enable 1	GSE1	always	21042
Profile	ProF	Profile 1 Step x	P1		1 - 10			Guaranteed Soak Enable 2	GSE2	always	21043
Profile	ProF	Profile 1 Step x	P1		1 - 10			Guaranteed Soak Enable 3	GSE3	always	21044
Profile	ProF	Profile 1 Step x	P1		1 - 10			Guaranteed Soak Enable 4	GSE4	always	21045
Profile	ProF	Profile 1 Step x	P1		1 - 10			Subroutine Step	SS	always	21034
Profile	ProF	Profile 1 Step x	P1		1 - 10			Subroutine Count	SC	always	21035
Profile	ProF	Profile 1 Step x	P1		1 - 10			Jump Step	JS	always	21012
Profile	ProF	Profile 1 Step x	P1		1 - 10			Jump Count	JC	always	21013
Profile	ProF	Profile 1 Step x	P1		1 - 10			Endy Type	End	always	21014
Profile	ProF	Profile 1 Step x	P1		1 - 10			Event 1	Ent1	always	21007
Profile	ProF	Profile 1 Step x	P1		1 - 10			Event 2	Ent2	always	21008
Profile	ProF	Profile 1 Step x	P1		1 - 10			Event 3	Ent3	always	21016
Profile	ProF	Profile 1 Step x	P1		1 - 10			Event 4	Ent4	always	21017
Profile	ProF	Profile 1 Step x	P1		1 - 10			Event 5	Ent5	always	21018
Profile	ProF	Profile 1 Step x	P1		1 - 10			Event 6	Ent6	always	21019
Profile	ProF	Profile 1 Step x	P1		1 - 10			Event 7	Ent7	always	21020
Profile	ProF	Profile 1 Step x	P1		1 - 10			Event 8	Ent8	always	21021
Profile	ProF	Profile 2 Step x	P2		11 - 20			Step Type	StyP	always	21001
Profile	ProF	Profile 2 Step x	P2		11 - 20			Control Mode Loop 1	C.M1	always	21024
Profile	ProF	Profile 2 Step x	P2		11 - 20			Control Mode Loop 2	C.M2	always	21025
Profile	ProF	Profile 2 Step x	P2		11 - 20			Control Mode Loop 3	C.M3	always	21026
Profile	ProF	Profile 2 Step x	P2		11 - 20			Control Mode Loop 4	C.M4	always	21027
Profile	ProF	Profile 2 Step x	P2		11 - 20			Target Set Point Loop 1	t.SP1	always	21002
Profile	ProF	Profile 2 Step x	P2		11 - 20			Target Set Point Loop 2	t.SP2	always	21028
Profile	ProF	Profile 2 Step x	P2		11 - 20			Target Set Point Loop 3	t.SP3	always	21029
Profile	ProF	Profile 2 Step x	P2		11 - 20			Target Set Point Loop 4	t.SP4	always	21030
Profile	ProF	Profile 2 Step x	P2		11 - 20			Hours	hoUr	always	21003

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 2 Step x	P2		11 - 20			Minutes	mn.in	always	21004
Profile	ProF	Profile 2 Step x	P2		11 - 20			Seconds	SEC	always	21005
Profile	ProF	Profile 2 Step x	P2		11 - 20			Rate	rAtE	always	21006
Profile	ProF	Profile 2 Step x	P2		11 - 20			Step Wait For Process Enable 1	P.E1	always	21036
Profile	ProF	Profile 2 Step x	P2		11 - 20			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 2 Step x	P2		11 - 20			Step Wait For Process Enable 2	P.E2	always	21037
Profile	ProF	Profile 2 Step x	P2		11 - 20			Wait For Process 2	WJP2	always	21031
Profile	ProF	Profile 2 Step x	P2		11 - 20			Step Wait For Process Enable 3	P.E3	always	21038
Profile	ProF	Profile 2 Step x	P2		11 - 20			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 2 Step x	P2		11 - 20			Step Wait For Process Enable 4	P.E4	always	21039
Profile	ProF	Profile 2 Step x	P2		11 - 20			Wait For Process 4	WJP4	always	21033
Profile	ProF	Profile 2 Step x	P2	always	11 - 20	always		Wait Event 1	WJE1	always	21009
Profile	ProF	Profile 2 Step x	P2		11 - 20			Wait Event 2	WJE2	always	21010
Profile	ProF	Profile 2 Step x	P2		11 - 20			Wait Event 3	WJE3	always	21022
Profile	ProF	Profile 2 Step x	P2		11 - 20			Wait Event 4	WJE4	always	21023
Profile	ProF	Profile 2 Step x	P2		11 - 20			Day of Week	doW	always	21041
Profile	ProF	Profile 2 Step x	P2		11 - 20			Guaranteed Soak Enable 1	gSE1	always	21042
Profile	ProF	Profile 2 Step x	P2		11 - 20			Guaranteed Soak Enable 2	gSE2	always	21043
Profile	ProF	Profile 2 Step x	P2		11 - 20			Guaranteed Soak Enable 3	gSE3	always	21044
Profile	ProF	Profile 2 Step x	P2		11 - 20			Guaranteed Soak Enable 4	gSE4	always	21045
Profile	ProF	Profile 2 Step x	P2		11 - 20			Subroutine Step	SS	always	21034
Profile	ProF	Profile 2 Step x	P2		11 - 20			Subroutine Count	SC	always	21035
Profile	ProF	Profile 2 Step x	P2		11 - 20			Jump Step	JS	always	21012
Profile	ProF	Profile 2 Step x	P2		11 - 20			Jump Count	JC	always	21013
Profile	ProF	Profile 2 Step x	P2		11 - 20			Endy Type	End	always	21014
Profile	ProF	Profile 2 Step x	P2		11 - 20			Event 1	Ent1	always	21007
Profile	ProF	Profile 2 Step x	P2		11 - 20			Event 2	Ent2	always	21008
Profile	ProF	Profile 2 Step x	P2		11 - 20			Event 3	Ent3	always	21016
Profile	ProF	Profile 2 Step x	P2		11 - 20			Event 4	Ent4	always	21017
Profile	ProF	Profile 2 Step x	P2		11 - 20			Event 5	Ent5	always	21018
Profile	ProF	Profile 2 Step x	P2		11 - 20			Event 6	Ent6	always	21019
Profile	ProF	Profile 2 Step x	P2		11 - 20			Event 7	Ent7	always	21020
Profile	ProF	Profile 2 Step x	P2		11 - 20			Event 8	Ent8	always	21021
Profile	ProF	Profile 3 Step x	P3		21 - 30			Step Type	StyP	always	21001
Profile	ProF	Profile 3 Step x	P3		21 - 30			Control Mode Loop 1	C.M1	always	21024
Profile	ProF	Profile 3 Step x	P3		21 - 30			Control Mode Loop 2	C.M2	always	21025
Profile	ProF	Profile 3 Step x	P3		21 - 30			Control Mode Loop 3	C.M3	always	21026
Profile	ProF	Profile 3 Step x	P3		21 - 30			Control Mode Loop 4	C.M4	always	21027
Profile	ProF	Profile 3 Step x	P3		21 - 30			Target Set Point Loop 1	t.SP1	always	21002
Profile	ProF	Profile 3 Step x	P3		21 - 30			Target Set Point Loop 2	t.SP2	always	21028
Profile	ProF	Profile 3 Step x	P3		21 - 30			Target Set Point Loop 3	t.SP3	always	21029
Profile	ProF	Profile 3 Step x	P3		21 - 30			Target Set Point Loop 4	t.SP4	always	21030
Profile	ProF	Profile 3 Step x	P3		21 - 30			Hours	hour	always	21003
Profile	ProF	Profile 3 Step x	P3		21 - 30			Minutes	mn.in	always	21004
Profile	ProF	Profile 3 Step x	P3		21 - 30			Seconds	SEC	always	21005
Profile	ProF	Profile 3 Step x	P3		21 - 30			Rate	rAtE	always	21006

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 3 Step x	P3		21 - 30			Step Wait For Process Enable 1	P.E 1	always	21036
Profile	ProF	Profile 3 Step x	P3		21 - 30			Wait For Process 1	uJ.P 1	always	21011
Profile	ProF	Profile 3 Step x	P3		21 - 30			Step Wait For Process Enable 2	P.E 2	always	21037
Profile	ProF	Profile 3 Step x	P3		21 - 30			Wait For Process 2	uJ.P2	always	21031
Profile	ProF	Profile 3 Step x	P3		21 - 30			Step Wait For Process Enable 3	P.E 3	always	21038
Profile	ProF	Profile 3 Step x	P3		21 - 30			Wait For Process 3	uJ.P 3	always	21032
Profile	ProF	Profile 3 Step x	P3		21 - 30			Step Wait For Process Enable 4	P.E 4	always	21039
Profile	ProF	Profile 3 Step x	P3		21 - 30			Wait For Process 4	uJ.P 4	always	21033
Profile	ProF	Profile 3 Step x	P3	always	21 - 30	always		Wait Event 1	uJE.1	always	21009
Profile	ProF	Profile 3 Step x	P3		21 - 30			Wait Event 2	uJE.2	always	21010
Profile	ProF	Profile 3 Step x	P3		21 - 30			Wait Event 3	uJE.3	always	21022
Profile	ProF	Profile 3 Step x	P3		21 - 30			Wait Event 4	uJE.4	always	21023
Profile	ProF	Profile 3 Step x	P3		21 - 30			Day of Week	doUJ	always	21041
Profile	ProF	Profile 3 Step x	P3		21 - 30			Guaranteed Soak Enable 1	gSE 1	always	21042
Profile	ProF	Profile 3 Step x	P3		21 - 30			Guaranteed Soak Enable 2	gSE2	always	21043
Profile	ProF	Profile 3 Step x	P3		21 - 30			Guaranteed Soak Enable 3	gSE3	always	21044
Profile	ProF	Profile 3 Step x	P3		21 - 30			Guaranteed Soak Enable 4	gSE4	always	21045
Profile	ProF	Profile 3 Step x	P3		21 - 30			Subroutine Step	SS	always	21034
Profile	ProF	Profile 3 Step x	P3		21 - 30			Subroutine Count	SC	always	21035
Profile	ProF	Profile 3 Step x	P3		21 - 30			Jump Step	JS	always	21012
Profile	ProF	Profile 3 Step x	P3		21 - 30			Jump Count	JC	always	21013
Profile	ProF	Profile 3 Step x	P3		21 - 30			Endy Type	End	always	21014
Profile	ProF	Profile 3 Step x	P3		21 - 30			Event 1	Ent 1	always	21007
Profile	ProF	Profile 3 Step x	P3		21 - 30			Event 2	Ent2	always	21008
Profile	ProF	Profile 3 Step x	P3		21 - 30			Event 3	Ent3	always	21016
Profile	ProF	Profile 3 Step x	P3		21 - 30			Event 4	Ent4	always	21017
Profile	ProF	Profile 3 Step x	P3		21 - 30			Event 5	Ent5	always	21018
Profile	ProF	Profile 3 Step x	P3		21 - 30			Event 6	Ent6	always	21019
Profile	ProF	Profile 3 Step x	P3		21 - 30			Event 7	Ent7	always	21020
Profile	ProF	Profile 3 Step x	P3		21 - 30			Event 8	Ent8	always	21021
Profile	ProF	Profile 4 Step x	P4		31 - 40			Step Type	StyP	always	21001
Profile	ProF	Profile 4 Step x	P4		31 - 40			Control Mode Loop 1	C.M1	always	21024
Profile	ProF	Profile 4 Step x	P4		31 - 40			Control Mode Loop 2	C.M2	always	21025
Profile	ProF	Profile 4 Step x	P4		31 - 40			Control Mode Loop 3	C.M3	always	21026
Profile	ProF	Profile 4 Step x	P4		31 - 40			Control Mode Loop 4	C.M4	always	21027
Profile	ProF	Profile 4 Step x	P4		31 - 40			Target Set Point Loop 1	t.SP 1	always	21002
Profile	ProF	Profile 4 Step x	P4		31 - 40			Target Set Point Loop 2	t.SP2	always	21028
Profile	ProF	Profile 4 Step x	P4		31 - 40			Target Set Point Loop 3	t.SP3	always	21029
Profile	ProF	Profile 4 Step x	P4		31 - 40			Target Set Point Loop 4	t.SP4	always	21030
Profile	ProF	Profile 4 Step x	P4		31 - 40			Hours	hoUr	always	21003
Profile	ProF	Profile 4 Step x	P4		31 - 40			Minutes	Min	always	21004
Profile	ProF	Profile 4 Step x	P4		31 - 40			Seconds	SEC	always	21005
Profile	ProF	Profile 4 Step x	P4		31 - 40			Rate	rAtE	always	21006
Profile	ProF	Profile 4 Step x	P4		31 - 40			Step Wait For Process Enable 1	P.E 1	always	21036
Profile	ProF	Profile 4 Step x	P4		31 - 40			Wait For Process 1	uJ.P 1	always	21011
Profile	ProF	Profile 4 Step x	P4		31 - 40			Step Wait For Process Enable 2	P.E 2	always	21037

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 4 Step x	P4		31 - 40			Wait For Process 2	uJP2	always	21031
Profile	ProF	Profile 4 Step x	P4		31 - 40			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 4 Step x	P4		31 - 40			Wait For Process 3	uJP3	always	21032
Profile	ProF	Profile 4 Step x	P4		31 - 40			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 4 Step x	P4		31 - 40			Wait For Process 4	uJP4	always	21033
Profile	ProF	Profile 4 Step x	P4	always	31 - 40	always		Wait Event 1	uJE1	always	21009
Profile	ProF	Profile 4 Step x	P4		31 - 40			Wait Event 2	uJE2	always	21010
Profile	ProF	Profile 4 Step x	P4		31 - 40			Wait Event 3	uJE3	always	21022
Profile	ProF	Profile 4 Step x	P4		31 - 40			Wait Event 4	uJE4	always	21023
Profile	ProF	Profile 4 Step x	P4		31 - 40			Day of Week	doWJ	always	21041
Profile	ProF	Profile 4 Step x	P4		31 - 40			Guaranteed Soak Enable 1	gSE1	always	21042
Profile	ProF	Profile 4 Step x	P4		31 - 40			Guaranteed Soak Enable 2	gSE2	always	21043
Profile	ProF	Profile 4 Step x	P4		31 - 40			Guaranteed Soak Enable 3	gSE3	always	21044
Profile	ProF	Profile 4 Step x	P4		31 - 40			Guaranteed Soak Enable 4	gSE4	always	21045
Profile	ProF	Profile 4 Step x	P4		31 - 40			Subroutine Step	SS	always	21034
Profile	ProF	Profile 4 Step x	P4		31 - 40			Subroutine Count	SC	always	21035
Profile	ProF	Profile 4 Step x	P4		31 - 40			Jump Step	JS	always	21012
Profile	ProF	Profile 4 Step x	P4		31 - 40			Jump Count	JC	always	21013
Profile	ProF	Profile 4 Step x	P4		31 - 40			Endy Type	End	always	21014
Profile	ProF	Profile 4 Step x	P4		31 - 40			Event 1	Ent1	always	21007
Profile	ProF	Profile 4 Step x	P4		31 - 40			Event 2	Ent2	always	21008
Profile	ProF	Profile 4 Step x	P4		31 - 40			Event 3	Ent3	always	21016
Profile	ProF	Profile 4 Step x	P4		31 - 40			Event 4	Ent4	always	21017
Profile	ProF	Profile 4 Step x	P4		31 - 40			Event 5	Ent5	always	21018
Profile	ProF	Profile 4 Step x	P4		31 - 40			Event 6	Ent6	always	21019
Profile	ProF	Profile 4 Step x	P4		31 - 40			Event 7	Ent7	always	21020
Profile	ProF	Profile 4 Step x	P4		31 - 40			Event 8	Ent8	always	21021
Profile	ProF	Profile 5 Step x	P5		41 - 50			Step Type	StyP	always	21001
Profile	ProF	Profile 5 Step x	P5		41 - 50			Control Mode Loop 1	Cm1	always	21024
Profile	ProF	Profile 5 Step x	P5		41 - 50			Control Mode Loop 2	Cm2	always	21025
Profile	ProF	Profile 5 Step x	P5		41 - 50			Control Mode Loop 3	Cm3	always	21026
Profile	ProF	Profile 5 Step x	P5		41 - 50			Control Mode Loop 4	Cm4	always	21027
Profile	ProF	Profile 5 Step x	P5		41 - 50			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 5 Step x	P5		41 - 50			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 5 Step x	P5		41 - 50			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 5 Step x	P5		41 - 50			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 5 Step x	P5		41 - 50			Hours	hoUr	always	21003
Profile	ProF	Profile 5 Step x	P5		41 - 50			Minutes	Min	always	21004
Profile	ProF	Profile 5 Step x	P5		41 - 50			Seconds	SEC	always	21005
Profile	ProF	Profile 5 Step x	P5		41 - 50			Rate	rAtE	always	21006
Profile	ProF	Profile 5 Step x	P5		41 - 50			Step Wait For Process Enable 1	PE1	always	21036
Profile	ProF	Profile 5 Step x	P5		41 - 50			Wait For Process 1	uJP1	always	21011
Profile	ProF	Profile 5 Step x	P5		41 - 50			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 5 Step x	P5		41 - 50			Wait For Process 2	uJP2	always	21031
Profile	ProF	Profile 5 Step x	P5		41 - 50			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 5 Step x	P5		41 - 50			Wait For Process 3	uJP3	always	21032

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 5 Step x	P5		41 - 50			Step Wait For Process Enable 4	P.E4	always	21039
Profile	ProF	Profile 5 Step x	P5		41 - 50			Wait For Process 4	uJP4	always	21033
Profile	ProF	Profile 5 Step x	P5	always	41 - 50	always		Wait Event 1	uJE.1	always	21009
Profile	ProF	Profile 5 Step x	P5		41 - 50			Wait Event 2	uJE.2	always	21010
Profile	ProF	Profile 5 Step x	P5		41 - 50			Wait Event 3	uJE.3	always	21022
Profile	ProF	Profile 5 Step x	P5		41 - 50			Wait Event 4	uJE.4	always	21023
Profile	ProF	Profile 5 Step x	P5		41 - 50			Day of Week	doU	always	21041
Profile	ProF	Profile 5 Step x	P5		41 - 50			Guaranteed Soak Enable 1	gSE1	always	21042
Profile	ProF	Profile 5 Step x	P5		41 - 50			Guaranteed Soak Enable 2	gSE2	always	21043
Profile	ProF	Profile 5 Step x	P5		41 - 50			Guaranteed Soak Enable 3	gSE3	always	21044
Profile	ProF	Profile 5 Step x	P5		41 - 50			Guaranteed Soak Enable 4	gSE4	always	21045
Profile	ProF	Profile 5 Step x	P5		41 - 50			Subroutine Step	SS	always	21034
Profile	ProF	Profile 5 Step x	P5		41 - 50			Subroutine Count	SC	always	21035
Profile	ProF	Profile 5 Step x	P5		41 - 50			Jump Step	JS	always	21012
Profile	ProF	Profile 5 Step x	P5		41 - 50			Jump Count	JC	always	21013
Profile	ProF	Profile 5 Step x	P5		41 - 50			Endy Type	End	always	21014
Profile	ProF	Profile 5 Step x	P5		41 - 50			Event 1	Ent1	always	21007
Profile	ProF	Profile 5 Step x	P5		41 - 50			Event 2	Ent2	always	21008
Profile	ProF	Profile 5 Step x	P5		41 - 50			Event 3	Ent3	always	21016
Profile	ProF	Profile 5 Step x	P5		41 - 50			Event 4	Ent4	always	21017
Profile	ProF	Profile 5 Step x	P5		41 - 50			Event 5	Ent5	always	21018
Profile	ProF	Profile 5 Step x	P5		41 - 50			Event 6	Ent6	always	21019
Profile	ProF	Profile 5 Step x	P5		41 - 50			Event 7	Ent7	always	21020
Profile	ProF	Profile 5 Step x	P5		41 - 50			Event 8	Ent8	always	21021
Profile	ProF	Profile 6 Step x	P6		51 - 60			Step Type	StYP	always	21001
Profile	ProF	Profile 6 Step x	P6		51 - 60			Control Mode Loop 1	CM1	always	21024
Profile	ProF	Profile 6 Step x	P6		51 - 60			Control Mode Loop 2	CM2	always	21025
Profile	ProF	Profile 6 Step x	P6		51 - 60			Control Mode Loop 3	CM3	always	21026
Profile	ProF	Profile 6 Step x	P6		51 - 60			Control Mode Loop 4	CM4	always	21027
Profile	ProF	Profile 6 Step x	P6		51 - 60			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 6 Step x	P6		51 - 60			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 6 Step x	P6		51 - 60			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 6 Step x	P6		51 - 60			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 6 Step x	P6		51 - 60			Hours	hoUr	always	21003
Profile	ProF	Profile 6 Step x	P6		51 - 60			Minutes	Min	always	21004
Profile	ProF	Profile 6 Step x	P6		51 - 60			Seconds	SEC	always	21005
Profile	ProF	Profile 6 Step x	P6		51 - 60			Rate	rAtE	always	21006
Profile	ProF	Profile 6 Step x	P6		51 - 60			Step Wait For Process Enable 1	P.E1	always	21036
Profile	ProF	Profile 6 Step x	P6		51 - 60			Wait For Process 1	uJP1	always	21011
Profile	ProF	Profile 6 Step x	P6		51 - 60			Step Wait For Process Enable 2	P.E2	always	21037
Profile	ProF	Profile 6 Step x	P6		51 - 60			Wait For Process 2	uJP2	always	21031
Profile	ProF	Profile 6 Step x	P6		51 - 60			Step Wait For Process Enable 3	P.E3	always	21038
Profile	ProF	Profile 6 Step x	P6		51 - 60			Wait For Process 3	uJP3	always	21032
Profile	ProF	Profile 6 Step x	P6		51 - 60			Step Wait For Process Enable 4	P.E4	always	21039
Profile	ProF	Profile 6 Step x	P6		51 - 60			Wait For Process 4	uJP4	always	21033
Profile	ProF	Profile 6 Step x	P6	always	51 - 60	always		Wait Event 1	uJE.1	always	21009

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 6 Step x	P6		51 - 60			Wait Event 2	uJE.2	always	21010
Profile	ProF	Profile 6 Step x	P6		51 - 60			Wait Event 3	uJE.3	always	21022
Profile	ProF	Profile 6 Step x	P6		51 - 60			Wait Event 4	uJE.4	always	21023
Profile	ProF	Profile 6 Step x	P6		51 - 60			Day of Week	doUJ	always	21041
Profile	ProF	Profile 6 Step x	P6		51 - 60			Guaranteed Soak Enable 1	gSE 1	always	21042
Profile	ProF	Profile 6 Step x	P6		51 - 60			Guaranteed Soak Enable 2	gSE2	always	21043
Profile	ProF	Profile 6 Step x	P6		51 - 60			Guaranteed Soak Enable 3	gSE3	always	21044
Profile	ProF	Profile 6 Step x	P6		51 - 60			Guaranteed Soak Enable 4	gSE4	always	21045
Profile	ProF	Profile 6 Step x	P6		51 - 60			Subroutine Step	SS	always	21034
Profile	ProF	Profile 6 Step x	P6		51 - 60			Subroutine Count	SC	always	21035
Profile	ProF	Profile 6 Step x	P6		51 - 60			Jump Step	JS	always	21012
Profile	ProF	Profile 6 Step x	P6		51 - 60			Jump Count	JC	always	21013
Profile	ProF	Profile 6 Step x	P6		51 - 60			Endy Type	End	always	21014
Profile	ProF	Profile 6 Step x	P6		51 - 60			Event 1	Ent 1	always	21007
Profile	ProF	Profile 6 Step x	P6		51 - 60			Event 2	Ent2	always	21008
Profile	ProF	Profile 6 Step x	P6		51 - 60			Event 3	Ent3	always	21016
Profile	ProF	Profile 6 Step x	P6		51 - 60			Event 4	Ent4	always	21017
Profile	ProF	Profile 6 Step x	P6		51 - 60			Event 5	Ent5	always	21018
Profile	ProF	Profile 6 Step x	P6		51 - 60			Event 6	Ent6	always	21019
Profile	ProF	Profile 6 Step x	P6		51 - 60			Event 7	Ent7	always	21020
Profile	ProF	Profile 6 Step x	P6		51 - 60			Event 8	Ent8	always	21021
Profile	ProF	Profile 7 Step x	P7		61 - 70			Step Type	StYP	always	21001
Profile	ProF	Profile 7 Step x	P7		61 - 70			Control Mode Loop 1	CM1	always	21024
Profile	ProF	Profile 7 Step x	P7		61 - 70			Control Mode Loop 2	CM2	always	21025
Profile	ProF	Profile 7 Step x	P7		61 - 70			Control Mode Loop 3	CM3	always	21026
Profile	ProF	Profile 7 Step x	P7		61 - 70			Control Mode Loop 4	CM4	always	21027
Profile	ProF	Profile 7 Step x	P7		61 - 70			Target Set Point Loop 1	tSP 1	always	21002
Profile	ProF	Profile 7 Step x	P7		61 - 70			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 7 Step x	P7		61 - 70			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 7 Step x	P7		61 - 70			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 7 Step x	P7		61 - 70			Hours	hoUr	always	21003
Profile	ProF	Profile 7 Step x	P7		61 - 70			Minutes	MIn	always	21004
Profile	ProF	Profile 7 Step x	P7		61 - 70			Seconds	SEC	always	21005
Profile	ProF	Profile 7 Step x	P7		61 - 70			Rate	rAtE	always	21006
Profile	ProF	Profile 7 Step x	P7		61 - 70			Step Wait For Process Enable 1	PE 1	always	21036
Profile	ProF	Profile 7 Step x	P7		61 - 70			Wait For Process 1	uJP 1	always	21011
Profile	ProF	Profile 7 Step x	P7		61 - 70			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 7 Step x	P7		61 - 70			Wait For Process 2	uJP2	always	21031
Profile	ProF	Profile 7 Step x	P7		61 - 70			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 7 Step x	P7		61 - 70			Wait For Process 3	uJP3	always	21032
Profile	ProF	Profile 7 Step x	P7		61 - 70			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 7 Step x	P7		61 - 70			Wait For Process 4	uJP4	always	21033
Profile	ProF	Profile 7 Step x	P7	always	61 - 70	always		Wait Event 1	uJE.1	always	21009
Profile	ProF	Profile 7 Step x	P7		61 - 70			Wait Event 2	uJE.2	always	21010
Profile	ProF	Profile 7 Step x	P7		61 - 70			Wait Event 3	uJE.3	always	21022
Profile	ProF	Profile 7 Step x	P7		61 - 70			Wait Event 4	uJE.4	always	21023

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 7 Step x	P7		61 - 70			Day of Week	doW	always	21041
Profile	ProF	Profile 7 Step x	P7		61 - 70			Guaranteed Soak Enable 1	gSE1	always	21042
Profile	ProF	Profile 7 Step x	P7		61 - 70			Guaranteed Soak Enable 2	gSE2	always	21043
Profile	ProF	Profile 7 Step x	P7		61 - 70			Guaranteed Soak Enable 3	gSE3	always	21044
Profile	ProF	Profile 7 Step x	P7		61 - 70			Guaranteed Soak Enable 4	gSE4	always	21045
Profile	ProF	Profile 7 Step x	P7		61 - 70			Subroutine Step	SS	always	21034
Profile	ProF	Profile 7 Step x	P7		61 - 70			Subroutine Count	SC	always	21035
Profile	ProF	Profile 7 Step x	P7		61 - 70			Jump Step	JS	always	21012
Profile	ProF	Profile 7 Step x	P7		61 - 70			Jump Count	JC	always	21013
Profile	ProF	Profile 7 Step x	P7		61 - 70			Endy Type	End	always	21014
Profile	ProF	Profile 7 Step x	P7		61 - 70			Event 1	Ent1	always	21007
Profile	ProF	Profile 7 Step x	P7		61 - 70			Event 2	Ent2	always	21008
Profile	ProF	Profile 7 Step x	P7		61 - 70			Event 3	Ent3	always	21016
Profile	ProF	Profile 7 Step x	P7		61 - 70			Event 4	Ent4	always	21017
Profile	ProF	Profile 7 Step x	P7		61 - 70			Event 5	Ent5	always	21018
Profile	ProF	Profile 7 Step x	P7		61 - 70			Event 6	Ent6	always	21019
Profile	ProF	Profile 7 Step x	P7		61 - 70			Event 7	Ent7	always	21020
Profile	ProF	Profile 7 Step x	P7		61 - 70			Event 8	Ent8	always	21021
Profile	ProF	Profile 8 Step x	P8		71 - 80			Step Type	StyP	always	21001
Profile	ProF	Profile 8 Step x	P8		71 - 80			Control Mode Loop 1	Cm1	always	21024
Profile	ProF	Profile 8 Step x	P8		71 - 80			Control Mode Loop 2	Cm2	always	21025
Profile	ProF	Profile 8 Step x	P8		71 - 80			Control Mode Loop 3	Cm3	always	21026
Profile	ProF	Profile 8 Step x	P8		71 - 80			Control Mode Loop 4	Cm4	always	21027
Profile	ProF	Profile 8 Step x	P8		71 - 80			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 8 Step x	P8		71 - 80			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 8 Step x	P8		71 - 80			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 8 Step x	P8		71 - 80			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 8 Step x	P8		71 - 80			Hours	hour	always	21003
Profile	ProF	Profile 8 Step x	P8		71 - 80			Minutes	Min	always	21004
Profile	ProF	Profile 8 Step x	P8		71 - 80			Seconds	SEC	always	21005
Profile	ProF	Profile 8 Step x	P8		71 - 80			Rate	rAtE	always	21006
Profile	ProF	Profile 8 Step x	P8		71 - 80			Step Wait For Process Enable 1	PE1	always	21036
Profile	ProF	Profile 8 Step x	P8		71 - 80			Wait For Process 1	WjP1	always	21011
Profile	ProF	Profile 8 Step x	P8		71 - 80			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 8 Step x	P8		71 - 80			Wait For Process 2	WjP2	always	21031
Profile	ProF	Profile 8 Step x	P8		71 - 80			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 8 Step x	P8		71 - 80			Wait For Process 3	WjP3	always	21032
Profile	ProF	Profile 8 Step x	P8		71 - 80			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 8 Step x	P8		71 - 80			Wait For Process 4	WjP4	always	21033
Profile	ProF	Profile 8 Step x	P8	always	71 - 80	always		Wait Event 1	WjE1	always	21009
Profile	ProF	Profile 8 Step x	P8		71 - 80			Wait Event 2	WjE2	always	21010
Profile	ProF	Profile 8 Step x	P8		71 - 80			Wait Event 3	WjE3	always	21022
Profile	ProF	Profile 8 Step x	P8		71 - 80			Wait Event 4	WjE4	always	21023
Profile	ProF	Profile 8 Step x	P8		71 - 80			Day of Week	doW	always	21041
Profile	ProF	Profile 8 Step x	P8		71 - 80			Guaranteed Soak Enable 1	gSE1	always	21042
Profile	ProF	Profile 8 Step x	P8		71 - 80			Guaranteed Soak Enable 2	gSE2	always	21043

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 8 Step x	P8		71 - 80			Guaranteed Soak Enable 3	9SE3	always	21044
Profile	ProF	Profile 8 Step x	P8		71 - 80			Guaranteed Soak Enable 4	9SE4	always	21045
Profile	ProF	Profile 8 Step x	P8		71 - 80			Subroutine Step	SS	always	21034
Profile	ProF	Profile 8 Step x	P8		71 - 80			Subroutine Count	SC	always	21035
Profile	ProF	Profile 8 Step x	P8		71 - 80			Jump Step	JS	always	21012
Profile	ProF	Profile 8 Step x	P8		71 - 80			Jump Count	JC	always	21013
Profile	ProF	Profile 8 Step x	P8		71 - 80			Endy Type	End	always	21014
Profile	ProF	Profile 8 Step x	P8		71 - 80			Event 1	Ent1	always	21007
Profile	ProF	Profile 8 Step x	P8		71 - 80			Event 2	Ent2	always	21008
Profile	ProF	Profile 8 Step x	P8		71 - 80			Event 3	Ent3	always	21016
Profile	ProF	Profile 8 Step x	P8		71 - 80			Event 4	Ent4	always	21017
Profile	ProF	Profile 8 Step x	P8		71 - 80			Event 5	Ent5	always	21018
Profile	ProF	Profile 8 Step x	P8		71 - 80			Event 6	Ent6	always	21019
Profile	ProF	Profile 8 Step x	P8		71 - 80			Event 7	Ent7	always	21020
Profile	ProF	Profile 8 Step x	P8		71 - 80			Event 8	Ent8	always	21021
Profile	ProF	Profile 9 Step x	P9		81 - 90			Step Type	StyP	always	21001
Profile	ProF	Profile 9 Step x	P9		81 - 90			Control Mode Loop 1	Cm1	always	21024
Profile	ProF	Profile 9 Step x	P9		81 - 90			Control Mode Loop 2	Cm2	always	21025
Profile	ProF	Profile 9 Step x	P9		81 - 90			Control Mode Loop 3	Cm3	always	21026
Profile	ProF	Profile 9 Step x	P9		81 - 90			Control Mode Loop 4	Cm4	always	21027
Profile	ProF	Profile 9 Step x	P9		81 - 90			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 9 Step x	P9		81 - 90			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 9 Step x	P9		81 - 90			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 9 Step x	P9		81 - 90			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 9 Step x	P9		81 - 90			Hours	hour	always	21003
Profile	ProF	Profile 9 Step x	P9		81 - 90			Minutes	Min	always	21004
Profile	ProF	Profile 9 Step x	P9		81 - 90			Seconds	SEC	always	21005
Profile	ProF	Profile 9 Step x	P9		81 - 90			Rate	rAtE	always	21006
Profile	ProF	Profile 9 Step x	P9		81 - 90			Step Wait For Process Enable 1	PE1	always	21036
Profile	ProF	Profile 9 Step x	P9		81 - 90			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 9 Step x	P9		81 - 90			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 9 Step x	P9		81 - 90			Wait For Process 2	WJP2	always	21031
Profile	ProF	Profile 9 Step x	P9		81 - 90			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 9 Step x	P9		81 - 90			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 9 Step x	P9		81 - 90			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 9 Step x	P9		81 - 90			Wait For Process 4	WJP4	always	21033
Profile	ProF	Profile 9 Step x	P9	always	81 - 90	always		Wait Event 1	WJE1	always	21009
Profile	ProF	Profile 9 Step x	P9		81 - 90			Wait Event 2	WJE2	always	21010
Profile	ProF	Profile 9 Step x	P9		81 - 90			Wait Event 3	WJE3	always	21022
Profile	ProF	Profile 9 Step x	P9		81 - 90			Wait Event 4	WJE4	always	21023
Profile	ProF	Profile 9 Step x	P9		81 - 90			Day of Week	dotW	always	21041
Profile	ProF	Profile 9 Step x	P9		81 - 90			Guaranteed Soak Enable 1	9SE1	always	21042
Profile	ProF	Profile 9 Step x	P9		81 - 90			Guaranteed Soak Enable 2	9SE2	always	21043
Profile	ProF	Profile 9 Step x	P9		81 - 90			Guaranteed Soak Enable 3	9SE3	always	21044
Profile	ProF	Profile 9 Step x	P9		81 - 90			Guaranteed Soak Enable 4	9SE4	always	21045
Profile	ProF	Profile 9 Step x	P9		81 - 90			Subroutine Step	SS	always	21034

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 9 Step x	P9		81 - 90			Subroutine Count	SC	always	21035
Profile	ProF	Profile 9 Step x	P9		81 - 90			Jump Step	JS	always	21012
Profile	ProF	Profile 9 Step x	P9		81 - 90			Jump Count	JC	always	21013
Profile	ProF	Profile 9 Step x	P9		81 - 90			Endy Type	End	always	21014
Profile	ProF	Profile 9 Step x	P9		81 - 90			Event 1	Ent1	always	21007
Profile	ProF	Profile 9 Step x	P9		81 - 90			Event 2	Ent2	always	21008
Profile	ProF	Profile 9 Step x	P9		81 - 90			Event 3	Ent3	always	21016
Profile	ProF	Profile 9 Step x	P9		81 - 90			Event 4	Ent4	always	21017
Profile	ProF	Profile 9 Step x	P9		81 - 90			Event 5	Ent5	always	21018
Profile	ProF	Profile 9 Step x	P9		81 - 90			Event 6	Ent6	always	21019
Profile	ProF	Profile 9 Step x	P9		81 - 90			Event 7	Ent7	always	21020
Profile	ProF	Profile 9 Step x	P9		81 - 90			Event 8	Ent8	always	21021
Profile	ProF	Profile 10 Step x	P10		91 - 100			Step Type	StyP	always	21001
Profile	ProF	Profile 10 Step x	P10		91 - 100			Control Mode Loop 1	Cm1	always	21024
Profile	ProF	Profile 10 Step x	P10		91 - 100			Control Mode Loop 2	Cm2	always	21025
Profile	ProF	Profile 10 Step x	P10		91 - 100			Control Mode Loop 3	Cm3	always	21026
Profile	ProF	Profile 10 Step x	P10		91 - 100			Control Mode Loop 4	Cm4	always	21027
Profile	ProF	Profile 10 Step x	P10		91 - 100			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 10 Step x	P10		91 - 100			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 10 Step x	P10		91 - 100			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 10 Step x	P10		91 - 100			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 10 Step x	P10		91 - 100			Hours	hour	always	21003
Profile	ProF	Profile 10 Step x	P10		91 - 100			Minutes	Min	always	21004
Profile	ProF	Profile 10 Step x	P10		91 - 100			Seconds	SEC	always	21005
Profile	ProF	Profile 10 Step x	P10		91 - 100			Rate	rAtE	always	21006
Profile	ProF	Profile 10 Step x	P10		91 - 100			Step Wait For Process Enable 1	PE1	always	21036
Profile	ProF	Profile 10 Step x	P10		91 - 100			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 10 Step x	P10		91 - 100			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 10 Step x	P10		91 - 100			Wait For Process 2	WJP2	always	21031
Profile	ProF	Profile 10 Step x	P10		91 - 100			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 10 Step x	P10		91 - 100			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 10 Step x	P10		91 - 100			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 10 Step x	P10		91 - 100			Wait For Process 4	WJP4	always	21033
Profile	ProF	Profile 10 Step x	P10	always	91 - 100	always		Wait Event 1	WJE1	always	21009
Profile	ProF	Profile 10 Step x	P10		91 - 100			Wait Event 2	WJE2	always	21010
Profile	ProF	Profile 10 Step x	P10		91 - 100			Wait Event 3	WJE3	always	21022
Profile	ProF	Profile 10 Step x	P10		91 - 100			Wait Event 4	WJE4	always	21023
Profile	ProF	Profile 10 Step x	P10		91 - 100			Day of Week	doW	always	21041
Profile	ProF	Profile 10 Step x	P10		91 - 100			Guaranteed Soak Enable 1	GSE1	always	21042
Profile	ProF	Profile 10 Step x	P10		91 - 100			Guaranteed Soak Enable 2	GSE2	always	21043
Profile	ProF	Profile 10 Step x	P10		91 - 100			Guaranteed Soak Enable 3	GSE3	always	21044
Profile	ProF	Profile 10 Step x	P10		91 - 100			Guaranteed Soak Enable 4	GSE4	always	21045
Profile	ProF	Profile 10 Step x	P10		91 - 100			Subroutine Step	SS	always	21034
Profile	ProF	Profile 10 Step x	P10		91 - 100			Subroutine Count	SC	always	21035
Profile	ProF	Profile 10 Step x	P10		91 - 100			Jump Step	JS	always	21012
Profile	ProF	Profile 10 Step x	P10		91 - 100			Jump Count	JC	always	21013

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 10 Step x	P10		91 - 100			Endy Type	End	always	21014
Profile	ProF	Profile 10 Step x	P10		91 - 100			Event 1	Ent1	always	21007
Profile	ProF	Profile 10 Step x	P10		91 - 100			Event 2	Ent2	always	21008
Profile	ProF	Profile 10 Step x	P10		91 - 100			Event 3	Ent3	always	21016
Profile	ProF	Profile 10 Step x	P10		91 - 100			Event 4	Ent4	always	21017
Profile	ProF	Profile 10 Step x	P10		91 - 100			Event 5	Ent5	always	21018
Profile	ProF	Profile 10 Step x	P10		91 - 100			Event 6	Ent6	always	21019
Profile	ProF	Profile 10 Step x	P10		91 - 100			Event 7	Ent7	always	21020
Profile	ProF	Profile 10 Step x	P10		91 - 100			Event 8	Ent8	always	21021
Profile	ProF	Profile 11 Step x	P11		101 - 110			Step Type	StYP	always	21001
Profile	ProF	Profile 11 Step x	P11		101 - 110			Control Mode Loop 1	Cm1	always	21024
Profile	ProF	Profile 11 Step x	P11		101 - 110			Control Mode Loop 2	Cm2	always	21025
Profile	ProF	Profile 11 Step x	P11		101 - 110			Control Mode Loop 3	Cm3	always	21026
Profile	ProF	Profile 11 Step x	P11		101 - 110			Control Mode Loop 4	Cm4	always	21027
Profile	ProF	Profile 11 Step x	P11		101 - 110			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 11 Step x	P11		101 - 110			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 11 Step x	P11		101 - 110			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 11 Step x	P11		101 - 110			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 11 Step x	P11		101 - 110			Hours	hoUr	always	21003
Profile	ProF	Profile 11 Step x	P11		101 - 110			Minutes	Min	always	21004
Profile	ProF	Profile 11 Step x	P11		101 - 110			Seconds	SEC	always	21005
Profile	ProF	Profile 11 Step x	P11		101 - 110			Rate	rAtE	always	21006
Profile	ProF	Profile 11 Step x	P11		101 - 110			Step Wait For Process Enable 1	PE1	always	21036
Profile	ProF	Profile 11 Step x	P11		101 - 110			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 11 Step x	P11		101 - 110			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 11 Step x	P11		101 - 110			Wait For Process 2	WJP2	always	21031
Profile	ProF	Profile 11 Step x	P11		101 - 110			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 11 Step x	P11		101 - 110			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 11 Step x	P11		101 - 110			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 11 Step x	P11		101 - 110			Wait For Process 4	WJP4	always	21033
Profile	ProF	Profile 11 Step x	P11	always	101 - 110	always		Wait Event 1	WJE1	always	21009
Profile	ProF	Profile 11 Step x	P11		101 - 110			Wait Event 2	WJE2	always	21010
Profile	ProF	Profile 11 Step x	P11		101 - 110			Wait Event 3	WJE3	always	21022
Profile	ProF	Profile 11 Step x	P11		101 - 110			Wait Event 4	WJE4	always	21023
Profile	ProF	Profile 11 Step x	P11		101 - 110			Day of Week	doWd	always	21041
Profile	ProF	Profile 11 Step x	P11		101 - 110			Guaranteed Soak Enable 1	gSE1	always	21042
Profile	ProF	Profile 11 Step x	P11		101 - 110			Guaranteed Soak Enable 2	gSE2	always	21043
Profile	ProF	Profile 11 Step x	P11		101 - 110			Guaranteed Soak Enable 3	gSE3	always	21044
Profile	ProF	Profile 11 Step x	P11		101 - 110			Guaranteed Soak Enable 4	gSE4	always	21045
Profile	ProF	Profile 11 Step x	P11		101 - 110			Subroutine Step	SS	always	21034
Profile	ProF	Profile 11 Step x	P11		101 - 110			Subroutine Count	SC	always	21035
Profile	ProF	Profile 11 Step x	P11		101 - 110			Jump Step	JS	always	21012
Profile	ProF	Profile 11 Step x	P11		101 - 110			Jump Count	JC	always	21013
Profile	ProF	Profile 11 Step x	P11		101 - 110			Endy Type	End	always	21014
Profile	ProF	Profile 11 Step x	P11		101 - 110			Event 1	Ent1	always	21007
Profile	ProF	Profile 11 Step x	P11		101 - 110			Event 2	Ent2	always	21008

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 11 Step x	P11		101 - 110			Event 3	Ent3	always	21016
Profile	ProF	Profile 11 Step x	P11		101 - 110			Event 4	Ent4	always	21017
Profile	ProF	Profile 11 Step x	P11		101 - 110			Event 5	Ent5	always	21018
Profile	ProF	Profile 11 Step x	P11		101 - 110			Event 6	Ent6	always	21019
Profile	ProF	Profile 11 Step x	P11		101 - 110			Event 7	Ent7	always	21020
Profile	ProF	Profile 11 Step x	P11		101 - 110			Event 8	Ent8	always	21021
Profile	ProF	Profile 12 Step x	P12		111 - 120			Step Type	StYP	always	21001
Profile	ProF	Profile 12 Step x	P12		111 - 120			Control Mode Loop 1	Cm1	always	21024
Profile	ProF	Profile 12 Step x	P12		111 - 120			Control Mode Loop 2	Cm2	always	21025
Profile	ProF	Profile 12 Step x	P12		111 - 120			Control Mode Loop 3	Cm3	always	21026
Profile	ProF	Profile 12 Step x	P12		111 - 120			Control Mode Loop 4	Cm4	always	21027
Profile	ProF	Profile 12 Step x	P12		111 - 120			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 12 Step x	P12		111 - 120			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 12 Step x	P12		111 - 120			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 12 Step x	P12		111 - 120			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 12 Step x	P12		111 - 120			Hours	hour	always	21003
Profile	ProF	Profile 12 Step x	P12		111 - 120			Minutes	Min	always	21004
Profile	ProF	Profile 12 Step x	P12		111 - 120			Seconds	SEC	always	21005
Profile	ProF	Profile 12 Step x	P12		111 - 120			Rate	rAtE	always	21006
Profile	ProF	Profile 12 Step x	P12		111 - 120			Step Wait For Process Enable 1	PE1	always	21036
Profile	ProF	Profile 12 Step x	P12		111 - 120			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 12 Step x	P12		111 - 120			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 12 Step x	P12		111 - 120			Wait For Process 2	WJP2	always	21031
Profile	ProF	Profile 12 Step x	P12		111 - 120			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 12 Step x	P12		111 - 120			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 12 Step x	P12		111 - 120			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 12 Step x	P12		111 - 120			Wait For Process 4	WJP4	always	21033
Profile	ProF	Profile 12 Step x	P12	always	111 - 120	always		Wait Event 1	WJE1	always	21009
Profile	ProF	Profile 12 Step x	P12		111 - 120			Wait Event 2	WJE2	always	21010
Profile	ProF	Profile 12 Step x	P12		111 - 120			Wait Event 3	WJE3	always	21022
Profile	ProF	Profile 12 Step x	P12		111 - 120			Wait Event 4	WJE4	always	21023
Profile	ProF	Profile 12 Step x	P12		111 - 120			Day of Week	doW	always	21041
Profile	ProF	Profile 12 Step x	P12		111 - 120			Guaranteed Soak Enable 1	gSE1	always	21042
Profile	ProF	Profile 12 Step x	P12		111 - 120			Guaranteed Soak Enable 2	gSE2	always	21043
Profile	ProF	Profile 12 Step x	P12		111 - 120			Guaranteed Soak Enable 3	gSE3	always	21044
Profile	ProF	Profile 12 Step x	P12		111 - 120			Guaranteed Soak Enable 4	gSE4	always	21045
Profile	ProF	Profile 12 Step x	P12		111 - 120			Subroutine Step	SS	always	21034
Profile	ProF	Profile 12 Step x	P12		111 - 120			Subroutine Count	SC	always	21035
Profile	ProF	Profile 12 Step x	P12		111 - 120			Jump Step	JS	always	21012
Profile	ProF	Profile 12 Step x	P12		111 - 120			Jump Count	JC	always	21013
Profile	ProF	Profile 12 Step x	P12		111 - 120			Endy Type	End	always	21014
Profile	ProF	Profile 12 Step x	P12		111 - 120			Event 1	Ent1	always	21007
Profile	ProF	Profile 12 Step x	P12		111 - 120			Event 2	Ent2	always	21008
Profile	ProF	Profile 12 Step x	P12		111 - 120			Event 3	Ent3	always	21016
Profile	ProF	Profile 12 Step x	P12		111 - 120			Event 4	Ent4	always	21017
Profile	ProF	Profile 12 Step x	P12		111 - 120			Event 5	Ent5	always	21018

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 12 Step x	P12		111 - 120			Event 6	Ent6	always	21019
Profile	ProF	Profile 12 Step x	P12		111 - 120			Event 7	Ent7	always	21020
Profile	ProF	Profile 12 Step x	P12		111 - 120			Event 8	Ent8	always	21021
Profile	ProF	Profile 13 Step x	P13		121 - 130			Step Type	StyP	always	21001
Profile	ProF	Profile 13 Step x	P13		121 - 130			Control Mode Loop 1	Cm1	always	21024
Profile	ProF	Profile 13 Step x	P13		121 - 130			Control Mode Loop 2	Cm2	always	21025
Profile	ProF	Profile 13 Step x	P13		121 - 130			Control Mode Loop 3	Cm3	always	21026
Profile	ProF	Profile 13 Step x	P13		121 - 130			Control Mode Loop 4	Cm4	always	21027
Profile	ProF	Profile 13 Step x	P13		121 - 130			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 13 Step x	P13		121 - 130			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 13 Step x	P13		121 - 130			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 13 Step x	P13		121 - 130			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 13 Step x	P13		121 - 130			Hours	hour	always	21003
Profile	ProF	Profile 13 Step x	P13		121 - 130			Minutes	Min	always	21004
Profile	ProF	Profile 13 Step x	P13		121 - 130			Seconds	SEC	always	21005
Profile	ProF	Profile 13 Step x	P13		121 - 130			Rate	rAtE	always	21006
Profile	ProF	Profile 13 Step x	P13		121 - 130			Step Wait For Process Enable 1	PE1	always	21036
Profile	ProF	Profile 13 Step x	P13		121 - 130			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 13 Step x	P13		121 - 130			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 13 Step x	P13		121 - 130			Wait For Process 2	WJP2	always	21031
Profile	ProF	Profile 13 Step x	P13		121 - 130			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 13 Step x	P13		121 - 130			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 13 Step x	P13		121 - 130			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 13 Step x	P13		121 - 130			Wait For Process 4	WJP4	always	21033
Profile	ProF	Profile 13 Step x	P13	always	121 - 130	always		Wait Event 1	WJE1	always	21009
Profile	ProF	Profile 13 Step x	P13		121 - 130			Wait Event 2	WJE2	always	21010
Profile	ProF	Profile 13 Step x	P13		121 - 130			Wait Event 3	WJE3	always	21022
Profile	ProF	Profile 13 Step x	P13		121 - 130			Wait Event 4	WJE4	always	21023
Profile	ProF	Profile 13 Step x	P13		121 - 130			Day of Week	doW	always	21041
Profile	ProF	Profile 13 Step x	P13		121 - 130			Guaranteed Soak Enable 1	GSE1	always	21042
Profile	ProF	Profile 13 Step x	P13		121 - 130			Guaranteed Soak Enable 2	GSE2	always	21043
Profile	ProF	Profile 13 Step x	P13		121 - 130			Guaranteed Soak Enable 3	GSE3	always	21044
Profile	ProF	Profile 13 Step x	P13		121 - 130			Guaranteed Soak Enable 4	GSE4	always	21045
Profile	ProF	Profile 13 Step x	P13		121 - 130			Subroutine Step	SS	always	21034
Profile	ProF	Profile 13 Step x	P13		121 - 130			Subroutine Count	SC	always	21035
Profile	ProF	Profile 13 Step x	P13		121 - 130			Jump Step	JS	always	21012
Profile	ProF	Profile 13 Step x	P13		121 - 130			Jump Count	JC	always	21013
Profile	ProF	Profile 13 Step x	P13		121 - 130			Endy Type	End	always	21014
Profile	ProF	Profile 13 Step x	P13		121 - 130			Event 1	Ent1	always	21007
Profile	ProF	Profile 13 Step x	P13		121 - 130			Event 2	Ent2	always	21008
Profile	ProF	Profile 13 Step x	P13		121 - 130			Event 3	Ent3	always	21016
Profile	ProF	Profile 13 Step x	P13		121 - 130			Event 4	Ent4	always	21017
Profile	ProF	Profile 13 Step x	P13		121 - 130			Event 5	Ent5	always	21018
Profile	ProF	Profile 13 Step x	P13		121 - 130			Event 6	Ent6	always	21019
Profile	ProF	Profile 13 Step x	P13		121 - 130			Event 7	Ent7	always	21020
Profile	ProF	Profile 13 Step x	P13		121 - 130			Event 8	Ent8	always	21021

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Step Type	StyP	always	21001
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Control Mode Loop 1	Cn1	always	21024
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Control Mode Loop 2	Cn2	always	21025
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Control Mode Loop 3	Cn3	always	21026
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Control Mode Loop 4	Cn4	always	21027
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Hours	hoUr	always	21003
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Minutes	Mn in	always	21004
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Seconds	SEC	always	21005
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Rate	rAtE	always	21006
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Step Wait For Process Enable 1	PE1	always	21036
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Wait For Process 2	WJP2	always	21031
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Wait For Process 4	WJP4	always	21033
Profile	ProF	Profile 14 Step x	P 14	always	131 - 140	always		Wait Event 1	WJE1	always	21009
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Wait Event 2	WJE2	always	21010
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Wait Event 3	WJE3	always	21022
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Wait Event 4	WJE4	always	21023
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Day of Week	doWJ	always	21041
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Guaranteed Soak Enable 1	gSE1	always	21042
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Guaranteed Soak Enable 2	gSE2	always	21043
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Guaranteed Soak Enable 3	gSE3	always	21044
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Guaranteed Soak Enable 4	gSE4	always	21045
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Subroutine Step	SS	always	21034
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Subroutine Count	SC	always	21035
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Jump Step	JS	always	21012
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Jump Count	JC	always	21013
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Endy Type	End	always	21014
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Event 1	Ent1	always	21007
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Event 2	Ent2	always	21008
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Event 3	Ent3	always	21016
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Event 4	Ent4	always	21017
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Event 5	Ent5	always	21018
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Event 6	Ent6	always	21019
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Event 7	Ent7	always	21020
Profile	ProF	Profile 14 Step x	P 14		131 - 140			Event 8	Ent8	always	21021
Profile	ProF	Profile 15 Step x	P 15		141 - 150			Step Type	StyP	always	21001
Profile	ProF	Profile 15 Step x	P 15		141 - 150			Control Mode Loop 1	Cn1	always	21024

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 15 Step x	P15		141 - 150			Control Mode Loop 2	Cn2	always	21025
Profile	ProF	Profile 15 Step x	P15		141 - 150			Control Mode Loop 3	Cn3	always	21026
Profile	ProF	Profile 15 Step x	P15		141 - 150			Control Mode Loop 4	Cn4	always	21027
Profile	ProF	Profile 15 Step x	P15		141 - 150			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 15 Step x	P15		141 - 150			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 15 Step x	P15		141 - 150			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 15 Step x	P15		141 - 150			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 15 Step x	P15		141 - 150			Hours	hour	always	21003
Profile	ProF	Profile 15 Step x	P15		141 - 150			Minutes	Min	always	21004
Profile	ProF	Profile 15 Step x	P15		141 - 150			Seconds	SEC	always	21005
Profile	ProF	Profile 15 Step x	P15		141 - 150			Rate	rAtE	always	21006
Profile	ProF	Profile 15 Step x	P15		141 - 150			Step Wait For Process Enable 1	PE1	always	21036
Profile	ProF	Profile 15 Step x	P15		141 - 150			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 15 Step x	P15		141 - 150			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 15 Step x	P15		141 - 150			Wait For Process 2	WJP2	always	21031
Profile	ProF	Profile 15 Step x	P15		141 - 150			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 15 Step x	P15		141 - 150			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 15 Step x	P15		141 - 150			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 15 Step x	P15		141 - 150			Wait For Process 4	WJP4	always	21033
Profile	ProF	Profile 15 Step x	P15	always	141 - 150	always		Wait Event 1	WJE1	always	21009
Profile	ProF	Profile 15 Step x	P15		141 - 150			Wait Event 2	WJE2	always	21010
Profile	ProF	Profile 15 Step x	P15		141 - 150			Wait Event 3	WJE3	always	21022
Profile	ProF	Profile 15 Step x	P15		141 - 150			Wait Event 4	WJE4	always	21023
Profile	ProF	Profile 15 Step x	P15		141 - 150			Day of Week	doW	always	21041
Profile	ProF	Profile 15 Step x	P15		141 - 150			Guaranteed Soak Enable 1	GSE1	always	21042
Profile	ProF	Profile 15 Step x	P15		141 - 150			Guaranteed Soak Enable 2	GSE2	always	21043
Profile	ProF	Profile 15 Step x	P15		141 - 150			Guaranteed Soak Enable 3	GSE3	always	21044
Profile	ProF	Profile 15 Step x	P15		141 - 150			Guaranteed Soak Enable 4	GSE4	always	21045
Profile	ProF	Profile 15 Step x	P15		141 - 150			Subroutine Step	SS	always	21034
Profile	ProF	Profile 15 Step x	P15		141 - 150			Subroutine Count	SC	always	21035
Profile	ProF	Profile 15 Step x	P15		141 - 150			Jump Step	JS	always	21012
Profile	ProF	Profile 15 Step x	P15		141 - 150			Jump Count	JC	always	21013
Profile	ProF	Profile 15 Step x	P15		141 - 150			Endy Type	End	always	21014
Profile	ProF	Profile 15 Step x	P15		141 - 150			Event 1	Ent1	always	21007
Profile	ProF	Profile 15 Step x	P15		141 - 150			Event 2	Ent2	always	21008
Profile	ProF	Profile 15 Step x	P15		141 - 150			Event 3	Ent3	always	21016
Profile	ProF	Profile 15 Step x	P15		141 - 150			Event 4	Ent4	always	21017
Profile	ProF	Profile 15 Step x	P15		141 - 150			Event 5	Ent5	always	21018
Profile	ProF	Profile 15 Step x	P15		141 - 150			Event 6	Ent6	always	21019
Profile	ProF	Profile 15 Step x	P15		141 - 150			Event 7	Ent7	always	21020
Profile	ProF	Profile 15 Step x	P15		141 - 150			Event 8	Ent8	always	21021
Profile	ProF	Profile 16 Step x	P16		151 - 160			Step Type	StyP	always	21001
Profile	ProF	Profile 16 Step x	P16		151 - 160			Control Mode Loop 1	Cn1	always	21024
Profile	ProF	Profile 16 Step x	P16		151 - 160			Control Mode Loop 2	Cn2	always	21025
Profile	ProF	Profile 16 Step x	P16		151 - 160			Control Mode Loop 3	Cn3	always	21026
Profile	ProF	Profile 16 Step x	P16		151 - 160			Control Mode Loop 4	Cn4	always	21027

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 16 Step x	P16		151 - 160			Target Set Point Loop 1	t.SP1	always	21002
Profile	ProF	Profile 16 Step x	P16		151 - 160			Target Set Point Loop 2	t.SP2	always	21028
Profile	ProF	Profile 16 Step x	P16		151 - 160			Target Set Point Loop 3	t.SP3	always	21029
Profile	ProF	Profile 16 Step x	P16		151 - 160			Target Set Point Loop 4	t.SP4	always	21030
Profile	ProF	Profile 16 Step x	P16		151 - 160			Hours	hoUr	always	21003
Profile	ProF	Profile 16 Step x	P16		151 - 160			Minutes	MIn	always	21004
Profile	ProF	Profile 16 Step x	P16		151 - 160			Seconds	SEC	always	21005
Profile	ProF	Profile 16 Step x	P16		151 - 160			Rate	rAtE	always	21006
Profile	ProF	Profile 16 Step x	P16		151 - 160			Step Wait For Process Enable 1	P.E1	always	21036
Profile	ProF	Profile 16 Step x	P16		151 - 160			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 16 Step x	P16		151 - 160			Step Wait For Process Enable 2	P.E2	always	21037
Profile	ProF	Profile 16 Step x	P16		151 - 160			Wait For Process 2	WJP2	always	21031
Profile	ProF	Profile 16 Step x	P16		151 - 160			Step Wait For Process Enable 3	P.E3	always	21038
Profile	ProF	Profile 16 Step x	P16		151 - 160			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 16 Step x	P16		151 - 160			Step Wait For Process Enable 4	P.E4	always	21039
Profile	ProF	Profile 16 Step x	P16		151 - 160			Wait For Process 4	WJP4	always	21033
Profile	ProF	Profile 16 Step x	P16	always	151 - 160	always		Wait Event 1	WJE1	always	21009
Profile	ProF	Profile 16 Step x	P16		151 - 160			Wait Event 2	WJE2	always	21010
Profile	ProF	Profile 16 Step x	P16		151 - 160			Wait Event 3	WJE3	always	21022
Profile	ProF	Profile 16 Step x	P16		151 - 160			Wait Event 4	WJE4	always	21023
Profile	ProF	Profile 16 Step x	P16		151 - 160			Day of Week	doWW	always	21041
Profile	ProF	Profile 16 Step x	P16		151 - 160			Guaranteed Soak Enable 1	gSE1	always	21042
Profile	ProF	Profile 16 Step x	P16		151 - 160			Guaranteed Soak Enable 2	gSE2	always	21043
Profile	ProF	Profile 16 Step x	P16		151 - 160			Guaranteed Soak Enable 3	gSE3	always	21044
Profile	ProF	Profile 16 Step x	P16		151 - 160			Guaranteed Soak Enable 4	gSE4	always	21045
Profile	ProF	Profile 16 Step x	P16		151 - 160			Subroutine Step	SS	always	21034
Profile	ProF	Profile 16 Step x	P16		151 - 160			Subroutine Count	SC	always	21035
Profile	ProF	Profile 16 Step x	P16		151 - 160			Jump Step	JS	always	21012
Profile	ProF	Profile 16 Step x	P16		151 - 160			Jump Count	JC	always	21013
Profile	ProF	Profile 16 Step x	P16		151 - 160			Endy Type	End	always	21014
Profile	ProF	Profile 16 Step x	P16		151 - 160			Event 1	Ent1	always	21007
Profile	ProF	Profile 16 Step x	P16		151 - 160			Event 2	Ent2	always	21008
Profile	ProF	Profile 16 Step x	P16		151 - 160			Event 3	Ent3	always	21016
Profile	ProF	Profile 16 Step x	P16		151 - 160			Event 4	Ent4	always	21017
Profile	ProF	Profile 16 Step x	P16		151 - 160			Event 5	Ent5	always	21018
Profile	ProF	Profile 16 Step x	P16		151 - 160			Event 6	Ent6	always	21019
Profile	ProF	Profile 16 Step x	P16		151 - 160			Event 7	Ent7	always	21020
Profile	ProF	Profile 16 Step x	P16		151 - 160			Event 8	Ent8	always	21021
Profile	ProF	Profile 17 Step x	P17		161 - 170			Step Type	StyP	always	21001
Profile	ProF	Profile 17 Step x	P17		161 - 170			Control Mode Loop 1	CM1	always	21024
Profile	ProF	Profile 17 Step x	P17		161 - 170			Control Mode Loop 2	CM2	always	21025
Profile	ProF	Profile 17 Step x	P17		161 - 170			Control Mode Loop 3	CM3	always	21026
Profile	ProF	Profile 17 Step x	P17		161 - 170			Control Mode Loop 4	CM4	always	21027
Profile	ProF	Profile 17 Step x	P17		161 - 170			Target Set Point Loop 1	t.SP1	always	21002
Profile	ProF	Profile 17 Step x	P17		161 - 170			Target Set Point Loop 2	t.SP2	always	21028
Profile	ProF	Profile 17 Step x	P17		161 - 170			Target Set Point Loop 3	t.SP3	always	21029

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 17 Step x	P17		161 - 170			Target Set Point Loop 4	t.SP4	always	21030
Profile	ProF	Profile 17 Step x	P17		161 - 170			Hours	hoUr	always	21003
Profile	ProF	Profile 17 Step x	P17		161 - 170			Minutes	mn.in	always	21004
Profile	ProF	Profile 17 Step x	P17		161 - 170			Seconds	SEC	always	21005
Profile	ProF	Profile 17 Step x	P17		161 - 170			Rate	rAtE	always	21006
Profile	ProF	Profile 17 Step x	P17		161 - 170			Step Wait For Process Enable 1	P.E1	always	21036
Profile	ProF	Profile 17 Step x	P17		161 - 170			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 17 Step x	P17		161 - 170			Step Wait For Process Enable 2	P.E2	always	21037
Profile	ProF	Profile 17 Step x	P17		161 - 170			Wait For Process 2	WJP2	always	21031
Profile	ProF	Profile 17 Step x	P17		161 - 170			Step Wait For Process Enable 3	P.E3	always	21038
Profile	ProF	Profile 17 Step x	P17		161 - 170			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 17 Step x	P17		161 - 170			Step Wait For Process Enable 4	P.E4	always	21039
Profile	ProF	Profile 17 Step x	P17		161 - 170			Wait For Process 4	WJP4	always	21033
Profile	ProF	Profile 17 Step x	P17	always	161 - 170	always		Wait Event 1	WJE1	always	21009
Profile	ProF	Profile 17 Step x	P17		161 - 170			Wait Event 2	WJE2	always	21010
Profile	ProF	Profile 17 Step x	P17		161 - 170			Wait Event 3	WJE3	always	21022
Profile	ProF	Profile 17 Step x	P17		161 - 170			Wait Event 4	WJE4	always	21023
Profile	ProF	Profile 17 Step x	P17		161 - 170			Day of Week	doWJ	always	21041
Profile	ProF	Profile 17 Step x	P17		161 - 170			Guaranteed Soak Enable 1	GSE1	always	21042
Profile	ProF	Profile 17 Step x	P17		161 - 170			Guaranteed Soak Enable 2	GSE2	always	21043
Profile	ProF	Profile 17 Step x	P17		161 - 170			Guaranteed Soak Enable 3	GSE3	always	21044
Profile	ProF	Profile 17 Step x	P17		161 - 170			Guaranteed Soak Enable 4	GSE4	always	21045
Profile	ProF	Profile 17 Step x	P17		161 - 170			Subroutine Step	SS	always	21034
Profile	ProF	Profile 17 Step x	P17		161 - 170			Subroutine Count	SC	always	21035
Profile	ProF	Profile 17 Step x	P17		161 - 170			Jump Step	JS	always	21012
Profile	ProF	Profile 17 Step x	P17		161 - 170			Jump Count	JC	always	21013
Profile	ProF	Profile 17 Step x	P17		161 - 170			Endy Type	End	always	21014
Profile	ProF	Profile 17 Step x	P17		161 - 170			Event 1	Ent1	always	21007
Profile	ProF	Profile 17 Step x	P17		161 - 170			Event 2	Ent2	always	21008
Profile	ProF	Profile 17 Step x	P17		161 - 170			Event 3	Ent3	always	21016
Profile	ProF	Profile 17 Step x	P17		161 - 170			Event 4	Ent4	always	21017
Profile	ProF	Profile 17 Step x	P17		161 - 170			Event 5	Ent5	always	21018
Profile	ProF	Profile 17 Step x	P17		161 - 170			Event 6	Ent6	always	21019
Profile	ProF	Profile 17 Step x	P17		161 - 170			Event 7	Ent7	always	21020
Profile	ProF	Profile 17 Step x	P17		161 - 170			Event 8	Ent8	always	21021
Profile	ProF	Profile 18 Step x	P18		171 - 180			Step Type	St.yP	always	21001
Profile	ProF	Profile 18 Step x	P18		171 - 180			Control Mode Loop 1	C.M1	always	21024
Profile	ProF	Profile 18 Step x	P18		171 - 180			Control Mode Loop 2	C.M2	always	21025
Profile	ProF	Profile 18 Step x	P18		171 - 180			Control Mode Loop 3	C.M3	always	21026
Profile	ProF	Profile 18 Step x	P18		171 - 180			Control Mode Loop 4	C.M4	always	21027
Profile	ProF	Profile 18 Step x	P18		171 - 180			Target Set Point Loop 1	t.SP1	always	21002
Profile	ProF	Profile 18 Step x	P18		171 - 180			Target Set Point Loop 2	t.SP2	always	21028
Profile	ProF	Profile 18 Step x	P18		171 - 180			Target Set Point Loop 3	t.SP3	always	21029
Profile	ProF	Profile 18 Step x	P18		171 - 180			Target Set Point Loop 4	t.SP4	always	21030
Profile	ProF	Profile 18 Step x	P18		171 - 180			Hours	hoUr	always	21003
Profile	ProF	Profile 18 Step x	P18		171 - 180			Minutes	mn.in	always	21004

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Seconds	SEC	always	21005
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Rate	rAtE	always	21006
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Step Wait For Process Enable 1	P.E 1	always	21036
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Wait For Process 1	WJP 1	always	21011
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Step Wait For Process Enable 2	P.E2	always	21037
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Wait For Process 2	WJP2	always	21031
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Step Wait For Process Enable 3	P.E3	always	21038
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Step Wait For Process Enable 4	P.E4	always	21039
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Wait For Process 4	WJP4	always	21033
Profile	ProF	Profile 18 Step x	P 18	always	171 - 180	always		Wait Event 1	WJE.1	always	21009
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Wait Event 2	WJE.2	always	21010
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Wait Event 3	WJE.3	always	21022
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Wait Event 4	WJE.4	always	21023
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Day of Week	doWJ	always	21041
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Guaranteed Soak Enable 1	gSE 1	always	21042
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Guaranteed Soak Enable 2	gSE2	always	21043
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Guaranteed Soak Enable 3	gSE3	always	21044
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Guaranteed Soak Enable 4	gSE4	always	21045
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Subroutine Step	SS	always	21034
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Subroutine Count	SC	always	21035
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Jump Step	JS	always	21012
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Jump Count	JC	always	21013
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Endy Type	End	always	21014
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Event 1	Ent 1	always	21007
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Event 2	Ent2	always	21008
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Event 3	Ent3	always	21016
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Event 4	Ent4	always	21017
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Event 5	Ent5	always	21018
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Event 6	Ent6	always	21019
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Event 7	Ent7	always	21020
Profile	ProF	Profile 18 Step x	P 18		171 - 180			Event 8	Ent8	always	21021
Profile	ProF	Profile 19 Step x	P 19		181 - 190			Step Type	StyP	always	21001
Profile	ProF	Profile 19 Step x	P 19		181 - 190			Control Mode Loop 1	C.M1	always	21024
Profile	ProF	Profile 19 Step x	P 19		181 - 190			Control Mode Loop 2	C.M2	always	21025
Profile	ProF	Profile 19 Step x	P 19		181 - 190			Control Mode Loop 3	C.M3	always	21026
Profile	ProF	Profile 19 Step x	P 19		181 - 190			Control Mode Loop 4	C.M4	always	21027
Profile	ProF	Profile 19 Step x	P 19		181 - 190			Target Set Point Loop 1	t.SP 1	always	21002
Profile	ProF	Profile 19 Step x	P 19		181 - 190			Target Set Point Loop 2	t.SP2	always	21028
Profile	ProF	Profile 19 Step x	P 19		181 - 190			Target Set Point Loop 3	t.SP3	always	21029
Profile	ProF	Profile 19 Step x	P 19		181 - 190			Target Set Point Loop 4	t.SP4	always	21030
Profile	ProF	Profile 19 Step x	P 19		181 - 190			Hours	hoUr	always	21003
Profile	ProF	Profile 19 Step x	P 19		181 - 190			Minutes	MIn	always	21004
Profile	ProF	Profile 19 Step x	P 19		181 - 190			Seconds	SEC	always	21005
Profile	ProF	Profile 19 Step x	P 19		181 - 190			Rate	rAtE	always	21006
Profile	ProF	Profile 19 Step x	P 19		181 - 190			Step Wait For Process Enable 1	P.E 1	always	21036

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 19 Step x	P19		181 - 190			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 19 Step x	P19		181 - 190			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 19 Step x	P19		181 - 190			Wait For Process 2	WJP2	always	21031
Profile	ProF	Profile 19 Step x	P19		181 - 190			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 19 Step x	P19		181 - 190			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 19 Step x	P19		181 - 190			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 19 Step x	P19		181 - 190			Wait For Process 4	WJP4	always	21033
Profile	ProF	Profile 19 Step x	P19	always	181 - 190	always		Wait Event 1	WJE1	always	21009
Profile	ProF	Profile 19 Step x	P19		181 - 190			Wait Event 2	WJE2	always	21010
Profile	ProF	Profile 19 Step x	P19		181 - 190			Wait Event 3	WJE3	always	21022
Profile	ProF	Profile 19 Step x	P19		181 - 190			Wait Event 4	WJE4	always	21023
Profile	ProF	Profile 19 Step x	P19		181 - 190			Day of Week	doWJ	always	21041
Profile	ProF	Profile 19 Step x	P19		181 - 190			Guaranteed Soak Enable 1	GSE1	always	21042
Profile	ProF	Profile 19 Step x	P19		181 - 190			Guaranteed Soak Enable 2	GSE2	always	21043
Profile	ProF	Profile 19 Step x	P19		181 - 190			Guaranteed Soak Enable 3	GSE3	always	21044
Profile	ProF	Profile 19 Step x	P19		181 - 190			Guaranteed Soak Enable 4	GSE4	always	21045
Profile	ProF	Profile 19 Step x	P19		181 - 190			Subroutine Step	SS	always	21034
Profile	ProF	Profile 19 Step x	P19		181 - 190			Subroutine Count	SC	always	21035
Profile	ProF	Profile 19 Step x	P19		181 - 190			Jump Step	JS	always	21012
Profile	ProF	Profile 19 Step x	P19		181 - 190			Jump Count	JC	always	21013
Profile	ProF	Profile 19 Step x	P19		181 - 190			Endy Type	End	always	21014
Profile	ProF	Profile 19 Step x	P19		181 - 190			Event 1	Ent1	always	21007
Profile	ProF	Profile 19 Step x	P19		181 - 190			Event 2	Ent2	always	21008
Profile	ProF	Profile 19 Step x	P19		181 - 190			Event 3	Ent3	always	21016
Profile	ProF	Profile 19 Step x	P19		181 - 190			Event 4	Ent4	always	21017
Profile	ProF	Profile 19 Step x	P19		181 - 190			Event 5	Ent5	always	21018
Profile	ProF	Profile 19 Step x	P19		181 - 190			Event 6	Ent6	always	21019
Profile	ProF	Profile 19 Step x	P19		181 - 190			Event 7	Ent7	always	21020
Profile	ProF	Profile 19 Step x	P19		181 - 190			Event 8	Ent8	always	21021
Profile	ProF	Profile 20 Step x	P20		191 - 200			Step Type	StyP	always	21001
Profile	ProF	Profile 20 Step x	P20		191 - 200			Control Mode Loop 1	Cm1	always	21024
Profile	ProF	Profile 20 Step x	P20		191 - 200			Control Mode Loop 2	Cm2	always	21025
Profile	ProF	Profile 20 Step x	P20		191 - 200			Control Mode Loop 3	Cm3	always	21026
Profile	ProF	Profile 20 Step x	P20		191 - 200			Control Mode Loop 4	Cm4	always	21027
Profile	ProF	Profile 20 Step x	P20		191 - 200			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 20 Step x	P20		191 - 200			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 20 Step x	P20		191 - 200			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 20 Step x	P20		191 - 200			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 20 Step x	P20		191 - 200			Hours	hour	always	21003
Profile	ProF	Profile 20 Step x	P20		191 - 200			Minutes	Min	always	21004
Profile	ProF	Profile 20 Step x	P20		191 - 200			Seconds	SEC	always	21005
Profile	ProF	Profile 20 Step x	P20		191 - 200			Rate	rAtE	always	21006
Profile	ProF	Profile 20 Step x	P20		191 - 200			Step Wait For Process Enable 1	PE1	always	21036
Profile	ProF	Profile 20 Step x	P20		191 - 200			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 20 Step x	P20		191 - 200			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 20 Step x	P20		191 - 200			Wait For Process 2	WJP2	always	21031

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 20 Step x	P20		191 - 200			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 20 Step x	P20		191 - 200			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 20 Step x	P20		191 - 200			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 20 Step x	P20		191 - 200			Wait For Process 4	WJP4	always	21033
Profile	ProF	Profile 20 Step x	P20	always	191 - 200	always		Wait Event 1	WJE1	always	21009
Profile	ProF	Profile 20 Step x	P20		191 - 200			Wait Event 2	WJE2	always	21010
Profile	ProF	Profile 20 Step x	P20		191 - 200			Wait Event 3	WJE3	always	21022
Profile	ProF	Profile 20 Step x	P20		191 - 200			Wait Event 4	WJE4	always	21023
Profile	ProF	Profile 20 Step x	P20		191 - 200			Day of Week	doW	always	21041
Profile	ProF	Profile 20 Step x	P20		191 - 200			Guaranteed Soak Enable 1	GSE1	always	21042
Profile	ProF	Profile 20 Step x	P20		191 - 200			Guaranteed Soak Enable 2	GSE2	always	21043
Profile	ProF	Profile 20 Step x	P20		191 - 200			Guaranteed Soak Enable 3	GSE3	always	21044
Profile	ProF	Profile 20 Step x	P20		191 - 200			Guaranteed Soak Enable 4	GSE4	always	21045
Profile	ProF	Profile 20 Step x	P20		191 - 200			Subroutine Step	SS	always	21034
Profile	ProF	Profile 20 Step x	P20		191 - 200			Subroutine Count	SC	always	21035
Profile	ProF	Profile 20 Step x	P20		191 - 200			Jump Step	JS	always	21012
Profile	ProF	Profile 20 Step x	P20		191 - 200			Jump Count	JC	always	21013
Profile	ProF	Profile 20 Step x	P20		191 - 200			Endy Type	End	always	21014
Profile	ProF	Profile 20 Step x	P20		191 - 200			Event 1	Ent1	always	21007
Profile	ProF	Profile 20 Step x	P20		191 - 200			Event 2	Ent2	always	21008
Profile	ProF	Profile 20 Step x	P20		191 - 200			Event 3	Ent3	always	21016
Profile	ProF	Profile 20 Step x	P20		191 - 200			Event 4	Ent4	always	21017
Profile	ProF	Profile 20 Step x	P20		191 - 200			Event 5	Ent5	always	21018
Profile	ProF	Profile 20 Step x	P20		191 - 200			Event 6	Ent6	always	21019
Profile	ProF	Profile 20 Step x	P20		191 - 200			Event 7	Ent7	always	21020
Profile	ProF	Profile 20 Step x	P20		191 - 200			Event 8	Ent8	always	21021
Profile	ProF	Profile 21 Step x	P21		201 - 210			Step Type	StyP	always	21001
Profile	ProF	Profile 21 Step x	P21		201 - 210			Control Mode Loop 1	Cnt1	always	21024
Profile	ProF	Profile 21 Step x	P21		201 - 210			Control Mode Loop 2	Cnt2	always	21025
Profile	ProF	Profile 21 Step x	P21		201 - 210			Control Mode Loop 3	Cnt3	always	21026
Profile	ProF	Profile 21 Step x	P21		201 - 210			Control Mode Loop 4	Cnt4	always	21027
Profile	ProF	Profile 21 Step x	P21		201 - 210			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 21 Step x	P21		201 - 210			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 21 Step x	P21		201 - 210			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 21 Step x	P21		201 - 210			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 21 Step x	P21		201 - 210			Hours	hour	always	21003
Profile	ProF	Profile 21 Step x	P21		201 - 210			Minutes	Min	always	21004
Profile	ProF	Profile 21 Step x	P21		201 - 210			Seconds	SEC	always	21005
Profile	ProF	Profile 21 Step x	P21		201 - 210			Rate	rAtE	always	21006
Profile	ProF	Profile 21 Step x	P21		201 - 210			Step Wait For Process Enable 1	PE1	always	21036
Profile	ProF	Profile 21 Step x	P21		201 - 210			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 21 Step x	P21		201 - 210			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 21 Step x	P21		201 - 210			Wait For Process 2	WJP2	always	21031
Profile	ProF	Profile 21 Step x	P21		201 - 210			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 21 Step x	P21		201 - 210			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 21 Step x	P21		201 - 210			Step Wait For Process Enable 4	PE4	always	21039

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 21 Step x	P21		201 - 210			Wait For Process 4	uJP4	always	21033
Profile	ProF	Profile 21 Step x	P21	always	201 - 210	always		Wait Event 1	uJE1	always	21009
Profile	ProF	Profile 21 Step x	P21		201 - 210			Wait Event 2	uJE2	always	21010
Profile	ProF	Profile 21 Step x	P21		201 - 210			Wait Event 3	uJE3	always	21022
Profile	ProF	Profile 21 Step x	P21		201 - 210			Wait Event 4	uJE4	always	21023
Profile	ProF	Profile 21 Step x	P21		201 - 210			Day of Week	doU	always	21041
Profile	ProF	Profile 21 Step x	P21		201 - 210			Guaranteed Soak Enable 1	gSE1	always	21042
Profile	ProF	Profile 21 Step x	P21		201 - 210			Guaranteed Soak Enable 2	gSE2	always	21043
Profile	ProF	Profile 21 Step x	P21		201 - 210			Guaranteed Soak Enable 3	gSE3	always	21044
Profile	ProF	Profile 21 Step x	P21		201 - 210			Guaranteed Soak Enable 4	gSE4	always	21045
Profile	ProF	Profile 21 Step x	P21		201 - 210			Subroutine Step	SS	always	21034
Profile	ProF	Profile 21 Step x	P21		201 - 210			Subroutine Count	SC	always	21035
Profile	ProF	Profile 21 Step x	P21		201 - 210			Jump Step	JS	always	21012
Profile	ProF	Profile 21 Step x	P21		201 - 210			Jump Count	JC	always	21013
Profile	ProF	Profile 21 Step x	P21		201 - 210			Endy Type	End	always	21014
Profile	ProF	Profile 21 Step x	P21		201 - 210			Event 1	Ent1	always	21007
Profile	ProF	Profile 21 Step x	P21		201 - 210			Event 2	Ent2	always	21008
Profile	ProF	Profile 21 Step x	P21		201 - 210			Event 3	Ent3	always	21016
Profile	ProF	Profile 21 Step x	P21		201 - 210			Event 4	Ent4	always	21017
Profile	ProF	Profile 21 Step x	P21		201 - 210			Event 5	Ent5	always	21018
Profile	ProF	Profile 21 Step x	P21		201 - 210			Event 6	Ent6	always	21019
Profile	ProF	Profile 21 Step x	P21		201 - 210			Event 7	Ent7	always	21020
Profile	ProF	Profile 21 Step x	P21		201 - 210			Event 8	Ent8	always	21021
Profile	ProF	Profile 22 Step x	P22		211 - 220			Step Type	StyP	always	21001
Profile	ProF	Profile 22 Step x	P22		211 - 220			Control Mode Loop 1	CM1	always	21024
Profile	ProF	Profile 22 Step x	P22		211 - 220			Control Mode Loop 2	CM2	always	21025
Profile	ProF	Profile 22 Step x	P22		211 - 220			Control Mode Loop 3	CM3	always	21026
Profile	ProF	Profile 22 Step x	P22		211 - 220			Control Mode Loop 4	CM4	always	21027
Profile	ProF	Profile 22 Step x	P22		211 - 220			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 22 Step x	P22		211 - 220			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 22 Step x	P22		211 - 220			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 22 Step x	P22		211 - 220			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 22 Step x	P22		211 - 220			Hours	hoUr	always	21003
Profile	ProF	Profile 22 Step x	P22		211 - 220			Minutes	MIn	always	21004
Profile	ProF	Profile 22 Step x	P22		211 - 220			Seconds	SEC	always	21005
Profile	ProF	Profile 22 Step x	P22		211 - 220			Rate	rAtE	always	21006
Profile	ProF	Profile 22 Step x	P22		211 - 220			Step Wait For Process Enable 1	PE1	always	21036
Profile	ProF	Profile 22 Step x	P22		211 - 220			Wait For Process 1	uJP1	always	21011
Profile	ProF	Profile 22 Step x	P22		211 - 220			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 22 Step x	P22		211 - 220			Wait For Process 2	uJP2	always	21031
Profile	ProF	Profile 22 Step x	P22		211 - 220			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 22 Step x	P22		211 - 220			Wait For Process 3	uJP3	always	21032
Profile	ProF	Profile 22 Step x	P22		211 - 220			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 22 Step x	P22		211 - 220			Wait For Process 4	uJP4	always	21033
Profile	ProF	Profile 22 Step x	P22	always	211 - 220	always		Wait Event 1	uJE1	always	21009
Profile	ProF	Profile 22 Step x	P22		211 - 220			Wait Event 2	uJE2	always	21010

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 22 Step x	P22		211 - 220			Wait Event 3	uJE.3	always	21022
Profile	ProF	Profile 22 Step x	P22		211 - 220			Wait Event 4	uJE.4	always	21023
Profile	ProF	Profile 22 Step x	P22		211 - 220			Day of Week	doUJ	always	21041
Profile	ProF	Profile 22 Step x	P22		211 - 220			Guaranteed Soak Enable 1	gSE1	always	21042
Profile	ProF	Profile 22 Step x	P22		211 - 220			Guaranteed Soak Enable 2	gSE2	always	21043
Profile	ProF	Profile 22 Step x	P22		211 - 220			Guaranteed Soak Enable 3	gSE3	always	21044
Profile	ProF	Profile 22 Step x	P22		211 - 220			Guaranteed Soak Enable 4	gSE4	always	21045
Profile	ProF	Profile 22 Step x	P22		211 - 220			Subroutine Step	SS	always	21034
Profile	ProF	Profile 22 Step x	P22		211 - 220			Subroutine Count	SC	always	21035
Profile	ProF	Profile 22 Step x	P22		211 - 220			Jump Step	JS	always	21012
Profile	ProF	Profile 22 Step x	P22		211 - 220			Jump Count	JC	always	21013
Profile	ProF	Profile 22 Step x	P22		211 - 220			Endy Type	End	always	21014
Profile	ProF	Profile 22 Step x	P22		211 - 220			Event 1	Ent1	always	21007
Profile	ProF	Profile 22 Step x	P22		211 - 220			Event 2	Ent2	always	21008
Profile	ProF	Profile 22 Step x	P22		211 - 220			Event 3	Ent3	always	21016
Profile	ProF	Profile 22 Step x	P22		211 - 220			Event 4	Ent4	always	21017
Profile	ProF	Profile 22 Step x	P22		211 - 220			Event 5	Ent5	always	21018
Profile	ProF	Profile 22 Step x	P22		211 - 220			Event 6	Ent6	always	21019
Profile	ProF	Profile 22 Step x	P22		211 - 220			Event 7	Ent7	always	21020
Profile	ProF	Profile 22 Step x	P22		211 - 220			Event 8	Ent8	always	21021
Profile	ProF	Profile 23 Step x	P23		221 - 230			Step Type	StYP	always	21001
Profile	ProF	Profile 23 Step x	P23		221 - 230			Control Mode Loop 1	Cm1	always	21024
Profile	ProF	Profile 23 Step x	P23		221 - 230			Control Mode Loop 2	Cm2	always	21025
Profile	ProF	Profile 23 Step x	P23		221 - 230			Control Mode Loop 3	Cm3	always	21026
Profile	ProF	Profile 23 Step x	P23		221 - 230			Control Mode Loop 4	Cm4	always	21027
Profile	ProF	Profile 23 Step x	P23		221 - 230			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 23 Step x	P23		221 - 230			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 23 Step x	P23		221 - 230			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 23 Step x	P23		221 - 230			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 23 Step x	P23		221 - 230			Hours	hoUr	always	21003
Profile	ProF	Profile 23 Step x	P23		221 - 230			Minutes	Min	always	21004
Profile	ProF	Profile 23 Step x	P23		221 - 230			Seconds	SEC	always	21005
Profile	ProF	Profile 23 Step x	P23		221 - 230			Rate	rAtE	always	21006
Profile	ProF	Profile 23 Step x	P23		221 - 230			Step Wait For Process Enable 1	PE1	always	21036
Profile	ProF	Profile 23 Step x	P23		221 - 230			Wait For Process 1	uJP1	always	21011
Profile	ProF	Profile 23 Step x	P23		221 - 230			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 23 Step x	P23		221 - 230			Wait For Process 2	uJP2	always	21031
Profile	ProF	Profile 23 Step x	P23		221 - 230			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 23 Step x	P23		221 - 230			Wait For Process 3	uJP3	always	21032
Profile	ProF	Profile 23 Step x	P23		221 - 230			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 23 Step x	P23		221 - 230			Wait For Process 4	uJP4	always	21033
Profile	ProF	Profile 23 Step x	P23	always	221 - 230	always		Wait Event 1	uJE.1	always	21009
Profile	ProF	Profile 23 Step x	P23		221 - 230			Wait Event 2	uJE.2	always	21010
Profile	ProF	Profile 23 Step x	P23		221 - 230			Wait Event 3	uJE.3	always	21022
Profile	ProF	Profile 23 Step x	P23		221 - 230			Wait Event 4	uJE.4	always	21023
Profile	ProF	Profile 23 Step x	P23		221 - 230			Day of Week	doUJ	always	21041

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 23 Step x	P23		221 - 230			Guaranteed Soak Enable 1	9SE1	always	21042
Profile	ProF	Profile 23 Step x	P23		221 - 230			Guaranteed Soak Enable 2	9SE2	always	21043
Profile	ProF	Profile 23 Step x	P23		221 - 230			Guaranteed Soak Enable 3	9SE3	always	21044
Profile	ProF	Profile 23 Step x	P23		221 - 230			Guaranteed Soak Enable 4	9SE4	always	21045
Profile	ProF	Profile 23 Step x	P23		221 - 230			Subroutine Step	SS	always	21034
Profile	ProF	Profile 23 Step x	P23		221 - 230			Subroutine Count	SC	always	21035
Profile	ProF	Profile 23 Step x	P23		221 - 230			Jump Step	JS	always	21012
Profile	ProF	Profile 23 Step x	P23		221 - 230			Jump Count	JC	always	21013
Profile	ProF	Profile 23 Step x	P23		221 - 230			Endy Type	End	always	21014
Profile	ProF	Profile 23 Step x	P23		221 - 230			Event 1	Ent1	always	21007
Profile	ProF	Profile 23 Step x	P23		221 - 230			Event 2	Ent2	always	21008
Profile	ProF	Profile 23 Step x	P23		221 - 230			Event 3	Ent3	always	21016
Profile	ProF	Profile 23 Step x	P23		221 - 230			Event 4	Ent4	always	21017
Profile	ProF	Profile 23 Step x	P23		221 - 230			Event 5	Ent5	always	21018
Profile	ProF	Profile 23 Step x	P23		221 - 230			Event 6	Ent6	always	21019
Profile	ProF	Profile 23 Step x	P23		221 - 230			Event 7	Ent7	always	21020
Profile	ProF	Profile 23 Step x	P23		221 - 230			Event 8	Ent8	always	21021
Profile	ProF	Profile 24 Step x	P24		231 - 240			Step Type	StyP	always	21001
Profile	ProF	Profile 24 Step x	P24		231 - 240			Control Mode Loop 1	Cm1	always	21024
Profile	ProF	Profile 24 Step x	P24		231 - 240			Control Mode Loop 2	Cm2	always	21025
Profile	ProF	Profile 24 Step x	P24		231 - 240			Control Mode Loop 3	Cm3	always	21026
Profile	ProF	Profile 24 Step x	P24		231 - 240			Control Mode Loop 4	Cm4	always	21027
Profile	ProF	Profile 24 Step x	P24		231 - 240			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 24 Step x	P24		231 - 240			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 24 Step x	P24		231 - 240			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 24 Step x	P24		231 - 240			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 24 Step x	P24		231 - 240			Hours	hour	always	21003
Profile	ProF	Profile 24 Step x	P24		231 - 240			Minutes	Min	always	21004
Profile	ProF	Profile 24 Step x	P24		231 - 240			Seconds	SEC	always	21005
Profile	ProF	Profile 24 Step x	P24		231 - 240			Rate	rAtE	always	21006
Profile	ProF	Profile 24 Step x	P24		231 - 240			Step Wait For Process Enable 1	PE1	always	21036
Profile	ProF	Profile 24 Step x	P24		231 - 240			Wait For Process 1	WJP1	always	21011
Profile	ProF	Profile 24 Step x	P24		231 - 240			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 24 Step x	P24		231 - 240			Wait For Process 2	WJP2	always	21031
Profile	ProF	Profile 24 Step x	P24		231 - 240			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 24 Step x	P24		231 - 240			Wait For Process 3	WJP3	always	21032
Profile	ProF	Profile 24 Step x	P24		231 - 240			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 24 Step x	P24		231 - 240			Wait For Process 4	WJP4	always	21033
Profile	ProF	Profile 24 Step x	P24	always	231 - 240	always		Wait Event 1	WJE1	always	21009
Profile	ProF	Profile 24 Step x	P24		231 - 240			Wait Event 2	WJE2	always	21010
Profile	ProF	Profile 24 Step x	P24		231 - 240			Wait Event 3	WJE3	always	21022
Profile	ProF	Profile 24 Step x	P24		231 - 240			Wait Event 4	WJE4	always	21023
Profile	ProF	Profile 24 Step x	P24		231 - 240			Day of Week	doW	always	21041
Profile	ProF	Profile 24 Step x	P24		231 - 240			Guaranteed Soak Enable 1	9SE1	always	21042
Profile	ProF	Profile 24 Step x	P24		231 - 240			Guaranteed Soak Enable 2	9SE2	always	21043
Profile	ProF	Profile 24 Step x	P24		231 - 240			Guaranteed Soak Enable 3	9SE3	always	21044

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 24 Step x	P24		231 - 240			Guaranteed Soak Enable 4	9SE4	always	21045
Profile	ProF	Profile 24 Step x	P24		231 - 240			Subroutine Step	SS	always	21034
Profile	ProF	Profile 24 Step x	P24		231 - 240			Subroutine Count	SC	always	21035
Profile	ProF	Profile 24 Step x	P24		231 - 240			Jump Step	JS	always	21012
Profile	ProF	Profile 24 Step x	P24		231 - 240			Jump Count	JC	always	21013
Profile	ProF	Profile 24 Step x	P24		231 - 240			Endy Type	End	always	21014
Profile	ProF	Profile 24 Step x	P24		231 - 240			Event 1	Ent1	always	21007
Profile	ProF	Profile 24 Step x	P24		231 - 240			Event 2	Ent2	always	21008
Profile	ProF	Profile 24 Step x	P24		231 - 240			Event 3	Ent3	always	21016
Profile	ProF	Profile 24 Step x	P24		231 - 240			Event 4	Ent4	always	21017
Profile	ProF	Profile 24 Step x	P24		231 - 240			Event 5	Ent5	always	21018
Profile	ProF	Profile 24 Step x	P24		231 - 240			Event 6	Ent6	always	21019
Profile	ProF	Profile 24 Step x	P24		231 - 240			Event 7	Ent7	always	21020
Profile	ProF	Profile 24 Step x	P24		231 - 240			Event 8	Ent8	always	21021
Profile	ProF	Profile 25 Step x	P25		241 - 250			Step Type	StyP	always	21001
Profile	ProF	Profile 25 Step x	P25		241 - 250			Control Mode Loop 1	Cm1	always	21024
Profile	ProF	Profile 25 Step x	P25		241 - 250			Control Mode Loop 2	Cm2	always	21025
Profile	ProF	Profile 25 Step x	P25		241 - 250			Control Mode Loop 3	Cm3	always	21026
Profile	ProF	Profile 25 Step x	P25		241 - 250			Control Mode Loop 4	Cm4	always	21027
Profile	ProF	Profile 25 Step x	P25		241 - 250			Target Set Point Loop 1	tSP1	always	21002
Profile	ProF	Profile 25 Step x	P25		241 - 250			Target Set Point Loop 2	tSP2	always	21028
Profile	ProF	Profile 25 Step x	P25		241 - 250			Target Set Point Loop 3	tSP3	always	21029
Profile	ProF	Profile 25 Step x	P25		241 - 250			Target Set Point Loop 4	tSP4	always	21030
Profile	ProF	Profile 25 Step x	P25		241 - 250			Hours	hour	always	21003
Profile	ProF	Profile 25 Step x	P25		241 - 250			Minutes	Min	always	21004
Profile	ProF	Profile 25 Step x	P25		241 - 250			Seconds	SEC	always	21005
Profile	ProF	Profile 25 Step x	P25		241 - 250			Rate	rAtE	always	21006
Profile	ProF	Profile 25 Step x	P25		241 - 250			Step Wait For Process Enable 1	PE1	always	21036
Profile	ProF	Profile 25 Step x	P25		241 - 250			Wait For Process 1	WiP1	always	21011
Profile	ProF	Profile 25 Step x	P25		241 - 250			Step Wait For Process Enable 2	PE2	always	21037
Profile	ProF	Profile 25 Step x	P25		241 - 250			Wait For Process 2	WiP2	always	21031
Profile	ProF	Profile 25 Step x	P25		241 - 250			Step Wait For Process Enable 3	PE3	always	21038
Profile	ProF	Profile 25 Step x	P25		241 - 250			Wait For Process 3	WiP3	always	21032
Profile	ProF	Profile 25 Step x	P25		241 - 250			Step Wait For Process Enable 4	PE4	always	21039
Profile	ProF	Profile 25 Step x	P25		241 - 250			Wait For Process 4	WiP4	always	21033
Profile	ProF	Profile 25 Step x	P25	always	241 - 250	always		Wait Event 1	WiE1	always	21009
Profile	ProF	Profile 25 Step x	P25		241 - 250			Wait Event 2	WiE2	always	21010
Profile	ProF	Profile 25 Step x	P25		241 - 250			Wait Event 3	WiE3	always	21022
Profile	ProF	Profile 25 Step x	P25		241 - 250			Wait Event 4	WiE4	always	21023
Profile	ProF	Profile 25 Step x	P25		241 - 250			Day of Week	doW	always	21041
Profile	ProF	Profile 25 Step x	P25		241 - 250			Guaranteed Soak Enable 1	9SE1	always	21042
Profile	ProF	Profile 25 Step x	P25		241 - 250			Guaranteed Soak Enable 2	9SE2	always	21043
Profile	ProF	Profile 25 Step x	P25		241 - 250			Guaranteed Soak Enable 3	9SE3	always	21044
Profile	ProF	Profile 25 Step x	P25		241 - 250			Guaranteed Soak Enable 4	9SE4	always	21045
Profile	ProF	Profile 25 Step x	P25		241 - 250			Subroutine Step	SS	always	21034
Profile	ProF	Profile 25 Step x	P25		241 - 250			Subroutine Count	SC	always	21035

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Profile 25 Step x	P25		241 - 250			Jump Step	JS	always	21012
Profile	ProF	Profile 25 Step x	P25		241 - 250			Jump Count	JC	always	21013
Profile	ProF	Profile 25 Step x	P25		241 - 250			Endy Type	End	always	21014
Profile	ProF	Profile 25 Step x	P25		241 - 250			Event 1	Ent 1	always	21007
Profile	ProF	Profile 25 Step x	P25		241 - 250			Event 2	Ent2	always	21008
Profile	ProF	Profile 25 Step x	P25		241 - 250			Event 3	Ent3	always	21016
Profile	ProF	Profile 25 Step x	P25		241 - 250			Event 4	Ent4	always	21017
Profile	ProF	Profile 25 Step x	P25		241 - 250			Event 5	Ent5	always	21018
Profile	ProF	Profile 25 Step x	P25		241 - 250			Event 6	Ent6	always	21019
Profile	ProF	Profile 25 Step x	P25		241 - 250			Event 7	Ent7	always	21020
Profile	ProF	Profile 25 Step x	P25		241 - 250			Event 8	Ent8	always	21021
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Step Type	StyP	always	5001
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Control Mode Loop 1	Cm1	always	5002
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Control Mode Loop 2	Cm2	always	5003
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Control Mode Loop 3	Cm3	always	5004
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Control Mode Loop 4	Cm4	always	5005
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Target Set Point Loop 1	tSP1	always	5006
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Target Set Point Loop 2	tSP2	always	5007
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Target Set Point Loop 3	tSP3	always	5008
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Target Set Point Loop 4	tSP4	always	5009
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Hours	hour	always	5010
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Minutes	Min	always	5011
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Seconds	SEC	always	5012
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Rate	rAtE	always	5013
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Step Wait For Process Enable 1	PE1	always	5026
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Wait For Process 1	WJP1	always	5030
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Step Wait For Process Enable 2	PE2	always	5027
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Wait For Process 2	WJP2	always	5031
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Step Wait For Process Enable 3	PE3	always	5028
Profile	ProF	Subroutine 1 Step x	S1	always	1 - 10	always		Wait For Process 3	WJP3	always	5032
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Step Wait For Process Enable 4	PE4	always	5029
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Wait For Process 4	WJP4	always	5033
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Wait Event 1	WJE1	always	5022
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Wait Event 2	WJE2	always	5023
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Wait Event 3	WJE3	always	5024
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Wait Event 4	WJE4	always	5025
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Day of Week	dowJ	always	5035
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Guaranteed Soak Enable 1	gSE1	always	5036
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Guaranteed Soak Enable 2	gSE2	always	5037
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Guaranteed Soak Enable 3	gSE3	always	5038
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Guaranteed Soak Enable 4	gSE4	always	5039
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Event 1	Ent 1	always	5014
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Event 2	Ent2	always	5015
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Event 3	Ent3	always	5016
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Event 4	Ent4	always	5017
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Event 5	Ent5	always	5018

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Event 6	Ent6	always	5019
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Event 7	Ent7	always	5020
Profile	ProF	Subroutine 1 Step x	S1		1 - 10			Event 8	Ent8	always	5021
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Step Type	StYP	always	5001
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Control Mode Loop 1	Cn71	always	5002
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Control Mode Loop 2	Cn72	always	5003
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Control Mode Loop 3	Cn73	always	5004
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Control Mode Loop 4	Cn74	always	5005
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Target Set Point Loop 1	tSP1	always	5006
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Target Set Point Loop 2	tSP2	always	5007
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Target Set Point Loop 3	tSP3	always	5008
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Target Set Point Loop 4	tSP4	always	5009
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Hours	hour	always	5010
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Minutes	Min	always	5011
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Seconds	SEC	always	5012
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Rate	rAtE	always	5013
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Step Wait For Process Enable 1	PE1	always	5026
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Wait For Process 1	WdP1	always	5030
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Step Wait For Process Enable 2	PE2	always	5027
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Wait For Process 2	WdP2	always	5031
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Step Wait For Process Enable 3	PE3	always	5028
Profile	ProF	Subroutine 2 Step x	S2	always	11 - 20	always		Wait For Process 3	WdP3	always	5032
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Step Wait For Process Enable 4	PE4	always	5029
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Wait For Process 4	WdP4	always	5033
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Wait Event 1	WdE1	always	5022
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Wait Event 2	WdE2	always	5023
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Wait Event 3	WdE3	always	5024
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Wait Event 4	WdE4	always	5025
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Day of Week	doW	always	5035
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Guaranteed Soak Enable 1	gSE1	always	5036
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Guaranteed Soak Enable 2	gSE2	always	5037
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Guaranteed Soak Enable 3	gSE3	always	5038
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Guaranteed Soak Enable 4	gSE4	always	5039
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Event 1	Ent1	always	5014
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Event 2	Ent2	always	5015
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Event 3	Ent3	always	5016
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Event 4	Ent4	always	5017
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Event 5	Ent5	always	5018
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Event 6	Ent6	always	5019
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Event 7	Ent7	always	5020
Profile	ProF	Subroutine 2 Step x	S2		11 - 20			Event 8	Ent8	always	5021
Profile	ProF	Subroutine 3 Step x	S3		21 - 30			Step Type	StYP	always	5001
Profile	ProF	Subroutine 3 Step x	S3		21 - 30			Control Mode Loop 1	Cn71	always	5002
Profile	ProF	Subroutine 3 Step x	S3		21 - 30			Control Mode Loop 2	Cn72	always	5003
Profile	ProF	Subroutine 3 Step x	S3		21 - 30			Control Mode Loop 3	Cn73	always	5004

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Subroutine 3 Step x	53	always	21 - 30	always		Control Mode Loop 4	CM74	always	5005
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Target Set Point Loop 1	t.SP1	always	5006
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Target Set Point Loop 2	t.SP2	always	5007
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Target Set Point Loop 3	t.SP3	always	5008
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Target Set Point Loop 4	t.SP4	always	5009
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Hours	hoUr	always	5010
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Minutes	MIn	always	5011
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Seconds	SEC	always	5012
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Rate	rAtE	always	5013
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Step Wait For Process Enable 1	P.E1	always	5026
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Wait For Process 1	WJP1	always	5030
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Step Wait For Process Enable 2	P.E2	always	5027
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Wait For Process 2	WJP2	always	5031
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Step Wait For Process Enable 3	P.E3	always	5028
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Wait For Process 3	WJP3	always	5032
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Step Wait For Process Enable 4	P.E4	always	5029
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Wait For Process 4	WJP4	always	5033
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Wait Event 1	WJE1	always	5022
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Wait Event 2	WJE2	always	5023
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Wait Event 3	WJE3	always	5024
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Wait Event 4	WJE4	always	5025
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Day of Week	doW	always	5035
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Guaranteed Soak Enable 1	gSE1	always	5036
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Guaranteed Soak Enable 2	gSE2	always	5037
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Guaranteed Soak Enable 3	gSE3	always	5038
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Guaranteed Soak Enable 4	gSE4	always	5039
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Event 1	Ent1	always	5014
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Event 2	Ent2	always	5015
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Event 3	Ent3	always	5016
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Event 4	Ent4	always	5017
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Event 5	Ent5	always	5018
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Event 6	Ent6	always	5019
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Event 7	Ent7	always	5020
Profile	ProF	Subroutine 3 Step x	53		21 - 30			Event 8	Ent8	always	5021
Profile	ProF	Subroutine 4 Step x	54		31 - 40			Step Type	StYP	always	5001
Profile	ProF	Subroutine 4 Step x	54		31 - 40			Control Mode Loop 1	CM71	always	5002
Profile	ProF	Subroutine 4 Step x	54		31 - 40			Control Mode Loop 2	CM72	always	5003
Profile	ProF	Subroutine 4 Step x	54		31 - 40			Control Mode Loop 3	CM73	always	5004
Profile	ProF	Subroutine 4 Step x	54		31 - 40			Control Mode Loop 4	CM74	always	5005
Profile	ProF	Subroutine 4 Step x	54		31 - 40			Target Set Point Loop 1	t.SP1	always	5006
Profile	ProF	Subroutine 4 Step x	54		31 - 40			Target Set Point Loop 2	t.SP2	always	5007
Profile	ProF	Subroutine 4 Step x	54		31 - 40			Target Set Point Loop 3	t.SP3	always	5008
Profile	ProF	Subroutine 4 Step x	54		31 - 40			Target Set Point Loop 4	t.SP4	always	5009
Profile	ProF	Subroutine 4 Step x	54		31 - 40			Hours	hoUr	always	5010
Profile	ProF	Subroutine 4 Step x	54		31 - 40			Minutes	MIn	always	5011
Profile	ProF	Subroutine 4 Step x	54		31 - 40			Seconds	SEC	always	5012

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Subroutine 4 Step x	S4	always	31 - 40	always		Rate	rAtE	always	5013
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Step Wait For Process Enable 1	P.E1	always	5026
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Wait For Process 1	WJP1	always	5030
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Step Wait For Process Enable 2	P.E2	always	5027
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Wait For Process 2	WJP2	always	5031
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Step Wait For Process Enable 3	P.E3	always	5028
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Wait For Process 3	WJP3	always	5032
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Step Wait For Process Enable 4	P.E4	always	5029
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Wait For Process 4	WJP4	always	5033
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Wait Event 1	WJE1	always	5022
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Wait Event 2	WJE2	always	5023
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Wait Event 3	WJE3	always	5024
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Wait Event 4	WJE4	always	5025
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Day of Week	doW	always	5035
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Guaranteed Soak Enable 1	gSE1	always	5036
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Guaranteed Soak Enable 2	gSE2	always	5037
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Guaranteed Soak Enable 3	gSE3	always	5038
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Guaranteed Soak Enable 4	gSE4	always	5039
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Event 1	Ent1	always	5014
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Event 2	Ent2	always	5015
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Event 3	Ent3	always	5016
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Event 4	Ent4	always	5017
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Event 5	Ent5	always	5018
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Event 6	Ent6	always	5019
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Event 7	Ent7	always	5020
Profile	ProF	Subroutine 4 Step x	S4		31 - 40			Event 8	Ent8	always	5021
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Step Type	StyP	always	5001
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Control Mode Loop 1	C.M1	always	5002
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Control Mode Loop 2	C.M2	always	5003
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Control Mode Loop 3	C.M3	always	5004
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Control Mode Loop 4	C.M4	always	5005
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Target Set Point Loop 1	t.SP1	always	5006
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Target Set Point Loop 2	t.SP2	always	5007
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Target Set Point Loop 3	t.SP3	always	5008
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Target Set Point Loop 4	t.SP4	always	5009
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Hours	hoUr	always	5010
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Minutes	MIn	always	5011
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Seconds	SEC	always	5012
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Rate	rAtE	always	5013
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Step Wait For Process Enable 1	P.E1	always	5026
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Wait For Process 1	WJP1	always	5030
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Step Wait For Process Enable 2	P.E2	always	5027
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Wait For Process 2	WJP2	always	5031
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Step Wait For Process Enable 3	P.E3	always	5028
Profile	ProF	Subroutine 5 Step x	S5		41 - 50			Wait For Process 3	WJP3	always	5032
Profile	ProF	Subroutine 5 Step x	S5	always	41 - 50	always		Step Wait For Process Enable 4	P.E4	always	5029

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Wait For Process 4	uJP4	always	5033
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Wait Event 1	uJE1	always	5022
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Wait Event 2	uJE2	always	5023
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Wait Event 3	uJE3	always	5024
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Wait Event 4	uJE4	always	5025
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Day of Week	doUJ	always	5035
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Guaranteed Soak Enable 1	gSE1	always	5036
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Guaranteed Soak Enable 2	gSE2	always	5037
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Guaranteed Soak Enable 3	gSE3	always	5038
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Guaranteed Soak Enable 4	gSE4	always	5039
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Event 1	Ent1	always	5014
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Event 2	Ent2	always	5015
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Event 3	Ent3	always	5016
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Event 4	Ent4	always	5017
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Event 5	Ent5	always	5018
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Event 6	Ent6	always	5019
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Event 7	Ent7	always	5020
Profile	ProF	Subroutine 5 Step x	55		41 - 50			Event 8	Ent8	always	5021
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Step Type	StYP	always	5001
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Control Mode Loop 1	Cm1	always	5002
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Control Mode Loop 2	Cm2	always	5003
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Control Mode Loop 3	Cm3	always	5004
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Control Mode Loop 4	Cm4	always	5005
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Target Set Point Loop 1	tSP1	always	5006
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Target Set Point Loop 2	tSP2	always	5007
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Target Set Point Loop 3	tSP3	always	5008
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Target Set Point Loop 4	tSP4	always	5009
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Hours	hoUr	always	5010
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Minutes	Min	always	5011
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Seconds	SEC	always	5012
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Rate	rAtE	always	5013
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Step Wait For Process Enable 1	PE1	always	5026
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Wait For Process 1	uJP1	always	5030
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Step Wait For Process Enable 2	PE2	always	5027
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Wait For Process 2	uJP2	always	5031
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Step Wait For Process Enable 3	PE3	always	5028
Profile	ProF	Subroutine 6 Step x	56	always	51 - 60	always		Wait For Process 3	uJP3	always	5032
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Step Wait For Process Enable 4	PE4	always	5029
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Wait For Process 4	uJP4	always	5033
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Wait Event 1	uJE1	always	5022
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Wait Event 2	uJE2	always	5023
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Wait Event 3	uJE3	always	5024
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Wait Event 4	uJE4	always	5025
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Day of Week	doUJ	always	5035
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Guaranteed Soak Enable 1	gSE1	always	5036
Profile	ProF	Subroutine 6 Step x	56		51 - 60			Guaranteed Soak Enable 2	gSE2	always	5037

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Subroutine 6 Step x	S6		51 - 60			Guaranteed Soak Enable 3	gSE3	always	5038
Profile	ProF	Subroutine 6 Step x	S6		51 - 60			Guaranteed Soak Enable 4	gSE4	always	5039
Profile	ProF	Subroutine 6 Step x	S6		51 - 60			Event 1	Ent 1	always	5014
Profile	ProF	Subroutine 6 Step x	S6		51 - 60			Event 2	Ent2	always	5015
Profile	ProF	Subroutine 6 Step x	S6		51 - 60			Event 3	Ent3	always	5016
Profile	ProF	Subroutine 6 Step x	S6		51 - 60			Event 4	Ent4	always	5017
Profile	ProF	Subroutine 6 Step x	S6		51 - 60			Event 5	Ent5	always	5018
Profile	ProF	Subroutine 6 Step x	S6		51 - 60			Event 6	Ent6	always	5019
Profile	ProF	Subroutine 6 Step x	S6		51 - 60			Event 7	Ent7	always	5020
Profile	ProF	Subroutine 6 Step x	S6		51 - 60			Event 8	Ent8	always	5021
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Step Type	StyP	always	5001
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Control Mode Loop 1	Cnt1	always	5002
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Control Mode Loop 2	Cnt2	always	5003
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Control Mode Loop 3	Cnt3	always	5004
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Control Mode Loop 4	Cnt4	always	5005
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Target Set Point Loop 1	tSP1	always	5006
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Target Set Point Loop 2	tSP2	always	5007
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Target Set Point Loop 3	tSP3	always	5008
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Target Set Point Loop 4	tSP4	always	5009
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Hours	hoUr	always	5010
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Minutes	Mnin	always	5011
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Seconds	SEC	always	5012
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Rate	rAtE	always	5013
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Step Wait For Process Enable 1	PE1	always	5026
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Wait For Process 1	WaP1	always	5030
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Step Wait For Process Enable 2	PE2	always	5027
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Wait For Process 2	WaP2	always	5031
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Step Wait For Process Enable 3	PE3	always	5028
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Wait For Process 3	WaP3	always	5032
Profile	ProF	Subroutine 7 Step x	S7	always	61 - 70	always		Step Wait For Process Enable 4	PE4	always	5029
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Wait For Process 4	WaP4	always	5033
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Wait Event 1	WaE1	always	5022
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Wait Event 2	WaE2	always	5023
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Wait Event 3	WaE3	always	5024
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Wait Event 4	WaE4	always	5025
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Day of Week	doWd	always	5035
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Guaranteed Soak Enable 1	gSE1	always	5036
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Guaranteed Soak Enable 2	gSE2	always	5037
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Guaranteed Soak Enable 3	gSE3	always	5038
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Guaranteed Soak Enable 4	gSE4	always	5039
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Event 1	Ent 1	always	5014
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Event 2	Ent2	always	5015
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Event 3	Ent3	always	5016
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Event 4	Ent4	always	5017
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Event 5	Ent5	always	5018
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Event 6	Ent6	always	5019

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Event 7	Ent7	always	5020
Profile	ProF	Subroutine 7 Step x	S7		61 - 70			Event 8	Ent8	always	5021
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Step Type	StYP	always	5001
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Control Mode Loop 1	Cm1	always	5002
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Control Mode Loop 2	Cm2	always	5003
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Control Mode Loop 3	Cm3	always	5004
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Control Mode Loop 4	Cm4	always	5005
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Target Set Point Loop 1	tSP1	always	5006
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Target Set Point Loop 2	tSP2	always	5007
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Target Set Point Loop 3	tSP3	always	5008
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Target Set Point Loop 4	tSP4	always	5009
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Hours	hour	always	5010
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Minutes	Min	always	5011
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Seconds	SEC	always	5012
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Rate	rAtE	always	5013
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Step Wait For Process Enable 1	PE1	always	5026
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Wait For Process 1	WjP1	always	5030
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Step Wait For Process Enable 2	PE2	always	5027
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Wait For Process 2	WjP2	always	5031
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Step Wait For Process Enable 3	PE3	always	5028
Profile	ProF	Subroutine 8 Step x	S8	always	71 - 80	always		Wait For Process 3	WjP3	always	5032
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Step Wait For Process Enable 4	PE4	always	5029
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Wait For Process 4	WjP4	always	5033
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Wait Event 1	WjE1	always	5022
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Wait Event 2	WjE2	always	5023
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Wait Event 3	WjE3	always	5024
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Wait Event 4	WjE4	always	5025
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Day of Week	doW	always	5035
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Guaranteed Soak Enable 1	gSE1	always	5036
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Guaranteed Soak Enable 2	gSE2	always	5037
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Guaranteed Soak Enable 3	gSE3	always	5038
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Guaranteed Soak Enable 4	gSE4	always	5039
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Event 1	Ent1	always	5014
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Event 2	Ent2	always	5015
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Event 3	Ent3	always	5016
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Event 4	Ent4	always	5017
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Event 5	Ent5	always	5018
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Event 6	Ent6	always	5019
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Event 7	Ent7	always	5020
Profile	ProF	Subroutine 8 Step x	S8		71 - 80			Event 8	Ent8	always	5021
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Step Type	StYP	always	5001
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Control Mode Loop 1	Cm1	always	5002
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Control Mode Loop 2	Cm2	always	5003
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Control Mode Loop 3	Cm3	always	5004
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Control Mode Loop 4	Cm4	always	5005

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Target Set Point Loop 1	t.SP1	always	5006
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Target Set Point Loop 2	t.SP2	always	5007
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Target Set Point Loop 3	t.SP3	always	5008
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Target Set Point Loop 4	t.SP4	always	5009
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Hours	hoUr	always	5010
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Minutes	mn.in	always	5011
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Seconds	SEC	always	5012
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Rate	rAtE	always	5013
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Step Wait For Process Enable 1	P.E1	always	5026
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Wait For Process 1	WJP1	always	5030
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Step Wait For Process Enable 2	P.E2	always	5027
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Wait For Process 2	WJP2	always	5031
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Step Wait For Process Enable 3	P.E3	always	5028
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Wait For Process 3	WJP3	always	5032
Profile	ProF	Subroutine 9 Step x	S9	always	81 - 90	always		Step Wait For Process Enable 4	P.E4	always	5029
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Wait For Process 4	WJP4	always	5033
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Wait Event 1	WJE1	always	5022
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Wait Event 2	WJE2	always	5023
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Wait Event 3	WJE3	always	5024
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Wait Event 4	WJE4	always	5025
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Day of Week	doWJ	always	5035
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Guaranteed Soak Enable 1	GSE1	always	5036
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Guaranteed Soak Enable 2	GSE2	always	5037
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Guaranteed Soak Enable 3	GSE3	always	5038
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Guaranteed Soak Enable 4	GSE4	always	5039
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Event 1	Ent1	always	5014
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Event 2	Ent2	always	5015
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Event 3	Ent3	always	5016
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Event 4	Ent4	always	5017
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Event 5	Ent5	always	5018
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Event 6	Ent6	always	5019
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Event 7	Ent7	always	5020
Profile	ProF	Subroutine 9 Step x	S9		81 - 90			Event 8	Ent8	always	5021
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Step Type	StYP	always	5001
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Control Mode Loop 1	C.M1	always	5002
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Control Mode Loop 2	C.M2	always	5003
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Control Mode Loop 3	C.M3	always	5004
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Control Mode Loop 4	C.M4	always	5005
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Target Set Point Loop 1	t.SP1	always	5006
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Target Set Point Loop 2	t.SP2	always	5007
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Target Set Point Loop 3	t.SP3	always	5008
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Target Set Point Loop 4	t.SP4	always	5009
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Hours	hoUr	always	5010
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Minutes	mn.in	always	5011
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Seconds	SEC	always	5012
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Rate	rAtE	always	5013

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Subroutine 10 Step x	S10	always	91 - 100	always		Step Wait For Process Enable 1	PE1	always	5026
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Wait For Process 1	WJP1	always	5030
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Step Wait For Process Enable 2	PE2	always	5027
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Wait For Process 2	WJP2	always	5031
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Step Wait For Process Enable 3	PE3	always	5028
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Wait For Process 3	WJP3	always	5032
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Step Wait For Process Enable 4	PE4	always	5029
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Wait For Process 4	WJP4	always	5033
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Wait Event 1	WJE1	always	5022
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Wait Event 2	WJE2	always	5023
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Wait Event 3	WJE3	always	5024
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Wait Event 4	WJE4	always	5025
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Day of Week	doWJ	always	5035
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Guaranteed Soak Enable 1	gSE1	always	5036
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Guaranteed Soak Enable 2	gSE2	always	5037
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Guaranteed Soak Enable 3	gSE3	always	5038
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Guaranteed Soak Enable 4	gSE4	always	5039
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Event 1	Ent1	always	5014
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Event 2	Ent2	always	5015
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Event 3	Ent3	always	5016
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Event 4	Ent4	always	5017
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Event 5	Ent5	always	5018
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Event 6	Ent6	always	5019
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Event 7	Ent7	always	5020
Profile	ProF	Subroutine 10 Step x	S10		91 - 100			Event 8	Ent8	always	5021
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Step Type	StyP	always	5001
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Control Mode Loop 1	Cm1	always	5002
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Control Mode Loop 2	Cm2	always	5003
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Control Mode Loop 3	Cm3	always	5004
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Control Mode Loop 4	Cm4	always	5005
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Target Set Point Loop 1	tSP1	always	5006
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Target Set Point Loop 2	tSP2	always	5007
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Target Set Point Loop 3	tSP3	always	5008
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Target Set Point Loop 4	tSP4	always	5009
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Hours	hoUr	always	5010
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Minutes	Min	always	5011
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Seconds	SEC	always	5012
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Rate	rAtE	always	5013
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Step Wait For Process Enable 1	PE1	always	5026
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Wait For Process 1	WJP1	always	5030
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Step Wait For Process Enable 2	PE2	always	5027
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Wait For Process 2	WJP2	always	5031
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Step Wait For Process Enable 3	PE3	always	5028
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Wait For Process 3	WJP3	always	5032
Profile	ProF	Subroutine 11 Step x	S11	always	101 - 110	always		Step Wait For Process Enable 4	PE4	always	5029
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Wait For Process 4	WJP4	always	5033

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Wait Event 1	WJE.1	always	5022
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Wait Event 2	WJE.2	always	5023
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Wait Event 3	WJE.3	always	5024
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Wait Event 4	WJE.4	always	5025
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Day of Week	doW	always	5035
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Guaranteed Soak Enable 1	gSE1	always	5036
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Guaranteed Soak Enable 2	gSE2	always	5037
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Guaranteed Soak Enable 3	gSE3	always	5038
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Guaranteed Soak Enable 4	gSE4	always	5039
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Event 1	Ent1	always	5014
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Event 2	Ent2	always	5015
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Event 3	Ent3	always	5016
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Event 4	Ent4	always	5017
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Event 5	Ent5	always	5018
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Event 6	Ent6	always	5019
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Event 7	Ent7	always	5020
Profile	ProF	Subroutine 11 Step x	S11		101 - 110			Event 8	Ent8	always	5021
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Step Type	StyP	always	5001
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Control Mode Loop 1	Cm1	always	5002
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Control Mode Loop 2	Cm2	always	5003
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Control Mode Loop 3	Cm3	always	5004
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Control Mode Loop 4	Cm4	always	5005
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Target Set Point Loop 1	tSP1	always	5006
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Target Set Point Loop 2	tSP2	always	5007
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Target Set Point Loop 3	tSP3	always	5008
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Target Set Point Loop 4	tSP4	always	5009
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Hours	hour	always	5010
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Minutes	Min	always	5011
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Seconds	SEC	always	5012
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Rate	rAtE	always	5013
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Step Wait For Process Enable 1	PE1	always	5026
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Wait For Process 1	WJP1	always	5030
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Step Wait For Process Enable 2	PE2	always	5027
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Wait For Process 2	WJP2	always	5031
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Step Wait For Process Enable 3	PE3	always	5028
Profile	ProF	Subroutine 12 Step x	S12	always	111 - 120	always		Wait For Process 3	WJP3	always	5032
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Step Wait For Process Enable 4	PE4	always	5029
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Wait For Process 4	WJP4	always	5033
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Wait Event 1	WJE.1	always	5022
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Wait Event 2	WJE.2	always	5023
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Wait Event 3	WJE.3	always	5024
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Wait Event 4	WJE.4	always	5025
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Day of Week	doW	always	5035
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Guaranteed Soak Enable 1	gSE1	always	5036
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Guaranteed Soak Enable 2	gSE2	always	5037
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Guaranteed Soak Enable 3	gSE3	always	5038

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Guaranteed Soak Enable 4	gSE4	always	5039
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Event 1	Ent 1	always	5014
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Event 2	Ent2	always	5015
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Event 3	Ent3	always	5016
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Event 4	Ent4	always	5017
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Event 5	Ent5	always	5018
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Event 6	Ent6	always	5019
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Event 7	Ent7	always	5020
Profile	ProF	Subroutine 12 Step x	S12		111 - 120			Event 8	Ent8	always	5021
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Step Type	StYP	always	5001
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Control Mode Loop 1	Cm1	always	5002
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Control Mode Loop 2	Cm2	always	5003
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Control Mode Loop 3	Cm3	always	5004
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Control Mode Loop 4	Cm4	always	5005
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Target Set Point Loop 1	tSP1	always	5006
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Target Set Point Loop 2	tSP2	always	5007
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Target Set Point Loop 3	tSP3	always	5008
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Target Set Point Loop 4	tSP4	always	5009
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Hours	hoUr	always	5010
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Minutes	Min	always	5011
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Seconds	SEC	always	5012
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Rate	rAtE	always	5013
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Step Wait For Process Enable 1	PE1	always	5026
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Wait For Process 1	WJP1	always	5030
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Step Wait For Process Enable 2	PE2	always	5027
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Wait For Process 2	WJP2	always	5031
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Step Wait For Process Enable 3	PE3	always	5028
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Wait For Process 3	WJP3	always	5032
Profile	ProF	Subroutine 13 Step x	S13	always	121 - 130	always		Step Wait For Process Enable 4	PE4	always	5029
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Wait For Process 4	WJP4	always	5033
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Wait Event 1	WJE1	always	5022
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Wait Event 2	WJE2	always	5023
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Wait Event 3	WJE3	always	5024
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Wait Event 4	WJE4	always	5025
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Day of Week	doWJ	always	5035
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Guaranteed Soak Enable 1	gSE1	always	5036
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Guaranteed Soak Enable 2	gSE2	always	5037
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Guaranteed Soak Enable 3	gSE3	always	5038
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Guaranteed Soak Enable 4	gSE4	always	5039
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Event 1	Ent 1	always	5014
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Event 2	Ent2	always	5015
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Event 3	Ent3	always	5016
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Event 4	Ent4	always	5017
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Event 5	Ent5	always	5018
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Event 6	Ent6	always	5019
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Event 7	Ent7	always	5020

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Subroutine 13 Step x	S13		121 - 130			Event 8	Ent8	always	5021
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Step Type	StYP	always	5001
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Control Mode Loop 1	CM1	always	5002
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Control Mode Loop 2	CM2	always	5003
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Control Mode Loop 3	CM3	always	5004
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Control Mode Loop 4	CM4	always	5005
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Target Set Point Loop 1	tSP1	always	5006
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Target Set Point Loop 2	tSP2	always	5007
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Target Set Point Loop 3	tSP3	always	5008
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Target Set Point Loop 4	tSP4	always	5009
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Hours	hour	always	5010
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Minutes	Min	always	5011
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Seconds	SEC	always	5012
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Rate	rATE	always	5013
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Step Wait For Process Enable 1	PE1	always	5026
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Wait For Process 1	WJP1	always	5030
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Step Wait For Process Enable 2	PE2	always	5027
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Wait For Process 2	WJP2	always	5031
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Step Wait For Process Enable 3	PE3	always	5028
Profile	ProF	Subroutine 14 Step x	S14	always	131 - 140	always		Wait For Process 3	WJP3	always	5032
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Step Wait For Process Enable 4	PE4	always	5029
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Wait For Process 4	WJP4	always	5033
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Wait Event 1	WJE1	always	5022
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Wait Event 2	WJE2	always	5023
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Wait Event 3	WJE3	always	5024
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Wait Event 4	WJE4	always	5025
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Day of Week	doW	always	5035
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Guaranteed Soak Enable 1	SSE1	always	5036
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Guaranteed Soak Enable 2	SSE2	always	5037
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Guaranteed Soak Enable 3	SSE3	always	5038
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Guaranteed Soak Enable 4	SSE4	always	5039
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Event 1	Ent1	always	5014
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Event 2	Ent2	always	5015
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Event 3	Ent3	always	5016
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Event 4	Ent4	always	5017
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Event 5	Ent5	always	5018
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Event 6	Ent6	always	5019
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Event 7	Ent7	always	5020
Profile	ProF	Subroutine 14 Step x	S14		131 - 140			Event 8	Ent8	always	5021
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Step Type	StYP	always	5001
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Control Mode Loop 1	CM1	always	5002
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Control Mode Loop 2	CM2	always	5003
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Control Mode Loop 3	CM3	always	5004
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Control Mode Loop 4	CM4	always	5005
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Target Set Point Loop 1	tSP1	always	5006

EZ-ZONE RMC Menus

EZC Page	LED Page	EZC Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Profile	ProF	Subroutine 15 Step x	S15	always	141 - 150	always		Target Set Point Loop 2	t.SP2	always	5007
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Target Set Point Loop 3	t.SP3	always	5008
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Target Set Point Loop 4	t.SP4	always	5009
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Hours	hoUr	always	5010
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Minutes	MIn	always	5011
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Seconds	SEC	always	5012
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Rate	rAtE	always	5013
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Step Wait For Process Enable 1	P.E1	always	5026
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Wait For Process 1	WP1	always	5030
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Step Wait For Process Enable 2	P.E2	always	5027
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Wait For Process 2	WP2	always	5031
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Step Wait For Process Enable 3	P.E3	always	5028
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Wait For Process 3	WP3	always	5032
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Step Wait For Process Enable 4	P.E4	always	5029
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Wait For Process 4	WP4	always	5033
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Wait Event 1	WE1	always	5022
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Wait Event 2	WE2	always	5023
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Wait Event 3	WE3	always	5024
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Wait Event 4	WE4	always	5025
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Day of Week	doW	always	5035
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Guaranteed Soak Enable 1	GSE1	always	5036
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Guaranteed Soak Enable 2	GSE2	always	5037
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Guaranteed Soak Enable 3	GSE3	always	5038
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Guaranteed Soak Enable 4	GSE4	always	5039
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Event 1	Ent1	always	5014
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Event 2	Ent2	always	5015
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Event 3	Ent3	always	5016
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Event 4	Ent4	always	5017
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Event 5	Ent5	always	5018
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Event 6	Ent6	always	5019
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Event 7	Ent7	always	5020
Profile	ProF	Subroutine 15 Step x	S15		141 - 150			Event 8	Ent8	always	5021

EZ-ZONE RME Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Digital I/O x	d.io	If model number character 5, 6, 7, or 8 is a C	1-24	Instance 1-6 = 5th character Instance 7-12 = 6th character Instance 13-18 = 7th character Instance 19-24 = 8th character		Output State	do.S	always	6007
Operations	oPEr	Digital I/O x	d.io		1-24			Input State	d.S	always	6011
Operations	oPEr	Action x	ACt	always	1 - 8	always		Event Status	E.S	always	10005
Operations	oPEr	Alarm x	ALM	always	1 - 8	always		Alarm Low Set Point	A.Lo	always	9002
Operations	oPEr	Alarm x	ALM		1 - 8			Alarm High Set Point	A.h.i	always	9001
Operations	oPEr	Alarm x	ALM		1 - 8			Alarm Clear Request	A.CLr	always	9026
Operations	oPEr	Alarm x	ALM		1 - 8			Alarm Silence Request	A.S.ir	always	9027
Operations	oPEr	Alarm x	ALM		1 - 8			Alarm State	A.St	always	9009
Operations	oPEr	Current x	Curr	If model number character 8 is a T	1 - 4	always		Current High Set Point	C.h.i	always	15008
Operations	oPEr	Current x	Curr		1 - 4			Current Low Set Point	C.Lo	always	15009
Operations	oPEr	Current x	Curr		1 - 4			Current Read	CU.r	always	15007
Operations	oPEr	Current x	Curr		1 - 4			Current Error	C.Er	always	15002
Operations	oPEr	Current x	Curr		1 - 4			Heater Error	h.Er	always	15003
Operations	oPEr	Linearization x	L.in	always	1 - 8	always		Source Value A	Su.A	always	34004
Operations	oPEr	Linearization x	L.in		1 - 8			Offset	oFSt	always	34006
Operations	oPEr	Linearization x	L.in		1 - 8			Output Value	o.u	always	34007
Operations	oPEr	Compare x	CPE	always	1 - 8	always		Source Value A	Su.A	always	28007
Operations	oPEr	Compare x	CPE		1 - 8			Source Value B	Su.b	always	28008
Operations	oPEr	Compare x	CPE		1 - 8			Output Value	o.u	always	28010
Operations	oPEr	Timer x	tMr	always	1 - 8	always		Source Value A	Su.A	always	31007
Operations	oPEr	Timer x	tMr		1 - 8			Source Value B	Su.b	always	31008
Operations	oPEr	Timer x	tMr		1 - 8			Elapsed Time	E.t	always	31016
Operations	oPEr	Timer x	tMr		1 - 8			Output Value	o.u	always	31010
Operations	oPEr	Counter x	Ctr	always	1 - 8	always		Count	Cnt	always	30015
Operations	oPEr	Counter x	Ctr		1 - 8			Source Value A	Su.A	always	30007
Operations	oPEr	Counter x	Ctr		1 - 8			Source Value B	Su.b	always	30008
Operations	oPEr	Counter x	Ctr		1 - 8			Output Value	o.u	always	30010
Operations	oPEr	Logic x	LGC	always	1-8	always		Source Value A	Su.A	always	27025
Operations	oPEr	Logic x	LGC		1-8			Source Value B	Su.b	always	27026
Operations	oPEr	Logic x	LGC		1-8			Source Value C	Su.C	always	27027
Operations	oPEr	Logic x	LGC		1-8			Source Value D	Su.d	always	27028
Operations	oPEr	Logic x	LGC		1-8			Source Value E	Su.E	always	27029
Operations	oPEr	Logic x	LGC		1-8			Source Value F	Su.F	always	27030
Operations	oPEr	Logic x	LGC		1-8			Source Value G	Su.g	always	27031
Operations	oPEr	Logic x	LGC		1-8			Source Value H	Su.h	always	27032
Operations	oPEr	Logic x	LGC		1-8			Output Value	o.u	always	27034
Operations	oPEr	Math x	MAt		1-8			Source Value A	Su.A	always	25016

EZ-ZONE RME Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Math x	mAt	always	1-8	always		Source Value B	Su.b	always	25017
Operations	oPEr	Math x	mAt		1-8			Source Value C	Su.C	always	25018
Operations	oPEr	Math x	mAt		1-8			Source Value D	Su.d	always	25019
Operations	oPEr	Math x	mAt		1-8			Source Value E	Su.E	always	25020
Operations	oPEr	Math x	mAt		1-8			Offset	oFSt	always	25023
Operations	oPEr	Math x	mAt		1-8			Output Value	o.u	always	25022
Operations	oPEr	Special Output Function x	SoF	always	1-4	always		Source Value A	Su.A	always	35007
Operations	oPEr	Special Output Function x	SoF		1-4			Source Value B	Su.b	always	35008
Operations	oPEr	Special Output Function x	SoF		1-4			Output Value 1	o.u 1	always	35010
Operations	oPEr	Special Output Function x	SoF		1-4			Output Value 2	o.u2	always	35012
Operations	oPEr	Special Output Function x	SoF		1-4			Output Value 3	o.u3	always	35014
Operations	oPEr	Special Output Function x	SoF		1-4			Output Value 4	o.u4	always	35016
Setup	SEt	Digital I/O x	d.io	If model number character 5, 6, 7, or 8 is a C	1-24	Instance 1-6 = 5th character Instance 7-12 = 6th character Instance 13-18 = 7th character Instance 19-24 = 8th character if character = C then visible		Digital I/O Direction	d.ir	3	6001
Setup	SEt	Digital I/O x	d.io		1-24			Output Function	Fn	always	6005
Setup	SEt	Digital I/O x	d.io		1-24			Output Function Instance	F.i	always	6006
Setup	SEt	Digital I/O x	d.io		1-24			Output Source Zone A	o.Ct	always	6012
Setup	SEt	Digital I/O x	d.io		1-24			Output Control	o.tb	always	6002
Setup	SEt	Digital I/O x	d.io		1-24			Output Time Base	o.Lo	always	6003
Setup	SEt	Digital I/O x	d.io		1-24			Output Low Power Scale	o.hi	always	6009
Setup	SEt	Digital I/O x	d.io		1-24			Output High Power Scale	LEu	always	6010
Setup	SEt	Action x	ACt	always	1 - 8	always		Action Function	Fn	always	10003
Setup	SEt	Action x	ACt		1 - 8			Function Instance	F.i	always	10004
Setup	SEt	Action x	ACt		1 - 8			Source Function A	SFn.A	always	10006
Setup	SEt	Action x	ACt		1 - 8			Source Instance A	S.iA	always	10002
Setup	SEt	Action x	ACt		1 - 8			Source Zone A	S2.A	always	10007
Setup	SEt	Action x	ACt		1 - 8			Active Level	LEu	always	10001
Setup	SEt	Output x	OtPt	If model number character 5, 6, 7, or 8 is J, K, L, or F	1-22	Instance 1 - 2: if 5th digit is J, K, L, or F Instance 3: if 5th digit is J, L, or F Instance 4: if 5th digit is J or L Instance 7 - 9: if 6th digit is J, L, or F Instance 10: if 6th digit is J or L Instance 13 - 14: if 7th digit is J, K, L, or F Instance 15: if 7th digit is J, L, or F Instance 16: if 7th digit is J or L Instance 19 - 21: if 8th digit is L or F Instance 22: if 8th digit is L		Output Function	Fn	Instance 1 - 2: if 5th digit is J, K, or L Instance 3 - 4: if 5th digit is J or L Instance 7 - 10: if 6th digit is J or L Instance 13 - 14: if 7th digit is J, K, or L Instance 15 - 16: if 7th digit is J or L Instance 19 - 22: if 8th digit is L	6005
Setup	SEt	Output x	OtPt		1-22			Output Function Instance	F.i		6006
Setup	SEt	Output x	OtPt		1-22			Output Source Zone	S2.A		6012
Setup	SEt	Output x	OtPt		1-22			Output Control	o.Ct		6002
Setup	SEt	Output x	OtPt		1-22			Output Time Base	o.tb		6003
Setup	SEt	Output x	OtPt		1-22			Output Low Power Scale	o.Lo		6009
Setup	SEt	Output x	OtPt		1-22			Output High Power Scale	o.hi		6010
Setup	SEt	Output x	OtPt		1-22			Output Type	o.tY		18001
Setup	SEt	Output x	OtPt		1-22			Output Function	Fn	Instance 1 - 3: if 5th digit is F Instance 7 - 9: if 6th digit is F Instance 13 - 15: if 7th digit is F Instance 19 - 21: if 8th digit is F {output is analog}	18002
Setup	SEt	Output x	OtPt		1-22			Output Function Instance	F.i		18004
Setup	SEt	Output x	OtPt		1-22			Output Source Zone	S2.A		18019
Setup	SEt	Output x	OtPt		1-22			Scale Low	SLo		18009
Setup	SEt	Output x	OtPt		1-22			Scale High	SHi		18010
Setup	SEt	Output x	OtPt		1-22			Range Low	rLo		18011
Setup	SEt	Output x	OtPt		1-22			Range High	rhi		18012
Setup	SEt	Output x	OtPt		1-22			Calibration Offset	oCA		18007

EZ-ZONE RME Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Alarm x	ALrn	always	1 - 8	always		Alarm Type	A.tY	always	9015
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm Source	Sr.A	always	9017
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm Source Instance	i5.A	always	9018
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm Source Zone	S2.A	always	9025
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm Hysteresis	A.hY	always	9003
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm Logic	A.Lg	always	9005
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm Sides	A.Sd	always	9004
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm Low Set Point	A.Lo	always	9002
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm High Set Point	A.h i	always	9001
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm Latching	A.LA	always	9007
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm Blocking	A.bL	always	9008
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm Silencing	A.S i	always	9006
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm Display	A.dSP	always	9016
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm Delay Time	A.dL	always	9021
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm Clear Request	A.CLr	always	9026
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm Silence	A.S ir	always	9027
Setup	SEt	Alarm x	ALrn		1 - 8			Alarm State	A.St	always	9009
Setup	SEt	Current x	CUrr	If model number character 8 is a T	1 - 4	always		Current Sides	C.Sd	always	15005
Setup	SEt	Current x	CUrr		1 - 4			Current Read Enable	C.Ur	always	15004
Setup	SEt	Current x	CUrr		1 - 4			Input Current Detection Threshold	C.dt	always	15012
Setup	SEt	Current x	CUrr		1 - 4			Current Scaling	C.SC	always	15022
Setup	SEt	Current x	CUrr		1 - 4			Heater Current Offset	C.oFS	always	15011
Setup	SEt	Current x	CUrr		1 - 4			Current Output Source Instance	C.S i	always	15019
Setup	SEt	Linearization x	Lin	always	1 - 8	always		Function	Fn	always	34005
Setup	SEt	Linearization x	Lin		1 - 8			Source Function A	SFn.A	always	34001
Setup	SEt	Linearization x	Lin		1 - 8			Source Instance A	S i.A	always	34002
Setup	SEt	Linearization x	Lin		1 - 8			Source Zone A	S2.A	always	34003
Setup	SEt	Linearization x	Lin		1 - 8			Units	Un.t	always	34029
Setup	SEt	Linearization x	Lin		1 - 8			Input Point 1	iP.1	always	34008
Setup	SEt	Linearization x	Lin		1 - 8			Output Point 1	oP.1	always	34018
Setup	SEt	Linearization x	Lin		1 - 8			Input Point 2	iP.2	always	34009
Setup	SEt	Linearization x	Lin		1 - 8			Output Point 2	oP.2	always	34019
Setup	SEt	Linearization x	Lin		1 - 8			Input Point 3	iP.3	always	34010
Setup	SEt	Linearization x	Lin		1 - 8			Output Point 3	oP.3	always	34020
Setup	SEt	Linearization x	Lin		1 - 8			Input Point 4	iP.4	always	34011
Setup	SEt	Linearization x	Lin		1 - 8			Output Point 4	oP.4	always	34021
Setup	SEt	Linearization x	Lin		1 - 8			Input Point 5	iP.5	always	34012
Setup	SEt	Linearization x	Lin		1 - 8			Output Point 5	oP.5	always	34022
Setup	SEt	Linearization x	Lin		1 - 8			Input Point 6	iP.6	always	34013
Setup	SEt	Linearization x	Lin		1 - 8			Output Point 6	oP.6	always	34023
Setup	SEt	Linearization x	Lin		1 - 8			Input Point 7	iP.7	always	34014
Setup	SEt	Linearization x	Lin		1 - 8			Output Point 7	oP.7	always	34024
Setup	SEt	Linearization x	Lin		1 - 8			Input Point 8	iP.8	always	34015
Setup	SEt	Linearization x	Lin		1 - 8			Output Point 8	oP.8	always	34025

EZ-ZONE RME Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Linearization x	L in		1 - 8			Input Point 9	iP.9	always	34016
Setup	SEt	Linearization x	L in		1 - 8			Output Point 9	oP.9	always	34026
Setup	SEt	Linearization x	L in		1 - 8			Input Point 10	iP.10	always	34017
Setup	SEt	Linearization x	L in		1 - 8			Output Point 10	oP.10	always	34027
Setup	SEt	Compare x	CPE		1 - 8			Function	Fn	always	28009
Setup	SEt	Compare x	CPE		1 - 8			Tolerance	tol	always	28011
Setup	SEt	Compare x	CPE		1 - 8			Source Function A	SFn.A	always	28001
Setup	SEt	Compare x	CPE		1 - 8			Source Instance A	S i.A	always	28003
Setup	SEt	Compare x	CPE	always	1 - 8	always		Source Zone A	S2.A	always	28005
Setup	SEt	Compare x	CPE		1 - 8			Source Function B	SFn.b	always	28002
Setup	SEt	Compare x	CPE		1 - 8			Source Instance B	S i.b	always	28004
Setup	SEt	Compare x	CPE		1 - 8			Source Zone B	S2.b	always	28006
Setup	SEt	Compare x	CPE		1 - 8			Error Handling	Erh	always	28012
Setup	SEt	Timer x	tMr		1 - 8			Function	Fn	always	31009
Setup	SEt	Timer x	tMr		1 - 8			Source Function A	SFn.A	always	31001
Setup	SEt	Timer x	tMr		1 - 8			Source Instance A	S i.A	always	31003
Setup	SEt	Timer x	tMr		1 - 8			Source Zone A	S2.A	always	31005
Setup	SEt	Timer x	tMr		1 - 8			Source Active State A	SAS.A	always	31011
Setup	SEt	Timer x	tMr	always	1 - 8	always		Source Function B	SFn.b	always	31002
Setup	SEt	Timer x	tMr	always	1 - 8	always		Source Instance B	S i.b	always	31004
Setup	SEt	Timer x	tMr		1 - 8			Source Zone B	S2.b	always	31006
Setup	SEt	Timer x	tMr		1 - 8			Source Active State B	SAS.b	always	31012
Setup	SEt	Timer x	tMr		1 - 8			Time	t i	always	31013
Setup	SEt	Timer x	tMr		1 - 8			Active Level	LEv	always	31014
Setup	SEt	Counter x	Ctr		1 - 8			Function	Fn	always	30009
Setup	SEt	Counter x	Ctr		1 - 8			Source Function A	SFn.A	always	30001
Setup	SEt	Counter x	Ctr		1 - 8			Source Instance A	S i.A	always	30003
Setup	SEt	Counter x	Ctr		1 - 8			Source Zone A	S2.A	always	30005
Setup	SEt	Counter x	Ctr		1 - 8			Source Active State A	SAS.A	always	30011
Setup	SEt	Counter x	Ctr	always	1 - 8	always		Source Function B	SFn.b	always	30002
Setup	SEt	Counter x	Ctr	always	1 - 8	always		Source Instance B	S i.b	always	30004
Setup	SEt	Counter x	Ctr		1 - 8			Source Zone B	S2.b	always	30006
Setup	SEt	Counter x	Ctr		1 - 8			Source Active State B	SAS.b	always	30012
Setup	SEt	Counter x	Ctr		1 - 8			Load Value	LoAd	always	30013
Setup	SEt	Counter x	Ctr		1 - 8			Target Value	trgt	always	30014
Setup	SEt	Counter x	Ctr		1 - 8			Latching	LAt	always	30017
Setup	SEt	Logic x	LgC		1 - 8			Function	Fn	always	27033
Setup	SEt	Logic x	LgC		1 - 8			Source Function A	SFn.A	always	27001
Setup	SEt	Logic x	LgC		1 - 8			Source Instance A	S i.A	always	27009
Setup	SEt	Logic x	LgC		1 - 8			Source Zone A	S2.A	always	27017
Setup	SEt	Logic x	LgC		1 - 8			Source Function B	SFn.b	always	27002
Setup	SEt	Logic x	LgC		1 - 8			Source Instance B	S i.b	always	27010
Setup	SEt	Logic x	LgC		1 - 8			Source Zone B	S2.b	always	27018

EZ-ZONE RME Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Logic x	LGC	always	1 - 8	always		Source Function C	SFn.C	always	27003
Setup	SEt	Logic x	LGC		1 - 8			Source Instance C	S 1.C	always	27011
Setup	SEt	Logic x	LGC		1 - 8			Source Zone C	S2.C	always	27019
Setup	SEt	Logic x	LGC		1 - 8			Source Function D	SFn.d	always	27004
Setup	SEt	Logic x	LGC		1 - 8			Source Instance D	S 1.d	always	27012
Setup	SEt	Logic x	LGC		1 - 8			Source Zone D	S2.d	always	27020
Setup	SEt	Logic x	LGC		1 - 8			Source Function E	SFn.E	always	27005
Setup	SEt	Logic x	LGC		1 - 8			Source Instance E	S 1.E	always	27013
Setup	SEt	Logic x	LGC		1 - 8			Source Zone E	S2.E	always	27021
Setup	SEt	Logic x	LGC		1 - 8			Source Function F	SFn.F	always	27006
Setup	SEt	Logic x	LGC		1 - 8			Source Instance F	S 1.F	always	27014
Setup	SEt	Logic x	LGC		1 - 8			Source Zone F	S2.F	always	27022
Setup	SEt	Logic x	LGC		1 - 8			Source Function G	SFn.9	always	27007
Setup	SEt	Logic x	LGC		1 - 8			Source Instance G	S 1.9	always	27015
Setup	SEt	Logic x	LGC		1 - 8			Source Zone G	S2.9	always	27023
Setup	SEt	Logic x	LGC		1 - 8			Source Function H	SFn.h	always	27008
Setup	SEt	Logic x	LGC		1 - 8			Source Instance H	S 1.h	always	27016
Setup	SEt	Logic x	LGC		1 - 8			Source Zone H	S2.h	always	27024
Setup	SEt	Logic x	LGC		1 - 8			Error Handling	Erh	always	27035
Setup	SEt	Math x	MAt	always	1 - 8	always		Function	Fn	always	25021
Setup	SEt	Math x	MAt		1 - 8			Source Function A	SFn.A	always	25001
Setup	SEt	Math x	MAt		1 - 8			Source Instance A	S 1.A	always	25006
Setup	SEt	Math x	MAt		1 - 8			Source Zone A	S2.A	always	25011
Setup	SEt	Math x	MAt		1 - 8			Source Function B	SFn.b	always	25002
Setup	SEt	Math x	MAt		1 - 8			Source Instance B	S 1.b	always	25007
Setup	SEt	Math x	MAt		1 - 8			Source Zone B	S2.b	always	25012
Setup	SEt	Math x	MAt		1 - 8			Source Function C	SFn.C	always	25003
Setup	SEt	Math x	MAt		1 - 8			Source Instance C	S 1.C	always	25008
Setup	SEt	Math x	MAt		1 - 8			Source Zone C	S2.C	always	25013
Setup	SEt	Math x	MAt		1 - 8			Source Function D	SFn.d	always	25004
Setup	SEt	Math x	MAt		1 - 8			Source Instance D	S 1.d	always	25009
Setup	SEt	Math x	MAt		1 - 8			Source Zone D	S2.d	always	25014
Setup	SEt	Math x	MAt		1 - 8			Source Function E	SFn.E	always	25005
Setup	SEt	Math x	MAt		1 - 8			Source Instance E	S 1.E	always	25010
Setup	SEt	Math x	MAt		1 - 8			Source Zone E	S2.E	always	25015
Setup	SEt	Math x	MAt		1 - 8			Scale Low	SLo	always	25024
Setup	SEt	Math x	MAt		1 - 8			Scale High	Sh i	always	25025
Setup	SEt	Math x	MAt		1 - 8			Units	Unit	always	25032
Setup	SEt	Math x	MAt		1 - 8			Range Low	rLo	always	25026
Setup	SEt	Math x	MAt		1 - 8			Range High	rh i	always	25027
Setup	SEt	Math x	MAt		1 - 8			Pressure Units	Punt	always	25030
Setup	SEt	Math x	MAt		1 - 8			Altitude Units	Aunt	always	25031
Setup	SEt	Math x	MAt		1 - 8			Filter	F iL	always	25028
Setup	SEt	Special Output Function x	SoF		1-4			Function	Fn	always	35009
Setup	SEt	Special Output Function x	SoF		1-4			Source Function A	SFn.A	always	35001

EZ-ZONE RME Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Special Output Function x	SoF		1-4			Source Instance A	S .A	always	35003
Setup	SEt	Special Output Function x	SoF		1-4			Source Zone A	S2.A	always	35005
Setup	SEt	Special Output Function x	SoF		1-4			Source Function B	SFn.b	always	35002
Setup	SEt	Special Output Function x	SoF		1-4			Source Instance B	S .b	always	35004
Setup	SEt	Special Output Function x	SoF		1-4			Source Zone B	S2.b	always	35006
Setup	SEt	Special Output Function x	SoF		1-4			Power On Level 1	Pon.A	always	35018
Setup	SEt	Special Output Function x	SoF		1-4			Power Off Level 1	PoF.A	always	35019
Setup	SEt	Special Output Function x	SoF		1-4			Power On Level 2	Pon.b	always	35020
Setup	SEt	Special Output Function x	SoF	always	1-4	always		Power Off Level 2	PoF.b	always	35021
Setup	SEt	Special Output Function x	SoF		1-4			On Time	on.t	always	35022
Setup	SEt	Special Output Function x	SoF		1-4			Off Time	oF.t	always	35023
Setup	SEt	Special Output Function x	SoF		1-4			Valve Travel Time	t.t	always	35024
Setup	SEt	Special Output Function x	SoF		1-4			Dead Band	db	always	35025
Setup	SEt	Special Output Function x	SoF		1-4			Output 1 Size	o.S1	always	35028
Setup	SEt	Special Output Function x	SoF		1-4			Output 2 Size	o.S2	always	35029
Setup	SEt	Special Output Function x	SoF		1-4			Output 3 Size	o.S3	always	35030
Setup	SEt	Special Output Function x	SoF		1-4			Output 4 Size	o.S4	always	35031
Setup	SEt	Special Output Function x	SoF		1-4			Time Delay	t.dL	always	35026
Setup	SEt	Special Output Function x	SoF		1-4			Output Order	ot.o	always	35027
Setup	SEt	Variable x	uAr		1 - 8			Data Type	tYPE	always	2001
Setup	SEt	Variable x	uAr	always	1 - 8	always		Units	Un.t	always	2007
Setup	SEt	Variable x	uAr		1 - 8			Digital	d.9	always	2002
Setup	SEt	Variable x	uAr		1 - 8			Analog	AnL9	always	2003
Setup	SEt	Global 1	9LbL		1			Display Units	C_F	always	3005
Setup	SEt	Global 1	9LbL		1			AC Line Frequency	ACLF	always	1034
Setup	SEt	Global 1	9LbL	always	1	always		Display Pairs	d.Pr5	always	3028
Setup	SEt	Global 1	9LbL		1			User Settings Save	USr.S	always	1014
Setup	SEt	Global 1	9LbL		1			User Settings Restore	USr.r	always	1013
Factory	FctY	Custom Setup x	CUSt	always	1 - 20	always		Parameter	PAr	always	14005
Factory	FctY	Custom Setup x	CUSt		1 - 20			Instance ID	.id	always	14003
Factory	FctY	Lock 1	LoC		1			Operations Page	LoC.o	always	3002
Factory	FctY	Lock 1	LoC		1			Password Enable	PASE	always	3015
Factory	FctY	Lock 1	LoC		1			Read Lock	rLoC	always	3010
Factory	FctY	Lock 1	LoC	If DspLockedState = PASS ADMIN	1	always		Write Security	SLoC	always	3011
Factory	FctY	Lock 1	LoC		1			Locked Access Level	LoC.L	always	3016
Factory	FctY	Lock 1	LoC		1			Rolling Password	roLL	always	3019
Factory	FctY	Lock 1	LoC		1			User Password	PAS.u	always	3017
Factory	FctY	Lock 1	LoC		1			Administrator Password	PAS.A	always	3018
										always	
Factory	FctY	Unlock 1	ULoC	If DspSecurityEnable == ON	1	always		Public Key	CodE	always	3020
Factory	FctY	Unlock 1	ULoC		1			Password	PASS	always	3022
Factory	FctY	Diagnostics 1	d.A9		1			Part Number	Pn	always	1009

EZ-ZONE RME Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Factory	FctY	Diagnostics 1	d iAG	always	1	always		Software Revision	rEv	always	1017
Factory	FctY	Diagnostics 1	d iAG		1			Software Build Number	S.bLd	always	1005
Factory	FctY	Diagnostics 1	d iAG		1			Serial Number	Sn	always	1032
Factory	FctY	Diagnostics 1	d iAG		1			Date of Manufacture	dAtE	always	1008
Factory	FctY	Calibration x	CAL	If model number character 5, 6, 7, or 8 is F	1-21	Instance 1 - 3: if 5th digit is F Instance 7 - 9: if 6th digit is F Instance 13 - 15: if 7th digit is F Instance 19 - 21: if 8th digit is F		Electrical Output Offset	EL o.o	always	18005
Factory	FctY	Calibration x	CAL		1-21			Electrical Output Slope	EL o.S	always	18006

EZ-ZONE RMA Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Data Logging 1	dLo9	[IF 8th position of model number = D]	1	Always		Status	StAt	always	37002
Operations	oPEr	Data Logging 1	dLo9		1			Available Logging Memory	AMnE	always	37004
Operations	oPEr	Data Logging 1	dLo9		1			Available Logging Time	At i	always	37005
Operations	oPEr	Backup 1	bCUP	always	1	Always		Status	StAt	always	38003
Operations	oPEr	Backup 1	bCUP		1			Zone	ZonE	always	38004
Operations	oPEr	Backup Status x	b.StA	always	instance 1-4 always instance 5-24 if PN digit 8 = B,Y, or D {backup for all modules}	Always		Status	StAt	always	54001
Setup	SEt	Global 1	9Lbl	always	1	always		Display Pairs	d.Pr5	always	3028
Setup	SEt	Global 1	9Lbl		1			User Settings Save	USr.S	always	1014
Setup	SEt	Global 1	9Lbl		1			User Settings Restore	USr.r	always	1013
Setup	SEt	Communications 2	CoM	If field comms is installed.	2	always		Modbus Address	Ad.M	if 6th digit of PN = 2 { has modbus RTU }	17007
Setup	SEt	Communications 2	CoM		2			Baud Rate	bAUd		17002
Setup	SEt	Communications 2	CoM		2			Parity	PAr		17003
Setup	SEt	Communications 2	CoM		2			Modbus Word Order	M.hL	if 6th digit of PN = 2 or 3 { supports modbus RTU or TCP }	17043
Setup	SEt	Communications 2	CoM		2			IP Address Mode	iP.M	if 6th digit of PN = 3 {it has ethernet}	17012
Setup	SEt	Communications 2	CoM		2			IP Fixed Address Part 1	iP.F1		17014
Setup	SEt	Communications 2	CoM		2			IP Fixed Address Part 2	iP.F2		17015
Setup	SEt	Communications 2	CoM		2			IP Fixed Address Part 3	iP.F3		17016
Setup	SEt	Communications 2	CoM		2			IP Fixed Address Part 4	iP.F4		17017
Setup	SEt	Communications 2	CoM		2			IP Fixed Address Part 5	iP.F5		17018
Setup	SEt	Communications 2	CoM		2			IP Fixed Address Part 6	iP.F6		17019
Setup	SEt	Communications 2	CoM		2			IP Fixed Subnet Part 1	iP.S1		17020
Setup	SEt	Communications 2	CoM		2			IP Fixed Subnet Part 2	iP.S2		17021
Setup	SEt	Communications 2	CoM		2			IP Fixed Subnet Part 3	iP.S3		17022
Setup	SEt	Communications 2	CoM		2			IP Fixed Subnet Part 4	iP.S4		17023
Setup	SEt	Communications 2	CoM		2			IP Fixed Subnet Part 5	iP.S5		17024
Setup	SEt	Communications 2	CoM		2			IP Fixed Subnet Part 6	iP.S6		17025
Setup	SEt	Communications 2	CoM		2			Fixed IP Gateway Part 1	iP.G1		17026
Setup	SEt	Communications 2	CoM		2			Fixed IP Gateway Part 2	iP.G2		17027
Setup	SEt	Communications 2	CoM		2			Fixed IP Gateway Part 3	iP.G3		17028
Setup	SEt	Communications 2	CoM		2			Fixed IP Gateway Part 4	iP.G4		17029
Setup	SEt	Communications 2	CoM		2			Fixed IP Gateway Part 5	iP.G5		17030
Setup	SEt	Communications 2	CoM		2			Fixed IP Gateway Part 6	iP.G6		17031
Setup	SEt	Communications 2	CoM		2			Modbus TCP Enable	M.bE		17041
Setup	SEt	Communications 2	CoM		2			EtherNet/IP Enable	E.iPE		17042
Setup	SEt	Communications 2	CoM		2			Display Units	C_F	if 6th digit of PN = 5 { has devicenet }	17052
Setup	SEt	Communications 2	CoM		2			Baud Rate DeviceNet	bAUd		17053
Setup	SEt	Communications 2	CoM		2			DeviceNet Quick Connect Enable	FCE		17054
Setup	SEt	Communications 2	CoM		2			Profibus Node Address	P.Add	if 6th digit of PN = 6 {it has profibus}	17060
Setup	SEt	Communications 2	CoM		2			Profibus Address Lock	A.Loc		17061
Setup	SEt	Communications 2	CoM		2			Profibus Status	StAt		17063
Setup	SEt	Communications 2	CoM		2			Display Units	C_F	if 6th digit of PN = 2, 3, or 5 { does not have profibus }	17050

EZ-ZONE RMA Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Communications 2	CoM		2			Non-Volatile Save	nV.S	always	17051
Setup	SEt	Local Remote Gateway x	gtwy	if field comms is installed	1-17	Always		Device Enabled	dv.En	always	24002
Setup	SEt	Local Remote Gateway x	gtwy		1-17			Device Status	dv.St	always	24006
Setup	SEt	Local Remote Gateway x	gtwy		1-17			Modbus Address Offset	MAoF	if 6th digit of PN = 2 or 3	24003
Setup	SEt	Local Remote Gateway x	gtwy		1-17			CIP Instance Offset	oSt	if 6th digit of PN = 3 or 5	24004
Setup	SEt	Local Remote Gateway x	gtwy		1-17			CIP Implicit Assembly Output Member Quantity	Ao.nb	if 6th digit of PN = 3 or 5	24009
Setup	SEt	Local Remote Gateway x	gtwy		1-17			CIP Implicit Assembly Input Member Quantity	A .nb	if 6th digit of PN = 3 or 5	24010
Setup	SEt	Local Remote Gateway x	gtwy		1-17			Slot Offset	S.oF	if 6th digit of PN = 6	24011
Setup	SEt	Real Time Clock 1	rtC	[IF 7th position of model number = B OR 8th position = U,Y,D]	1	Always		Hours	hoUr	always	36003
Setup	SEt	Real Time Clock 1	rtC		1			Minutes	MI.in	always	36004
Setup	SEt	Real Time Clock 1	rtC		1			Month	MAon	always	36006
Setup	SEt	Real Time Clock 1	rtC		1			Date	dAtE	always	36007
Setup	SEt	Real Time Clock 1	rtC		1			Year	YEAr	always	36008
Setup	SEt	Real Time Clock 1	rtC		1			Day of Week	doW	always	36002
Setup	SEt	Real Time Clock 1	rtC		1			Time Format	t.For	always	36011
Setup	SEt	Real Time Clock 1	rtC		1			Date Format	d.For	always	36012
Setup	SEt	Profile 1	Pro	[IF character 7 = B]	1	Always		Power Off Time	Pot	always	22073
Setup	SEt	Data Logging 1	dLo9	[IF 8th position of model number = D]	1	Always		Period	PErd	always	37001
Setup	SEt	Data Logging 1	dLo9		1			Full Action	F.Act	always	37003
Setup	SEt	Data Logging 1	dLo9		1			Source Function A	SFnA	always	37006
Setup	SEt	Data Logging 1	dLo9		1			Source Instance A	S .A	always	37007
Setup	SEt	Data Logging 1	dLo9		1			Source Zone A	S2.A	always	37008
Setup	SEt	Log Point x	LgPt	[IF 8th position of model number = D]	1-200	Always		Source Function A	SFnA	always	39001
Setup	SEt	Log Point x	LgPt		1-200			Source Instance A	S .A	always	39002
Setup	SEt	Log Point x	LgPt		1-200			Source Zone A	S2.A	always	39003
Setup	SEt	Log Point x	LgPt		1-200			Display Precision	dEC	always	39007
Setup	SEt	Backup 1	bCUP	always	1	Always		Save	SAvE	always	38001
Setup	SEt	Backup 1	bCUP		1			Restore	rESt	always	38002
Setup	SEt	Variable 1	uAr	always	1	always		Data Type	tYPE	always	2001
Setup	SEt	Variable 1	uAr		1			Units	Unit	always	2007
Setup	SEt	Variable 1	uAr		1			Digital	d.9	always	2002
Setup	SEt	Variable 1	uAr		1			Analog	AnL9	always	2003
Factory	FctY	Lock 1	LoC	[DspLockedState = PASS ADMI	1	Always		Operations Page	LoCo	always	3002
Factory	FctY	Lock 1	LoC		1			Password Enable	PASE	always	3015
Factory	FctY	Lock 1	LoC		1			Read Lock	rLoC	always	3010
Factory	FctY	Lock 1	LoC		1			Write Security	SLoC	always	3011
Factory	FctY	Lock 1	LoC		1			Locked Access Level	LoCL	always	3016
Factory	FctY	Lock 1	LoC		1			Rolling Password	roLL	always	3019
Factory	FctY	Lock 1	LoC		1			User Password	PASu	always	3017
Factory	FctY	Lock 1	LoC		1			Administrator Password	PASA	always	3018

EZ-ZONE RMA Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Factory	FctY	Unlock 1	ULoC		1	always		Public Key	CodE	always	3020
Factory	FctY	Unlock 1	ULoC	If DspSecurityEnable == ON	1			Password	PASS	always	3022
Factory	FctY	Diagnostics 1	diAG		1			Software ID	S.id	always	1002
Factory	FctY	Diagnostics 1	diAG		1			Software Release Version	S.rL	always	1003
Factory	FctY	Diagnostics 1	diAG		1			Software Prototype Version	S.Pr	always	1004
Factory	FctY	Diagnostics 1	diAG		1			Software Build Number	S.bLd	always	1005
Factory	FctY	Diagnostics 1	diAG		1			Serial Number	Sn	always	1032
Factory	FctY	Diagnostics 1	diAG		1			Date of Manufacture	dAtE	always	1008
Factory	FctY	Diagnostics 1	diAG	Always	1	Always		Actual IP Addressing Mode	iP.AC	if 6th digit of PN = 3	17013
Factory	FctY	Diagnostics 1	diAG		1			IP Actual Address Part 1	iP.A1	if 6th digit of PN = 3	17044
Factory	FctY	Diagnostics 1	diAG		1			IP Actual Address Part 2	iP.A2	if 6th digit of PN = 3	17045
Factory	FctY	Diagnostics 1	diAG		1			IP Actual Address Part 3	iP.A3	if 6th digit of PN = 3	17046
Factory	FctY	Diagnostics 1	diAG		1			IP Actual Address Part 4	iP.A4	if 6th digit of PN = 3	17047
Factory	FctY	Diagnostics 1	diAG		1			IP Actual Address Part 5	iP.A5	if 6th digit of PN = 3	17048
Factory	FctY	Diagnostics 1	diAG		1			IP Actual Address Part 6	iP.A6	if 6th digit of PN = 3	17049

EZ-ZONE RMH Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Analog Input x	A i	always	1 - 16	Instance 1-4 = always Instance 5-8 if PN digit 6 = 1 or 2 Instance 9-12 if PN digit 7 = 1 or 2 Instance 13-16 if PN digit 8 = 1 or 2		Analog Input Value	A in	always	4001
Operations	oPEr	Analog Input x	A i		1 - 16			Input Error	i.Er	always	4002
Operations	oPEr	Analog Input x	A i		1 - 16			Calibration Offset	i.CA	always	4012
Operations	oPEr	Process Value x	Pu	always	1 - 16	Instance 1-4 = always Instance 5-8 if PN digit 6 = 1 or 2 Instance 9-12 if PN digit 7 = 1 or 2 Instance 13-16 if PN digit 8 = 1 or 2		Source Value A	Su.A	always	26016
Operations	oPEr	Process Value x	Pu		1 - 16			Source Value B	Su.b	always	26017
Operations	oPEr	Process Value x	Pu		1 - 16			Source Value C	Su.C	always	26018
Operations	oPEr	Process Value x	Pu		1 - 16			Source Value D	Su.d	always	26019
Operations	oPEr	Process Value x	Pu		1 - 16			Source Value E	Su.E	always	26020
Operations	oPEr	Process Value x	Pu		1 - 16			Offset	oFSt	always	26023
Operations	oPEr	Process Value x	Pu		1 - 16			Output Value	ou	always	26022
Operations	oPEr	Digital I/O x	d io	If PN digit 7 = C or digit 8 = C	1-12	Instance 1-6 if PN digit 7 = C Instance 7-12 if PN digit 8 = C		Output State	do.S	always	6007
Operations	oPEr	Digital I/O x	d io		1-12			Input State	di.S	always	6011
Operations	oPEr	Action x	ACt	always	1 - 24	always		Event Status	E.S	always	10005
Operations	oPEr	Monitor x	mon	always	1 - 16	Instance 1-4 = always Instance 5-8 if PN digit 6 = 1 or 2 Instance 9-12 if PN digit 7 = 1 or 2 Instance 13-16 if PN digit 8 = 1 or 2		Control Mode Active	C.mA	always	8002
Operations	oPEr	Monitor x	mon		1 - 16			Heat Power	h.Pr	always	8011
Operations	oPEr	Monitor x	mon		1 - 16			Cool Power	C.Pr	always	8014
Operations	oPEr	Monitor x	mon		1 - 16			Closed-Loop Set Point	C.SP	always	8029
Operations	oPEr	Monitor x	mon		1 - 16			Process Value Active	Pu.A	always	8031
Operations	oPEr	Control Loop x	LooP	always	1 - 16	Instance 1-4 = always Instance 5-8 if PN digit 6 = 1 or 2 Instance 9-12 if PN digit 7 = 1 or 2 Instance 13-16 if PN digit 8 = 1 or 2		Remote Enable	r.En	always	7021
Operations	oPEr	Control Loop x	LooP		1 - 16			Control Mode	C.mn	always	8001
Operations	oPEr	Control Loop x	LooP		1 - 16			Autotune Set Point	A.tSP	always	8025
Operations	oPEr	Control Loop x	LooP		1 - 16			Autotune	AUt	always	8026
Operations	oPEr	Control Loop x	LooP		1 - 16			Closed-Loop Set Point	C.SP	always	7001
Operations	oPEr	Control Loop x	LooP		1 - 16			Idle Set Point	id.S	always	7009
Operations	oPEr	Control Loop x	LooP		1 - 16			Heat Proportional Band	h.Pb	always	8009
Operations	oPEr	Control Loop x	LooP		1 - 16			Heat Hysteresis	h.hy	always	8010
Operations	oPEr	Control Loop x	LooP		1 - 16			Cool Proportional Band	C.Pb	always	8012
Operations	oPEr	Control Loop x	LooP		1 - 16			Cool Hysteresis	C.hy	always	8013
Operations	oPEr	Control Loop x	LooP		1 - 16			Time Integral	ti	always	8006
Operations	oPEr	Control Loop x	LooP		1 - 16			Time Derivative	td	always	8007
Operations	oPEr	Control Loop x	LooP		1 - 16			Dead Band	db	always	8008
Operations	oPEr	Control Loop x	LooP		1 - 16			Open Loop Set Point	o.SP	always	7002
Operations	oPEr	Alarm x	ALMn	always	1 - 24	always		Alarm Low Set Point	A.Lo	always	9002
Operations	oPEr	Alarm x	ALMn		1 - 24			Alarm High Set Point	A.hi	always	9001
Operations	oPEr	Alarm x	ALMn		1 - 24			Alarm Clear Request	A.Clr	always	9026
Operations	oPEr	Alarm x	ALMn		1 - 24			Alarm Silence Request	A.Sir	always	9027
Operations	oPEr	Alarm x	ALMn		1 - 24			Alarm State	A.St	always	9009
Operations	oPEr	Linearization x	Lin	always	1 - 24	always		Source Value A	Su.A	always	34004
Operations	oPEr	Linearization x	Lin		1 - 24			Offset	oFSt	always	34006
Operations	oPEr	Linearization x	Lin		1 - 24			Output Value	ou	always	34007

EZ-ZONE RMH Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Compare x	CPE	always	1 - 24	always		Source Value A	Su.A	always	28007
Operations	oPEr	Compare x	CPE		1 - 24			Source Value B	Su.b	always	28008
Operations	oPEr	Compare x	CPE		1 - 24			Output Value	o.u	always	28010
Operations	oPEr	Timer x	tMr	always	1 - 24	always		Source Value A	Su.A	always	31007
Operations	oPEr	Timer x	tMr		1 - 24			Source Value B	Su.b	always	31008
Operations	oPEr	Timer x	tMr		1 - 24			Elapsed Time	Et	always	31016
Operations	oPEr	Timer x	tMr		1 - 24			Output Value	o.u	always	31010
Operations	oPEr	Counter x	Ctr	always	1 - 24	always		Count	Cnt	always	30015
Operations	oPEr	Counter x	Ctr		1 - 24			Source Value A	Su.A	always	30007
Operations	oPEr	Counter x	Ctr		1 - 24			Source Value B	Su.b	always	30008
Operations	oPEr	Counter x	Ctr		1 - 24			Output Value	o.u	always	30010
Operations	oPEr	Logic x	LGC	always	1 - 24	always		Source Value A	Su.A	always	27025
Operations	oPEr	Logic x	LGC		1 - 24			Source Value B	Su.b	always	27026
Operations	oPEr	Logic x	LGC		1 - 24			Source Value C	Su.C	always	27027
Operations	oPEr	Logic x	LGC		1 - 24			Source Value D	Su.d	always	27028
Operations	oPEr	Logic x	LGC		1 - 24			Source Value E	Su.E	always	27029
Operations	oPEr	Logic x	LGC		1 - 24			Source Value F	Su.F	always	27030
Operations	oPEr	Logic x	LGC		1 - 24			Source Value G	Su.g	always	27031
Operations	oPEr	Logic x	LGC		1 - 24			Source Value H	Su.h	always	27032
Operations	oPEr	Logic x	LGC		1 - 24			Output Value	o.u	always	27034
Operations	oPEr	Math x	MAt	always	1 - 24	always		Source Value A	Su.A	always	25016
Operations	oPEr	Math x	MAt		1 - 24			Source Value B	Su.b	always	25017
Operations	oPEr	Math x	MAt		1 - 24			Source Value C	Su.C	always	25018
Operations	oPEr	Math x	MAt		1 - 24			Source Value D	Su.d	always	25019
Operations	oPEr	Math x	MAt		1 - 24			Source Value E	Su.E	always	25020
Operations	oPEr	Math x	MAt		1 - 24			Offset	oFSt	always	25023
Operations	oPEr	Math x	MAt		1 - 24			Output Value	o.u	always	25022
Setup	SEt	Analog Input x	A i	always	1 - 16	Instance 1-4 = always Instance 5-8 if PN digit 6 = 1 or 2 Instance 9-12 if PN digit 7 = 1 or 2 Instance 13-16 if PN digit 8 = 1 or 2		Sensor Type	SEn	always	4005
Setup	SEt	Analog Input x	A i		1 - 16			TC Linearization	L in	Instance 1-4 if PN digit 5 = 1 Instance 5-8 if PN digit 6 = 1 Instance 9-12 if PN digit 7 = 1 Instance 13-16 if PN digit 8 = 1 { input is universal }	4006
Setup	SEt	Analog Input x	A i		1 - 16			Units	Unit		4042
Setup	SEt	Analog Input x	A i		1 - 16			Scale Low	S.Lo		4015
Setup	SEt	Analog Input x	A i		1 - 16			Scale High	S.h i		4016
Setup	SEt	Analog Input x	A i		1 - 16			Range Low	r.Lo		4017
Setup	SEt	Analog Input x	A i		1 - 16			Range High	r.h i		4018
Setup	SEt	Analog Input x	A i		1 - 16			Process Error Enable	P.EE		4030
Setup	SEt	Analog Input x	A i		1 - 16			Process Error Low Value	P.EL		4031
Setup	SEt	Analog Input x	A i		1 - 16			Thermistor Curve	t.C	Instance 1-4 if PN digit 5 = 2 Instance 5-8 if PN digit 6 = 2 Instance 9-12 if PN digit 7 = 2 Instance 13-16 if PN digit 8 = 2 { input is thermistor }	4038
Setup	SEt	Analog Input x	A i		1 - 16			Resistance Range	r.r		4037
Setup	SEt	Analog Input x	A i		1 - 16			Filter	F iL	always	4014

EZ-ZONE RMH Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Analog Input x	A i		1 - 16			Input Error Latching	i.Er	always	4028
Setup	SEt	Analog Input x	A i		1 - 16			Display Precision	dEC	always	4020
Setup	SEt	Analog Input x	A i		1 - 16			Calibration Offset	i.CA	always	4012
Setup	SEt	Analog Input x	A i		1 - 16			Analog Input Value	A in	always	4001
Setup	SEt	Analog Input x	A i		1 - 16			Input Error	i.Er	always	4002
Setup	SEt	Process Value x	Pu		1 - 16			Function	Fn	always	26021
Setup	SEt	Process Value x	Pu		1 - 16			Source Function A	SFn.A	always	26001
Setup	SEt	Process Value x	Pu		1 - 16			Source Instance A	S i.A	always	26006
Setup	SEt	Process Value x	Pu		1 - 16			Source Function B	SFn.b	always	26002
Setup	SEt	Process Value x	Pu		1 - 16			Source Instance B	S i.b	always	26007
Setup	SEt	Process Value x	Pu		1 - 16			Source Zone B	S2.b	always	26012
Setup	SEt	Process Value x	Pu		1 - 16			Source Function C	SFn.C	always	26003
Setup	SEt	Process Value x	Pu		1 - 16			Source Instance C	S i.C	always	26008
Setup	SEt	Process Value x	Pu		1 - 16			Source Zone C	S2.C	always	26013
Setup	SEt	Process Value x	Pu		1 - 16	Instance 1-4 = always Instance 5-8 if PN digit 6 = 1 or 2 Instance 9-12 if PN digit 7 = 1 or 2 Instance 13-16 if PN digit 8 = 1 or 2		Source Function D	SFn.d	always	26004
Setup	SEt	Process Value x	Pu	always	1 - 16			Source Instance D	S i.d	always	26009
Setup	SEt	Process Value x	Pu		1 - 16			Source Zone D	S2.d	always	26014
Setup	SEt	Process Value x	Pu		1 - 16			Source Function E	SFn.E	always	26005
Setup	SEt	Process Value x	Pu		1 - 16			Source Instance E	S i.E	always	26010
Setup	SEt	Process Value x	Pu		1 - 16			Source Zone E	S2.E	always	26015
Setup	SEt	Process Value x	Pu		1 - 16			Cross Over Point	C.P	always	26024
Setup	SEt	Process Value x	Pu		1 - 16			Cross Over Band	C.b	always	26025
Setup	SEt	Process Value x	Pu		1 - 16			Pressure Units	P.unt	always	26028
Setup	SEt	Process Value x	Pu		1 - 16			Altitude Units	A.unt	always	26029
Setup	SEt	Process Value x	Pu		1 - 16			Barometric Pressure	b.Pr	always	26030
Setup	SEt	Process Value x	Pu		1 - 16			Filter	F iL	always	26026
Setup	SEt	Digital I/O x	d io		1-12			Digital I/O Direction	d ir	always	6001
Setup	SEt	Digital I/O x	d io		1-12			Output Function	Fn	always	6005
Setup	SEt	Digital I/O x	d io		1-12			Output Function Instance	F i	always	6006
Setup	SEt	Digital I/O x	d io	If PN digit 7 = C or digit 8 = C	1-12	Instance 1-6 if PN digit 7 = C Instance 7-12 if PN digit 8 = C		Output Source Zone A	o.Ct	always	6012
Setup	SEt	Digital I/O x	d io		1-12			Output Control	o.tb	always	6002
Setup	SEt	Digital I/O x	d io		1-12			Output Time Base	o.Lo	always	6003
Setup	SEt	Digital I/O x	d io		1-12			Output Low Power Scale	o.h i	always	6009
Setup	SEt	Digital I/O x	d io		1-12			Output High Power Scale	LEu	always	6010
Setup	SEt	Action x	ACt		1 - 24			Action Function	Fn	always	10003
Setup	SEt	Action x	ACt		1 - 24			Function Instance	F i	always	10004
Setup	SEt	Action x	ACt		1 - 24			Source Function A	SFn.A	always	10006
Setup	SEt	Action x	ACt	always	1 - 24	always		Source Instance A	S i.A	always	10002
Setup	SEt	Action x	ACt		1 - 24			Source Zone A	S2.A	always	10007
Setup	SEt	Action x	ACt		1 - 24			Active Level	LEu	always	10001
Setup	SEt	Control Loop x	LooP		1 - 16			Source Function A	SFn.A	always	8050
Setup	SEt	Control Loop x	LooP		1 - 16			Source Instance A	S i.A	always	8021
Setup	SEt	Control Loop x	LooP		1 - 16			Heat Algorithm	h.Ag	always	8003

EZ-ZONE RMH Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Control Loop x	LooP	always	1 - 16	Instance 1-4 = always Instance 5-8 if PN digit 6 = 1 or 2 Instance 9-12 if PN digit 7 = 1 or 2 Instance 13-16 if PN digit 8 = 1 or 2		Cool Algorithm	CAG	always	8004
Setup	SEt	Control Loop x	LooP		1 - 16			Cool Output Curve	CCr	always	8038
Setup	SEt	Control Loop x	LooP		1 - 16			Heat Proportional Band	hPb	always	8009
Setup	SEt	Control Loop x	LooP		1 - 16			Heat Hysteresis	hhy	always	8010
Setup	SEt	Control Loop x	LooP		1 - 16			Cool Proportional Band	CPb	always	8012
Setup	SEt	Control Loop x	LooP		1 - 16			Cool Hysteresis	Chy	always	8013
Setup	SEt	Control Loop x	LooP		1 - 16			Time Integral	ti	always	8006
Setup	SEt	Control Loop x	LooP		1 - 16			Time Derivative	td	always	8007
Setup	SEt	Control Loop x	LooP		1 - 16			Dead Band	db	always	8008
Setup	SEt	Control Loop x	LooP		1 - 16			TRU-TUNE+ Enable	tUn	always	8022
Setup	SEt	Control Loop x	LooP		1 - 16			TRU-TUNE+ Band	tbnd	always	8034
Setup	SEt	Control Loop x	LooP		1 - 16			TRU-TUNE+ Gain	tgn	always	8035
Setup	SEt	Control Loop x	LooP		1 - 16			Autotune Set Point	AtSP	always	8025
Setup	SEt	Control Loop x	LooP		1 - 16			Autotune Aggressiveness	tAgr	always	8024
Setup	SEt	Control Loop x	LooP		1 - 16			Peltier Delay	Pdl	always	8051
Setup	SEt	Control Loop x	LooP		1 - 16			Remote Set Point	rEn	always	7021
Setup	SEt	Control Loop x	LooP		1 - 16			Source Function B	SFnb	always	7023
Setup	SEt	Control Loop x	LooP		1 - 16			Source Instance B	S1b	always	7024
Setup	SEt	Control Loop x	LooP		1 - 16			Source Zone B	S2b	always	7026
Setup	SEt	Control Loop x	LooP		1 - 16			Remote Set Point Type	rty	always	7022
Setup	SEt	Control Loop x	LooP		1 - 16			User Failure Action	UFA	always	7012
Setup	SEt	Control Loop x	LooP		1 - 16			Input Error Failure	FAiL	always	7013
Setup	SEt	Control Loop x	LooP		1 - 16			Fixed Power	mAn	always	7011
Setup	SEt	Control Loop x	LooP		1 - 16			Open Loop Detect Enable	LdE	always	8039
Setup	SEt	Control Loop x	LooP		1 - 16			Open Loop Detect Time	Ldt	always	8040
Setup	SEt	Control Loop x	LooP		1 - 16			Open Loop Detect Deviation	Ldd	always	8041
Setup	SEt	Control Loop x	LooP		1 - 16			Ramp Action	rP	always	7014
Setup	SEt	Control Loop x	LooP		1 - 16			Ramp Scale	rSC	always	7015
Setup	SEt	Control Loop x	LooP		1 - 16			Ramp Rate	rrt	always	7017
Setup	SEt	Control Loop x	LooP		1 - 16			Low Set Point	LSP	always	7003
Setup	SEt	Control Loop x	LooP		1 - 16			High Set Point	hSP	always	7004
Setup	SEt	Control Loop x	LooP		1 - 16			Closed-Loop Set Point	CSP	always	7001
Setup	SEt	Control Loop x	LooP		1 - 16			Idle Set Point	idS	always	7009
Setup	SEt	Control Loop x	LooP		1 - 16			Set Point Open Limit Low	SPLo	always	7005
Setup	SEt	Control Loop x	LooP		1 - 16			Set Point Open Limit High	SPhi	always	7006
Setup	SEt	Control Loop x	LooP		1 - 16			Open Loop Set Point	oSP	always	7002
Setup	SEt	Control Loop x	LooP		1 - 16			Control Mode	Cnt	always	8001
Setup	SEt	Output x	OtPt	If PN digit 7 or 8 = J, L, or F	1-10	Instance 1 - 3: if 7th digit is J, L, or F Instance 4: if 7th digit is J or L Instance 7 - 9: if 8th digit is J, L, or		Output Function	Fn	Instance 1 - 4: if 7th digit is J or L Instance 7 - 10: if 8th digit is J or L {output is digital}	6005
Setup	SEt	Output x	OtPt		1-10			Output Function Instance	Fi		6006
Setup	SEt	Output x	OtPt		1-10			Output Source Zone	S2A		6012
Setup	SEt	Output x	OtPt		1-10			Output Control	oCt		6002
Setup	SEt	Output x	OtPt		1-10			Output Time Base	otb		6003
Setup	SEt	Output x	OtPt		1-10			Output Low Power Scale	oLo		6009
Setup	SEt	Output x	OtPt		1-10			Output High Power Scale	ohi		6010
Setup	SEt	Output x	OtPt		1-10			Output Type	oty		18001
Setup	SEt	Output x	OtPt		1-10			Output Function	Fn		18002

EZ-ZONE RMH Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Output x	OtPt		1-10	F Instance 10: if 8th digit is J or L		Output Function Instance	F ,	Instance 1 - 3: if 7th digit is F Instance 7 - 9: if 8th digit is F {output is analog}	18004
Setup	SEt	Output x	OtPt		1-10			Output Source Zone	S2.A		18019
Setup	SEt	Output x	OtPt		1-10			Scale Low	S.Lo		18009
Setup	SEt	Output x	OtPt		1-10			Scale High	S.h ,		18010
Setup	SEt	Output x	OtPt		1-10			Range Low	r.Lo		18011
Setup	SEt	Output x	OtPt		1-10			Range High	r.h ,		18012
Setup	SEt	Output x	OtPt		1-10			Calibration Offset	o.CA		18007
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm Type	A.tY	always	9015
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm Source	Sr.A	always	9017
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm Source Instance	,S.A	always	9018
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm Source Zone	S2.A	always	9025
Setup	SEt	Alarm x	ALM1		1 - 24			Control Loop	LooP	always	9023
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm Hysteresis	A.hY	always	9003
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm Logic	A.L9	always	9005
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm Sides	A.Sd	always	9004
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm Low Set Point	A.Lo	always	9002
Setup	SEt	Alarm x	ALM1	always	1 - 24	always		Alarm High Set Point	A.h ,	always	9001
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm Latching	A.LA	always	9007
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm Blocking	A.bL	always	9008
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm Silencing	A.S ,	always	9006
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm Display	A.dSP	always	9016
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm Delay Time	A.dL	always	9021
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm Clear Request	A.CLr	always	9026
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm Silence	A.Sir	always	9027
Setup	SEt	Alarm x	ALM1		1 - 24			Alarm State	A.St	always	9009
Setup	SEt	Linearization x	L in		1 - 24			Function	Fn	always	34005
Setup	SEt	Linearization x	L in		1 - 24			Source Function A	SFn.A	always	34001
Setup	SEt	Linearization x	L in		1 - 24			Source Instance A	S ,A	always	34002
Setup	SEt	Linearization x	L in		1 - 24			Source Zone A	S2.A	always	34003
Setup	SEt	Linearization x	L in		1 - 24			Units	Unit	always	34029
Setup	SEt	Linearization x	L in		1 - 24			Input Point 1	,P.1	always	34008
Setup	SEt	Linearization x	L in		1 - 24			Output Point 1	oP.1	always	34018
Setup	SEt	Linearization x	L in		1 - 24			Input Point 2	,P.2	always	34009
Setup	SEt	Linearization x	L in		1 - 24			Output Point 2	oP.2	always	34019
Setup	SEt	Linearization x	L in		1 - 24			Input Point 3	,P.3	always	34010
Setup	SEt	Linearization x	L in		1 - 24			Output Point 3	oP.3	always	34020
Setup	SEt	Linearization x	L in		1 - 24			Input Point 4	,P.4	always	34011
Setup	SEt	Linearization x	L in	always	1 - 24	always		Output Point 4	oP.4	always	34021
Setup	SEt	Linearization x	L in		1 - 24			Input Point 5	,P.5	always	34012
Setup	SEt	Linearization x	L in		1 - 24			Output Point 5	oP.5	always	34022
Setup	SEt	Linearization x	L in		1 - 24			Input Point 6	,P.6	always	34013
Setup	SEt	Linearization x	L in		1 - 24			Output Point 6	oP.6	always	34023
Setup	SEt	Linearization x	L in		1 - 24			Input Point 7	,P.7	always	34014
Setup	SEt	Linearization x	L in		1 - 24			Output Point 7	oP.7	always	34024
Setup	SEt	Linearization x	L in		1 - 24			Input Point 8	,P.8	always	34015

EZ-ZONE RMH Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Linearization x	L in		1 - 24			Output Point 8	oP.8	always	34025
Setup	SEt	Linearization x	L in		1 - 24			Input Point 9	iP.9	always	34016
Setup	SEt	Linearization x	L in		1 - 24			Output Point 9	oP.9	always	34026
Setup	SEt	Linearization x	L in		1 - 24			Input Point 10	iP.10	always	34017
Setup	SEt	Linearization x	L in		1 - 24			Output Point 10	oP.10	always	34027
Setup	SEt	Compare x	CPE		1 - 24			Function	Fn	always	28009
Setup	SEt	Compare x	CPE		1 - 24			Tolerance	toL	always	28011
Setup	SEt	Compare x	CPE		1 - 24			Source Function A	SFn.A	always	28001
Setup	SEt	Compare x	CPE		1 - 24			Source Instance A	S .A	always	28003
Setup	SEt	Compare x	CPE	always	1 - 24	always		Source Zone A	S2.A	always	28005
Setup	SEt	Compare x	CPE		1 - 24			Source Function B	SFn.b	always	28002
Setup	SEt	Compare x	CPE		1 - 24			Source Instance B	S .b	always	28004
Setup	SEt	Compare x	CPE		1 - 24			Source Zone B	S2.b	always	28006
Setup	SEt	Compare x	CPE		1 - 24			Error Handling	Er.h	always	28012
Setup	SEt	Timer x	tMr		1 - 24			Function	Fn	always	31009
Setup	SEt	Timer x	tMr		1 - 24			Source Function A	SFn.A	always	31001
Setup	SEt	Timer x	tMr		1 - 24			Source Instance A	S .A	always	31003
Setup	SEt	Timer x	tMr		1 - 24			Source Zone A	S2.A	always	31005
Setup	SEt	Timer x	tMr		1 - 24			Source Active State A	SAS.A	always	31011
Setup	SEt	Timer x	tMr	always	1 - 24	always		Source Function B	SFn.b	always	31002
Setup	SEt	Timer x	tMr		1 - 24			Source Instance B	S .b	always	31004
Setup	SEt	Timer x	tMr		1 - 24			Source Zone B	S2.b	always	31006
Setup	SEt	Timer x	tMr		1 - 24			Source Active State B	SAS.b	always	31012
Setup	SEt	Timer x	tMr		1 - 24			Time	t i	always	31013
Setup	SEt	Timer x	tMr		1 - 24			Active Level	LEu	always	31014
Setup	SEt	Counter x	Ctr		1 - 24			Function	Fn	always	30009
Setup	SEt	Counter x	Ctr		1 - 24			Source Function A	SFn.A	always	30001
Setup	SEt	Counter x	Ctr		1 - 24			Source Instance A	S .A	always	30003
Setup	SEt	Counter x	Ctr		1 - 24			Source Zone A	S2.A	always	30005
Setup	SEt	Counter x	Ctr		1 - 24			Source Active State A	SAS.A	always	30011
Setup	SEt	Counter x	Ctr	always	1 - 24	always		Source Function B	SFn.b	always	30002
Setup	SEt	Counter x	Ctr		1 - 24			Source Instance B	S .b	always	30004
Setup	SEt	Counter x	Ctr		1 - 24			Source Zone B	S2.b	always	30006
Setup	SEt	Counter x	Ctr		1 - 24			Source Active State B	SAS.b	always	30012
Setup	SEt	Counter x	Ctr		1 - 24			Load Value	LoAd	always	30013
Setup	SEt	Counter x	Ctr		1 - 24			Target Value	trGt	always	30014
Setup	SEt	Counter x	Ctr		1 - 24			Latching	LAt	always	30017
Setup	SEt	Logic x	LGC		1 - 24			Function	Fn	always	27033
Setup	SEt	Logic x	LGC		1 - 24			Source Function A	SFn.A	always	27001
Setup	SEt	Logic x	LGC		1 - 24			Source Instance A	S .A	always	27009
Setup	SEt	Logic x	LGC		1 - 24			Source Zone A	S2.A	always	27017
Setup	SEt	Logic x	LGC		1 - 24			Source Function B	SFn.b	always	27002
Setup	SEt	Logic x	LGC		1 - 24			Source Instance B	S .b	always	27010

EZ-ZONE RMH Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Logic x	LGC	always	1 - 24	always		Source Zone B	S2.b	always	27018
Setup	SEt	Logic x	LGC		1 - 24			Source Function C	SFn.C	always	27003
Setup	SEt	Logic x	LGC		1 - 24			Source Instance C	S .C	always	27011
Setup	SEt	Logic x	LGC		1 - 24			Source Zone C	S2.C	always	27019
Setup	SEt	Logic x	LGC		1 - 24			Source Function D	SFn.d	always	27004
Setup	SEt	Logic x	LGC		1 - 24			Source Instance D	S .d	always	27012
Setup	SEt	Logic x	LGC		1 - 24			Source Zone D	S2.d	always	27020
Setup	SEt	Logic x	LGC		1 - 24			Source Function E	SFn.E	always	27005
Setup	SEt	Logic x	LGC		1 - 24			Source Instance E	S .E	always	27013
Setup	SEt	Logic x	LGC		1 - 24			Source Zone E	S2.E	always	27021
Setup	SEt	Logic x	LGC		1 - 24			Source Function F	SFn.F	always	27006
Setup	SEt	Logic x	LGC		1 - 24			Source Instance F	S .F	always	27014
Setup	SEt	Logic x	LGC		1 - 24			Source Zone F	S2.F	always	27022
Setup	SEt	Logic x	LGC		1 - 24			Source Function G	SFn.9	always	27007
Setup	SEt	Logic x	LGC		1 - 24			Source Instance G	S .9	always	27015
Setup	SEt	Logic x	LGC		1 - 24			Source Zone G	S2.9	always	27023
Setup	SEt	Logic x	LGC		1 - 24			Source Function H	SFn.h	always	27008
Setup	SEt	Logic x	LGC		1 - 24			Source Instance H	S .h	always	27016
Setup	SEt	Logic x	LGC		1 - 24			Source Zone H	S2.h	always	27024
Setup	SEt	Logic x	LGC		1 - 24			Error Handling	Er.h	always	27035
Setup	SEt	Math x	MAt	always	1 - 24	always		Function	Fn	always	25021
Setup	SEt	Math x	MAt		1 - 24			Source Function A	SFn.A	always	25001
Setup	SEt	Math x	MAt		1 - 24			Source Instance A	S .A	always	25006
Setup	SEt	Math x	MAt		1 - 24			Source Zone A	S2.A	always	25011
Setup	SEt	Math x	MAt		1 - 24			Source Function B	SFn.b	always	25002
Setup	SEt	Math x	MAt		1 - 24			Source Instance B	S .b	always	25007
Setup	SEt	Math x	MAt		1 - 24			Source Zone B	S2.b	always	25012
Setup	SEt	Math x	MAt		1 - 24			Source Function C	SFn.C	always	25003
Setup	SEt	Math x	MAt		1 - 24			Source Instance C	S .C	always	25008
Setup	SEt	Math x	MAt		1 - 24			Source Zone C	S2.C	always	25013
Setup	SEt	Math x	MAt		1 - 24			Source Function D	SFn.d	always	25004
Setup	SEt	Math x	MAt		1 - 24			Source Instance D	S .d	always	25009
Setup	SEt	Math x	MAt		1 - 24			Source Zone D	S2.d	always	25014
Setup	SEt	Math x	MAt		1 - 24			Source Function E	SFn.E	always	25005
Setup	SEt	Math x	MAt		1 - 24			Source Instance E	S .E	always	25010
Setup	SEt	Math x	MAt		1 - 24			Source Zone E	S2.E	always	25015
Setup	SEt	Math x	MAt		1 - 24			Scale Low	S.Lo	always	25024
Setup	SEt	Math x	MAt		1 - 24			Scale High	S.h i	always	25025
Setup	SEt	Math x	MAt		1 - 24			Units	Un it	always	25032
Setup	SEt	Math x	MAt		1 - 24			Range Low	r.Lo	always	25026
Setup	SEt	Math x	MAt		1 - 24			Range High	r.h i	always	25027
Setup	SEt	Math x	MAt		1 - 24			Pressure Units	P.unt	always	25030
Setup	SEt	Math x	MAt		1 - 24			Altitude Units	A.unt	always	25031
Setup	SEt	Math x	MAt		1 - 24			Filter	F iL	always	25028
Setup	SEt	Variable x	uAr		1 - 24			Data Type	tYPE	always	2001

EZ-ZONE RMH Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Variable x	uAr	always	1 - 24	always		Units	Unit	always	2007
Setup	SEt	Variable x	uAr		1 - 24			Digital	dig	always	2002
Setup	SEt	Variable x	uAr		1 - 24			Analog	AnLg	always	2003
Setup	SEt	Global 1	GLbL	always	1	always		Display Units	C_F	always	3005
Setup	SEt	Global 1	GLbL		1			AC Line Frequency	AC.LF	always	1034
Setup	SEt	Global 1	GLbL		1			Display Pairs	dPrS	always	3028
Setup	SEt	Global 1	GLbL		1			User Settings Save	USr.S	always	1014
Setup	SEt	Global 1	GLbL		1			User Settings Restore	USr.r	always	1013
Setup	SEt	Communications 1	Conn	If PN digit 10 = 1	1	always		Baud Rate	bAUd	always	17002
Setup	SEt	Communications 1	Conn		1			Parity	PAr	always	17003
Setup	SEt	Communications 1	Conn		1			Modbus Word Order	Cmhl	always	17043
Setup	SEt	Communications 1	Conn		1			Display Units	C_F	always	17050
Setup	SEt	Communications 1	Conn		1			Non-Volatile Save	nvS	always	17051
Factory	FCtY	Custom Setup x	CUSt	always	1 - 50	always		Parameter	PAr	always	14005
Factory	FCtY	Custom Setup x	CUSt		1 - 50			Instance ID	Inid	always	14003
Factory	FCtY	Lock 1	LoC	If DspLockedState = PASS ADMIN	1	always		Operations Page	LoCo	always	3002
Factory	FCtY	Lock 1	LoC		1			Password Enable	PASE	always	3015
Factory	FCtY	Lock 1	LoC		1			Read Lock	rLoC	always	3010
Factory	FCtY	Lock 1	LoC		1			Write Security	SLoC	always	3011
Factory	FCtY	Lock 1	LoC		1			Locked Access Level	LoCL	always	3016
Factory	FCtY	Lock 1	LoC		1			Rolling Password	roLL	always	3019
Factory	FCtY	Lock 1	LoC		1			User Password	PASu	always	3017
Factory	FCtY	Lock 1	LoC		1			Administrator Password	PASA	always	3018
Factory	FCtY	Unlock 1	ULoC	If DspSecurityEnable == ON	1	always		Public Key	CodE	always	3020
Factory	FCtY	Unlock 1	ULoC		1			Password	PASS	always	3022
Factory	FCtY	Diagnostics 1	diAG	always	1	always		Part Number	Pn	always	1009
Factory	FCtY	Diagnostics 1	diAG		1			Software Revision	rEv	always	1017
Factory	FCtY	Diagnostics 1	diAG		1			Software Build Number	SbLd	always	1005
Factory	FCtY	Diagnostics 1	diAG		1			Serial Number	Sn	always	1032
Factory	FCtY	Diagnostics 1	diAG		1			Date of Manufacture	dAtE	always	1008
Factory	FCtY	Calibration x	CAL	always	1-16	Instance 1 - 4: always Instance 5 - 6: if 6th digit is 1 or 2 Instance 7 - 8: if 6th digit is 1 or 2 OR 7th digit is F Instance 9: if 7th digit is 1 or 2 OR 8th digit is F Instance 10 - 12: if 7th digit is 1 or 2 Instance 13 - 16: if 8th digit is 1 or 2		Electrical Measurement	CMu	Instance 1 - 4: if 5th digit is 1 or 2 Instance 5 - 8: if 6th digit is 1 or 2 Instance 9 - 12: if 7th digit is 1 or 2 Instance 13 - 16: if 8th digit is 1 or 2 {input is analog}	4021
Factory	FCtY	Calibration x	CAL		1-16			Electrical Input Offset	EL.o		4010
Factory	FCtY	Calibration x	CAL		1-16			Electrical Input Slope	EL.S		4011
Factory	FCtY	Calibration x	CAL		1-16			Electrical Output Offset	ELoo	Instance 1 - 3: if 7th digit is F Instance 7 - 9: if 8th digit is F {output is analog}	18005
Factory	FCtY	Calibration x	CAL		1-16			Electrical Output Slope	ELoS		18006

EZ-ZONE RML Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Analog Input x	A i	always	1 - 12	Instance 1-4 = always Instance 5-8 if PN digit 6 = 5 or 6 Instance 9-12 if PN digit 7 = 5 or 6		Analog Input Value	A in	always	4001
Operations	oPEr	Analog Input x	A i		1 - 12			Input Error	i.Er	always	4002
Operations	oPEr	Analog Input x	A i		1 - 12			Calibration Offset	i.CA	always	4012
Operations	oPEr	Digital I/O x	d io	If PN digit 7 = C or PN digit 8 = B	1 - 6,9	Instance 1-6 if PN digit 7 = C Instance 9 if PN digit 8 = B		Output State	do.S	always	6007
Operations	oPEr	Digital I/O x	d io		1 - 6,9			Input State	di.S	always	6011
Operations	oPEr	Action x	ACt	always	1 - 16	always		Event Status	E.S	always	10005
Operations	oPEr	Limit x	LiM	always	1 - 12	Instance 1-4 = always Instance 5-8 if PN digit 6 = 5 or 6 Instance 9-12 if PN digit 7 = 5 or 6		Limit Low Set Point	LLS	always	12003
Operations	oPEr	Limit x	LiM		1 - 12			Limit High Set Point	LhS	always	12004
Operations	oPEr	Limit x	LiM		1 - 12			Limit Clear Request	LCr	always	12014
Operations	oPEr	Limit x	LiM		1 - 12			Limit Status	LSt	always	12013
Operations	oPEr	Alarm x	ALM	always	1 - 16	always		Alarm Low Set Point	ALo	always	9002
Operations	oPEr	Alarm x	ALM		1 - 16			Alarm High Set Point	Ahi	always	9001
Operations	oPEr	Alarm x	ALM		1 - 16			Alarm Clear Request	ACLr	always	9026
Operations	oPEr	Alarm x	ALM		1 - 16			Alarm Silence Request	ASir	always	9027
Operations	oPEr	Alarm x	ALM		1 - 16			Alarm State	ASt	always	9009
Operations	oPEr	Linearization x	Lin	always	1 - 16	always		Source Value A	Su.A	always	34004
Operations	oPEr	Linearization x	Lin		1 - 16			Offset	oFSt	always	34006
Operations	oPEr	Linearization x	Lin		1 - 16			Output Value	ou	always	34007
Operations	oPEr	Compare x	CPE	always	1 - 16	always		Source Value A	Su.A	always	28007
Operations	oPEr	Compare x	CPE		1 - 16			Source Value B	Su.b	always	28008
Operations	oPEr	Compare x	CPE		1 - 16			Output Value	ou	always	28010
Operations	oPEr	Timer x	tMr	always	1 - 16	always		Source Value A	Su.A	always	31007
Operations	oPEr	Timer x	tMr		1 - 16			Source Value B	Su.b	always	31008
Operations	oPEr	Timer x	tMr		1 - 16			Elapsed Time	Et	always	31016
Operations	oPEr	Timer x	tMr		1 - 16			Output Value	ou	always	31010
Operations	oPEr	Counter x	Ctr	always	1 - 16	always		Count	Cnt	always	30015
Operations	oPEr	Counter x	Ctr		1 - 16			Source Value A	Su.A	always	30007
Operations	oPEr	Counter x	Ctr		1 - 16			Source Value B	Su.b	always	30008
Operations	oPEr	Counter x	Ctr		1 - 16			Output Value	ou	always	30010
Operations	oPEr	Logic x	LgC	always	1 - 16	always		Source Value A	Su.A	always	27025
Operations	oPEr	Logic x	LgC		1 - 16			Source Value B	Su.b	always	27026
Operations	oPEr	Logic x	LgC		1 - 16			Source Value C	Su.C	always	27027
Operations	oPEr	Logic x	LgC		1 - 16			Source Value D	Su.d	always	27028
Operations	oPEr	Logic x	LgC		1 - 16			Source Value E	Su.E	always	27029
Operations	oPEr	Logic x	LgC		1 - 16			Source Value F	Su.F	always	27030
Operations	oPEr	Logic x	LgC		1 - 16			Source Value G	Su.g	always	27031
Operations	oPEr	Logic x	LgC		1 - 16			Source Value H	Su.h	always	27032
Operations	oPEr	Logic x	LgC		1 - 16			Output Value	ou	always	27034

EZ-ZONE RML Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Math x	MAtH	always	1 - 16	always		Source Value A	Su.A	always	25016
Operations	oPEr	Math x	MAtH		1 - 16			Source Value B	Su.b	always	25017
Operations	oPEr	Math x	MAtH		1 - 16			Source Value C	Su.C	always	25018
Operations	oPEr	Math x	MAtH		1 - 16			Source Value D	Su.d	always	25019
Operations	oPEr	Math x	MAtH		1 - 16			Source Value E	Su.E	always	25020
Operations	oPEr	Math x	MAtH		1 - 16			Offset	oFSt	always	25023
Operations	oPEr	Math x	MAtH		1 - 16			Output Value	ou	always	25022
Setup	SEt	Analog Input x	AI	always	1 - 12	Instance 1-4 = always Instance 5-8 if PN digit 6 = 5 or 6 Instance 9-12 if PN digit 7 = 5 or 6		Sensor Type	SEn	always	4005
Setup	SEt	Analog Input x	AI		1 - 12			TC Linearization	L in	Instance 1-4 if PN digit 5 = 5 Instance 5-8 if PN digit 6 = 5 Instance 9-12 if PN digit 7 = 5 { input is universal }	4006
Setup	SEt	Analog Input x	AI		1 - 12			Units	Unit		4042
Setup	SEt	Analog Input x	AI		1 - 12			Scale Low	S.Lo		4015
Setup	SEt	Analog Input x	AI		1 - 12			Scale High	S.h i		4016
Setup	SEt	Analog Input x	AI		1 - 12			Range Low	r.Lo		4017
Setup	SEt	Analog Input x	AI		1 - 12			Range High	r.h i		4018
Setup	SEt	Analog Input x	AI		1 - 12			Process Error Enable	PEE		4030
Setup	SEt	Analog Input x	AI		1 - 12			Process Error Low Value	PEL		4031
Setup	SEt	Analog Input x	AI		1 - 12			Thermistor Curve	t.C	Instance 1-4 if PN digit 5 = 6 Instance 5-8 if PN digit 6 = 6 Instance 9-12 if PN digit 7 = 6 { input is thermistor }	4038
Setup	SEt	Analog Input x	AI		1 - 12			Resistance Range	r.r		4037
Setup	SEt	Analog Input x	AI		1 - 12			Filter	F iL	always	4014
Setup	SEt	Analog Input x	AI		1 - 12			Input Error Latching	iEr	always	4028
Setup	SEt	Analog Input x	AI		1 - 12			Display Precision	dEC	always	4020
Setup	SEt	Analog Input x	AI		1 - 12			Calibration Offset	iCA	always	4012
Setup	SEt	Analog Input x	AI		1 - 12			Analog Input Value	A in	always	4001
Setup	SEt	Analog Input x	AI		1 - 12			Input Error	iEr	always	4002
Setup	SEt	Digital I/O x	dIO	If PN digit 7 = C or PN digit 8 = B	1 - 6,9	Instance 1-6 if PN digit 7 = C Instance 9 if PN digit 8 = B		Digital I/O Direction	dir	always	6001
Setup	SEt	Digital I/O x	dIO		1 - 6,9			Output Function	Fn	always	6005
Setup	SEt	Digital I/O x	dIO		1 - 6,9			Output Function Instance	F i	always	6006
Setup	SEt	Digital I/O x	dIO		1 - 6,9			Output Source Zone A	o.Ct	always	6012
Setup	SEt	Digital I/O x	dIO		1 - 6,9			Output Control	o.tb	always	6002
Setup	SEt	Digital I/O x	dIO		1 - 6,9			Output Time Base	o.Lo	always	6003
Setup	SEt	Digital I/O x	dIO		1 - 6,9			Output Low Power Scale	o.h i	always	6009
Setup	SEt	Digital I/O x	dIO		1 - 6,9			Output High Power Scale	LEu	always	6010
Setup	SEt	Action x	ACt	always	1 - 16	always		Action Function	Fn	always	10003
Setup	SEt	Action x	ACt		1 - 16			Function Instance	F i	always	10004
Setup	SEt	Action x	ACt		1 - 16			Source Function A	SFnA	always	10006
Setup	SEt	Action x	ACt		1 - 16			Source Instance A	S iA	always	10002
Setup	SEt	Action x	ACt		1 - 16			Source Zone A	S2A	always	10007
Setup	SEt	Action x	ACt		1 - 16			Active Level	LEu	always	10001
Setup	SEt	Limit x	LIM		1 - 12			Limit Sides	LSd	always	12005
Setup	SEt	Limit x	LIM		1 - 12			Limit Hysteresis	LhY	always	12002
Setup	SEt	Limit x	LIM		1 - 12			Set Point High Limit	SPLh	always	12009

EZ-ZONE RML Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Limit x	LIM7	always	1 - 12	Instance 1-4 = always Instance 5-8 if PN digit 6 = 5 or 6 Instance 9-12 if PN digit 7 = 5 or 6		Set Point Low Limit	SPLL	always	12010
Setup	SEt	Limit x	LIM7		1 - 12			Limit High Set Point	Lh.S	always	12004
Setup	SEt	Limit x	LIM7		1 - 12			Limit Low Set Point	LL.S	always	12003
Setup	SEt	Limit x	LIM7		1 - 12			Source Function A	SFn.A	always	12015
Setup	SEt	Limit x	LIM7		1 - 12			Source Instance A	S1.A	always	12016
Setup	SEt	Limit x	LIM7		1 - 12			Source Zone A	S2.A	always	12017
Setup	SEt	Limit x	LIM7		1 - 12			Limit Clear Request	LCr	always	12014
Setup	SEt	Limit x	LIM7		1 - 12			Limit Status	LSt	always	12013
Setup	SEt	Output x	OtPt	always	1 - 4, 7-10	Instance 1-4 if PN digit 7 = J Instance 7-8 if PN digit 8 = B or J Instance 9-10 if PN digit 8 = J		Output Function	Fn	always	6005
Setup	SEt	Output x	OtPt		1 - 4, 7-10			Output Function Instance	F1	always	6006
Setup	SEt	Output x	OtPt		1 - 4, 7-10			Output Source Zone	S2.A	always	6012
Setup	SEt	Output x	OtPt		1 - 4, 7-10			Output Control	oCt	always	6002
Setup	SEt	Output x	OtPt		1 - 4, 7-10			Output Time Base	otb	always	6003
Setup	SEt	Output x	OtPt		1 - 4, 7-10			Output Low Power Scale	oLo	always	6009
Setup	SEt	Output x	OtPt		1 - 4, 7-10			Output High Power Scale	oh1	always	6010
Setup	SEt	Alarm x	ALM7	always	1 - 16	always		Alarm Type	AtY	always	9015
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm Source	Sr.A	always	9017
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm Source Instance	1S.A	always	9018
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm Source Zone	S2.A	always	9025
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm Hysteresis	AhY	always	9003
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm Logic	AtY	always	9005
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm Sides	ASd	always	9004
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm Low Set Point	ALo	always	9002
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm High Set Point	Ah1	always	9001
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm Latching	ALA	always	9007
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm Blocking	AbL	always	9008
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm Silencing	AS1	always	9006
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm Display	AdSP	always	9016
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm Delay Time	AdL	always	9021
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm Clear Request	AClr	always	9026
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm Silence	ASir	always	9027
Setup	SEt	Alarm x	ALM7		1 - 16			Alarm State	ASt	always	9009
Setup	SEt	Linearization x	Lin	always	1 - 16	always		Function	Fn	always	34005
Setup	SEt	Linearization x	Lin		1 - 16			Source Function A	SFn.A	always	34001
Setup	SEt	Linearization x	Lin		1 - 16			Source Instance A	S1.A	always	34002
Setup	SEt	Linearization x	Lin		1 - 16			Source Zone A	S2.A	always	34003
Setup	SEt	Linearization x	Lin		1 - 16			Units	Unit	always	34029
Setup	SEt	Linearization x	Lin		1 - 16			Input Point 1	iP.1	always	34008
Setup	SEt	Linearization x	Lin		1 - 16			Output Point 1	oP.1	always	34018
Setup	SEt	Linearization x	Lin		1 - 16			Input Point 2	iP.2	always	34009
Setup	SEt	Linearization x	Lin		1 - 16			Output Point 2	oP.2	always	34019
Setup	SEt	Linearization x	Lin		1 - 16			Input Point 3	iP.3	always	34010
Setup	SEt	Linearization x	Lin		1 - 16			Output Point 3	oP.3	always	34020
Setup	SEt	Linearization x	Lin		1 - 16			Input Point 4	iP.4	always	34011

EZ-ZONE RML Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Linearization x	L in	always	1 - 16	always		Output Point 4	oP.4	always	34021
Setup	SEt	Linearization x	L in		1 - 16			Input Point 5	iP.5	always	34012
Setup	SEt	Linearization x	L in		1 - 16			Output Point 5	oP.5	always	34022
Setup	SEt	Linearization x	L in		1 - 16			Input Point 6	iP.6	always	34013
Setup	SEt	Linearization x	L in		1 - 16			Output Point 6	oP.6	always	34023
Setup	SEt	Linearization x	L in		1 - 16			Input Point 7	iP.7	always	34014
Setup	SEt	Linearization x	L in		1 - 16			Output Point 7	oP.7	always	34024
Setup	SEt	Linearization x	L in		1 - 16			Input Point 8	iP.8	always	34015
Setup	SEt	Linearization x	L in		1 - 16			Output Point 8	oP.8	always	34025
Setup	SEt	Linearization x	L in		1 - 16			Input Point 9	iP.9	always	34016
Setup	SEt	Linearization x	L in		1 - 16			Output Point 9	oP.9	always	34026
Setup	SEt	Linearization x	L in		1 - 16			Input Point 10	iP.10	always	34017
Setup	SEt	Linearization x	L in		1 - 16			Output Point 10	oP.10	always	34027
Setup	SEt	Compare x	CPE	always	1 - 16	always		Function	Fn	always	28009
Setup	SEt	Compare x	CPE		1 - 16			Tolerance	tol	always	28011
Setup	SEt	Compare x	CPE		1 - 16			Source Function A	SFn.A	always	28001
Setup	SEt	Compare x	CPE		1 - 16			Source Instance A	S i.A	always	28003
Setup	SEt	Compare x	CPE		1 - 16			Source Zone A	S2.A	always	28005
Setup	SEt	Compare x	CPE		1 - 16			Source Function B	SFn.b	always	28002
Setup	SEt	Compare x	CPE		1 - 16			Source Instance B	S i.b	always	28004
Setup	SEt	Compare x	CPE		1 - 16			Source Zone B	S2.b	always	28006
Setup	SEt	Compare x	CPE		1 - 16			Error Handling	Er.h	always	28012
Setup	SEt	Timer x	tMr	always	1 - 16	always		Function	Fn	always	31009
Setup	SEt	Timer x	tMr		1 - 16			Source Function A	SFn.A	always	31001
Setup	SEt	Timer x	tMr		1 - 16			Source Instance A	S i.A	always	31003
Setup	SEt	Timer x	tMr		1 - 16			Source Zone A	S2.A	always	31005
Setup	SEt	Timer x	tMr		1 - 16			Source Active State A	SAS.A	always	31011
Setup	SEt	Timer x	tMr		1 - 16			Source Function B	SFn.b	always	31002
Setup	SEt	Timer x	tMr		1 - 16			Source Instance B	S i.b	always	31004
Setup	SEt	Timer x	tMr		1 - 16			Source Zone B	S2.b	always	31006
Setup	SEt	Timer x	tMr		1 - 16			Source Active State B	SAS.b	always	31012
Setup	SEt	Timer x	tMr		1 - 16			Time	t i	always	31013
Setup	SEt	Timer x	tMr		1 - 16			Active Level	LEu	always	31014
Setup	SEt	Counter x	Ctr	always	1 - 16	always		Function	Fn	always	30009
Setup	SEt	Counter x	Ctr		1 - 16			Source Function A	SFn.A	always	30001
Setup	SEt	Counter x	Ctr		1 - 16			Source Instance A	S i.A	always	30003
Setup	SEt	Counter x	Ctr		1 - 16			Source Zone A	S2.A	always	30005
Setup	SEt	Counter x	Ctr		1 - 16			Source Active State A	SAS.A	always	30011
Setup	SEt	Counter x	Ctr		1 - 16			Source Function B	SFn.b	always	30002
Setup	SEt	Counter x	Ctr		1 - 16			Source Instance B	S i.b	always	30004
Setup	SEt	Counter x	Ctr		1 - 16			Source Zone B	S2.b	always	30006
Setup	SEt	Counter x	Ctr		1 - 16			Source Active State B	SAS.b	always	30012
Setup	SEt	Counter x	Ctr		1 - 16			Load Value	LoAd	always	30013
Setup	SEt	Counter x	Ctr		1 - 16			Target Value	trgt	always	30014

EZ-ZONE RML Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Counter x	Ctr		1 - 16			Latching	LAt	always	30017
Setup	SEt	Logic x	LGC		1 - 16			Function	Fn	always	27033
Setup	SEt	Logic x	LGC		1 - 16			Source Function A	SFn.A	always	27001
Setup	SEt	Logic x	LGC		1 - 16			Source Instance A	S .A	always	27009
Setup	SEt	Logic x	LGC		1 - 16			Source Zone A	S2.A	always	27017
Setup	SEt	Logic x	LGC		1 - 16			Source Function B	SFn.b	always	27002
Setup	SEt	Logic x	LGC		1 - 16			Source Instance B	S .b	always	27010
Setup	SEt	Logic x	LGC		1 - 16			Source Zone B	S2.b	always	27018
Setup	SEt	Logic x	LGC		1 - 16			Source Function C	SFn.C	always	27003
Setup	SEt	Logic x	LGC		1 - 16			Source Instance C	S .C	always	27011
Setup	SEt	Logic x	LGC		1 - 16			Source Zone C	S2.C	always	27019
Setup	SEt	Logic x	LGC		1 - 16			Source Function D	SFn.d	always	27004
Setup	SEt	Logic x	LGC		1 - 16			Source Instance D	S .d	always	27012
Setup	SEt	Logic x	LGC		1 - 16			Source Zone D	S2.d	always	27020
Setup	SEt	Logic x	LGC	always	1 - 16	always		Source Function E	SFn.E	always	27005
Setup	SEt	Logic x	LGC		1 - 16			Source Instance E	S .E	always	27013
Setup	SEt	Logic x	LGC		1 - 16			Source Zone E	S2.E	always	27021
Setup	SEt	Logic x	LGC		1 - 16			Source Function F	SFn.F	always	27006
Setup	SEt	Logic x	LGC		1 - 16			Source Instance F	S .F	always	27014
Setup	SEt	Logic x	LGC		1 - 16			Source Zone F	S2.F	always	27022
Setup	SEt	Logic x	LGC		1 - 16			Source Function G	SFn.9	always	27007
Setup	SEt	Logic x	LGC		1 - 16			Source Instance G	S .9	always	27015
Setup	SEt	Logic x	LGC		1 - 16			Source Zone G	S2.9	always	27023
Setup	SEt	Logic x	LGC		1 - 16			Source Function H	SFn.h	always	27008
Setup	SEt	Logic x	LGC		1 - 16			Source Instance H	S .h	always	27016
Setup	SEt	Logic x	LGC		1 - 16			Source Zone H	S2.h	always	27024
Setup	SEt	Logic x	LGC		1 - 16			Error Handling	Erh	always	27035
Setup	SEt	Math x	MAt		1 - 16			Function	Fn	always	25021
Setup	SEt	Math x	MAt		1 - 16			Source Function A	SFn.A	always	25001
Setup	SEt	Math x	MAt		1 - 16			Source Instance A	S .A	always	25006
Setup	SEt	Math x	MAt		1 - 16			Source Zone A	S2.A	always	25011
Setup	SEt	Math x	MAt		1 - 16			Source Function B	SFn.b	always	25002
Setup	SEt	Math x	MAt		1 - 16			Source Instance B	S .b	always	25007
Setup	SEt	Math x	MAt		1 - 16			Source Zone B	S2.b	always	25012
Setup	SEt	Math x	MAt		1 - 16			Source Function C	SFn.C	always	25003
Setup	SEt	Math x	MAt		1 - 16			Source Instance C	S .C	always	25008
Setup	SEt	Math x	MAt		1 - 16			Source Zone C	S2.C	always	25013
Setup	SEt	Math x	MAt		1 - 16			Source Function D	SFn.d	always	25004
Setup	SEt	Math x	MAt		1 - 16			Source Instance D	S .d	always	25009
Setup	SEt	Math x	MAt	always	1 - 16	always		Source Zone D	S2.d	always	25014
Setup	SEt	Math x	MAt		1 - 16			Source Function E	SFn.E	always	25005
Setup	SEt	Math x	MAt		1 - 16			Source Instance E	S .E	always	25010
Setup	SEt	Math x	MAt		1 - 16			Source Zone E	S2.E	always	25015
Setup	SEt	Math x	MAt		1 - 16			Scale Low	SLo	always	25024
Setup	SEt	Math x	MAt		1 - 16			Scale High	Sh .	always	25025

EZ-ZONE RML Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Math x	MAtH		1 - 16			Units	Unit	always	25032
Setup	SEt	Math x	MAtH		1 - 16			Range Low	r.Lo	always	25026
Setup	SEt	Math x	MAtH		1 - 16			Range High	r.hi	always	25027
Setup	SEt	Math x	MAtH		1 - 16			Pressure Units	P.unt	always	25030
Setup	SEt	Math x	MAtH		1 - 16			Altitude Units	A.unt	always	25031
Setup	SEt	Math x	MAtH		1 - 16			Filter	F iL	always	25028
Setup	SEt	Variable x	uAr		1 - 16			Data Type	tYPE	always	2001
Setup	SEt	Variable x	uAr	always	1 - 16	always		Units	Unit	always	2007
Setup	SEt	Variable x	uAr		1 - 16			Digital	dig	always	2002
Setup	SEt	Variable x	uAr		1 - 16			Analog	AnLG	always	2003
Setup	SEt	Global 1	GLbL		1			Display Units	C_F	always	3005
Setup	SEt	Global 1	GLbL		1			AC Line Frequency	ACLF	always	1034
Setup	SEt	Global 1	GLbL	always	1	always		Display Pairs	dPrS	always	3028
Setup	SEt	Global 1	GLbL		1			User Settings Save	USr.S	always	1014
Setup	SEt	Global 1	GLbL		1			User Settings Restore	USr.r	always	1013
Setup	SEt	Communications 1	CoM		1			Baud Rate	bAUd	always	17002
Setup	SEt	Communications 1	CoM		1			Parity	PAr	always	17003
Setup	SEt	Communications 1	CoM	If PN digit 10 = 1	1	always		Modbus Word Order	MWhL	always	17043
Setup	SEt	Communications 1	CoM		1			Display Units	C_F	always	17050
Setup	SEt	Communications 1	CoM		1			Non-Volatile Save	nUS	always	17051
Factory	FCtY	Custom Setup x	CUSt	always	1 - 30	always		Parameter	PAr	always	14005
Factory	FCtY	Custom Setup x	CUSt		1 - 30			Instance ID	iid	always	14003
Factory	FCtY	Lock 1	LoC		1			Operations Page	LoCo	always	3002
Factory	FCtY	Lock 1	LoC		1			Password Enable	PASE	always	3015
Factory	FCtY	Lock 1	LoC		1			Read Lock	rLoC	always	3010
Factory	FCtY	Lock 1	LoC	If DspLockedState = PASS ADMIN	1	always		Write Security	SLoC	always	3011
Factory	FCtY	Lock 1	LoC		1			Locked Access Level	LoCL	always	3016
Factory	FCtY	Lock 1	LoC		1			Rolling Password	roLL	always	3019
Factory	FCtY	Lock 1	LoC		1			User Password	PAS.u	always	3017
Factory	FCtY	Lock 1	LoC		1			Administrator Password	PAS.A	always	3018
Factory	FCtY	Unlock	ULoC	If DspSecurityEnable == ON	1	always		Public Key	CodE	always	3020
Factory	FCtY	Unlock	ULoC		1			Password	PASS	always	3022
Factory	FCtY	Diagnostics 1	diAG		1			Part Number	Pn	always	1009
Factory	FCtY	Diagnostics 1	diAG		1			Software Revision	rEv	always	1017
Factory	FCtY	Diagnostics 1	diAG	always	1	always		Software Build Number	S.bLd	always	1005
Factory	FCtY	Diagnostics 1	diAG		1			Serial Number	Sn	always	1032
Factory	FCtY	Diagnostics 1	diAG		1			Date of Manufacture	dAtE	always	1008
Factory	FCtY	Calibration x	CAL		1 - 12	Instance 1-4 = always Instance 5-8 if PN digit 6 = 5 or 6		Electrical Measurement	MMu	always	4021
Factory	FCtY	Calibration x	CAL	always	1 - 12			Electrical Input Offset	EL io	always	4010

EZ-ZONE RML Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Factory	FCtY	Calibration x	CAL		1 - 12	Instance 9-12 if PN digit 7 = 5 or 6		Electrical Input Slope	EL.S	always	4011

EZ-ZONE RMS Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Analog Input x	A i	always	1 - 16	Instance 1-4 = always Instance 5-8 if PN digit 6 = R or P Instance 9-12 if PN digit 7 = R or P Instance 13-16 if PN digit 8 = R or P		Analog Input Value	A in	always	4001
Operations	oPEr	Analog Input x	A i		1 - 16			Input Error	i.Er	always	4002
Operations	oPEr	Analog Input x	A i		1 - 16			Calibration Offset	i.CA	always	4012
Operations	oPEr	Process Value x	Pu	always	1 - 16	Instance 1-4 = always Instance 5-8 if PN digit 6 = R or P Instance 9-12 if PN digit 7 = R or P Instance 13-16 if PN digit 8 = R or P		Source Value A	Su.A	always	26016
Operations	oPEr	Process Value x	Pu		1 - 16			Source Value B	Su.b	always	26017
Operations	oPEr	Process Value x	Pu		1 - 16			Source Value C	Su.C	always	26018
Operations	oPEr	Process Value x	Pu		1 - 16			Source Value D	Su.d	always	26019
Operations	oPEr	Process Value x	Pu		1 - 16			Source Value E	Su.E	always	26020
Operations	oPEr	Process Value x	Pu		1 - 16			Offset	oFSt	always	26023
Operations	oPEr	Process Value x	Pu		1 - 16			Output Value	o.u	always	26022
Operations	oPEr	Digital I/O x	d io	If PN digit 7 = C or digit 8 = B or C	1-12	Instance 1-6 if PN digit 7 = C Instance 7-8 if PN digit 8 = C Instance 9 if PN digit 8 = B or C Instance 10-12 if PN digit 8 = C		Output State	do.S	always	6007
Operations	oPEr	Digital I/O x	d io		1-12			Input State	d i.S	always	6011
Operations	oPEr	Action x	ACt	always	1 - 16	always		Event Status	E i.S	always	10005
Operations	oPEr	Alarm x	ALM	always	1 - 16	always		Alarm Low Set Point	A.Lo	always	9002
Operations	oPEr	Alarm x	ALM		1 - 16			Alarm High Set Point	A.h i	always	9001
Operations	oPEr	Alarm x	ALM		1 - 16			Alarm Clear Request	A.CLr	always	9026
Operations	oPEr	Alarm x	ALM		1 - 16			Alarm Silence Request	A.S ir	always	9027
Operations	oPEr	Alarm x	ALM		1 - 16			Alarm State	A.St	always	9009
Operations	oPEr	Linearization x	Lin	always	1 - 24	always		Source Value A	Su.A	always	34004
Operations	oPEr	Linearization x	Lin		1 - 24			Offset	oFSt	always	34006
Operations	oPEr	Linearization x	Lin		1 - 24			Output Value	o.u	always	34007
Operations	oPEr	Compare x	CPE	always	1 - 24	always		Source Value A	Su.A	always	28007
Operations	oPEr	Compare x	CPE		1 - 24			Source Value B	Su.b	always	28008
Operations	oPEr	Compare x	CPE		1 - 24			Output Value	o.u	always	28010
Operations	oPEr	Timer x	tMr	always	1 - 24	always		Source Value A	Su.A	always	31007
Operations	oPEr	Timer x	tMr		1 - 24			Source Value B	Su.b	always	31008
Operations	oPEr	Timer x	tMr		1 - 24			Elapsed Time	Et	always	31016
Operations	oPEr	Timer x	tMr		1 - 24			Output Value	o.u	always	31010
Operations	oPEr	Counter x	Ctr	always	1 - 24	always		Count	Cnt	always	30015
Operations	oPEr	Counter x	Ctr		1 - 24			Source Value A	Su.A	always	30007
Operations	oPEr	Counter x	Ctr		1 - 24			Source Value B	Su.b	always	30008
Operations	oPEr	Counter x	Ctr		1 - 24			Output Value	o.u	always	30010
Operations	oPEr	Logic x	LGC	always	1 - 24	always		Source Value A	Su.A	always	27025
Operations	oPEr	Logic x	LGC		1 - 24			Source Value B	Su.b	always	27026
Operations	oPEr	Logic x	LGC		1 - 24			Source Value C	Su.C	always	27027
Operations	oPEr	Logic x	LGC		1 - 24			Source Value D	Su.d	always	27028
Operations	oPEr	Logic x	LGC		1 - 24			Source Value E	Su.E	always	27029

EZ-ZONE RMS Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Operations	oPEr	Logic x	LGC		1 - 24			Source Value F	Su.F	always	27030
Operations	oPEr	Logic x	LGC		1 - 24			Source Value G	Su.G	always	27031
Operations	oPEr	Logic x	LGC		1 - 24			Source Value H	Su.h	always	27032
Operations	oPEr	Logic x	LGC		1 - 24			Output Value	o.u	always	27034
Operations	oPEr	Math x	MAt		1 - 24			Source Value A	Su.A	always	25016
Operations	oPEr	Math x	MAt		1 - 24			Source Value B	Su.b	always	25017
Operations	oPEr	Math x	MAt		1 - 24			Source Value C	Su.C	always	25018
Operations	oPEr	Math x	MAt	always	1 - 24	always		Source Value D	Su.d	always	25019
Operations	oPEr	Math x	MAt		1 - 24			Source Value E	Su.E	always	25020
Operations	oPEr	Math x	MAt		1 - 24			Offset	oFSt	always	25023
Operations	oPEr	Math x	MAt		1 - 24			Output Value	o.u	always	25022
Setup	SEt	Analog Input x	Ai		1 - 16			Sensor Type	SEn	always	4005
Setup	SEt	Analog Input x	Ai		1 - 16			TC Linearization	Lin	Instance 1-4 if PN digit 5 = R Instance 5-8 if PN digit 6 = R Instance 9-12 if PN digit 7 = R Instance 13-16 if PN digit 8 = R { input is universal }	4006
Setup	SEt	Analog Input x	Ai		1 - 16			Units	Unit		4042
Setup	SEt	Analog Input x	Ai		1 - 16			Scale Low	SLo		4015
Setup	SEt	Analog Input x	Ai		1 - 16			Scale High	Sh i		4016
Setup	SEt	Analog Input x	Ai		1 - 16			Range Low	rLo		4017
Setup	SEt	Analog Input x	Ai		1 - 16			Range High	rh i		4018
Setup	SEt	Analog Input x	Ai		1 - 16			Process Error Enable	PEE		4030
Setup	SEt	Analog Input x	Ai		1 - 16	Instance 1-4 = always Instance 5-8 if PN digit 6 = R or P Instance 9-12 if PN digit 7 = R or P Instance 13-16 if PN digit 8 = R or P		Process Error Low Value	PEL		4031
Setup	SEt	Analog Input x	Ai	always	1 - 16			Thermistor Curve	tC	Instance 1-4 if PN digit 5 = P Instance 5-8 if PN digit 6 = P Instance 9-12 if PN digit 7 = P Instance 13-16 if PN digit 8 = P { input is thermistor }	4038
Setup	SEt	Analog Input x	Ai		1 - 16			Resistance Range	rr		4037
Setup	SEt	Analog Input x	Ai		1 - 16			Filter	FiL	always	4014
Setup	SEt	Analog Input x	Ai		1 - 16			Input Error Latching	iEr	always	4028
Setup	SEt	Analog Input x	Ai		1 - 16			Display Precision	dEC	always	4020
Setup	SEt	Analog Input x	Ai		1 - 16			Calibration Offset	iCA	always	4012
Setup	SEt	Analog Input x	Ai		1 - 16			Analog Input Value	Ain	always	4001
Setup	SEt	Analog Input x	Ai		1 - 16			Input Error	iEr	always	4002
Setup	SEt	Process Value x	Pu		1 - 16			Function	Fn	always	26021
Setup	SEt	Process Value x	Pu		1 - 16			Source Function A	SFnA	always	26001
Setup	SEt	Process Value x	Pu		1 - 16			Source Instance A	S iA	always	26006
Setup	SEt	Process Value x	Pu		1 - 16			Source Function B	SFnb	always	26002
Setup	SEt	Process Value x	Pu		1 - 16			Source Instance B	S ib	always	26007
Setup	SEt	Process Value x	Pu		1 - 16			Source Zone B	S2.b	always	26012
Setup	SEt	Process Value x	Pu		1 - 16			Source Function C	SFnC	always	26003
Setup	SEt	Process Value x	Pu		1 - 16			Source Instance C	S iC	always	26008
Setup	SEt	Process Value x	Pu		1 - 16			Source Zone C	S2.C	always	26013
Setup	SEt	Process Value x	Pu		1 - 16	Instance 1-4 = always Instance 5-8 if PN digit 6 = R or P Instance 9-12 if PN digit 7 = R or P Instance 13-16 if PN digit 8 = R or P		Source Function D	SFnd	always	26004
Setup	SEt	Process Value x	Pu	always	1 - 16			Source Instance D	S id	always	26009
Setup	SEt	Process Value x	Pu		1 - 16			Source Zone D	S2.d	always	26014
Setup	SEt	Process Value x	Pu		1 - 16			Source Function E	SFnE	always	26005
Setup	SEt	Process Value x	Pu		1 - 16			Source Instance E	S iE	always	26010

EZ-ZONE RMS Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Process Value x	Pu		1 - 16			Source Zone E	S2.E	always	26015
Setup	SEt	Process Value x	Pu		1 - 16			Cross Over Point	C.P	always	26024
Setup	SEt	Process Value x	Pu		1 - 16			Cross Over Band	C.b	always	26025
Setup	SEt	Process Value x	Pu		1 - 16			Pressure Units	P.unt	always	26028
Setup	SEt	Process Value x	Pu		1 - 16			Altitude Units	A.unt	always	26029
Setup	SEt	Process Value x	Pu		1 - 16			Barometric Pressure	b.Pr	always	26030
Setup	SEt	Process Value x	Pu		1 - 16			Filter	F iL	always	26026
Setup	SEt	Digital I/O x	d io		1-12			Digital I/O Direction	dir	always	6001
Setup	SEt	Digital I/O x	d io		1-12			Output Function	Fn	always	6005
Setup	SEt	Digital I/O x	d io		1-12	Instance 1-6 if PN digit 7 = C		Output Function Instance	F i	always	6006
Setup	SEt	Digital I/O x	d io	If PN digit 7 = C or digit 8 = B or C	1-12	Instance 7-8 if PN digit 8 = C		Output Source Zone A	o.Ct	always	6012
Setup	SEt	Digital I/O x	d io		1-12	Instance 9 if PN digit 8 = B or C		Output Control	o.tb	always	6002
Setup	SEt	Digital I/O x	d io		1-12	Instance 10-12 if PN digit 8 = C		Output Time Base	o.Lo	always	6003
Setup	SEt	Digital I/O x	d io		1-12			Output Low Power Scale	o.hi	always	6009
Setup	SEt	Digital I/O x	d io		1-12			Output High Power Scale	LEu	always	6010
Setup	SEt	Action x	ACt		1 - 16			Action Function	Fn	always	10003
Setup	SEt	Action x	ACt		1 - 16			Function Instance	F i	always	10004
Setup	SEt	Action x	ACt	always	1 - 16	always		Source Function A	SFn.A	always	10006
Setup	SEt	Action x	ACt		1 - 16			Source Instance A	S i.A	always	10002
Setup	SEt	Action x	ACt		1 - 16			Source Zone A	S2.A	always	10007
Setup	SEt	Action x	ACt		1 - 16			Active Level	LEu	always	10001
Setup	SEt	Output x	OtPt		1 - 4, 7-10			Output Function	Fn	always	6005
Setup	SEt	Output x	OtPt		1 - 4, 7-10			Output Function Instance	F i	always	6006
Setup	SEt	Output x	OtPt		1 - 4, 7-10	Instance 1-4 if PN digit 7 = J		Output Source Zone	S2.A	always	6012
Setup	SEt	Output x	OtPt	If PN digit 7 = J or digit 8 = B or J	1 - 4, 7-10	Instance 7-8 if PN digit 8 = B or J		Output Control	o.Ct	always	6002
Setup	SEt	Output x	OtPt		1 - 4, 7-10	Instance 9-10 if PN digit 8 = J		Output Time Base	o.tb	always	6003
Setup	SEt	Output x	OtPt		1 - 4, 7-10			Output Low Power Scale	o.Lo	always	6009
Setup	SEt	Output x	OtPt		1 - 4, 7-10			Output High Power Scale	o.hi	always	6010
Setup	SEt	Alarm x	ALM1		1 - 16			Alarm Type	A.tY	always	9015
Setup	SEt	Alarm x	ALM1		1 - 16			Alarm Source	Sr.A	always	9017
Setup	SEt	Alarm x	ALM1		1 - 16			Alarm Source Instance	iS.A	always	9018
Setup	SEt	Alarm x	ALM1		1 - 16			Alarm Source Zone	S2.A	always	9025
Setup	SEt	Alarm x	ALM1		1 - 16			Alarm Hysteresis	A.hY	always	9003
Setup	SEt	Alarm x	ALM1		1 - 16			Alarm Logic	A.Lg	always	9005
Setup	SEt	Alarm x	ALM1		1 - 16			Alarm Sides	A.Sd	always	9004
Setup	SEt	Alarm x	ALM1		1 - 16			Alarm Low Set Point	A.Lo	always	9002
Setup	SEt	Alarm x	ALM1	always	1 - 16	always		Alarm High Set Point	A.hi	always	9001
Setup	SEt	Alarm x	ALM1		1 - 16			Alarm Latching	A.LA	always	9007
Setup	SEt	Alarm x	ALM1		1 - 16			Alarm Blocking	A.bL	always	9008
Setup	SEt	Alarm x	ALM1		1 - 16			Alarm Silencing	A.Si	always	9006
Setup	SEt	Alarm x	ALM1		1 - 16			Alarm Display	A.dSP	always	9016
Setup	SEt	Alarm x	ALM1		1 - 16			Alarm Delay Time	A.dL	always	9021
Setup	SEt	Alarm x	ALM1		1 - 16			Alarm Clear Request	A.CLr	always	9026

EZ-ZONE RMS Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Alarm x	ALM		1 - 16			Alarm Silence	A.S ir	always	9027
Setup	SEt	Alarm x	ALM		1 - 16			Alarm State	A.St	always	9009
Setup	SEt	Linearization x	Lin		1 - 24			Function	Fn	always	34005
Setup	SEt	Linearization x	Lin		1 - 24			Source Function A	SFn.A	always	34001
Setup	SEt	Linearization x	Lin		1 - 24			Source Instance A	S i.A	always	34002
Setup	SEt	Linearization x	Lin		1 - 24			Source Zone A	S2.A	always	34003
Setup	SEt	Linearization x	Lin		1 - 24			Units	Unit	always	34029
Setup	SEt	Linearization x	Lin		1 - 24			Input Point 1	iP.1	always	34008
Setup	SEt	Linearization x	Lin		1 - 24			Output Point 1	oP.1	always	34018
Setup	SEt	Linearization x	Lin		1 - 24			Input Point 2	iP.2	always	34009
Setup	SEt	Linearization x	Lin		1 - 24			Output Point 2	oP.2	always	34019
Setup	SEt	Linearization x	Lin		1 - 24			Input Point 3	iP.3	always	34010
Setup	SEt	Linearization x	Lin		1 - 24			Output Point 3	oP.3	always	34020
Setup	SEt	Linearization x	Lin		1 - 24			Input Point 4	iP.4	always	34011
Setup	SEt	Linearization x	Lin	always	1 - 24	always		Output Point 4	oP.4	always	34021
Setup	SEt	Linearization x	Lin		1 - 24			Input Point 5	iP.5	always	34012
Setup	SEt	Linearization x	Lin		1 - 24			Output Point 5	oP.5	always	34022
Setup	SEt	Linearization x	Lin		1 - 24			Input Point 6	iP.6	always	34013
Setup	SEt	Linearization x	Lin		1 - 24			Output Point 6	oP.6	always	34023
Setup	SEt	Linearization x	Lin		1 - 24			Input Point 7	iP.7	always	34014
Setup	SEt	Linearization x	Lin		1 - 24			Output Point 7	oP.7	always	34024
Setup	SEt	Linearization x	Lin		1 - 24			Input Point 8	iP.8	always	34015
Setup	SEt	Linearization x	Lin		1 - 24			Output Point 8	oP.8	always	34025
Setup	SEt	Linearization x	Lin		1 - 24			Input Point 9	iP.9	always	34016
Setup	SEt	Linearization x	Lin		1 - 24			Output Point 9	oP.9	always	34026
Setup	SEt	Linearization x	Lin		1 - 24			Input Point 10	iP.10	always	34017
Setup	SEt	Linearization x	Lin		1 - 24			Output Point 10	oP.10	always	34027
Setup	SEt	Compare x	CPE		1 - 24			Function	Fn	always	28009
Setup	SEt	Compare x	CPE		1 - 24			Tolerance	tol	always	28011
Setup	SEt	Compare x	CPE		1 - 24			Source Function A	SFn.A	always	28001
Setup	SEt	Compare x	CPE		1 - 24			Source Instance A	S i.A	always	28003
Setup	SEt	Compare x	CPE	always	1 - 24	always		Source Zone A	S2.A	always	28005
Setup	SEt	Compare x	CPE		1 - 24			Source Function B	SFn.b	always	28002
Setup	SEt	Compare x	CPE		1 - 24			Source Instance B	S i.b	always	28004
Setup	SEt	Compare x	CPE		1 - 24			Source Zone B	S2.b	always	28006
Setup	SEt	Compare x	CPE		1 - 24			Error Handling	Er.h	always	28012
Setup	SEt	Timer x	tMr		1 - 24			Function	Fn	always	31009
Setup	SEt	Timer x	tMr		1 - 24			Source Function A	SFn.A	always	31001
Setup	SEt	Timer x	tMr		1 - 24			Source Instance A	S i.A	always	31003
Setup	SEt	Timer x	tMr		1 - 24			Source Zone A	S2.A	always	31005
Setup	SEt	Timer x	tMr		1 - 24			Source Active State A	SAS.A	always	31011
Setup	SEt	Timer x	tMr	always	1 - 24	always		Source Function B	SFn.b	always	31002
Setup	SEt	Timer x	tMr		1 - 24			Source Instance B	S i.b	always	31004
Setup	SEt	Timer x	tMr		1 - 24			Source Zone B	S2.b	always	31006

EZ-ZONE RMS Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Timer x	tMr		1 - 24			Source Active State B	SAS.b	always	31012
Setup	SEt	Timer x	tMr		1 - 24			Time	t i	always	31013
Setup	SEt	Timer x	tMr		1 - 24			Active Level	LEu	always	31014
Setup	SEt	Counter x	Ctr		1 - 24			Function	Fn	always	30009
Setup	SEt	Counter x	Ctr		1 - 24			Source Function A	SFn.A	always	30001
Setup	SEt	Counter x	Ctr		1 - 24			Source Instance A	S i.A	always	30003
Setup	SEt	Counter x	Ctr		1 - 24			Source Zone A	S2.A	always	30005
Setup	SEt	Counter x	Ctr		1 - 24			Source Active State A	SAS.A	always	30011
Setup	SEt	Counter x	Ctr		1 - 24			Source Function B	SFn.b	always	30002
Setup	SEt	Counter x	Ctr	always	1 - 24	always		Source Instance B	S i.b	always	30004
Setup	SEt	Counter x	Ctr		1 - 24			Source Zone B	S2.b	always	30006
Setup	SEt	Counter x	Ctr		1 - 24			Source Active State B	SAS.b	always	30012
Setup	SEt	Counter x	Ctr		1 - 24			Load Value	LoAd	always	30013
Setup	SEt	Counter x	Ctr		1 - 24			Target Value	tr9t	always	30014
Setup	SEt	Counter x	Ctr		1 - 24			Latching	LAt	always	30017
Setup	SEt	Logic x	LgC		1 - 24			Function	Fn	always	27033
Setup	SEt	Logic x	LgC		1 - 24			Source Function A	SFn.A	always	27001
Setup	SEt	Logic x	LgC		1 - 24			Source Instance A	S i.A	always	27009
Setup	SEt	Logic x	LgC		1 - 24			Source Zone A	S2.A	always	27017
Setup	SEt	Logic x	LgC		1 - 24			Source Function B	SFn.b	always	27002
Setup	SEt	Logic x	LgC		1 - 24			Source Instance B	S i.b	always	27010
Setup	SEt	Logic x	LgC		1 - 24			Source Zone B	S2.b	always	27018
Setup	SEt	Logic x	LgC		1 - 24			Source Function C	SFn.C	always	27003
Setup	SEt	Logic x	LgC		1 - 24			Source Instance C	S i.C	always	27011
Setup	SEt	Logic x	LgC		1 - 24			Source Zone C	S2.C	always	27019
Setup	SEt	Logic x	LgC		1 - 24			Source Function D	SFn.d	always	27004
Setup	SEt	Logic x	LgC		1 - 24			Source Instance D	S i.d	always	27012
Setup	SEt	Logic x	LgC	always	1 - 24	always		Source Zone D	S2.d	always	27020
Setup	SEt	Logic x	LgC		1 - 24			Source Function E	SFn.E	always	27005
Setup	SEt	Logic x	LgC		1 - 24			Source Instance E	S i.E	always	27013
Setup	SEt	Logic x	LgC		1 - 24			Source Zone E	S2.E	always	27021
Setup	SEt	Logic x	LgC		1 - 24			Source Function F	SFn.F	always	27006
Setup	SEt	Logic x	LgC		1 - 24			Source Instance F	S i.F	always	27014
Setup	SEt	Logic x	LgC		1 - 24			Source Zone F	S2.F	always	27022
Setup	SEt	Logic x	LgC		1 - 24			Source Function G	SFn.9	always	27007
Setup	SEt	Logic x	LgC		1 - 24			Source Instance G	S i.9	always	27015
Setup	SEt	Logic x	LgC		1 - 24			Source Zone G	S2.9	always	27023
Setup	SEt	Logic x	LgC		1 - 24			Source Function H	SFn.h	always	27008
Setup	SEt	Logic x	LgC		1 - 24			Source Instance H	S i.h	always	27016
Setup	SEt	Logic x	LgC		1 - 24			Source Zone H	S2.h	always	27024
Setup	SEt	Logic x	LgC		1 - 24			Error Handling	Er.h	always	27035
Setup	SEt	Math x	MAtH		1 - 24			Function	Fn	always	25021
Setup	SEt	Math x	MAtH		1 - 24			Source Function A	SFn.A	always	25001
Setup	SEt	Math x	MAtH		1 - 24			Source Instance A	S i.A	always	25006

EZ-ZONE RMS Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Setup	SEt	Math x	mAt	always	1 - 24	always		Source Zone A	S2.A	always	25011
Setup	SEt	Math x	mAt		1 - 24			Source Function B	SFn.b	always	25002
Setup	SEt	Math x	mAt		1 - 24			Source Instance B	S .b	always	25007
Setup	SEt	Math x	mAt		1 - 24			Source Zone B	S2.b	always	25012
Setup	SEt	Math x	mAt		1 - 24			Source Function C	SFn.C	always	25003
Setup	SEt	Math x	mAt		1 - 24			Source Instance C	S .C	always	25008
Setup	SEt	Math x	mAt		1 - 24			Source Zone C	S2.C	always	25013
Setup	SEt	Math x	mAt		1 - 24			Source Function D	SFn.d	always	25004
Setup	SEt	Math x	mAt		1 - 24			Source Instance D	S .d	always	25009
Setup	SEt	Math x	mAt		1 - 24			Source Zone D	S2.d	always	25014
Setup	SEt	Math x	mAt		1 - 24			Source Function E	SFn.E	always	25005
Setup	SEt	Math x	mAt		1 - 24			Source Instance E	S .E	always	25010
Setup	SEt	Math x	mAt		1 - 24			Source Zone E	S2.E	always	25015
Setup	SEt	Math x	mAt		1 - 24			Scale Low	S.Lo	always	25024
Setup	SEt	Math x	mAt		1 - 24			Scale High	S.h i	always	25025
Setup	SEt	Math x	mAt		1 - 24			Units	Un it	always	25032
Setup	SEt	Math x	mAt		1 - 24			Range Low	r.Lo	always	25026
Setup	SEt	Math x	mAt		1 - 24			Range High	r.h i	always	25027
Setup	SEt	Math x	mAt		1 - 24			Pressure Units	P.unt	always	25030
Setup	SEt	Math x	mAt		1 - 24			Altitude Units	A.unt	always	25031
Setup	SEt	Math x	mAt		1 - 24			Filter	F iL	always	25028
Setup	SEt	Variable x	uAr	always	1 - 24	always		Data Type	tYPE	always	2001
Setup	SEt	Variable x	uAr		1 - 24			Units	Un it	always	2007
Setup	SEt	Variable x	uAr		1 - 24			Digital	d i9	always	2002
Setup	SEt	Variable x	uAr		1 - 24			Analog	AnL9	always	2003
Setup	SEt	Global 1	9LbL	always	1	always		Display Units	C_F	always	3005
Setup	SEt	Global 1	9LbL		1			AC Line Frequency	AC.LF	always	1034
Setup	SEt	Global 1	9LbL		1			Display Pairs	d.Pr5	always	3028
Setup	SEt	Global 1	9LbL		1			User Settings Save	USr.S	always	1014
Setup	SEt	Global 1	9LbL		1			User Settings Restore	USr.r	always	1013
Setup	SEt	Communications 1	CoM	If PN digit 10 = 1	1	always		Baud Rate	bAUd	always	17002
Setup	SEt	Communications 1	CoM		1			Parity	PAr	always	17003
Setup	SEt	Communications 1	CoM		1			Modbus Word Order	rn.hL	always	17043
Setup	SEt	Communications 1	CoM		1			Display Units	C_F	always	17050
Setup	SEt	Communications 1	CoM		1			Non-Volatile Save	nU.S	always	17051
Setup	SEt	Log Point x	L9.Pt	If PN digit 7 = D	1-200	Always		Source Function A	SFn.A	always	39001
Setup	SEt	Log Point x	L9.Pt		1-200			Source Instance A	S .A	always	39002
Setup	SEt	Log Point x	L9.Pt		1-200			Source Zone A	S2.A	always	39003
Setup	SEt	Log Point x	L9.Pt		1-200			Display Precision	dEC	always	39007
Factory	FctY	Custom Setup x	CUSt	always	1-30	always		Parameter	PAr	always	14005
Factory	FctY	Custom Setup x	CUSt		1-30			Instance ID	i id	always	14003

EZ-ZONE RMS Menus

EZC Page	LED Page	Menu	LED Menu	Menu Visible	Instance	Instance Visible		EZC Parameter	LED Parameter	Included In Menu	Parameter ID
Factory	FctY	Lock 1	LoC	If DspLockedState = PASS ADMIN	1	always		Operations Page	LoC.o	always	3002
Factory	FctY	Lock 1	LoC		1			Password Enable	PAS.E	always	3015
Factory	FctY	Lock 1	LoC		1			Read Lock	rLoC	always	3010
Factory	FctY	Lock 1	LoC		1			Write Security	SLoC	always	3011
Factory	FctY	Lock 1	LoC		1			Locked Access Level	LoC.L	always	3016
Factory	FctY	Lock 1	LoC		1			Rolling Password	roLL	always	3019
Factory	FctY	Lock 1	LoC		1			User Password	PAS.u	always	3017
Factory	FctY	Lock 1	LoC		1			Administrator Password	PAS.A	always	3018
Factory	FctY	Unlock 1	ULoC	If DspSecurityEnable == ON	1	always		Public Key	CodE	always	3020
Factory	FctY	Unlock 1	ULoC		1			Password	PASS	always	3022
Factory	FctY	Diagnostics 1	diAG	always	1	always		Part Number	Pn	always	1009
Factory	FctY	Diagnostics 1	diAG		1			Software Revision	rEv	always	1017
Factory	FctY	Diagnostics 1	diAG		1			Software Build Number	S.bLd	always	1005
Factory	FctY	Diagnostics 1	diAG		1			Serial Number	Sn	always	1032
Factory	FctY	Diagnostics 1	diAG		1			Date of Manufacture	dAtE	always	1008
Factory	FctY	Calibration x	CAL	always	1 - 16	Instance 1-4 = always Instance 5-8 if PN digit 6 = R or P Instance 9-12 if PN digit 7 = R or P Instance 13-16 if PN digit 8 = R or P		Electrical Measurement	AnU	always	4021
Factory	FctY	Calibration x	CAL		1 - 16			Electrical Input Offset	EL.o	always	4010
Factory	FctY	Calibration x	CAL		1 - 16			Electrical Input Slope	EL.S	always	4011