

Notice when terminating the cable at the end of the link, tape the shield back so that it cannot make contact with ground or other devices and conductors.

Shield cannot be grounded

Terminations where the cable ends at the last device

