SYSTEM CONFIGURATION

Model SBE 16plusV2	**S/N 16-50670**
Instrument Type	**SBE 16plusV2 Seacat**
Firmware Version	**3.2.1**
Communications	**9600 baud, 8 data bits, no parity, one stop bit**
Memory	**64MB**
Housing	**600 meter (Acetron plastic)**
Pressure Sensor	**Strain Gauge: 600 dBar, S/N 12123927**
Zero Conductivity Raw Frequency	**2647.22 Hz**
Number of Voltages Sampled:	**0**
Serial RS-232C Sensor	**NONE**
Pump (SBE 5)	**05-12677**

Common SBE Factory Default Values for Sensor Delays:
Seacat without external sensors…….…… 0 Seconds
Minimum delay for external sensors (voltage or serial)……... 4 Seconds
Common sensors with a 4 second delay include:
Wet Labs ECO sensors, Seapoint STM and SCF, PAR sensors, SBE38, SBE50, Cylcops-7, & OBS3+
Wet Labs C-Star…… 10 Seconds
SBE43 (0.5 mil membrane) …… 30 Seconds
SBE43 (1.0 mil membrane) …… 40 Seconds
SBE63…… 40 Seconds
SBE18 or SBE27…….. 60 Seconds

Configured Overall Delay Setting for this CTD: 0 Seconds

Note: Overall Voltage Delay Setting is based on the longest time delay as needed. A list is provided above of common sensor delay values programmed into CTD when integrated and shipped from Sea-Bird Electronics. To recalculate this value when adding or removing sensors, please refer to CTD manual.

SEASOFT CONFIGURATION:

The settings for the configuration of your instrument as delivered are documented below: