



System Description

www.OPAL-RT.COM

26 Summit Street
Brighton, MI 48116

www.opal-rt.com

Contents

Overview	5
SECTION A – SYSTEM SUMMARY	6
Hardware Target Station information (OP5600 IO System)	6
System Diagrams and Schematics	6
Chassis PCI Slot Configuration	8
PWR OUT connector pinout	8
Signal Conditioning Module Configuration	9
I/O Bitstream Name and Configuration	10
RJ45 Connections – Signal Monitoring	10
SECTION B – MAPPING I/O BLOCKS TO SIGNAL CONDITIONING.....	12
OP5000 Series Modules.....	12
IO Group 1 / Section A: 16 Analog Out.....	12
IO Group 1 / Section B: 16 Analog In.....	13
IO Group 2 / Section A: 32 Digital In (Ch 00-15).....	14
IO Group 2 / Section A: 32 Digital In (Ch 16-31).....	15
IO Group 2 / Section B: 32 Digital Out (Ch 00-15)	16
IO Group 2 / Section B: 32 Digital Out (Ch 16-31)	17

OVERVIEW

PROJECT: PF312-193

CLIENT: NATIONAL RENEWABLE ENERGY LABORATORY (NREL)

SYSTEM S/N: PF312193S01 (OP5600 IO SYSTEM)

Section A	System summary
Section B	Mapping I/O blocks to signal conditioning

SECTION A – SYSTEM SUMMARY

HARDWARE TARGET STATION INFORMATION (OP5600 IO SYSTEM)

Items	Quantity	Description
Operating System	1	Redhat v2.6.29.6-opalrt-5
Chassis Type	1	OP5600 Chassis
CPU	1	Intel Xeon Six-Core 3.46GHz 12M Cache
Total Core #	6	
Memory	2	1GB
Motherboard		X8DTL-I-O Supermicro Motherboard, Intel® Xeon® processor 5600/5500 series, with QPI up to 6.4 GT/s
IP Address		192.168.10.101 (eth 0) - see Figure 2 for Ethernet port identification
AC Input		100-240V, 60-50Hz

SYSTEM DIAGRAMS AND SCHEMATICS




Figure 1: System Hardware Overview




Figure 2: OP5600 chassis front view



Monitoring Panel has a gain of 0.1




Figure 3: OP5600 Chassis Rear View

CHASSIS PCI SLOT CONFIGURATION

PCI Slot	PCI Card	Notes
1	Empty	
2	Empty	
3	Empty	
4	Empty	
5	SATA port for DVD or CD drive	
6	Empty	

PWR OUT CONNECTOR PINOUT

Pin	Description	Connector Diagram
1	12 V	
2	GND	
3	GND	
4	5V	

SIGNAL CONDITIONING MODULE CONFIGURATION

I/O Group	Subsection A	Subsection B
1	OP5330 Analog Out	OP5340 Analog In (1 MSPS)
2	OP5353 Digital In	OP5354 Digital Out
3	Empty	Empty
4	Empty	Empty



On the OP5354 Digital Output module, two pins are provided to connect Vuser_RTN. This is a common return used by both 16 Digital Output banks.




Figure 4: Top View of mezzanines installed on carrier

CAUTION

The system must be powered down before changing the mezzanines. Failure to do so may damage the equipment.

I/O BITSTREAM NAME AND CONFIGURATION

I/O Bitstream	IO Configuration
OP5142_1-EX-0000-2_1-96IO-04-01.bin	16 Analog Inputs 16 Analog Outputs 16 Time-Stamped Digital Inputs 16 Time-Stamped Digital Outputs 16 Static Digital Inputs 16 Static Digital Outputs

RJ45 CONNECTIONS – SIGNAL MONITORING

Each RJ45 monitoring Panel on the front of the OP5600 simulator connects to front and back mezzanines. The following images illustrate how the mezzanines are linked to the connectors.




Figure 5: Monitoring jacks - RJ45 to mezzanines relationship

Each mezzanine is assigned two columns of RJ45 connectors. Each column represents a series of channels, divided into 4 channels per RJ45 jack.




Figure 6: Monitoring jacks - RJ45 channel assignments

The signals from the signal conditioning modules can be monitored through RJ45 and mini BNC connectors to any monitoring device (i.e oscilloscope, etc). The mini BNC jacks let you monitor 4 channels individually. See the OP5600 user guide for connecting monitoring device instructions.

Only connect RJ45 cables from the monitoring jacks to the monitoring panel as indicated in the user manual. Connecting any other cable or device may result in damage to the equipment.


CAUTION The network cable must only be connected to the standard computer connector network jack. DO NOT connect the network cable in any jack other than the jack intended for that purpose.

SECTION B – MAPPING I/O BLOCKS TO SIGNAL CONDITIONING

OP5000 SERIES MODULES


The following I/O block mapping is applicable for model *pf312193_hw_test_model.mdl* which is used to validate the hardware functionality.

IO GROUP 1 / SECTION A: 16 ANALOG OUT




Relation between Simulink blocks and OP5330

	Simulink block library path: RT-LAB I/O \ Opal-RT \ OP5142 \ OP5142EX1 AnalogOut		Pinout		
Bloc k #	Description OP5142EX1 AnalogOut	Ch	Pin # DB37 Connector P1 ch. 0-15	Name	Comments
1	OP5142EX1 AnalogOut Parameters Controller Name 'OP5142EX1 Ctrl' DataIn port number 1 Number of channels 8	0	1	+OUT00	
		0	20	-OUT00	
		1	2	+OUT01	
		1	21	-OUT01	
		2	3	+OUT02	
		2	22	-OUT02	
		3	4	+OUT03	
		3	23	-OUT03	
		4	5	+OUT04	
		4	24	-OUT04	
		5	6	+OUT05	
		5	25	-OUT05	
		6	7	+OUT06	
		6	26	-OUT06	
		7	8	+OUT07	
		7	27	-OUT07	
2	OP5142EX1 AnalogOut Parameters Controller Name 'OP5142EX1 Ctrl' DataIn port number 2 Number of channels 8	8	9	+OUT08	
		8	28	-OUT08	
		9	10	+OUT09	
		9	29	-OUT09	
		10	11	+OUT10	
		10	30	-OUT10	
		11	12	+OUT11	
		11	31	-OUT11	
		12	13	+OUT12	
		12	32	-OUT12	
		13	14	+OUT13	
		13	33	-OUT13	
		14	15	+OUT14	
		14	34	-OUT14	
		15	16	+OUT15	
		15	35	-OUT15	




IO GROUP 1 / SECTION B: 16 ANALOG IN




Relation between Simulink blocks and OP5340

	Simulink block library path: RT-LAB I/O \ Opal-RT \ OP5142 \ OP5142EX1 AnalogIn	Pinout			
Block #	Description OP5142EX1 AnalogIn	Ch	Pin # DB37 Connector P1 ch. 0-15	Name	Comments
1	OP5142EX1 AnalogIn Parameters Controller Name 'OP5142EX1 Ctrl' DataOut port number 1 Number of channels 8	0	1	+IN00	
		0	20	-IN00	
		1	2	+IN01	
		1	21	-IN01	
		2	3	+IN02	
		2	22	-IN02	
		3	4	+IN03	
		3	23	-IN03	
		4	5	+IN04	
		4	24	-IN04	
		5	6	+IN05	
		5	25	-IN05	
		6	7	+IN06	
		6	26	-IN06	
		7	8	+IN07	
		7	27	-IN07	
2	OP5142EX1 AnalogIn Parameters Controller Name 'OP5142EX1 Ctrl' DataOut port number 2 Number of channels 8	8	9	+IN08	
		8	28	-IN08	
		9	10	+IN09	
		9	29	-IN09	
		10	11	+IN10	
		10	30	-IN10	
		11	12	+IN11	
		11	31	-IN11	
		12	13	+IN12	
		12	32	-IN12	
		13	14	+IN13	
		13	33	-IN13	
		14	15	+IN14	
		14	34	-IN14	
		15	16	+IN15	
		15	35	-IN15	




IO GROUP 2 / SECTION A: 32 DIGITAL IN (CH 00-15)




Relation between Simulink blocks and OP5353

	Simulink block library path: RT-LAB I/O \ Opal-RT \ OP5142 \ OP5142EX1 EventDetector		Pinout		
Block #	Description OP5142EX1 EventDetector	Ch	Pin # DB37 Connector P1 ch. 0-15	Name	Comments
1	OP5142EX1 EventDetector Parameters Controller Name 'OP5142EX1 Ctrl' DataOut port number 3 Number of channels 8 Events per channel 4	0	1	+DIN00	
			20	-DIN00	
			2	+DIN01	
			21	-DIN01	
			3	+DIN02	
			22	-DIN02	
			4	+DIN03	
			23	-DIN03	
			5	+DIN04	
			24	-DIN04	
			6	+DIN05	
			25	-DIN05	
			7	+DIN06	
			26	-DIN06	
			8	+DIN07	
			27	-DIN07	
2	OP5142EX1 EventDetector Parameters Controller Name 'OP5142EX1 Ctrl' DataOut port number 4 Number of channels 8 Events per channel 4	8	9	+DIN08	
			28	-DIN08	
			10	+DIN09	
			29	-DIN09	
			11	+DIN10	
			30	-DIN10	
			12	+DIN11	
			31	-DIN11	
			13	+DIN12	
			32	-DIN12	
			14	+DIN13	
			33	-DIN13	
			15	+DIN14	
			34	-DIN14	
			16	+DIN15	
			35	-DIN15	




IO GROUP 2 / SECTION A: 32 DIGITAL IN (CH 16-31)




Relation between Simulink blocks and OP5353

Block #	Description OP5142EX1 Digitalln	Ch	Pinout		
			Pin # DB37 Connector P2 ch. 16-31	Name	Comments
1	OP5142EX1 Digitalln Parameters Controller Name 'OP5142EX1 Ctrl' DataOut port number 5 Number of Din channels 8	16	1	+DIN16	
			20	-DIN16	
		17	2	+DIN17	
			21	-DIN17	
		18	3	+DIN18	
			22	-DIN18	
		19	4	+DIN19	
			23	-DIN19	
		20	5	+DIN20	
			24	-DIN20	
		21	6	+DIN21	
			25	-DIN21	
		22	7	+DIN22	
			26	-DIN22	
		23	8	+DIN23	
			27	-DIN23	
2	OP5142EX1 Digitalln Parameters Controller Name 'OP5142EX1 Ctrl' DataOut port number 6 Number of Din channels 8	24	9	+DIN24	
			28	-DIN24	
		25	10	+DIN25	
			29	-DIN25	
		26	11	+DIN26	
			30	-DIN26	
		27	12	+DIN27	
			31	-DIN27	
		28	13	+DIN28	
			32	-DIN28	
		29	14	+DIN29	
			33	-DIN29	
		30	15	+DIN30	
			34	-DIN30	
		31	16	+DIN31	
			35	-DIN31	




IO GROUP 2 / SECTION B: 32 DIGITAL OUT (CH 00-15)




Relation between Simulink blocks and OP5354

Block #	Simulink block library path: RT-LAB I/O \ Opal-RT \ OP5142 \ OP5142EX1 EventGenerator	Description OP5142EX1 EventGenerator	Ch	Pinout		
				Pin # DB37 Connector P1 ch. 0-15	Name	Comments
1	OP5142EX1 EventGenerator Parameters Controller Name 'OP5142EX1 Ctrl' DataIn port number 3 Number of channels 8 Events per channel 4		0	1	+DOUT00	
				20	-DOUT00	
			1	2	+DOUT01	
				21	-DOUT01	
			2	3	+DOUT02	
				22	-DOUT02	
			3	4	+DOUT03	
				23	-DOUT03	
			4	5	+DOUT04	
				24	-DOUT04	
			5	6	+DOUT05	
				25	-DOUT05	
			6	7	+DOUT06	
				26	-DOUT06	
			7	8	+DOUT07	
				27	-DOUT07	
2	OP5142EX1 EventGenerator Parameters Controller Name 'OP5142EX1 Ctrl' DataIn port number 4 Number of channels 8 Events per channel 4		8	9	+DOUT08	
				28	-DOUT08	
			9	10	+DOUT09	
				29	-DOUT09	
			10	11	+DOUT10	
				30	-DOUT10	
			11	12	+DOUT11	
				31	-DOUT11	
			12	13	+DOUT12	
				32	-DOUT12	
			13	14	+DOUT13	
				33	-DOUT13	
			14	15	+DOUT14	
				34	-DOUT14	
			15	16	+DOUT15	
				35	-DOUT15	




IO GROUP 2 / SECTION B: 32 DIGITAL OUT (CH 16-31)



Relation between Simulink blocks and OP5354

Block #	Description OP5142EX1 DigitalOut	Ch	Pinout		
			Pin # DB37 Connector P2 ch. 16-31	Name	Comments
1	OP5142EX1 DigitalOut Parameters Controller Name 'OP5142EX1 Ctrl' DataIn port number 5 Number of Dout channels 8	16	1	+DOUT16	
			20	-DOUT16	
		17	2	+DOUT17	
			21	-DOUT17	
		18	3	+DOUT18	
			22	-DOUT18	
		19	4	+DOUT19	
			23	-DOUT19	
		20	5	+DOUT20	
			24	-DOUT20	
		21	6	+DOUT21	
			25	-DOUT21	
		22	7	+DOUT22	
			26	-DOUT22	
		23	8	+DOUT23	
			27	-DOUT23	
2	OP5142EX1 DigitalOut Parameters Controller Name 'OP5142EX1 Ctrl' DataIn port number 6 Number of Dout channels 8	24	9	+DOUT24	
			28	-DOUT24	
		25	10	+DOUT25	
			29	-DOUT25	
		26	11	+DOUT26	
			30	-DOUT26	
		27	12	+DOUT27	
			31	-DOUT27	
		28	13	+DOUT28	
			32	-DOUT28	
		29	14	+DOUT29	
			33	-DOUT29	
		30	15	+DOUT30	
			34	-DOUT30	
		31	16	+DOUT31	
			35	-DOUT31	



CONTACT

Opal-RT Corporation
26 Summit Street
Brighton, MI, USA
48116
Tel.: (734) 418-2961
Fax: (866) 462-5120

Technical Services
www.opal-rt.com/support

Note:

While every effort has been made to ensure accuracy in this publication, no responsibility can be accepted for errors or omissions. Data may change, as well as legislation, and you are strongly advised to obtain copies of the most recently issued regulations, standards, and guidelines.
This publication is not intended to form the basis of a contract.

