



Overview

- **A brief introduction to KIER**
 - History, personnel and budget
 - R&D Strategies and organization
- **An overview of KIER R&D on Thermal Energy Network**
 - KIER's approach to thermal energy network
 - Brief history of KIER R&D on thermal energy network
- KIER's Activities I : R&D on heat pumps for TEN**
 - Sea water source heat pump for a low-temperature TEN
 - Medium- and high-temperature heat pumps for an industrial TEN
- KIER's Activities II : 3025 Project**
 - Overview of 3025 Project (Demonstrative Research on TEN in KIER campus)
 - KIER Energy Center
- KIER's Activities III : R&D on EMS for TEN**
 - Local EMS for uni-directional thermal energy supply system with a local source
 - EMS for bi-directional thermal energy network
- **Summary**


Chapter 01

A brief introduction to KIER



The KIER, a global energy innovator, does its best in pursuing its mission to invent world-class energy technologies based on open innovation, life-cycle research quality assurance, participatory and open communication. Therefore the KIER will become the best energy technology R&D institute in the world, contributing to the creation of wealth and improvement of quality of life for the people.

1.1 History



Energy Economic Policy Division
(research branch in Seoul, Nov. 1979)

Separated to Korea Energy
Economics Institute
(Sep.1986)

1.2 Personnel & Budget

Personnel

619 employees in total with 411 of regular employees
(as of April 2015)



278
(252 PhDs, 90.6%)


Researchers



81
Technologists





52
Administration staff



208
Contract-based

2015 Budget (\$136M)



5.1 R&D Strategies



National Energy Master Plan	National Strategy for Green Growth	Green Energy Strategic Roadmap
<ul style="list-style-type: none"> ■ Realization of energy self-sufficient society ■ Convert to low energy consumption society ■ Convert to low carbon society and to lower the dependency on petroleum ■ Realization of energy society for mutual benefits 	<ul style="list-style-type: none"> ■ Adaptation to climate change and energy self-sufficiency ■ Creation of new growth engine ■ Improve the quality of life and the national status 	<ul style="list-style-type: none"> ■ Green energy technology as a new growth engine ■ GHGs emission reduction ■ Contribute to national energy security
Energy Self-sufficient	Expansion of Green Energy Supply	Expansion of Energy Efficiency
GHGs Emission Reduction	Promotion of Energy Welfare	Creation of New Growth Engine

4 Strategic Goals of KIER R&D

Strategic Goal 1

*Expansion of
renewable energy*

Strategic Goal 2

*GHGs emission
reduction*


Strategic Goal 3

*Energy efficiency
improvement*

Strategic Goal 4

*Decrease in
oil dependency*

Organization



1 vice president, 9 divisions, 20 laboratories, 11 offices, 7 teams, 6 centers, 1 branch

Chapter 02


An overview of KIER R&D on Thermal Energy Network




The KIER, a global energy innovator, does its best in pursuing its mission to invent world-class energy technologies based on open innovation, life-cycle research quality assurance, participatory and open communication. Therefore the KIER will become the best energy technology R&D institute in the world, contributing to the creation of wealth and improvement of quality of life for the people.



Where is a network or grid ?



<http://blog.skenergy.com/1707>



Anne Helmond, May 2009



<http://pcgladiator.blogspot.kr/2009/01/crazy-highway-intersections.html>




http://kamerican.com/GNC/new/secondary_contents.php?article_no=8&no=1201



<http://cfile21.uf.tistory.com/image/22662E3B54D44EB1301038>




Energy Networks



http://www.tokyo-gas.co.jp/techno/challenge/002_e.html




KIER's approach to thermal energy network




Why heat pump?



- Minimization of energy consumption to produce thermal energy



CO₂ cut increases to 10 %
80% replace with SPF=4




CO₂ savings as a function of the percentage of retrofitted homes


The figure shows CO₂ savings as a function of the percentage of homes retrofitted with heat pumps, in the OECD countries, and heat pump performance factor (SPF). Savings in tap water and heating can be added together. It is assumed that an electric heat pump with European emissions replaces an oil-fired boiler with 80% efficiency.

The potential contribution of heat pumps to CO₂ emissions reduction increases with improved technology and market penetration, as well as greening of electricity production.

Example
If 80% of the homes in the OECD countries replaced their oil boiler with a heat pump with an SPF=4, 2374 Mt of CO₂ could be saved, corresponding to 10% of global CO₂ emissions.



Cut 8 % of total global CO₂ emission
100% replace with SPF=3



24,466 금
화력발전소

나무
5천만 ha

자동차
5,200 만 대


원유
7천 8백 억
리터



Thermal station for a residential application

- Low temperature thermal network

- Minimization of combustive heat production facilities
- Short-distance network using heat pump systems






Thermal station for an industrial application

- Combustive energy from biomass/waste fuels to produce high temperature supply for industrial thermal station


- Heat exchange network design
- Ultra high temperature heat pump
- Waste heat storage



Graphical representation of KIER's concept for a thermal station




- Objective : Minimizing energy use in thermal energy production by utilizing available resources near demand





Thermal energy network





Brief history of KIER R&D on Thermal Energy Network

- Vision : Implementation of zero-waste energy network
- Budget : \$1M/yr for 2015-9
- Target for 2025 : 20% of energy saving in cooling and heating at KIER campus

- KIER 3025 project planning
- Sea water source heat pump
- Industrial heat pumps

Concept building (~2011)

- Heat pump-based thermal station
- Thermal station-based TEN

Core technologies for thermal station (2011~)

Lab-scale demonstrative R&D (2013~)

- KIER Energy Center
- Local EMS for uni-directional thermal energy supply system with a local source
- EMS for bi-directional thermal energy network
- Smart meter

μGrid-scale demonstrative R&D (2017~)

- Renewable-hybrid
- KIER 3025 project completion
- μGrid-scale demonstrative R&D planning




Chapter 03

KIER's Activities I





- R&D on heat pumps for TEN
 - Sea water source heat pump for a low-temperature TEN
 - Medium- and high-temperature heat pump for an industrial TEN



Sea water source heat pump for a low-temperature thermal energy network





- Objective of project : Development of CFC/HCFC-free 20 RT SWSHP
- Target performance
 - Cooling COP in summer season : 4.5, cooling supply : 7°C at sea water of 25°C
 - Heating COP in winter season : 3.3, heating supply : 50~60°C at sea water of 10°C
- Expected payback period : 5.9 year (with a subsidy from gvmt)



Demonstrative R&D on medium-temperature heat pump for an industrial TEN



- Objective of project : Development of waste heat recovery Heat Pump for industrial purpose
- 100kW of heating capacity with a heating COP of 3.5 at **65-70°C** of hot process water
- Increase in boiler efficiency : 8%
(Fuel consumption reduction: 12 kg/h, cost reduction: \$44,000/year)
- Expected payback period : 3.5 year



Demonstration plant
(Lotte food Co. Ltd.)




HP cycle analysis



Water-fluidized-bed Heat exchanger



Heat pump





Control/ monitoring system

On-going project on high-temperature steam generation heat pump for an industrial TEN





- Objective of project : Development of steam generation Heat Pump for industrial purpose
- Target performance : 300kW of heating capacity with a heating COP of 3.2 at 120°C of steam temperature

[Heats in industrial sector (Japan)]




Case Study : Thermal energy network in Food (Beer) Production Process






Prototype steam generation heat pump (40 kW) test loop



Compressor reliability test loop



100°C of steam generated (quality = 0.1)



Steam generation heat pump system layout


Chapter 04

KIER's Activities II




■ KIER 3025 Project

- Overview of 3025 Project
(Demonstrative Research on TEN in KIER campus)
- KIER Energy Center




KIER 3025 Project

(Demonstrative Research on TEN in KIER campus)




- Targeting KIER Daejeon headquarters to reduce 30% of energy consumption
- Remodeling ‘Exhaust Gas R&D plant’ into thermal station having combined heat and power plant






Scenario-based analysis on TEN in KIER campus


- Case 1: Combined Heat and Power Application (Steam extraction / bypass)




Exhaust Gas R&D Plant



- Case 2 : Condenser Heat Recovery (Absorption heat pump of type I)





- Direct utilization of condenser waste heat





Cost estimation and economic analysis

- 35% of energy saving (equiv. \$140 thousands of annual cost saving)




1500RT			750RT
Layout	Extraction ≈ By-pass (Applied to total thermal network of KIER)	About 12.4% per year - Heating energy saving: 10% - Cooling energy saving: 22%	Extraction ≫ By-pass (excluding Green Bld., Eco Bld., Complex Tech. Bld.) About 34.7% per year - Heating energy saving: 34% - Cooling energy saving: 36%
Energy saving (based on LHV)			
Cost saving (Energy cost)	About \$270 thousand per year Heating: \$230 k/ Cooling \$40 k		\$140 thousand per year
remarks	Effect of electricity reduction in EHP equipped Bld. wa s not considered in cost saving analysis		Net investment budget to building thermal energy net work is \$400 thousand and estimated pay back period is about 3 years.


Piping /facilities planning for a demonstrative thermal station




Steam extraction + Absorption HP (350 kWth-class)



Exhaust Gas R&D Plant
(Coal-fired power plant)



Relation between driving steam temp and COP



high-temp steam

	Conventional gas-fired AHP	Extracted steam driven AHP
heating capacity	350 kWth	350 kWth
thermal energy input	350 kWth	206 kWth
primary energy consumption	412 kWth (100%)	242 kWth (59%)


Real-time Energy Monitoring System (KIER Energy Center)




- Goal : Optimizing energy use in KIER campus
- Features
 - Real-time monitoring
 - Tag list of total 9,648 points
 - Web-based access/ Ethernet protocol
 - RTDB access through web browser
 - Web-based simulation



KIER Energy Center




KIER Energy Center Homepage



Laboratory building facilities Status




Schematic diagram of data flow





Hierarchial structure of data







Some features of KIER Energy Center

■ Real-time Electricity Network status


⚡ Electricity Energy Network



Energy Flow



share of each building



power usage pattern





■ Real-time office building room temperature

N1 (제1연구동)

실내온도


설비

facilities status tab

건물전경




실내온도 분포




실내온도 모니터링

3층



room temperature distribution

2층




실명	실내온도	설정온도
101호	22.2	26.5
102호	22.1	26.5
103호	22.2	26.5
104호	23.0	26.5
105호	23.8	26.5
106호	24.9	26.5
107호	25.1	26.5
108호	23.2	26.5
201호	22.4	26.5
202호	24.2	26.5
203호	24.0	26.5
204호	24.4	26.5
205호	25.1	26.5
206호	24.3	26.5
207호	24.7	26.5
208호	25.2	26.5
301호	21.7	26.5
302호	24.3	26.5
303호	24.8	26.5
304호	26.9	26.5
305호	25.5	26.5



■ Real-time coal power plant operating status

W3 (연소배가스처리기술 종합실험동)







KIER Energy DB access


KIER ENERGY CENTER

Electricity Energy Trend



구분 Consumption Generation

Peak [kW]	Monthly [kWh]	Peak [kW]	Sum [kWh]
2,881	13,140,137	39,467	6,479,346



power usage in each building

total power generation

1 Year Total Generation 8,004,255 kWh



Sum



Goal of KIER 3025 Project

<Exhaust Gas R&D Plant>

- Fuel : Coal
- Boiler capa. : 10 MWth
- Generating capa. : 2 MWe

Plant

<Heating supply Plant>

- Double effect Absorption Chiller : 2 units
- Fuel : LNG, (Steam)

ESS



- Low U-value of walls & windows
- Low energy lighting system

Solar + Geothermal Network (250RT)

Micro-grid

- Thermal grid
- New & Renewable electricity grid


Chapter 05

KIER's Activities III




■ R&D on EMS for TEN

- Local EMS for uni-directional thermal energy supply system with a local source
- EMS for bi-directional thermal energy network



uni-directional supply




bi-directional supply

Local EMS for uni-directional thermal energy supply system with a local source



Overview

- When a demand has a thermal station, and uni-directional thermal energy supply is also available, we can have a chance of cost or energy saving by using the local EMS.
- Optimal operation strategy of the local EMS considering demand, capacity, and real-time price is necessary.






Simulation approach


Heating and cooling demand analysis

Office model




Plan for demonstrative system at the office of N2-212


TRNSYS Simulation



Max. daily heating demand
980kcal/m²



Max. daily cooling demand
830kcal/m²




Experimental approach

Thermal storage-heat pump-based thermal station

Max. capacity

(cooling)	Ice	400 kg(ice)+Brine
32,000 kcal	Water	3,200 kg ($\Delta T=10^\circ\text{C}$)
	PCM	530 kg(PCM)+Brine



	phase change temp(°C)	latent heat (kJ/kg)	density (kg/l)	specific heat (kJ/kgK)
J11	3~5	252.30	0.825	2.07 (s)
W14	5~7	257.29	0.83	-



Thermal energy storage



indoor fan coil unit




heat pump



EMS for a bi-directional thermal energy network



Overview

- When multiple demands have different load pattern, we can have a chance of cost or energy saving by transmitting overs and shorts to neighbors.
- Another EMS, which transmits information on neighbors' status to each other, is necessary.
- Bi-directional heat meters are also necessary for a payment.





Bi-directional heat meter




Bi-directional heat meters designed by KIER


MODBUS RTL bi-directional data transfer protocol

STX	ACQ	LEN	ID	정방향열량	유량당열량	온도	연산유량	역방향열량	Status	CS	ETX
1Byte	1Byte	1Byte	1Byte	5Byte	3Byte	4Byte	1Byte	5Byte	1Byte	1Byte	1Byte

Bit8(MSB)	Bit7	Bit6	Bit5	Bit4	Bit3	Bit2	Bit1(LSB)
⑧	⑦Sensor Error	⑥	⑤	④Reverse flow	③	②	①Battery Low



Self-rechargeable battery
(with a thermo-electric energy harvester)




Electric circuit and protocol




■ Performance and reliability test

- Two heat demand simulators were designed and built, respectively.
- Two heat sources were linked to two heat demand simulators.






Bi-directional heat meter test loop with multiple sources and demands



HILS approach to design a cost-optimized operating schedule of EMS on a bi-directional TEN

(Hardware-in-the-Loop Simulation)



CHP-based bi-directional heat trade EMS Simulator for optimal operation

Mathematical model of the EMS on a CHP-based bi-directional thermal energy network



Modeling for the optimal design of EMS for a bi-directional TEN

Step 1 : BEMS

$$\text{Objective function } C_l^e \left(M_{CHP_1}^e(t) \dots M_{CHP_L}^e(t) \right) \\ = \sum_{l=1}^L \left\{ (C_{CHP_l}^e \cdot M_{CHP_l}^e(t)) + (C_{BUY_l}^e(t) \cdot M_l^{e-}(t)) - (C_{SELL_l}^e(t) \cdot M_l^{e+}(t)) \right\}$$

- 각 빌딩 단독으로 내부 수요량 총족
- μEMS로 잉여/부족 전기 에너지량 전달

Step 2 : μEMS

Objective function of electric part

$$C_{Elec}^e \left(M_{TRADE_1}^e(t) \dots M_{TRADE_L}^e(t), M_{BUY_1}^e(t) \dots \dots, M_{BUY_L}^e, M_{SELL_1}^e \dots \dots, M_{SELL_L}^e \right) \\ = \sum_{l=1}^L \left\{ (S_l^e(t) \cdot \max [C_{CHP_l}^e(t), C_{SELL_l}^e(t)] \cdot M_{TRADE_l}^e(t)) + (C_{BUY_l}^e(t) \cdot M_{BUY_l}^e(t)) - (C_{SELL_l}^e(t) \cdot M_{SELL_l}^e(t)) \right\}$$

Objective function of heat part

$$C_{Heat}^h \left(M_{CHP_1}^{e \rightarrow h}(t) \dots M_{CHP_L}^{e \rightarrow h}(t), M_{CHP_1}^h(t) \dots M_{CHP_L}^h(t), M_{HOB_{1,1}}^h(t) \dots M_{HOB_{L,J}}^h(t) \right) \\ = \sum_{l=1}^L \left\{ (C_{CHP_l}^e \cdot M_{CHP_l}^{e \rightarrow h}(t)) + (C_{CHP_l}^h(t) \cdot M_{CHP_l}^h(t)) + \sum_{j=1}^J (C_{HOB_{l,j}}^h(t) \cdot M_{HOB_{l,j}}^h(t)) \right\}$$


- BEMS에 의하여 제출된 잉여/부족 전기 에너지를 통한 μEMS 내부 전력 거래량 결정
- μEMS 내부 열 에너지 거래량 결정
- 각 빌딩(BEMS)으로 내부 에너지 거래량 통보

Step 3 : BEMS


Objective function

$$C_l^{Comb}(t) = \left(M_{CHP_1}'^e(t) \dots M_{CHP_L}'^e(t), M_{CHP_1}^h(t) \dots M_{CHP_L}^h(t), M_{HOB_{1,1}}^h(t) \dots M_{HOB_{L,J}}^h(t), \right. \\ M_{BUY_1}^e(t) \dots \dots M_{BUY_L}^e, M_{SELL_1}^e \dots \dots M_{SELL_L}^e \left. \right) \\ = \sum_{l=1}^L \left\{ (C_{CHP_l}^e \cdot M_{CHP_l}'^e(t)) + (C_{CHP_l}^h(t) \cdot M_{CHP_l}^h(t)) + \sum_{j=1}^J (C_{HOB_{l,j}}^h(t) \cdot M_{HOB_{l,j}}^h(t)) \right. \\ \left. + (C_{BUY_l}^e(t) \cdot M_{BUY_l}'^e(t)) - (C_{SELL_l}^e(t) \cdot M_{SELL_l}'^e(t)) \right\}$$


- 결정된 내부 에너지 거래량을 바탕으로 각 빌딩의 BEMS에 의한 전기/열원 설비 최적화 수행




- ① Optimization (BEMS)
- ② Informing surplus/short energy information
- ③ Optimization (EMS)
- ④ Informing results of optimization
- ⑤ Re-optimization (BEMS)



Role of an EMS



Electricity and thermal load profiles in demand 1 (house) with a Stirling engine-based CHP



Electricity and thermal load profiles in demand 2 (office) with a PEMFC-based CHP

EMS calculates cost-optimized operating schedule of each CHP system based on predicted load profiles and energy price.

Step 1 : BEMS

Objective function $C^1(M_{\text{Exp}}(t) - M_{\text{Desp}}(t))$
 $+ \sum_{i=1}^n (C_{\text{Exp}}^i(t) \cdot M_{\text{Exp}}^i(t)) + (C_{\text{Desp}}^i(t) \cdot M^*(t)) - (C_{\text{Total}}^i(t) \cdot M_t^*(t))$
 - 각 발동 단독으로 배내 수요량 충족
 μEMS로 의사소통 전략 예상화 수립

Step 2 : μEMS

Objective function of electric part
 $C^{\text{El}}(M_{\text{Exp}}(t) - M_{\text{Desp}}(t), M_{\text{Resv}}(t))$
 $\sum_{i=1}^n (C_{\text{Exp}}^i(t) \cdot \max(C_{\text{Exp}}^i(t), C_{\text{Desp}}^i(t)))$
 Objective function of heat part
 $C^{\text{Heat}}(M_{\text{Exp}}^h(t) - M_{\text{Desp}}^h(t), M_{\text{Resv}}^h(t))$
 $\sum_{i=1}^n (C_{\text{Exp}}^h(t) \cdot M_{\text{Exp}}^h(t)) + (C_{\text{Desp}}^h(t) \cdot M_{\text{Desp}}^h(t))$
 - BEMS과 의사소통 확보된 임의/보조 장치
 μNet 내부 및 예상화 전략 수립
 각 별도(BEMS)로 내부 예상화 거래

Step 3 : BEMS

Objective function
 $C^{\text{Opt}}(t) = (M_{\text{Exp}}^e(t) - M_{\text{Desp}}^e(t), M_{\text{Resv}}^e(t) - M_{\text{Exp}}^h(t) \dots M_{\text{Exp}}^n(t) - M_{\text{Desp}}^n(t), M_{\text{Resv}}^n(t) - M_{\text{Exp}}^n(t))$
 $- \sum_{i=1}^n (C_{\text{Exp}}^i(t) \cdot M_{\text{Exp}}^i(t)) + \sum_{i=1}^n (C_{\text{Desp}}^i(t) \cdot M_{\text{Desp}}^i(t))$
 $+ (C_{\text{Buy}}(t) \cdot M_{\text{Buy}}^*(t)) - (C_{\text{Sell}}(t) \cdot M_{\text{Sell}}^*(t))$
 - 결정된 내용 예상화 거래장을 바탕으로 각 별도의 BEMS에 의한 전기/열을 살피 최적화 수행

Step 4 : μEMS


Information on energy price
 Buy/Sell price
 - buy price(P_{-b}) - selling price(P_{-s})

Step 5 : BEMS


Cost-optimized operating schedule of a Stirling engine-based CHP in house

Step 6 : μEMS


Cost-optimized operating schedule of a PEMFC-based CHP in office



Plan for experiments to validate the optimized EMS



← Schematic diagram of CHP-based bi-directional micro energy network architecture




Schematic diagram of CHP-based bi-directional micro energy network test bed →



EMS test facility

■ Experimental test of the optimized EMS on a CHP-based bi-directional thermal energy network

- Two CHP-based thermal stations were introduced.
- Two heat demand simulators were designed and built, respectively.
- Bi-directional heat meter was introduced for heat trading.
- Cost-optimized scheduled EMS was tested.







EMS test results



20.9% of energy saving by introducing a cost-optimized scheduled EMS on the bi-directional thermal energy network



Chapter 06

Summary



The KIER, a global energy innovator, does its best in pursuing its mission to invent world-class energy technologies based on open innovation, life-cycle research quality assurance, participatory and open communication. Therefore the KIER will become the best energy technology R&D institute in the world, contributing to the creation of wealth and improvement of quality of life for the people.



Summary



KIER was introduced.

- History, personnel and budget
- R&D Strategies and organization



KIER's activities on thermal energy network were discussed.

- KIER's approach to thermal energy network
- Brief history of KIER R&D on thermal energy network

R&D on heat pumps for TEN

- Sea water source heat pump for a low-temperature TEN
- Medium- and high-temperature heat pumps for an industrial TEN

3025 Project


- Overview of 3025 Project (Demonstrative Research on TEN in KIER campus)
- KIER Energy Center

R&D on EMS for TEN

- Local EMS for uni-directional thermal energy supply system with a local source
- EMS for bi-directional thermal energy network



KIER hopes our meeting today will be a new initiative to strengthen our future cooperation !



Thank you !



The KIER, a global energy innovator, does its best in pursuing its mission to invent world-class energy technologies based on open innovation, life-cycle research quality assurance, participatory and open communication. Therefore the KIER will become the best energy technology R&D institute in the world, contributing to the creation of wealth and improvement of quality of life for the people.