

Utility Bill Summary (Sample)

Building: B001

Billing period: 2026-03-01 to 2026-03-31

Total energy: 5,382 kWh

Average daily usage: 173.6 kWh/day

Peak demand: 34.1 kW on 2026-03-23

Base load estimate: 11.5 kW

Power factor: 0.96

Tariff slab: Commercial LT

Total bill amount: INR 78,540

Notes: After-hours load observed in HVAC and corridor lighting.

Recommended checks

- Verify HVAC shutdown schedule after 10 PM
- Audit always-on lighting circuits
- Stagger heavy equipment startup between 8-10 AM