

Building Consent Application – Request for Further Information

Project Details

BC Application No.:	21655	Correspondence to:	A.P Plumbing and Gasfitting Ltd 7 Rotherham Street Wanganui
Date:	01/10/13		
Applicant Name:	Anderson		
Project Address:	Middle Road - Horopito		

Information Requested

Technical Assessor Use					Applicant or Designer or Agent Use	
#	Information Required	Reason for Request	Primary Code Clause/s	(✓) OK	(✓) Tick if Supplied	Supporting Comment
1.	Please complete in detail section 7 of the building consent checklist and supply more detailed plans of the sanitary fitting layout proposed within the buildings connected by drainage...	Not supplied. No scale or siting dimensions supplied. .	G12 / G13			
2.	With the connection of a water supply to the building please indicate how the water is to be rendered potable.	Tank water to services is deemed non-potable and requires a method of sanitizing.	G12			
3	There is no indication on file of a water supply to service this building . Please supply details requested in section 6 of the building application referring to water supply storage, capacity an delivery..	No indication on site plans of a water storage or supply system	G12			
5.	Please show layout of the gas hot water supply and installation details planned.	None shown				
6.	Copies to :- Mr N Anderson AP Plumbing & Gasfitting Ltd					
7.						