

A

Mounting: Surface

Location: Main Floor

Print Date

Voltage: 120V

Phases: 3 phase

Wires: 4

Circuits: 6

BUS Rating 20.92A

Main Breaker/MLO:

Isc Rating: AIC

Isca (Calculated): AIC

Rem	CCT No.	LOAD				BKR SIZE	PH	BKR SIZE	LOAD				CCT No.	Rem
		Descriptio	Qty	TYPE	kVA				kVA	TYPE	Qty	Descriptio		
	1	Receptacle	9		1.08	20	A	20	0.48	Light	4	Light	2	
	3	CCTV	2		0.24	20	B	20	0.72	Receptacle	4	Receptacle	4	
	5	Light	6		0.72	20	C	20	0.24	CCTV	2	CCTV	6	

B

Mounting: Surface

Location: Main Floor

Print Date

Voltage: 120V

Phases: 3 phase

Wires: 4

Circuits: 6

BUS Rating 29.58A

Main Breaker/MLO:

Isc Rating: AIC

Isca (Calculated): AIC

Rem	CCT No.	LOAD				BKR SIZE	PH	BKR SIZE	LOAD				CCT No.	Rem
		Descriptio	Qty	TYPE	kVA				kVA	TYPE	Qty	Descriptio		
	1	Receptacle	9	1.08	1.08	20	A	20	0.96	LTG.	8	Light	2	
	3	Comp Receptacle	2	0.24	0.24	20	B	20	1.2	LTG.	10	Light	4	
	5	Receptacle	8	1.2	0.96	20	C	20	0.24	OTH.	2	Card Reader	6	

C

Mounting: Surface

Location: Main Floor

Print Date

Voltage: 120V

Phases: 3 phase

Wires: 4

Circuits: 6

BUS Rating 35.36A

Main Breaker/MLO:

Isc Rating: AIC

Isca (Calculated): AIC

Rem	CCT No.	LOAD				BKR SIZE	PH	BKR SIZE	LOAD				CCT No.	Rem
		Descriptio	Qty	TYPE	kVA				kVA	TYPE	Qty	Descriptio		
	1	Light	10	LTG.	1.2	20	A	20	1.2	LTG.	10	Exit Light	2	
	3	Light	10	LTG.	1.2	20	B	20	1.08	REC.	9	Receptacle	4	
	5	Light	8	LTG.	0.96	20	C	20	0.24	OTH.	2	Fire+Smoke	6	

D

Mounting: Surface

Location: Main Floor

Print Date

Voltage: 120V

Phases: 3 phase

Wires: 4

Circuits: 6

BUS Rating 23.09A

Main Breaker/MLO:

Isc Rating: AIC

Isca (Calculated): AIC

Rem	CCT No.	LOAD				BKR SIZE	PH	BKR SIZE	LOAD				CCT No.	Rem
		Descriptio	Qty	TYPE	kVA				kVA	TYPE	Qty	Descriptio		
	1	Light	7	LTG.	0.84	20	A	20	0.48	REC.	4	Receptacle	2	
	3	Light	10	LTG.	1.2	20	B	20	0.12	OTH.	1	CCTV	4	
	5	Light	6	LTG.	0.72	20	C	20	0.48	OTH.	4	Fire+Somk	6	

E

Mounting: Surface

Location: Main Floor

Print Date

Voltage: 120V

Phases: 3 phase

Wires: 4

Circuits: 6

BUS Rating 17.32A

Main Breaker/MLO:

Isc Rating: AIC

Isca (Calculated): AIC

Rem	CCT No.	LOAD				BKR SIZE	PH	BKR SIZE	LOAD				CCT No.	Rem
		Descriptio	Qty	TYPE	kVA				kVA	TYPE	Qty	Descriptio		
	1	Receptacle	10	REC.	1.2	20	A	20	0.36	OTH.	3	wifi	2	
	3	Receptacle	9	REC.	1.2	20	B	20	0.24	OTH.	2	Motion Se	4	
	5	EV Chargin	1	AC	1.5	20	C						6	

F

Mounting: Surface

Location: 2nd Floor

Print Date

Voltage: 120V

Phases: 3 phase

Wires: 4

Circuits: 6

BUS Rating 31.75A

Main Breaker/MLO:

Isc Rating: AIC

Isca (Calculated): AIC

Rem	CCT No.	LOAD				BKR SIZE	PH	BKR SIZE	LOAD				CCT No.	Rem
		Descriptio	Qty	TYPE	kVA				kVA	TYPE	Qty	Descriptio		
	1	Light	10	LTG.	1.2	20	A	20	0.72	OTH.	6	Emergency	2	
	3	Light	9	LTG.	1.08	20	B	20	0.12	REC.	10	Receptacle	4	
	5	Light	9	LTG.	1.08	20	C	20	1.08	REC.	9	Receptacle	6	
	7	Motion Se	10	OTH.	1.2	20	A	20	1.2	OTH.	10	Occupancy	8	
	9	Air Quality	10	OTH.	1.2	20	B						10	
	11						C						12	