

**Minutes of Meeting of Committee on Regulatory Matters**

Minutes of Meeting of Committee on Regulatory Matters held virtually on 23rd September, 2025 at 3.00 PM.

At the outset, Shri Satyendra Nath Kalita, Director (Regulatory Affairs) of AIDA welcomed the members of the AIDA Committee on Regulatory Matters. The agenda of the meeting is to deliberate on determination of value of “X” for computation of the deviation (in %) for Wind and Solar (WS) Sellers from 01.04.2026 onwards under the provisions of the Central Electricity Regulatory Commission (Deviation Settlement Mechanism and Related Matters) Regulations, 2024 issued by Central Electricity Regulatory Commission.

**During the meeting, the following inputs/suggestions given by respective Committee Members:**

**Determination of value of “X” for computation of the deviation (in %) for Wind and Solar (WS) Sellers from 01.04.2026 onwards under the provisions of the Central Electricity Regulatory Commission (Deviation Settlement Mechanism and Related Matters) Regulations, 2024**

Shri S.N. Kalita, Director (RA), AIDA suggested tightening the frequency band limit from 50.05 Hz to 50.02 Hz as proposed in the draft, highlighting that grid stability remains a major concern in view of overdraw and over-injection issues.

DG, AIDA supported the suggestion, agreeing that reducing the frequency limit would help strengthen grid discipline and stability.

Shri Yogesh Gadkari, MSEDCL welcomed the proposal on determination of “X” but suggested that the transition period for existing RE generators is too long, as there are no technical or capital constraints unlike thermal plants. He proposed a faster reduction (around 30% per year).

DG, AIDA agreed with the observation, stating that the transition period for existing RE generators need not be so long, and a three-year timeline should suffice. He acknowledged that the grid is in a critical phase due to limited storage capacity, and hence, an accelerated transition would be beneficial.

Shri Sanjay Chaurasia, UPPCL suggested that solar generators within a state be aggregated for deviation calculation, so that schedules and actual generation are summed up and deviation charges are computed collectively. This state-level pooling would provide a more accurate and logical DSM framework compared to the current one-to-one approach.

**ALL INDIA DISCOMs ASSOCIATION (AIDA)**  
**CBIP Building, Malcha Marg, Chanakyapuri, New Delhi - 110021**

DG, AIDA acknowledged the suggestion, clarifying that CERC regulations apply to ISTS-connected projects, but noted that pooling is now feasible under GNA Regulations through the concept of a lead generator.

Shri Vidyadhar Wagle, Tata Power suggested a typographical correction in the formula by adding a missing closing bracket for clarity. He recommended using different deviation factors for wind and solar ( $x_w$ ,  $x_s$ ) due to wind's higher variability. He also sought clarity on how interstate generation deviations impact DISCOMs, noting that such power is scheduled. In response, DG AIDA clarified that while scheduling is correct, system-level costs from ancillary services needed due to variability are ultimately borne by DISCOMs. He added that hybrid projects should face stricter norms due to better controllability.



Satyendra Nath Kalita)

Convenor, AIDA Committee