


Performance Specifications

CLASS 600			
Test Pressure	Shell Test	15.4	MPa
	Back Seal Test	11.3	
	Seal Test	11.3	
	Air Test	0.6	
SuitableTemp.		-29~425 °C	
Suitable Media		W.O.G.etc	

NO.	Name Parts	Material
21	Seat Ring	ASTM A105+13Cr
20	Stem Nut	Ductile Iron+N
19	Lock Nut	AISI 1035
18	Hand Wheel	Ductile Iron
17	Retaining Nut	AISI 1035
16	Nipple	Copper Alloy
15	Bearings	Alloy Steel
14	Gland Flange	ASTM A216 WCB
13	Gland	ASTM A182 F6a
12	Gland Nut	ASTM A194 2H+Zn
11	Gland Eyebolt	ASTM A193 B7+Zn
10	Pin	AISI 1035
9	Packing	Graphite
8	Bonnet Nut	ASTM A194 2H
7	Bonnet Bolt	ASTM A193 B7
6	Bonnet	ASTM A216 WCB
5	Gasket	SS304+Flexible Graphite
4	Stem	ASTM A182 F6a
3	Disc Nut	ASTM 1035
2	Disc	ASTM A105+13Cr
1	Body	ASTM A216 WCB

Technical Requirements

1. Design & manufacture conform to API623
2. Face to Face dimension conforms to ASME B16.10
3. Flange dimension conforms to ASME B16.5
4. Test & Inspect conform to API 598

NPS-DN		Typical Dimensions				Class 600lb Flange Dimensions				
In	mm	d	L	H	W	D1	D2	D3	b	f	n-ød
6	150	152	559	787	500	355	292.1	215.9	47.7	7	12-28.5

TITLE	API CAST STEEL, NPS 6, CLASS 600, HW-OP BB,OS&Y, RF, GLOBE VALVE		
DESIGNED BY		DRAWN BY	
CHECKED BY		APPROVED BY	
DRAWING No.		DATE	

JOINT VALVE ROUTINE & SHUTDOWN MAINTENANCE FRAGNET

OPENING


- **Preparation**
  - **LOTO**
    - Depressurize
    - Isolate
  - **Inspect as found**
    - TAG
    - Inspect Body
    - Ispect Bonnet
  - **Functional Check**
    - Manual Operation
    - Check for Open/Close
- **Removal & Dissassemble**
  - **Drop the Valve**
    - Scaffold
    - Drop
    - Move to shop

REFURBISHMENT

- **Shop Activities**
  - **Dismantle Valve**
  - **Clean**
    - Remove Dirt
    - Remove Scale
    - Remove product
  - **Lubricate as recommended**
    - Lubricate stem
    - Lubricate gearboxes
    - Lubticator actuator links
  - **Seal & packing**
    - Replace valve gaskets
    - Replace valve packing
    - Replace O-rings
    - Replace seals
  - **Machining if needed**
    - Machine worn out parts
    - Machine gasket seats
    - Machine stem to free
  - **Reassemble**
    - Boxup Valve
    - Connect Body to Bonnet
    - Boltup end connections
  - **Valve testing**
    - Leak Test
    - Pressure test in shop
  - **Painting**
  - **Final Visual Inspection**

REFIXING

- **Valve return & refix**
  - **Rig Back**
    - Fix in location
    - Check direction and angle
  - **Bolting**
    - Clean mating flange surfaces
    - Replace gaskets
    - Boxup in location
    - Torque to appropriate value
  - **Reinsulate for HOT & Cold Services**
  - **Deblind**
  - **Descaffold**



T17QPWE1621: OLS- Replace Bypass Valve(41-7)		774	16-Jan-17 12:00	17-Feb-17 18:00
Pre Shutdown		3	16-Jan-17 12:00	16-Jan-17 15:00
PSTM-8505	Erect Scaffolding/Firebox	2	16-Jan-17 12:00	16-Jan-17 14:00
PSTM-8510	Remove Insulation	1	16-Jan-17 14:00	16-Jan-17 15:00
Shutdown		29	12-Feb-17 21:00	14-Feb-17 02:00
PSTM-8515	Verify LT&T and Obtain PTW	1	12-Feb-17 21:00	12-Feb-17 22:00
PSTM-8520	Blinding (Under: T17QPWE0966)	0	12-Feb-17 22:00	12-Feb-17 22:00
PSTM-8525	Cut & Remove 4" Valve /OLS Clamp	6	12-Feb-17 22:00	13-Feb-17 04:00
PSTM-8530	Fitup & Weld 4" Globe Valve	10	13-Feb-17 04:00	13-Feb-17 14:00
PSTM-8535	Inspection as per RAT Sheet	4	13-Feb-17 14:00	13-Feb-17 18:00
PSTM-8540	Hydro Test	6	13-Feb-17 18:00	14-Feb-17 00:00
PSTM-8550	Ready for De-Blinding (Under: T17QPWE0966)	0	14-Feb-17 00:00	14-Feb-17 00:00
PSTM-8555	Housekeeping & Close PTW	2	14-Feb-17 00:00	14-Feb-17 02:00
PSTM-8560	Mechanical Completion	0		14-Feb-17 02:00
PSTM-8545	Paint Weld Joints	2	14-Feb-17 00:00	14-Feb-17 02:00
Post Shutdown		88	14-Feb-17 02:00	17-Feb-17 18:00
PSTM-8565	Fix Back Insulation	6	14-Feb-17 02:00	14-Feb-17 08:00
PSTM-8570	Remove Scaffolding/Firebox	2	17-Feb-17 16:00	17-Feb-17 18:00



Drw Purpose Code :- R01- Educational

Status of Approval :- 01

Dimentions as Mentioned: NA

Drawing Scale :- NTS

Engg Code :- 99

Backup Info Code :- 04

Angle of Projection: NA

Sheet Size: A3

Statutory Note:
This document is prepared by rPlan and is the sole proprietory of the company.Its purpose is educational and no references within this document are for Engineering or Design corelation with the applicable codes. For any clarifications beyond the intended purpose viewers can always correspond to rPlan via its company website.This drw is not for duplication without company permission!

Drw electronic code

rPlan
AT 39, MERMAID 1 CHS LTD., SEC-11, CBD-BELAPUR, NAVI MUMBAI - 400614

Legal Owner

QR CODE: NA

Description: GLOBE VALVES - FRAGNET

Drawn By:	Drawn Date
DFT-01	20260804
Checked Approved by: rPlan-01	Checked Approved Date: 20260814

Drawing Number	Sheet	Rev
As Barcoaded	1 of 1	00