





CENTRIFUGAL PUMPS	RECIPROCATING PUMPS
Frequency - DAILY Visual Inspection Bearing visual function Checks Lubrication of rotating components Seals & Flush Lines	Frequency - DAILY Check oil levels Visual Check for leaks Noise checks for anomalies Monitor temperatures Check & Verify gauges
Frequency - WEEKLY Vibration Analysis: Lubrication Replenishment for housings Foundation and base frame condition monitoring	Frequency - WEEKLY Lubricate components Rotate (Manually) the crankshaft Check belts conditions
Frequency - MONTHLY Coupling & Alignment check Electrical checks on motor, panel and wiring Wear Rings check for condition . Function	Frequency - MONTHLY Valves and seals check Packing inspection Alignment check
Frequency - TURNAROUND LOTO Decouple Check all components Replace worn out components Overall load test for NPSH Shaft Alignment Check Remove / Clean Coupling if not worn out Change / Machine coupling if worn out Change Shaft Key if worn out Shaft dismantle and check for straightness Weld / Machine shaft Check bearing seat Replace shaft Replace bearing Change Belts Motor function check Motor rewinding if worn out Reassemble Run without coupling Couple and dry run manually Alignment recheck Full load test Paint and TAG if needed Commission	Frequency - TURNAROUND LOTO Decouple Shaft Alignment Check Remove / Clean Coupling if not worn out Change / Machine coupling if worn out Change Shaft Key if worn out Shaft dismantle and check for straightness Weld / Machine shaft Check bearing seat Replace shaft Replace bearing Change Belts Motor function check Motor rewinding if worn out Reassemble Run without coupling Couple and dry run manually Alignment recheck Full load test Paint and TAG if needed Commission

Drw Purpose Code :-	Statutory Note: This document is prepared by rPlan and is the sole proprietary of the company. Its purpose is educational and no references within this document are for Engineering or Design correlation with the applicable codes. For any clarifications beyond the intended purpose viewers can always correspond to rPlan via its company website. This drw is not for duplication without company permission!	Description: Typical Pumps FRAGNET Preliminary Doc under prep	
Status of Approval :-			
Dimentions as Mentioned		Drawn By:	Drawn Date
Drawing Scale :-	Backup Info Code :-	Checked Approved by	Checked Approved Date
Engg Code :-	Angle of Projection	Drawing Number	Sheet
	Sheet Size		Rev
		1 of 1	XX