

TAMILNADU FIRE AND RESCUE SERVICE

SCHOOL NO OBJECTION CERTIFICATE

R.C.NO: 143 /V/MWC/2022

DATED:23.07.2022

Certificated that the M/S.VIKAS MANTRA PUBLIC SCHOOL, at No:168/3, Anjur Village, Mahindra World City, Chengalpattu District occupied by M/S.VIKAS MANTRA PUBLIC SCHOOL have Fire Service Rules, and verified by the Station Officer Transport Mr.Anandan Concerned of Fire Service on 23.07.2022 in the presence of PRINCIPAL, M/S.VIKAS MANTRA PUBLIC SCHOOL, at No:168/3, Anjur Village, Mahindra World City, Chengalpattu District, and that the building/premises is for occupancy class School Premises With effect from 23/07/2022 for a period of 22/07/2023 Years in accordance with rule and subject to compliance of the conditions.

CONDITIONS

1. This License is valid for One year from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
6. a) Building occupancy capacity should not be more than 4 people per Sq. meter as per The National Building Code-2016.
b) The staircase treads and flooring shall be treated with rough finish (Grooving) to Avoid falling of children.
c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only One entrance, the capacity of the class room shall have to be limited to 45 students.

To:

M/s.Vikas Mantra Public School,
No:168/3, Anjur Village,
Mahindra World City,
Chengalpattu District.

Copy to: District officer, Chengalpattu.

22.07.2022
நிலைய அலுவலர்
தீயணைப்பு - மீட்டிங் நிர்வாகம்
மகேந்திரா போர்டு சிட்டி - 603002.

