

Tender Specification: Transformers and Cables

Item 1: Distribution Transformers

Oil-immersed distribution transformers up to 2500 kVA.

They must conform to IS 1180.

Item 2: Elastomer Insulated Cables

Elastomer insulated cables for working voltages up to and including 1100 V.

Must comply with IS 9968.

Item 3: PVC Insulated Cables

The cables must be PVC insulated (heavy duty) electric cables for working voltages up to 1100 V.

Must comply with IS 1554.