

INDIAN PUBLIC PROCUREMENT TENDER DOCUMENT

Product and Compliance Specifications

ITEM 1 - 11 kV Outdoor Oil-Immersed Distribution Transformer

Three-phase outdoor type mineral-oil-immersed distribution transformer, 1000 kVA, 11/0.433 kV, 50 Hz, suitable for continuous utility service, with off-circuit tap changer, ONAN cooling, copper windings, sealed conservator arrangement, low-loss construction and complete protection accessories. The transformer shall satisfy applicable performance, temperature-rise, dielectric, routine-test, marking and inspection requirements, with manufacturer test certificates and BIS certification evidence submitted with the bid. Applicable standard: IS 1180 (Part 1):2014.

ITEM 2 - Modular Plug and Socket-Outlets, 16 A, 250 V

13 A/16 A modular plugs and socket-outlets for indoor electrical installations, rated up to 250 V AC and moulded from flame-retardant insulating material, with secure contact pressure, shuttered socket construction where applicable, reliable terminals, and suitability for repeated insertion and withdrawal. The legacy specification reference for this test case is IS 1293:2005; bidders shall acknowledge that this is a superseded edition and that the currently applicable statutory and QCO requirements shall take precedence wherever they conflict with the legacy reference.

ITEM 3 - Ordinary Portland Cement for Structural Concrete

High-quality cement for reinforced concrete, masonry and associated civil works, supplied in fresh moisture-resistant bags with traceable batch identification and manufacturer details, exhibiting consistent setting characteristics, soundness, fineness, strength development and storage stability. The material shall conform to the applicable mandatory Quality Control Order, bear the required BIS Standard Mark and be supported by valid conformity documentation, factory test certificates and batch-wise quality records; no IS code is intentionally stated for this test case.

ITEM 4 - Crystalline Silicon Solar PV Module with Electrical Safety Compliance

Monocrystalline crystalline-silicon terrestrial photovoltaic modules, minimum 550 Wp per module, suitable for grid-connected outdoor operation, with robust framed construction, bypass diodes, weather-resistant junction box, UV-resistant cables and connectors, and documented power tolerance and degradation warranty. Design qualification and type approval shall comply with IS 14286 (Part 1/Sec 1):2023, while electrical safety and protection against electric shock, fire and mechanical hazards shall comply with IS 16221 (Part 2) and the applicable associated PV safety requirements; factory inspection and type-test reports shall be furnished with the bid.

ITEM 5 - LT Copper Power Cable, XLPE Insulated, 1.1 kV Grade

Armoured low-voltage copper power cable, 1.1 kV grade, XLPE insulated and PVC sheathed, suitable for fixed industrial and infrastructure installations, with stranded annealed copper conductors, appropriate armour, moisture-resistant outer sheath, identification markings and continuous operating temperature suitable for the insulation system. The supplied cable shall demonstrate compliance through routine and type test certificates, conductor resistance verification, insulation tests, high-voltage withstand testing and dimensional inspection, with mandatory BIS certification and conformity to IS 7098 (Part 2).