


☐ Interim
☒ Final

INSPECTION REPORT

NO. R115220719.01

BV Job nr: KHO.INI.19.206.SA.

PROJECT: Third Party Inspection for GENERATOR	Ref: KHO.INI.19.206.SA.
BV Client: Sudhir Rentals	P/o nr: N/A (client to BV)
Manufacturer: VARADA ENERGIES PVT.LTD	P/o nr: N/A (client to Manufacturer)

SUPPLY / SUBJECT OF INSPECTION	SN / TAG Nr	Owner ID No.:	QTY
VISUAL EXAMINATION AND FUNCTIONAL TEST OF GENERATOR	VEPL/2022-23-02	SG-602-40	1

DOCUMENTS OF REFERENCE : See continuation sheet for additional documents: ☐ Yes ☐ No				
Title	Reference n°	Rev.	Approved by	Date
ORIGINAL DECLARATION OF CONFORMITY	SG-602-40	-	VARADA ENERGIES PVT.LTD	2022

INSPECTIONS : <u>Inspection place & Date or Period:</u> Sudhir Rental Warehouse, DAMMAM YARD 19 , JUL , 2022 <u>Stage of inspection :</u> ☐ Before manufacturing ☐ During manufacturing ☒ Final ☐ Packing <u>Type of inspection:</u> ☐ Pre-inspection meeting ☐ Document and QC record review ☒ Visual examination, checks ☐ Witnessing tests ☐ Manufacturing progress status ☐ Vendor assessment ☒ Final inspection ☐ Packing (for details see continuation sheet) <u>Stamping :</u> ☒ No ☐ ☐		<u>Results of inspection :</u> ☒ Satisfactory ☐ Unsatisfactory <u>Non Conformities Reports (NCR):</u> o NCR's issued during reported period : N/A o List of outstanding NCR's : N/A <u>Main Conclusions & Remarks:</u> (for details see continuation sheet) Third party visual inspection of 1 unit of GENERATOR was carried out and found satisfactory at the time of Inspection. Valid Sticker Number : 01-32716 Next visit scheduled: 18 , JUL , 2023
---	--	--

☐ Interim
☒ Final**INSPECTION REPORT**

NO. R115220719.01

BV Job nr: KHO.INI.19.206.SA.

Description of the inspections carried out:**1. Introduction:**

The undersigned surveyor to Bureau Veritas acting within the scope of work along with the General condition which Regulate the intervention of the society IVS-Lifting/B&F Department at the Request of Sudhir Rentals on the purpose of Third Party Inspection .

2. Scope of Inspection :

a. Visual Inspection & Functional Test of GENERATOR

1- General Data

Equipment Type	Diesel Soundproof Generator
Manufacturer	VARADA ENERGIES PVT.LTD / 2022
Model	VEPL-40-CDP
Serial No.	VEPL/2022-23-02
Owner ID No	SG-602-40
FREQUENCY	60 HZ

2- Inspection and Test Results

Acceptance criteria	Result	Remarks
1. Document review (Original Declaration of Conformity)	Pass	Available
2. Visual inspection of Unit, wear, damage, loose connection /components, corrosion.	Pass	Found good condition.
3. Electrical,(conduct general inspection of wiring and connection cable termination, corrosion, damage	Pass	Found good condition.

➤ Conclusion:

The GENERATOR found in good condition at the time of Inspection.

Inspected by:

AHMED TAHER
EQUIPMENT INSPECTOR

Issued at Al Khobar office on 20 , JUL, 2022

Checked by:

OPERATION TEAM LEADER

