



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.
CR No. 2055011643
س.ت ٢٠٥٥٠١١٦٤٣



CERTIFICATE OF INSPECTION

Certificate No: UIC/DAM/20202464

Customer	:	Sudhir Equipment Rental Company
Location	:	Dammam, Kingdom of Saudi Arabia.
Description	:	Generator
Make	:	VARADA
Model Number	:	VEPL-60-CDP
Serial No	:	VEPL/2022-23/018
ID. No.	:	SG-624-60

This is to certify that the equipment detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Inspection: 05-Jul-2022

Due Date: 04-Jul-2023

Additional Certification

Sticker Number: 68838

Inspected By:

9

Industrial Inspector

Approved By:

QA/QC Engineer



P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢ ، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٨٨٨٢ ١٣ ٣٤٤ / فاكس ٨٨٨١ ١٣ ٣٤٤ +٩٦٦
هاتف ٥٥١٥ ٣٦٧ +٩٦٦ ١٣ ٣٦٧

Certificate No: UIC/DAM/20202464Specification:

Rated Power Prime	:	60 KVA	-	Engine Serial No :	NLHM101995
Voltage	:	220 Volts	-	Power Factor :	0.8
Phase	:	3	-	Freequency :	60Hz
Speed	:	1800 Rpm	-	Alternate Ser No :	G22B089912

Inspection and Test:

Internal Visual Test	:	Satisfactory	General Surface Test	:	Satisfactory
Compressor Shut-Down	:	Satisfactory			

Comments & Recommendations:


The Generator was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Generator.
2. Inspect the Generator regularly for damage before every use.
3. Check oil level before operation and moisture at outlet of the Generator.
4. Check the condition of the nozzles regularly.
5. Check the condition of Radiator in equal interval.
6. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.
7. **Remember - Safety always comes first!**

Inspected By:

9
INSPECTOR

Industrial Inspector



Approved By:

K. Elmaghrabi

QA/QC Engineer