

CERTIFICATE OF THOROUGH EXAMINATION OF DIESEL GENERATOR

Date of thorough examination: 22-07-2025		Date of issue: 22-07-2025		Report No.: ESICO-LFT-R25-4943	
Name & Address of employer		Location	Sticker No	Standards	
SUDHIR EQUIPMENT RENTALS COMAPNY		Riyadh	6595	SASO ISO 12100	

Equipment Identification No	Equipment Description	Safe Working Load(s)	Date of Manufacture	Manufacturer Name
SG-633-1250 OR 2532-834	DIESEL GENERATOR Model: C1250D2R Rated power factor: 0.8 Rated frequency (Hz): 60 Rating voltage: 480V Current : 400A Rating KW: 1270	1800 RPM	2007	CUMMINS


Is this the first examination after installation or assembly at a new site or location?	Yes	-	No	☒	Was the examination carried out within an interval of? - 6 Months	Yes	☒	No	-
If the answer to the above question is YES, has the equipment been installed correctly?	Yes	-	No	-	In accordance with an examination scheme?	Yes	☒	No	-
	Yes	-	No	-	After the occurrence of exceptional circumstances?	Yes	-	No	☒

Identification of any part found to have a defect which is or could become a danger to persons and a description of the defect (if none state NONE) : NONE	
Is the above an existing or imminent danger to persons, Note: This is a reportable defect?	N/A
Is the above a defect which is not yet could become a danger to persons (if YES state the date by when)	Yes by : N/A
Particulars of any repair, renewal or alteration required to remedy the defect identified above : N/A	
Particulars of any tests carried out as part of the examination (if none state NONE) : NONE	
Observation/additional comments relative to this thorough examination : At the time of inspection generator was found to be of good condition and reliable for safe operation	



☒ **Safe to operate**
Next Inspection: 21-01-2026

Inspected by: Mohamed Askar Ali



For confirmation scan QR code

Search with report number : **ESICO-LFT-R25-4943**