



الشركة العالمية لخدمات التفتيش المحدودة

UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣



## CERTIFICATE OF INSPECTION

Certificate No: UIC/RIY/20240958

Customer : **Sudhir Equipment Rental Company**

Address : Dammam, Kingdom of Saudi Arabia.

Description : **Generator**

Make : Cummins

Model : PI350C

Serial No. : G22PI509352

ID. No. : SG-637-350

This is to certify that the equipment detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Inspection: 22-APR-2024

Due Date : 21-OCT-2024

Additional Certification

Sticker Number: 135984

Inspected By:



Industrial Inspector



Approved By:

QA/QC Engineer

P.O. Box No. 2072, Jubail - 31951, K.S.A.

Tel.: +966 13 344 8882 / Fax: +966 13 344 8881

Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية

هاتف ٨٨٨٢ ١٣ ٩٦٦ / فاكس ٨٨٨١ ١٣ ٩٦٦

هاتف ٠٥١٥ ١٣ ٩٦٦

**Certificate No: UIC/RIY/20240958****Specification:**

|                 |   |          |
|-----------------|---|----------|
| Rated Power     | : | 400kW    |
| Speed           | : | 1500 RPM |
| Rated Frequency | : | 50 Hz    |
| Prime Power     | : | 350 KVA  |

|                                   |   |                         |
|-----------------------------------|---|-------------------------|
| <b><u>Reference Standards</u></b> | : | BS 5000 Part 3 IEC 34-1 |
|                                   | : | Nema MG 1-3L ISO 8528-3 |

**Inspection and Test:**

|                      |   |              |   |                      |   |              |
|----------------------|---|--------------|---|----------------------|---|--------------|
| Internal Visual Test | : | Satisfactory | - | General Surface Test | : | Satisfactory |
| Compressor Shut-Down | : | Satisfactory |   |                      |   |              |

**Comments & Recommendations:**

The Generator was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Generator.
2. Inspect the Generator regularly for damage before every use.
3. Check the operating characteristic before start the Generator.
4. Stop the engine before opening or removing engine covers.
5. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.
6. Remember - Safety always comes first!

Inspected By:



Industrial Inspector



Approved By:

QA/QC Engineer