

# Test Certificate

FOR

SALIENT POLE, SELF EXCITED / PMG EXCITED AND SELF REGULATED AC GENERATOR

Machine No. **N22E180002**

Type Test has been conducted on similar design machine  
 STANDARDS: Generator generally conforms to BS 5000 : Part 3,  
 Tested in accordance with BS EN 60034-1/IS/IEC 60034-1  
 Rotor dynamically balanced to BS ISO 1940 - 1

## ROUTINE TEST CERTIFICATE FOR BRUSHLESS AC GENERATOR:

|                  |                       |                       |                     |              |
|------------------|-----------------------|-----------------------|---------------------|--------------|
| FRAME: S4L1D-D41 | AVR: AS440            | AVR NO: 21481003/0034 | ENCLOSURE: IP23     |              |
| RATED KVA: 330   | RATED VOLTS: 400      | RATED AMPS: 476.3     | FREQUENCY: 50       | PHASE: 3     |
| POWER FACTOR: .8 | STR CONN: Series Star | STR WINDING: 311      | DUTY: Peak Stand-by | WIRE: 4-Wire |
| EXC. VOLTS: 41   | EXC.AMPS: 2.3         | AMB TEMP: 40          |                     |              |

FOR 3 PHASE SEQUENCE LOOKING FROM DRIVE END FOR CLOCKWISE ROTATION :U-V-W

| WINDING                 | COLD RESISTANCE IN Ohm(+/- 10 %) AT 22°C (MAX VALUES) | INSULATION RESISTANCE (M- Ohm) | HV TEST 2KV FOR 1 MIN | INSULATION CLASS |
|-------------------------|-------------------------------------------------------|--------------------------------|-----------------------|------------------|
| STATOR (Phase to Phase) | 0.0118                                                | 2+                             | OK                    | H                |
| ROTOR                   | 1.04                                                  | 2+                             | OK                    | H                |

## REGULATION TEST

| FREQ. | VOLTS  | AMPS  | KVA  | PF   | KW   | EXC.VOLT | EXC.AMP | % LOAD |
|-------|--------|-------|------|------|------|----------|---------|--------|
| 52    | 401.35 | 0.00  | 0.00 | 0.00 | 0.00 | 9        | .5      | 0.00   |
| 50    | 400    | 476.3 | 330  | .8   | 264  | 41       | 2.3     | 100.00 |

REGULATION = (N.L.VOLTAGE-F.L.VOLTAGE / RATED VOLTAGE)\*100 = 0.34 %

Item Description: AC Generator.S4L1D.4.D.1.311.,1.,14,AS440.Black - RAL9011

Remarks:

|                 |                     |                                                                   |
|-----------------|---------------------|-------------------------------------------------------------------|
| Date: 04-MAY-22 |                     | AUTHORISED BY<br><br><b>Nilesh V Devhare</b><br>Quality Assurance |
|                 | Job No: 4110510-001 |                                                                   |

## Certificate Of Conformity

Quality System Certification  
 ISO 9001:2015

Frame Size : **S4L1D-D41**Serial Number : **N22E180002**

Manufactured Date : 04-MAY-22

KVA: **330**Authorized By Quality Assurance: **Nilesh V Devhare**

This document is electronically generated, hence signature not required.

Print Date: 04-MAY-22