



CERTIFICATE OF THOROUGH EXAMINATION

GENERATOR

CERTIFICATE / REPORT NO : CRT-122776

STICKER NO : 092865

JOB NO : WO-33494

EQUIPMENT OWNER : 23/050 VALID TILL : 10-Nov-2024 Report No: CRT-122776 SERIAL NO: VEPL/2022-23/050 VALID TILL : 10-Nov-2024 Report No: CRT-122776 SE SUDHIR RENTALS -23/050 VALID TILL : 10-Nov-2024 Report No: CRT-122776 SERIAL NO: VEPL/2022-23/050 VALID TILL : 10-Nov-2024 Report No: CRT-122776 SE		TYPE OF INSPECTION : 23/050 VALID TILL : 10-Nov-2024 Report No: CRT-122776 SE PERIODIC VISUAL INSPECTION	
LOCATION: QIDDIYA	DATE OF INSPECTION : 11-May-2024	Frequency 6 month	Next Inspection Due 10-Nov-2024
EQUIPMENT DESCRIPTION : DIESEL ENGINE POWERED GENERATOR			
MANUFACTURER : VARADA ENERGIES PVT.LTD	MODEL/TYPE : NA	MANUFACTURED YEAR : 2022	
SERIAL NO : VEPL/2022-23/050	OWNER ID : SG-661-160	WORK PROCEDURE NO : SA-WP-06	
REFERENCE STANDARDS : ISO 8528-13:2016	DATE OF PREVIOUS INSPECTION :	PREVIOUS INSPECTION DETAILS: NA	

RATED POWER : 128 KW/160KVA	RATED FREQUENCY(HZ): 60
RATED VOLTAGE(V):400	MASS(KG): 2570
RESULT : PASS	CHECKLIST NO : 50799
REMARKS/RECOMMENDATION : AT THE TIME OF INSPECTION THE EQUIPMENT WAS FOUND IN GOOD CONDITION AND FREE FROM ALL IRREGULARITIES,HENCE IT IS SAFE FOR INTENDED USE.	

Reviewed By : MOHAMED ANWAR DEEN

Authorised Inspector : RENJI THOMAS KALLUPURACKAL



Serial NO: VEPL/2022-23/050 VALID TILL : 10-Nov-2024 Report No: CRT-122776 SERIAL NO: VEPL/2022-23/050 VALID TILL : 10-Nov-2024 Report No: CRT-122776 SE
Serial NO: VEPL/2022-23/050 VALID TILL : 10-Nov-2024 Report No: CRT-122776 SERIAL NO: VEPL/2022-23/050 VALID TILL : 10-Nov-2024 Report No: CRT-122776 SE
Serial NO: VEPL/2022-23/050 VALID TILL : 10-Nov-2024 Report No: CRT-122776 SERIAL NO: VEPL/2022-23/050 VALID TILL : 10-Nov-2024 Report No: CRT-122776 SE
Serial NO: VEPL/2022-23/050 VALID TILL : 10-Nov-2024 Report No: CRT-122776 SERIAL NO: VEPL/2022-23/050 VALID TILL : 10-Nov-2024 Report No: CRT-122776 SE

Note :This inspection certificate confirms that the inspected equipment comply with the specified requirements as per the inspection criteria.
However, this document does not constitute a conformity certificate for SABER

ملحوظة: تؤكد شهادة الفحص هذه أن المعدات التي تم فحصها تتوافق مع المتطلبات المحددة وفقا لمعايير الفحص. مع ذلك، هذه الوثيقة لا تعتبر شهادة مطابقة لمنصة سابير.

THIS CERTIFICATE BECOMES INVALID, IF ANY ALTERATION/REPAIR OR MODIFICATION IS MADE TO THE EQUIPMENT

THE CONCERNED INSPECTOR OR REPRESENTATIVE HAS THOROUGHLY EXAMINED THE EQUIPMENT IN ACCORDANCE TO THE RELEVANT STANDARDS. EXAMINATION INDICATES THAT THE SAID EQUIPMENT HAS NO APPARENT DEFECTS OR DEFORMATION WHICH MAY PROVE DANGEROUS DURING NORMAL OPERATION. THE SAID EQUIPMENT IS FOUND TO BE SATISFACTORY FOR FURTHER USE, PROVIDED THERE IS REGULAR MAINTENANCE AND OPERATED BY A CERTIFIED OPERATOR. THIS CERTIFICATE IS GRANTED SUBJECT TO THE CONDITION THAT IS AGREED & UNDERSTOOD THAT STANDARD ARABIA INSPECTION CO. LTD.'S LIABILITY SHALL BE LIMITED TO THE ACTS OF ITS EMPLOYEES ON PREMISES OF SUBCONTRACTORS. UNDER NO CIRCUMSTANCES WHATSOEVER SHALL STANDARD ARABIA INSPECTION CO. LTD. BE LIABLE FOR ANY INJURY OR DAMAGE TO ANY PERSON OR OCCURRING AS A RESULT OF NEGLIGENT OPERATION OR ANY DEFECT IN MATERIALS, MACHINERY, EQUIPMENT OR SYSTEMS OTHER THAN DEFECTS ASCERTAINABLE DURING ROUTINE INSPECTION. WE HEREBY REPORT THAT THE ALL PARTICULARS IN THIS REPORT ARE CORRECT AT THE TIME OF TEST / INSPECTION & OPERATIONAL MAINTENANCE IS THE SOLE RESPONSIBILITY OF THE EQUIPMENT OWNER.

THIS CERTIFICATE IS GENERATED AND AUTHORIZED ELECTRONICALLY AND CAN BE CONSIDERED AS ORIGINAL. TO VERIFY THE AUTHENTICITY OF THIS CERTIFICATE, PLEASE SCAN THE QR CODE.

CERTIFICATE OF THOROUGH EXAMINATION

GENERATOR

CERTIFICATE / REPORT NO : CRT-122777

STICKER NO : 092866

JOB NO : WO-33494

EQUIPMENT OWNER : 21/0055 VALID TILL : 10-Nov-2024 Report No: CRT-122777 SERIAL NO: VEPL/2020-21/0055 VALID TILL : 10-Nov-2024 Report No: CRT-122777		TYPE OF INSPECTION : 21/0055 VALID TILL : 10-Nov-2024 Report No: CRT-122777 SERIAL NO: VEPL/2020-21/0055 VALID TILL : 10-Nov-2024 Report No: CRT-122777	
SUDHIR RENTALS 21/0055 VALID TILL : 10-Nov-2024 Report No: CRT-122777 SERIAL NO: VEPL/2020-21/0055 VALID TILL : 10-Nov-2024 Report No: CRT-122777		PERIODIC VISUAL INSPECTION 21/0055 VALID TILL : 10-Nov-2024 Report No: CRT-122777 SERIAL NO: VEPL/2020-21/0055 VALID TILL : 10-Nov-2024 Report No: CRT-122777	
LOCATION: QIDDIYA	DATE OF INSPECTION : 11-May-2024	Frequency 6 month	Next Inspection Due 10-Nov-2024
EQUIPMENT DESCRIPTION : DIESEL ENGINE POWERED GENERATOR 21/0055 VALID TILL : 10-Nov-2024 Report No: CRT-122777 SERIAL NO: VEPL/2020-21/0055 VALID TILL : 10-Nov-2024 Report No: CRT-122777			
MANUFACTURER : VARADA ENERGIES PVT.LTD		MODEL/TYPE : NA	MANUFACTURED YEAR : 2021
SERIAL NO : VEPL/2020-21/0055		OWNER ID : SG-487-160	WORK PROCEDURE NO : SA-WP-06
REFERENCE STANDARDS : ISO 8528-13:2016		DATE OF PREVIOUS INSPECTION :	PREVIOUS INSPECTION DETAILS: NA

RATED POWER : 128 KW/160KVA	RATED FREQUENCY(HZ): 60
RATED VOLTAGE(V):400	MASS(KG): 2570
RESULT : PASS	CHECKLIST NO : 50800

REMARKS/RECOMMENDATION :

AT THE TIME OF INSPECTION THE EQUIPMENT WAS FOUND IN GOOD CONDITION AND FREE FROM ALL IRREGULARITIES,HENCE IT IS SAFE FOR INTENDED USE.

Reviewed By :

Authorised Inspector : RENJI THOMAS KALLUPURACKAL



22

Note: This inspection certificate confirms that the inspected equipment comply with the specified requirements as per the inspection criteria. However, this document does not constitute a conformity certificate for SABER.

ملحوظة: تؤكد شهادة الفحص هذه أن المعدات التي تم فحصها تتوافق مع المتطلبات المحددة وفقاً لمعايير الفحص. مع ذلك، هذه الوثيقة لا تعتبر شهادة مطابقة لمنصة سابر.

THIS CERTIFICATE BECOMES INVALID, IF ANY ALTERATION/REPAIR OR MODIFICATION IS MADE TO THE EQUIPMENT

THE CONCERNED INSPECTOR OR REPRESENTATIVE HAS THOROUGHLY EXAMINED THE EQUIPMENT IN ACCORDANCE TO THE RELEVANT STANDARDS. EXAMINATION INDICATES THAT THE SAID EQUIPMENT HAS NO APPARENT DEFECTS OR DEFORMATION WHICH COULD PROVE DANGEROUS DURING NORMAL OPERATION. THE SAID EQUIPMENT IS FOUND TO BE SATISFACTORY FOR FURTHER USE. PROVIDED HERE IS REGULAR MAINTENANCE AND OPERATED BY A CERTIFIED OPERATOR. THIS CERTIFICATE IS GRANTED SUBJECT TO THE CONDITION THAT IS AGREED & UNDERSTOOD THAT STANDARD ARABIA INSPECTION CO. LTD.'S LIABILITY SHALL BE LIMITED TO THE ACTS OF ITS EMPLOYEES ON PREMISES OF SUBCONTRACTORS. UNDER NO CIRCUMSTANCES WHATSOEVER SHALL STANDARD ARABIA INSPECTION CO. LTD. BE LIABLE FOR ANY INJURY OR DAMAGE TO ANY PERSON OR OCCURRING AS A RESULT OF NEGLIGENT OPERATION OR ANY DEFECT IN MATERIALS, MACHINERY, EQUIPMENT OR SYSTEMS OTHER THAN DEFECTS ASCERTAINABLE DURING ROUTINE INSPECTION. WE HEREBY REPORT THAT THE ALL PARTICULARS IN THIS REPORT ARE CORRECT AT THE TIME OF TEST / INSPECTION & OPERATIONAL MAINTENANCE IS THE SOLE RESPONSIBILITY OF THE EQUIPMENT OWNER.

THIS CERTIFICATE IS GENERATED AND AUTHORIZED ELECTRONICALLY AND CAN BE CONSIDERED AS ORIGINAL. TO VERIFY THE AUTHENTICITY OF THIS CERTIFICATE, PLEASE SCAN THE QR CODE.



CERTIFICATE OF THOROUGH EXAMINATION

GENERATOR

CERTIFICATE / REPORT NO : CRT-122778

STICKER NO : 092867

JOB NO : WO-33494

EQUIPMENT OWNER : 23/013 VALID TILL : 10-Nov-2024 Report No: CRT-122778 SERIAL NO: VEPL/2022-23/013 VALID TILL : 10-Nov-2024 Report No: CRT-122778 SE SUDHIR RENTALS -23/013 VALID TILL : 10-Nov-2024 Report No: CRT-122778 SERIAL NO: VEPL/2022-23/013 VALID TILL : 10-Nov-2024 Report No: CRT-122778 SE		TYPE OF INSPECTION : 23/013 VALID TILL : 10-Nov-2024 Report No: CRT-122778 SE PERIODIC VISUAL INSPECTION	
LOCATION: QIDDIYA	DATE OF INSPECTION : 11-May-2024	Frequency 6 month	Next Inspection Due 10-Nov-2024
EQUIPMENT DESCRIPTION : DIESEL ENGINE POWERED GENERATOR			
MANUFACTURER : VARADA ENERGIES PVT.LTD	MODEL/TYPE : NA	MANUFACTURED YEAR : 2022	
SERIAL NO : VEPL/2022-23/013	OWNER ID : SG-612-160	WORK PROCEDURE NO : SA-WP-06	
REFERENCE STANDARDS : ISO 8528-13:2016	DATE OF PREVIOUS INSPECTION :	PREVIOUS INSPECTION DETAILS: NA	

RATED POWER : 128 KW/160KVA	RATED FREQUENCY(HZ): 60
RATED VOLTAGE(V):400	MASS(KG): 2570
RESULT : PASS	CHECKLIST NO : 50801
REMARKS/RECOMMENDATION : AT THE TIME OF INSPECTION THE EQUIPMENT WAS FOUND IN GOOD CONDITION AND FREE FROM ALL IRREGULARITIES,HENCE IT IS SAFE FOR INTENDED USE.	

Reviewed By : MOHAMED ANWAR DEEN

Authorised Inspector : RENJI THOMAS KALLUPURACKAL



SERIAL NO: VEPL/2022-23/013 VALID TILL : 10-Nov-2024 Report No: CRT-122778 SERIAL NO: VEPL/2022-23/013 VALID TILL : 10-Nov-2024 Report No: CRT-122778 SE
SERIAL NO: VEPL/2022-23/013 VALID TILL : 10-Nov-2024 Report No: CRT-122778 SERIAL NO: VEPL/2022-23/013 VALID TILL : 10-Nov-2024 Report No: CRT-122778 SE
SERIAL NO: VEPL/2022-23/013 VALID TILL : 10-Nov-2024 Report No: CRT-122778 SERIAL NO: VEPL/2022-23/013 VALID TILL : 10-Nov-2024 Report No: CRT-122778 SE
SERIAL NO: VEPL/2022-23/013 VALID TILL : 10-Nov-2024 Report No: CRT-122778 SERIAL NO: VEPL/2022-23/013 VALID TILL : 10-Nov-2024 Report No: CRT-122778 SE

Note :This inspection certificate confirms that the inspected equipment comply with the specified requirements as per the inspection criteria.
However, this document does not constitute a conformity certificate for SABER

ملحوظة: تؤكد شهادة الفحص هذه أن المعدات التي تم فحصها تتوافق مع المتطلبات المحددة وفقا لمعايير الفحص. مع ذلك، هذه الوثيقة لا تعتبر شهادة مطابقة لمنصة سابير.

THIS CERTIFICATE BECOMES INVALID, IF ANY ALTERATION/REPAIR OR MODIFICATION IS MADE TO THE EQUIPMENT

THE CONCERNED INSPECTOR OR REPRESENTATIVE HAS THOROUGHLY EXAMINED THE EQUIPMENT IN ACCORDANCE TO THE RELEVANT STANDARDS. EXAMINATION INDICATES THAT THE SAID EQUIPMENT HAS NO APPARENT DEFECTS OR DEFORMATION WHICH MAY PROVE DANGEROUS DURING NORMAL OPERATION. THE SAID EQUIPMENT IS FOUND TO BE SATISFACTORY FOR FURTHER USE, PROVIDED THERE IS REGULAR MAINTENANCE AND OPERATED BY A CERTIFIED OPERATOR. THIS CERTIFICATE IS GRANTED SUBJECT TO THE CONDITION THAT IS AGREED & UNDERSTOOD THAT STANDARD ARABIA INSPECTION CO. LTD.'S LIABILITY SHALL BE LIMITED TO THE ACTS OF ITS EMPLOYEES ON PREMISES OF SUBCONTRACTORS. UNDER NO CIRCUMSTANCES WHATSOEVER SHALL STANDARD ARABIA INSPECTION CO. LTD. BE LIABLE FOR ANY INJURY OR DAMAGE TO ANY PERSON OR OCCURRING AS A RESULT OF NEGLIGENT OPERATION OR ANY DEFECT IN MATERIALS, MACHINERY, EQUIPMENT OR SYSTEMS OTHER THAN DEFECTS ASCERTAINABLE DURING ROUTINE INSPECTION. WE HEREBY REPORT THAT THE ALL PARTICULARS IN THIS REPORT ARE CORRECT AT THE TIME OF TEST / INSPECTION & OPERATIONAL MAINTENANCE IS THE SOLE RESPONSIBILITY OF THE EQUIPMENT OWNER.

THIS CERTIFICATE IS GENERATED AND AUTHORIZED ELECTRONICALLY AND CAN BE CONSIDERED AS ORIGINAL. TO VERIFY THE AUTHENTICITY OF THIS CERTIFICATE, PLEASE SCAN THE QR CODE.