

CERTIFICATE OF THOROUGH EXAMINATION

GENERATOR

CERTIFICATE / REPORT NO : CRT-114280

STICKER NO : 92302

JOB NO : WO-31356

EQUIPMENT OWNER : SUDHIR RENTALS		TYPE OF INSPECTION : PERIODIC VISUAL INSPECTION	
LOCATION: DAMMAM	DATE OF INSPECTION : 20-Feb-2024	Frequency 6 month	Next Inspection Due 19-Aug-2024
EQUIPMENT DESCRIPTION : DIESEL GENERATOR WITH CAPACITY OF 125 KVA			
MANUFACTURER : ASHOK LEYLAND	MODEL/TYPE : VEPL-125-CDP		MANUFACTURED YEAR : 2017
SERIAL NO : SG12.5-45	OWNER ID : SG-676-125		WORK PROCEDURE NO : SA-WP-06
REFERENCE STANDARDS : ISO 8528-13:2016	DATE OF PREVIOUS INSPECTION :		PREVIOUS INSPECTION DETAILS:

POWER RATING (KVA)	125
RATED CURRENT (AMP)	173.91
ELECTRIC POWER (KWE)	100
RESULT : SATISFACTORY	CHECKLIST NO : TS - 46352
REMARKS/RECOMMENDATION : AT THE TIME OF INSPECTION, THE GENERATOR WAS VISUALLY AND FUNCTIONALLY EVALUATED AND WAS FOUND TO BE IN GOOD WORKING CONDITION. IT IS OBSERVED TO BE FREE FROM ANY APPARENT DEFECTS.	

Reviewed By : MOHAMED ANWAR DEEN

Authorised Inspector : ALI MOHAMMED ALI ALSHAHRANI



THIS CERTIFICATE BECOMES INVALID, IF ANY ALTERATION/REPAIR OR MODIFICATION IS MADE TO THE EQUIPMENT

THE CONCERNED INSPECTOR OR REPRESENTATIVE HAS THOROUGHLY EXAMINED THE EQUIPMENT IN ACCORDANCE TO THE RELEVANT STANDARDS. EXAMINATION INDICATES THAT THE SAID EQUIPMENT HAS NO APPARENT DEFECTS OR DEFORMATION WHICH MAY PROVE DANGEROUS DURING NORMAL OPERATION. THE SAID EQUIPMENT IS FOUND TO BE SATISFACTORY. FURTHER SERVICE PROVIDED HEREIN IS LIMITED TO THE NORMAL OPERATION OF THE EQUIPMENT. THIS CERTIFICATE IS GRANTED SUBJECT TO THE CONDITION THAT IS AGREED & UNDERSTOOD THAT STANDARD ARABIA INSPECTION CO. LTD.'S LIABILITY SHALL BE LIMITED TO THE ACTS OF ITS EMPLOYEES ON PREMISES OF SUBCONTRACTORS. UNDER NO CIRCUMSTANCES WHATSOEVER SHALL STANDARD ARABIA INSPECTION CO. LTD. BE LIABLE FOR ANY INJURY OR DAMAGE TO ANY PERSON OR OCCURRING AS A RESULT OF NEGLIGENT OPERATION OR ANY DEFECT IN MATERIALS, MACHINERY, EQUIPMENT OR SYSTEMS OTHER THAN DEFECTS ASCERTAINABLE DURING ROUTINE INSPECTION. WE HEREBY REPORT THAT THE ALL PARTICULARS IN THIS REPORT ARE CORRECT AT THE TIME OF TEST / INSPECTION & OPERATIONAL MAINTENANCE IS THE SOLE RESPONSIBILITY OF THE EQUIPMENT OWNER.

THIS CERTIFICATE IS GENERATED AND AUTHORIZED ELECTRONICALLY AND CAN BE CONSIDERED AS ORIGINAL. TO VERIFY THE AUTHENTICITY OF THIS CERTIFICATE, PLEASE SCAN THE QR CODE.