



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت. ٢٠٥٥٠١١٦٤٣

CERTIFICATE OF INSPECTION

Certificate No: UIC/RIY/20250923

Customer : Sudhir Equipment Rental Company.
Location : Dammam, Kingdom of Saudi Arabia.
Description : Generator
Make : Varada Energies
Model : VEPL-650-CDP
Serial Number : VEPL/2022-23/066
ID Number : SG-685-650

This is to certify that the device detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Inspection : 27-MAR-2025

Due Date : 26-SEP-2025

Additional Certification

Sticker Number: 215693


Inspected By:



Industrial Inspector



Approved By:


QA/QC Engineer

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب. ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٨٨٨٢ ١٣ ٩٦٦ / فاكس ٨٨٨١ ١٣ ٩٦٦
هاتف ٠٥١٥ ٣٦٧ ١٣ ٩٦٦

Certificate No: UIC/RIY/20250923**Specifications:**

Rated Power in KVA	:	650KVA	Phase	:	3 Phase
Frequency	:	60 Hz	Rating	:	24 Kw
Rated Voltage	:	400 V	PF	:	0.8
Speed	:	1800 Rpm			

Reference Standards:*BS 5000 Part 3 IEC 34-1**Nema MG 1-3L ISO 8528-3**BSEW 60034-1***Comments & Recommendations:***The Generator was found to be of good working condition and reliable for safe operation.*

- 1. Do not exceed the capacity of the Generator.*
- 2. Inspect the Generator regularly for damage before every use.*
- 3. Check oil level before operation and moisture at outlet of the Generator.*
- 4. Check the condition of Control panel.*
- 5. Remember - Safety always comes first!***

Inspected By:



Industrial Inspector



Approved By:

QA/QC Engineer