



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت. ٢٠٥٥٠١١٦٤٣



CERTIFICATE OF INSPECTION

Certificate No: UIC/DAM/20242180

Customer : Sudhir Equipment Rental Company
Location : 2nd Industry Dammam Yard, Kingdom of Saudi Arabia.
Description : Generator
Make : Varada Energies Pvt.Ltd.
Model : N/A
Serial Number : VEPL/2022-23/120
ID Number : SG-726-500
Capacity : 500.0 KVA

This is to certify that the description detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Inspection: 25-MAR-2024

Due Date: 24-SEP-2024

Additional Certification

Sticker Number: 147026

Inspected By:



Industrial Inspector



Approved By:

QA/QC Engineer

Certificate No: UIC/DAM/20242180**Specification:**

Rated Power in KVA	:	500.0 KVA	-	Speed	:	1800 RPM
Rated Power Factor	:	0.8	-	Rated Frequency	:	60 Hz
Rated Voltage	:	400 V	-	Phases	:	3Ø
Weight	:	7050 kg	-	Rating KW	:	400

Inspection and Test:

Internal Visual Test	:	Satisfactory	-	General Surface Test:	Satisfactory
Generator Shut-Down	:	Satisfactory			

Comments & Recommendations:

The **Generator** was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the **Generator**.
2. Inspect the **Generator** regularly for damage before every use.
3. Check oil level before operation and moisture at outlet of the **Generator**.
4. Check the condition of the nozzles regularly.
5. Check the condition of Radiator in equal interval.
6. Check the operating characteristic before start the **Generator**.
7. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.

8. Remember - Safety always comes first!

Inspected By:



Industrial Inspector



Approved By:

QA/QC Engineer

No. 23104

Company Name & Address of the Site Location:

Company / Customer Name : Sunghid Equipment Ltd Purchase Order No. : 95/03/2010

Mr. /Mrs: _____

Date Of Calibration / Inspection : 23/05/2024

Mobile/Tel. No.: _____

Calibration / Inspection Validity : _____ 6M / 1Y _____

Email ID : hr@himalayabioscience.com

Location : 2nd floor

[illegible]

Cal. Engr/Insp. Sign: [Signature] Name: mt. Shikhar

(Client Sign) [Signature] Name: Asif

Witnessed & Approved by

Contact No: 088222 8031 Site Location: _____