

CERTIFICATE OF THOROUGH EXAMINATION OF ELECTRIC POWER EQUIPMENTS

Date of thorough examination : 26-06-2025		Date of issue : 26-06-2025		Report No. : ESICO-LFT-R25-4622	
Name & Address of employer		Location		Sticker No	Standards
SUDHIR EQUIPMENT RENTALS COMAPNY		Riyadh		6274	IEC 60034-1, ISO 8528
Equipment Identification No	Equipment Description	Safe Working Load(s)	Date of Manufacture	Manufacturer Name	
SG-736-40 OR VEPL/2022-23/139	DIESEL GENERATOR Rated power factor: 0.8 Rated frequency(Hz): 60 Rating voltage: 400 Rating KW: 32 PH: 3 Mass: 1680 kg	N/A	2022	VARADA ENERGIES	
Is this the first examination after installation or assembly at a new site or location?		Was the examination carried out within an interval of? - 6 Months			
Yes - No ✗		Yes ✓ No -			
If the answer to the above question is YES, has the equipment been installed correctly?		In accordance with an examination scheme?			
Yes - No -		Yes ✓ No -			
		After the occurrence of exceptional circumstances?			
		Yes - No ✗			
Identification of any part found to have a defect which is or could become a danger to persons and a description of the defect (if none state NONE) : NONE					
Is the above an existing or imminent danger to persons, Note: This is a reportable defect?					N/A
Is the above a defect which is not yet could become a danger to persons (if YES state the date by when)				Yes by : N/A	
Particulars of any repair, renewal or alteration required to remedy the defect identified above : N/A					
Particulars of any tests carried out as part of the examination (if none state NONE) : NONE					
Observation/additional comments relative to this thorough examination : At the time of inspection generator was found to be of good condition and reliable for safe operation					



For confirmation scan QR code
search with report number : ESICO-LFT-R25-4622



Safe to operate

Next Inspection : 25-12-2025

Inspected by : Mohamed Askar Ali

