



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.
CR No.2055011643 س.ت. ٢٠٥٥٠١٦٤٣



CERTIFICATE OF INSPECTION

Certificate No: UIC/20247719

Customer : Sudhir Equipment Rental Company
Address : Dammam, Kingdom of Saudi Arabia
Description : Generator
Make : VARADA
Model : VEPL-300-CDP
Serial No : VEPL/2022-23-244
ID. No. : SG-789-350
Capacity : 350 KVA

This is to certify that the equipment detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Inspection: 07-Sep-2023

Due Date: 06-Sep-2024

Additional Certification

Sticker Number: 106775

Inspected By:

20
INSPECTOR
Industrial Inspector



Approved By:

QA/QC Department

P.O.Box No.2072, Jubail-31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب. ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف: +٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس: +٩٦٦ ١٣ ٣٤٤ ٨٨٨١
هاتف: +٩٦٦ ١٣ ٣٦٧ ٠٥١٥

Certificate No: UIC/20247719**Specification:**

Capacity KVA	:	350 KVA	-	Manufacture Year	:	2023
Speed	:	1800 Rpm	-	Engine S/N	:	3008602361
Factor	:	0.8	-	Rated Frequency	:	60 Hz
Set Performance	:	H	-	Rated Voltage	:	400 Volts
Phase	:	3	-	Cycle	:	4 Strokes
Engine Make	:	Volvo	-	Engine Model	:	TAD843GE
Alternator S/N	:	N211389093				

Inspection and Test:

Internal Visual Test	:	Satisfactory	General Surface Test	:	Satisfactory
Compressor Shut-Down	:	Satisfactory			

Comments & Recommendations:

The Generator was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Generator.
2. Inspect the Generator regularly for damage before every use.
3. Check oil level before operation and moisture at outlet of the Generator.
4. Check the condition of the nozzles regularly.
5. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.
6. **Remember - Safety always comes first!**

**Industrial Inspector****Approved By:****QA/QC Department**



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

CR No.2055011643

س.ت ٢٠٥٥٠١١٦٤٣



CERTIFICATE OF INSPECTION

Certificate No: UIC/20247720

Customer : **Sudhir Equipment Rental Company**
Address : Dammam, Kingdom of Saudi Arabia
Description : **Generator**
Make : VARADA
Model : VEPL-300-CDP
Serial No : VEPL/2022-23-225
ID. No. : SG-791-350
Capacity : 350 KVA

This is to certify that the equipment detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Inspection: 07-Sep-2023

Due Date: 06-Sep-2024

Additional Certification

Sticker Number: 106776

Inspected By:

Industrial Inspector



Approved By:

QA/QC Department

P.O.Box No.2072, Jubail-31951, K.S.A.

Tel.: +966 13 344 8882 / Fax: +966 13 344 8881

Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢ ، الجبيل ٣١٩٥١ - المملكة العربية السعودية

هاتف : +٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس : +٩٦٦ ١٣ ٣٤٤ ٨٨٨١

هاتف : +٩٦٦ ١٣ ٣٦٧ ٠٥١٥

Certificate No: UIC/20247720**Specification:**

Capacity KVA	:	350 KVA	-	Manufacture Year	:	2023
Speed	:	1800 Rpm	-	Engine S/N	:	3008603030
Factor	:	0.8	-	Rated Frequency	:	60 Hz
Set Performance	:	H	-	Rated Voltage	:	400 Volts
Phase	:	3	-	Cycle	:	4 Strokes
Engine Make	:	Volvo	-	Engine Model	:	TAD843GE
Alternator S/N	:	N211389047				

Inspection and Test:

Internal Visual Test	:	Satisfactory	General Surface Test	:	Satisfactory
Compressor Shut-Down	:	Satisfactory			

Comments & Recommendations:

The Generator was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Generator.
2. Inspect the Generator regularly for damage before every use.
3. Check oil level before operation and moisture at outlet of the Generator.
4. Check the condition of the nozzles regularly.
5. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.
6. **Remember - Safety always comes first!**

Inspected By:

20
INSPECTOR
Industrial Inspector



Approved By:

QA/QC Department

No. 10517

Client Name & Address of the Site Location:

Mr./Mrs: Sudhir Rentals

Purchase Order No : _____

Designation: _____

Date Of Calibration / Inspection : 07-SEP-2023

Tel. No.: _____

Calibration /Inspection Validity : _____ 6M / 1Y ✓

Fax No.: _____

Location : _____

[illegible]

Calibration Engr Sign: Sumit Name: Shah Abdullah

(Client Sign) _____ Name: Kahaf Contact No: 0572555316 Site Location: _____
 Witnessed & Approved by _____