



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

CR No.2055011643

س.ت ٢٠٥٥٠١١٦٤٣



CERTIFICATE OF INSPECTION

CERTIFICATE NO: UIC/JED/20139763

Customer : SUDHIR EQUIPMENT RENTAL COMPANY
Address : JEDDAH - KINGDOM OF SAUDI ARABIA.
Description : POWER GENERATOR
Manufacturer : VARADA ENERGIES
Model : N/A
Serial No. : VEPL/2023-24/159
Equipment ID. No. : SG-841-750
Capacity : 750 kVA / 600 kW

This is to certify that the equipment detailed hereby have been tested against traceable International Standards for VISUAL & FUNCTIONAL INSPECTION only on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Inspection : 26-FEB-2024

Due Date : 25-AUG-2024

Additional Certification


Sticker Number: 127270

Inspected By:


Industrial Inspector



Approved By:


QA/QC Engineer

P.O.Box No.2072, Jubail-31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢ ، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف : +٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس : +٩٦٦ ١٣ ٣٤٤ ٨٨٨١
هاتف : +٩٦٦ ١٣ ٣٦٧ ٠٥١٥

CERTIFICATE NO: UIC/JED/20139763**Specifications:**

Prime Power	:	750kVA / 600 kW	Voltage	:	400V
Frequency	:	60 Hz	Power factor	:	0.8COS

Reference Standards:

NFPA 110

Comments & Recommendations:

The **Power Generator** was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Power Generator.
2. Inspect the Power Generator regularly for damage before every use.
3. Check oil level before operation of the Power Generator.
4. Check the condition of Control panel.
5. Check the operating characteristic before start the Power Generator.
6. Stop the engine before opening or removing engine covers.
7. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.

8. Remember – Safety always comes first!

Inspected By:

UIC
36
Industrial Inspector



Approved By:

QA/QC Engineer