



REPORT OF INSPECTION

Cert. No.: 1804671	Date of Examination: 25/12/2024	Sticker No.: 01-68274
Equipment Owner	SUDHIR	
Place of Inspection	DAMMAM YARD	
Equipment Type	AIR COMPRESSOR	
Manufacturer Name	DOOSAN	
Owner ID	SAC-185-048	
Serial No.	000412BCAGJ01	
Model	C185WKUB-T2	
Rated Power	185 CFM	
Max. Operating Pressure	6.9 BAR	
Rated Speed	-	

At the request of SUDHIR, Surveyor to BUREAU VERITAS, acting within the General Conditions of Services of the Society, attended on 25/12/2024 at DAMMAM YARD to witness Test and/or to carry out Thorough Examination of the above-mentioned equipment as per client requirement.

Inspection Activities:

Prior to commencing performance test, visual inspection of the equipment was carried out and no visible defects were observed. The equipment was then operated to all the functions to verify the performance of the equipment.

Result of Inspection:

Based on the visual inspection of the AIR COMPRESSOR and upon post-performance test & thorough examination, the above mentioned equipment has been found free from damage and/or permanent deformation at the time of inspection & is considered to be safe for further use, subject to continuous maintenance being applied and qualified operator being employed.

Remarks:

- Maintain regular maintenance.
- Maintain regular housekeeping.

Next Inspection Due on or before: 24/06/2025

Issued at Al Khobar on 30/12/2024

Inspected by

Signature:

Name: Hammad AHMED

Position: Inspector



Reviewed by

Signature:

Name: Abdullah SHEHRI

Position: Operations Manager

The technical conclusions thus expressed may have to be reconsidered in light of any modifications or alterations that would invalidate the data shown in the present certificate. These conclusions would become null & void should Bureau Veritas not be kept informed of such modifications or alterations with specific reference to the present certificate.

Any person not a party to the contract pursuant to which this document is delivered may not assert a claim against Bureau Veritas for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by the personnel of the Society or of its Agents in the establishment or issuance of this document, and in connection with any activities for which it may provide.

This not is NOT an indication that the item(s) is (are) fit for any specific purpose and does not release the manufacture, supplier and any party from their respective duty, guarantee, obligation and/or indemnity relating to, without limitation patents, workmanship, materials, safety, performance in operation and/or reliability.



CHECKLIST OF TEST AND THOROUGH EXAMINATION

Inspection Sticker No.: 01-68274		Date of Examination: 25/12/2024
DESCRIPTION		CONDITION/REMARKS
1.	Physical condition of the compressor tank	Satisfactory
2.	Condition of the motor	Satisfactory
3.	Condition of the piston	Satisfactory
4.	Display panel / pressure gauges	Satisfactory
5.	Safety valve	Satisfactory
6.	Condition of all valves	Satisfactory
7.	Protective covering	Satisfactory
8.	Any unnecessary vibration observed	Satisfactory
9.	Grounding	Satisfactory
10.	Ventilation condition	Satisfactory
11.	Markings & safety signage	Satisfactory
12.	Lifting points (if any)	Satisfactory
13.	Supporting legs / foundation structure	Satisfactory
14.	Name plate	Satisfactory
Remarks:		

Inspector to Bureau Veritas
Signature:




Name: Hammad AHMED
Position: Inspector

The technical conclusions thus expressed may have to be reconsidered in light of any modifications or alterations that would invalidate the data shown in the present certificate. These conclusions would become null & void should Bureau Veritas not be kept informed of such modifications or alterations with specific reference to the present certificate.

Any person not a party to the contract pursuant to which this document is delivered may not assert a claim against Bureau Veritas for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by the personnel of the Society or of its Agents in the establishment or issuance of this document, and in connection with any activities for which it may provide.

This not is NOT an indication that the item(s) is (are) fit for any specific purpose and does not release the manufacture, supplier and any party from their respective duty, guarantee, obligation and/or indemnity relating to, without limitation patents, workmanship, materials, safety, performance in operation and/or reliability.

