



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO: UIC/DAM/10935

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer	Sudhir Equipment Rental Company		
Address	Dammam, Kingdom of Saudi Arabia		
Description	Pressure Relief Valve		
Manufacturer	Doosan		
Model	N/A		
Serial No.	2118034	Receipt Date	: 06-Nov-22
ID No.	SAC-435-081	Calibration Date	: 06-Nov-22
Location	Calibration Lab(Dammam)	Calibration Due Date	: 05-Nov-23


The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements

Reference Standard Equipment Used

Description	Model / Cert. No.	Serial No	Due Date
High Pressure Pneumatic Pressure Source	DSC-21-01475	214E191209	20-Mar-23
Digital Pressure Calibrator	DSC-21-01474	223162191108	20-Mar-23

Calibrated By

Calibration Engineer



Approved By

QA/QC Engineer

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٨٨٨٢ ٣٤٤ ١٣ / فاكس ٨٨٨١ ٣٤٤ ١٣ +٩٦٦
هاتف ٠٥١٥ ٣٦٧ ١٣ +٩٦٦

CERTIFICATE NO: UIC/DAM/10935		Page 2 of 2
Customer	Sudhir Equipment Rental Company	
Address	Dammam, Kingdom of Saudi Arabia	
Description	Pressure Relief Valve	Calibration Date 06-Nov-22
Manufacturer	Doosan	Calibration Due Date 05-Nov-23
Model	N/A	Temperature 23.4°C
Serial No.	2118034	Relative Humidity RH 48%
ID No.	SAC-435-081	

Test Results

Set Pressure : 17.00 Bar	Spring Range : N/A
Back Pressure : 0.00 Bar	Size Inlet/Outlet : 3/4" X 1"
CDTP : 17.00 Bar	Type of Valve : Metal Seated
Setting Accuracy : ± 3 % of Setting	Test Medium : Air/Water/Oil/Gas
Pop Test : PASSED	

BASIS OF TEST:

Ref Standard ASME Sec VIII, Div I

Summary of Test Procedure:

The Calibration of above Pressure relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.


Traceability:

The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company maintains Traceability to the third party.

Condition of Instrument

With in the tolerance on receipt(as found)	No
The instrument was adjusted	Yes
The instrument was repaired	No

++++ End of the Certificate +++++



Calibrated By:
Calibration Engineer



Approved by:
QA/QC Engineer