



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت. ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO: UIC/DAM/29819

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer **Sudhir Equipment Rental Company**

Address Dammam, Kingdom of Saudi Arabia

Description **Pressure Relief Valve**

Manufacturer Doosan

Model N/A

Serial No. 2206198

Receipt Date : 20-Apr-24

ID. No. SAC-435-083

Calibration Date : 20-Apr-24

Location Calibration Lab (Dammam)

Calibration Due Date : 19-Oct-24

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements

Reference Standard Equipment Used

Description	Model / Cert. No.	Serial No	Due Date
High Pressure Pneumatic Pressure Source	2024001135	2000E2208001	18-Feb-25
Digital Pressure Calibrator	2024001136	2232209002	13-Feb-25

Calibrated By

40
Calibration Engineer

Approved By

QA/QC Engineer

UIC-QP-7.8-24 F02, REV 0

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.

Tel.: +966 13 344 8882 / Fax: +966 13 344 8881

Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب. ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية

هاتف ٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس ٩٦٦ ١٣ ٣٤٤ ٨٨٨١

هاتف ٩٦٦ ١٣ ٣٦٧ ٠٥١٥

CERTIFICATE NO: UIC/DAM/29819

Page

2 of 2

Customer **Sudhir Equipment Rental Company**
Address Dammam, Kingdom of Saudi Arabia

Description **Pressure Relief Valve**
Manufacturer Doosan
Model N/A
Serial No. 2206198
ID. No. SAC-435-083

Calibration Date 20-Apr-24
Calibration Due Date 19-Oct-24
Temperature Range 23.5°C
Relative Humidity RH 48%

Test Results

Set Pressure : 250.00 Psi Spring Range : N/A
 Back Pressure : 0.00 Psi Size Inlet/Outlet : 3/4" x 1"
 CDP : 250.00 Psi Type of Valve : Metal Seated
 Setting Accuracy : $\pm 3\%$ of Setting Test Medium : Air/Water/Oil/Gas
 Pop Test : PASSED

BASIS OF TEST:

Ref Standard ASME Sec VIII, Div I

Summary of Test Procedure:

The Calibration of above Pressure relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.

Traceability:

The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company maintains Traceability to the third party.

Condition of Instrument

With in the tolerance on receipt(as found)	Yes
The instrument was adjusted	No
The instrument was repaired	No

***** End of the Certificate *****



Calibrated By: Calibration Engineer



UIC-QP-7.8-24-162, REV 0

Approved by: QA/QC Engineer