



الشركة العالمية لخدمات التفتيش المحدودة

UNIVERSAL INSPECTION CO. LTD.

CR No.2055011643

س.ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO: UIC/HAR/ 32437

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer **Sudhir Equipment Rental Company.**

Address Haradh, Kingdom of Saudi Arabia

Description Pressure Relief Valve

Manufacturer N/A

Type SN50

Serial No. 23085

ID No. N/A

Location Calibration Lab (Haradh)

Receipt Date : 08-Feb-24

Calibration Date : 09-Feb-24

Calibration Due Date : 08-Aug-24

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements

Reference Standard Equipment Used

Description	Cert. No./Model	Serial No	Due Date
High Pressure Pneumatic Pressure Source	178189-204046	2011H160401	30-Sep-24
Digital Pressure Calibrator	178189-204051	700140649	30-Sep-24

Calibrated By

Calibration Engineer

UIC-QP-7.8-24-F02, REV 0

Approved By

QA/QC Engineer

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O.Box No.2072, Jubail-31951, K.S.A.

Tel.: +966 13 344 8882 / Fax: +966 13 344 8881

Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية

هاتف: +٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس: +٩٦٦ ١٣ ٣٤٤ ٨٨٨١

هاتف: +٩٦٦ ١٣ ٣٦٧ ٠٥١٥

CERTIFICATE NO: UIC/HAR/ 32437

Customer **Sudhir Equipment Rental Company.**
Address Haradh, Kingdom of Saudi Arabia

Description	Pressure Relief Valve	Calibration Date	09-Feb-24
Manufacturer	N/A	Calibration Due Date	08-Aug-24
Type	SN50	Temperature	23.0 ± 2°C
Serial No.	23085	Relative Humidity	RH 45% to 75%
ID No.	N/A		

Test Results

Set Pressure :	9.00 BAR	Spring Range :	N/A
Back Pressure:	0.00 BAR	Size Inlet :	1/2"
CDTP :	9.00 BAR	Type of Valve :	Metal Seated
Setting Accuracy :	± 3 % of Setting	Test Medium :	Air
Pop Test :	PASSED		

BASIS OF TEST:

Ref Standard ASME Sec VIII, Div I

Summary of Test Procedure:

The Calibration of above Pressure relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.

Traceability:

The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company maintains Traceability to the third party.

Condition of Instrument

With in the tolerance on receipt(as found)

Yes

The instrument was adjusted

No

The instrument was repaired

No

Calibrated By: _____

Calibration Engineer



Approved by: _____

QA/ QC Engineer