



الشركة العالمية لخدمات التفتيش المحدودة

UNIVERSAL INSPECTION CO. LTD.

CR No.2055011643

س.ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO: UIC / SAF / 55229

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer **China Eleventh Chemical Construction Co .Ltd**  
Address MIP,PKG-9,ELECO, Kingdom of Saudi Arabia.

Description **Pressure Relief Valve**  
Manufacturer ATLAS COPCO  
Part No. 0832100066  
Serial No. 2218081  
ID No. N/A  
Location Calibration Lab (Safaniya)


Receipt Date : 09-Nov-24  
Calibration Date : 11-May-24  
Calibration Due Date : 11-Nov-24

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements

Reference Standard Equipment Used

| Description                        | Cert. No.       | Serial No    | Due Date  |
|------------------------------------|-----------------|--------------|-----------|
| High Pressure Pneumatic Comparator | SA178189-202502 | 214E191210   | 16-Aug-24 |
| Digital Pressure Calibrator        | SA178189-202503 | 223162191111 | 16-Aug-24 |

Calibrated By  
  
Calibration Engineer



Approved By  
  
QA/QC Engineer

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O.Box No.2072, Jubail-31951, K.S.A.

Tel.: +966 13 344 8882 / Fax: +966 13 344 8881

Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢ ، الجبيل ٣١٩٥١ - المملكة العربية السعودية

هاتف : +٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس : +٩٦٦ ١٣ ٣٤٤ ٨٨٨١

هاتف : +٩٦٦ ١٣ ٣٦٧ ٠٥١٥



CERTIFICATE NO: UIC / SAF / 55229

PAGE

2 of 2

Customer  
Address**China Eleventh Chemical Construction Co .Ltd**

MIP,PKG-9,ELECO, Kingdom of Saudi Arabia.

Description

**Pressure Relief Valve**

Manufacturer

ATLAS COPCO

Part No.

0832100066

Serial No.

2218081

ID No.

N/A

Calibration Date

11-May-24

Calibration Due Date

11-Nov-24

Temperature

23.0 ± 2°C

Relative Humidity

RH 45% to 75%

Test Results

Set Pressure : 11.5 BARG

Spring Range : N/A

Back Pressure: 0.0 BARG

CDTP : 11.5 BARG

Size Inlet / Outlet : 1" X 1½"

Setting Accuracy : ± 3 % of Setting

Type of Valve : Metal Seated

Pop Test : PASSED

Test Medium : Air

BASIS OF TEST:

Ref Standard ASME Sec VIII,Div I

Summary of Test Procedure:

The Calibration of above Pressure relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.

Traceability:

The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company maintains Traceability to the third party.

Condition of Instrument

With in the tolerance on receipt( as found )

No

The instrument was adjusted

No

The instrument was repaired

No

++++ End of the Certificate +++++

Calibrated By:



Calibration Engineer



UIC-OP-7.8-24 F02, REV 0

Approved by:

QA/QC Engineer