



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO : UIC/RIY/37998

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer	Sudhir Equipment Rental Company.		
Address	Dammam, Kingdom of Saudi Arabia		
Description	Pressure Relief Valve		
Manufacturer	ATLAS COPCO	Receipt Date	: 18-Jan-26
Part No.	832100066	Calibration Date	: 18-Jan-26
Serial No.	2301128	Report Date	: 18-Jan-26
ID No.	SAC-500-145	Issue date	: 18-Jan-26
Location	Calibration Lab	Calibration Due Date	: 17-Jul-26

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements

Reference Standard Equipment Used

Description	Model/Cert No	Serial No	Due Date
Water Pressure Comparator	VIC-25-42247	990S2412008	4-May-26
Digital Pressure Gauge	VIC-25-57095	2232412038	4-May-26

Calibrated By

Calibration Engineer



UIC-QP-7.8.2-17, REV 02

Approved By

QA/QC Engineer

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٨٨٨٢ ١٣ ٩٦٦ / فاكس ٨٨٨١ ١٣ ٩٦٦
هاتف ٠٥١٥ ١٣ ٣٦٧ ٩٦٦

CERTIFICATE NO : UIC/RIY/37998

PAGE

1 of 2

Customer **Sudhir Equipment Rental Company.**
Address Dammam, Kingdom of Saudi Arabia

Description	Pressure Relief Valve	Calibration Date	18-Jan-26
Manufacturer	ATLAS COPCO	Calibration Due Date	17-Jul-26
Model	832100066	Temperature	23.0 ± 2°C
Serial No.	2301128	Relative Humidity	RH 45% to 75%
ID No.	SAC-500-145		

Test Results

Set Pressure :	11.0	BAR	Spring Range	: N/A
Back Pressure:	0.0	BAR	Size Inlet / Outlet	: 1" X 1.5"
CDTP :	11.0	BAR	Type of Valve	: Metal Seated
Setting Accuracy : ± 3 % of Setting			Test Medium	: Air/Water/Oil/Gas
Pop Test : PASSED				

BASIS OF TEST:

Ref Standard ASME Sec VIII, Div I

Summary of Test Procedure:

The Calibration of above Pressure relief valve is performed through the verification of set pressure using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.

Traceability:

The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company Maintains traceability to the third party.

Condition of Instrument

With in the tolerance on receipt(as found)	No
The instrument was adjusted	No
The instrument was repaired	No

Result:


Calibration Result is pass.

++++ End of the Certificate +++++



Calibrated By: 
Calibration Engineer

UIC-QP-7.8.2-17, REV 02

Approved by: 
QA/QC Engineer