



الشركة العالمية لخدمات التفتيش المحدودة

UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO: UIC/DAM/59309

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request


Customer	Sudhir Equipment Rental Company		
Location	Dammam, Kingdom of Saudi Arabia		
Description	Pressure Relief Valve		
Manufacturer	Harshad		
Part No.	N/A		
Serial No.	2404312	Receipt Date	21-Jun-25
ID. No.	SAC-825-152	Calibration Date	21-Jun-25
Location	Calibration Lab (Dammam)	Calibration Due Date	20-Dec-25

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements

Reference Standard Equipment Used

Description	Model / Cert. No.	Serial No.	Due Date
High Pressure Pneumatic Pressure Source	AME/24/TC/1212-A7	214E2408011	13-Dec-25
Digital Pressure Calibrator	AME/24/TC/1212-A12	2232411017	13-Dec-25


Calibrated By



Calibration Engineer



Approved By



QA/QC Engineer

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.

Tel.: +966 13 344 8882 / Fax: +966 13 344 8881

Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية

هاتف ٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس ٩٦٦ ١٣ ٣٤٤ ٨٨٨١

هاتف ٩٦٦ ١٣ ٣٦٧ ٠٥١٥

CERTIFICATE NO: UIC/DAM/59309

Page

2 of 2

Customer **Sudhir Equipment Rental Company**
Location Dammam, Kingdom of Saudi Arabia

Description **Pressure Relief Valve**

Manufacturer Harshad

Model N/A

Serial No. 2404312

ID. No. SAC-825-152

Calibration Date 21-Jun-25

Calibration Due Date 20-Dec-25

Temperature Range 23.5°C

Relative Humidity RH 48%

Test Results

Set Pressure : 11.00 BAR

Spring Range : N/A

Back Pressure : 0.00 BAR

Size Inlet/Outlet : 1" x 2"

CDTP : 11.00 BAR

Type of Valve : Metal Seated

Setting Accuracy : $\pm 3\%$ of Setting

Pop Test : PASSED

Test Medium : Air

BASIS OF TEST:

Ref Standard ASME Sec VIII, Div I

Summary of Test Procedure:

The Calibration of above Pressure relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.

Traceability:

The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company maintains Traceability to the third party.

Condition of Instrument

With in the tolerance on receipt(as found)

No

The instrument was adjusted

Yes

The instrument was repaired

No

***** End of the Certificate *****



Calibrated By: _____
 Calibration Engineer



UIC-QP-7.8-24 F02, REV 0

Approved by: _____
 QA/QC Engineer